

Perry Buckberg - Dec 12 Conference Call Record

From: Perry Buckberg
To: Doug Ellis
Date: 12/13/2006 6:47:43 AM
Subject: Dec 12 Conference Call Record
CC: Rajender Auluck

Doug,

The attached document is a draft of record of yesterday's conference call. Please e-mail or call me to provide your comments or concurrence.

Thanks,
Perry Buckberg
Project Manager - Division of License Renewal
phone: (301)415-1383
fax: (301)415-3031
phb1@nrc.gov

Mail Envelope Properties (457FE85F.F71 : 9 : 8248)

Subject: Dec 12 Conference Call Record
Creation Date 12/13/2006 6:47:43 AM
From: Perry Buckberg

Created By: PHB1@nrc.gov

Recipients	Action	Date & Time
entergy.com AM dellis1 (Doug Ellis)	Transferred	12/13/2006 6:48:00

nrc.gov OWGWPO01.HQGWDO01 AM RCA CC (Rajender Auluck)	Delivered	12/13/2006 6:47:43
--	-----------	--------------------

Post Office	Delivered	Route
OWGWPO01.HQGWDO01	12/13/2006 6:47:43 AM	entergy.com nrc.gov

Files	Size	Date & Time
MESSAGE	894	12/13/2006 6:47:42 AM
TEXT.htm	668	
MeetingSummary Dec 12 2006.wpd AM		51992 12/13/2006 6:45:00

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered

LICENSEE: Entergy Nuclear Operations, Inc.
FACILITY: Pilgrim Nuclear Power Station
SUBJECT: SUMMARY OF CONFERENCE CALL ON DECEMBER 12, 2006 WITH
ENTERGY NUCLEAR OPERATIONS, INC., REGARDING THE PILGRIM
LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission staff conducted a conference call with Entergy Nuclear Operations, Inc. (Entergy or the applicant) regarding the Pilgrim License Renewal Application (LRA) to discuss information sent to the NRC in response to requests for additional information (RAI) and to address other license renewal issues. The conference call was conducted on Tuesday December 12, 2006, between 12:30 p.m. and 1:30 p.m. at 11555 Rockville Pike, Rockville, MD 20852. The list of participants is shown in the enclosure. The following is a summary of the conference call.

The NRC Pilgrim Project Manager provided an introduction and began discussing the 9 subjects to be covered in the conference; NRC staff considers the response to Pilgrim RAI 2.3.3.9-8 incomplete, NRC staff feels RAI 2.4.3-1 trash racks and traveling screens require aging management programs, request Entergy justify the RAI 2.4.3-1 jib crane being considered out of scope of license renewal, concurrence that RAI 2.4.5-1 transmission towers are included in LRA Table 2.4-5, NRC staff requires the applicant to make a commitment to boiling water reactor vessel and internals program (BWRVIP) 94 and BWRVIP 76, discuss the core shroud tie rod upper bracket material and repair, discuss the validity of using one time inspections to assess reduction of fracture toughness in cast austenitic stainless steel (CASS) components and discuss RAI B.1.3-2 exception to NUREG 1800 AMP XI.M6. Discussion of RAI 2.3.3.9-8, resulted in the Entergy action to assess whether fire suppression systems for several transformers are within scope. Discussions regarding the trash racks, traveling screens and the jib crane resulted in an Entergy explanation as to why these components are considered out of scope. The discussion of the transmission towers resulted in the confirmation that the towers are represented in LRA table 2.4-5. Entergy stated that the commitment to BWRVIP is reflected in Entergy procedure ENN-DC-135 and that a commitment to BWRVIP 76 will be addressed in a pending LRA amendment. Entergy explained that the core shroud tie rod upper bracket will be replaced in the April, 2006 Pilgrim outage. Entergy took an action to research LRA inconsistencies regarding the inspection for reduction of fracture toughness of CASS piping and pump casings. Entergy stated that exception 1 to GALL AMP XI.M6 will not be deleted from the LRA.

The applicant had an opportunity to comment on the meeting summary.

Perry Buckberg, Project Manager
License Renewal Branch A
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure:
List of Participants

cc w/encl: See next page

LICENSEE: Entergy Nuclear Operations, Inc.
 FACILITY: Pilgrim Nuclear Power Station
 SUBJECT: SUMMARY OF CONFERENCE CALL ON DECEMBER 12, 2006 WITH
 ENTERGY NUCLEAR OPERATIONS, INC., REGARDING THE PILGRIM
 LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission staff conducted a conference call with Entergy Nuclear Operations, Inc. (Entergy or the applicant) regarding the Pilgrim License Renewal Application (LRA) to discuss information sent to the NRC in response to requests for additional information (RAI) and to address other license renewal issues. The conference call was conducted on Tuesday December 12, 2006, between 12:30 p.m. and 1:30 p.m. at 11555 Rockville Pike, Rockville, MD 20852. The list of participants is shown in the enclosure. The following is a summary of the conference call.

The NRC Pilgrim Project Manager provided an introduction and began discussing the 9 subjects to be covered in the conference; NRC staff considers the response to Pilgrim RAI 2.3.3.9-8 incomplete, NRC staff feels RAI 2.4.3-1 trash racks and traveling screens require aging management programs, request Entergy justify the RAI 2.4.3-1 jib crane being considered out of scope of license renewal, concurrence that RAI 2.4.5-1 transmission towers are included in LRA Table 2.4-5, NRC staff requires the applicant to make a commitment to boiling water reactor vessel and internals program (BWRVIP) 94 and BWRVIP 76, discuss the core shroud tie rod upper bracket material and repair, discuss the validity of using one time inspections to assess reduction of fracture toughness in cast austenitic stainless steel (CASS) components and discuss RAI B.1.3-2 exception to NUREG 1800 AMP XI.M6. Discussion of RAI 2.3.3.9-8, resulted in the Entergy action to assess whether fire suppression systems for several transformers are within scope. Discussions regarding the trash racks, traveling screens and the jib crane resulted in an Entergy explanation as to why these components are considered out of scope. The discussion of the transmission towers resulted in the confirmation that the towers are represented in LRA table 2.4-5. Entergy stated that the commitment to BWRVIP is reflected in Entergy procedure ENN-DC-135 and that a commitment to BWRVIP 76 will be addressed in a pending LRA amendment. Entergy explained that the core shroud tie rod upper bracket will be replaced in the April, 2006 Pilgrim outage. Entergy took an action to research LRA inconsistencies regarding the inspection for reduction of fracture toughness of CASS piping and pump casings. Entergy stated that exception 1 to GALL AMP XI.M6 will not be deleted from the LRA.

The applicant had an opportunity to comment on the meeting summary.

Perry Buckberg, Project Manager
 License Renewal Branch A
 Division of License Renewal
 Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure:
 List of Participants

cc w/encl: See next page

ADAMS Accession No.: **ML06**
 C:\temp\MeetingSummary Dec 12 2006.wpd

OFFICE	PM:RLRA:DLR	LA:DLR	PM:RLRC:DLR	BC:REBB:DLR
NAME	PBuckberg		JDavis	LLund
DATE	10/ 11 /06	10/ /06	10/ /06	10/ /06

WEVI

WEVI

re shrount
in action sta
ignize

WEVI

SS

... the April 1993 ...

SUBJECT: SUMMARY OF CONFERENCE CALL ON DECEMBER 12, 2006 WITH
ENTERGY NUCLEAR OPERATIONS, INC., REGARDING THE PILGRIM
LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

HARD COPY

DLR R/F

E-MAIL:

JFair
RWeisman
AMurphy
RPettis
GGalletti
DShum
GBagchi
SSmith (srs3)
SDuraiswamy
YL (Renee) Li
RidsNrrDlr
RidsNrrDlrRlra
RidsNrrDlrRlrb
RidsNrrDe
RidsNrrDci
RidsNrrEemb
RidsNrrDeEeeb
RidsNrrDeEqva
RidsNrrDss
RidsNrrDnrl
RidsOgcMailCenter
RidsNrrAdes
DLR Staff

PBuckberg
SHoffman
SUttal
JShea
JDavis
CAnderson, Region 1
WRaymond, Region 1
NSheehan, Region 1

DN
OgcM
Rlrb
Staff
Buckberg

Pilgrim Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Pilgrim Nuclear Power Station
Post Office Box 867
Plymouth, MA 02360

Chairman, Board of Selectmen
11 Lincoln Street
Plymouth, MA 02360

Chairman
Nuclear Matters Committee
Town Hall
11 Lincoln Street
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen
Town Hall
878 Tremont Street
Duxbury, MA 02332

Office of the Commissioner
Massachusetts Department of
Environmental Protection
One Winter Street
Boston, MA 02108

Office of the Attorney General
One Ashburton Place
20th Floor
Boston, MA 02108

MA Department of Public Health
Radiation Control Program
Schrafft Center, Suite 1M2A
529 Main Street
Charlestown, MA 02129

Secretary of Public Safety
Executive Office of Public Safety
One Ashburton Place
Boston, MA 02108

Director, Massachusetts Emergency
Management Agency
Attn: James Muckerheide
400 Worcester Road
Framingham, MA 01702-5399

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P.O. Box 426
Ludlow, MA 01056-0426

Mr. Michael A. Balduzzi
Site Vice President
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Stephen J. Bethay
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Bryan S. Ford
Manager, Licensing
Entergy Nuclear Operations, Inc.
Pilgrim Nuclear Power Station
600 Rocky Hill Road
Plymouth, MA 02360-5508

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

cc:

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Oscar Limpias
Vice President, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwarz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John F. McCann
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene D. Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. James Sniezek
5486 Nithsdale Drive
Salisbury, MD 21801

Mr. Travis C. McCullough
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Ross
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Plymouth Public Library
Attn: Dinah O'Brien
132 South Street
Plymouth, MA 02360

Duxbury Free Library
ATTN: Ms. Elaine Winquist
77 Alden Street
Duxbury, MA 02332

Kingston Public Library
ATTN: Reference Librarian
6 Green Street
Kingston, MA 02364

Ms. Mary Lampert
Duxbury Nuclear Advisory, Chair
Pilgrim Watch, Director
148 Washington Street
Duxbury, MA 02332

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL
TO DISCUSS THE PILGRIM NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION**

December 12, 2006

PARTICIPANTS

Perry Buckberg
Raj Auluck
Ganesh Cheruvenki
Naeem Iqbal
James Davis
Susan Lane
Peter Wen
Phil Qualls
James Medoff
Doug Ellis
Fred Mogolesko
Alan Cox
Ray Pace
Ray Zahrably
David Lach
Steve Burke

AFFILIATION

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
NRC
NRC
NRC
NRC
NRC
NRC
Entergy Nuclear Operations, Inc. (Entergy)
Entergy
Entergy
Entergy
Entergy
Entergy
Entergy

ENCLOSURE