SIMULATOR EXAMINATION SCENARIO

SCENARIO TITLE:	SGTR
SCENARIO NUMBER:	I ILT NRC ESG-001
EFFECTIVE DATE:	12/4/6
EXPECTED DURATION:	1.5 hours
REVISION NUMBER:	00
PROGRAM:	L.O. REQUAL
	X INITIAL LICENSE
	STA
	OTHER

Revision Summary:

Rev 0: New Issue for I ILT NRC exam

PREPARED BY:	Paul Williams	10/9/06
	(INSTRUCTOR)	(DATE)
APPROVED BY:		
	(OPERATIONS TRAINNG	(DATE)
	MANAGER OR DESIGNEE)	
APPROVED BY:		
	(OPERATIONS MANAGER OR DESIGNEE)	(DATE)

OBJECTIVES

I.

Enabling Objectives

- A. Given the unit at power the crew will reduce power to remove a Heater Drain Pump from service, IAW approved station procedures.
- B. Given the unit at power with a failure of a Pressurizer Pressure control channel, the crew will take action to stabilize RCS pressure and swap to a non-failed channel, IAW approved station procedures.
- C. Given the unit with a leak in a SW bay, the crew will take action to isolate the leak, IAW approved station procedures.
- D. Given a SGTL, the crew will identify and isolate the leaking SG, IAW approved station procedures.
- E. Given the unit with a SGTR and loss of off-site power, take actions to minimize off site dose and RCS leakage, IAW approved station procedures.

II. MAJOR EVENTS

- A. Power Reduction to 90%
- B. Pressurizer Pressure Channel 1 Fails High
- C. #2 SW Bay Leak
- D. SGTL
- E. SGTR on 21 SG with Loss of Off-Site Power and "B" Vital Bus

III. SCENARIO SUMMARY

- A. The crew will receive the unit at 100% power with all system in automatic. One major piece of equipment will be C/Ted, 2B D/G.
- B. Once the crew takes the watch they will reduce reactor power to 90% at 30% per hour to remove 22 Heater Drain pump from service due to an emergent mechanical seal leak.
- C. Once the power reduction to 90% is underway Channel 1 Pressurizer Pressure will fail high. The RO will take manual control of the Master Pressure Controller and adjust demand to stabilize RCS pressure. The CRS will enter AB.PZR-0001 and direct crew actions to remove the channel from service.
- D. After AB.PZR-0001 has been completed to the point of determining channel operability a leak will begin in #2 SW Bay. The CRS will enter AB.SW-0003 and direct crew actions to isolate and remove #2 bay from service.
- E. When the bay isolated a SGTL will occur on 21 SG. The CRS will enter AB.SG-0001 and direct the crew to perform actions to address the SGTL. During the SGTL, the SG tube will rupture. The CRS will direct a manual SI initiation.
- F. The RO will manually initiate SI and commence the Immediate Actions of EOP-TRIP-1. The CRS will enter EOP-TRIP-1. During the performance of EOP-TRIP-1 a loss of off-site power will occur coincident with the loss of "B" Vital Bus. This will necessitate the crew manually isolating service water to the turbine building.
- G. The crew will perform actions of EOP-TRIP-1 and then transition to EOP-SGTR-1

46 B 32

IV. INITIAL CONDITIONS

Presnapped IC-191 from portable exam drive

MALFUNCTIONS: -						
SELF-CHECK	Description	Delay	Ramp	Trigger	Severity	
1.	VL0055 23SW20 Fails to Position	NA	NA	NA	100	
2.	VL0053 2SW26 Fails to Position	NA	NA	NA	100	
3.	PR0016A Ch 1 Prz Press Fails High	NA	NA	ET-1	2500	
4.	SW0216A 2 SW Bay Leaks	NA	1 min	ET-2	10000	
5.	SG0078A SG Rupture	NA	3:00	ET-3	25	
6.	EL0134 Loss of Off-Site Power	:30	NA	ET-4	NA	

REM	OTES:				
SELF-CHECK	Description	Delay	Ramp	Trigger	Condition
1.	DG19D 2B D/G Locked Out	NA	NA	NA	Yes
2.	DG21D 2B DG BKR Rack Out	NA	NA	NA	Tagged
3.	DG20D 2B DG BKR Control Power	NA	NA	NA	Off
4.	PR34D PORV Stop Valve 2PR6 Tagged	NA	NA	RT-10	Tagged
5.	SW23D – 21 SW Pump Control Power	NA	NA	RT-11	Off
6.	SW27D – 22 SW Pump Control Power	:30	NA	RT-11	Off
7.	SW32D – 23 SW Pump Control Power	:60	NA	RT-11	Off

OVEF	RIDES:				Horas Haras	al and a line of the second
SELF-CHECK	Description		Delay	Ramp	Trigger	Action
1.	AI06 OV	AO BIT Flow meter failed	NA	NA	NA	0
EVEN	IT TRIGGE	IRS:				
SELF-CHECK	ET#n	Discription	Comm	nand	· · · · · · · · · · · · · · · · · · ·	
1.	ET-4	MONP 254<10				

_____2. ET-5 KA915TC4

DMF VL0055

T4	AGGED EQUIPMENT:
	Description
1. 2. 3. 4. 5. 6. 7. 8. 9. 10.	RH1 and RH2 VC 1-4 RH 18's RCPs (SELF CHECK) RT (SELF CHECK) MS 167s (SELF CHECK) 500 KV SWYD (SELF CHECK). 22 ABV Supply Fan 23 CV Pump (SELF CHECK) 2B D/G (C/T)
	OTHER CONDITIONS:
	Description

1. Ensure Channel 1 Pressurizer Pressure selected for control

V. SEQUENCE OF EVENTS

- A. State shift job assignments:
- B. Hold a shift briefing, detailing instruction to the shift: (provide CREW members a copy of the shift turnover sheet)
- C. Inform the crew "The simulator is running. You may commence panel walkdowns at this time. CRS please inform me when your crew is ready to assume the shift".
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.
- E. Do not review objectives with crew

Evaluator/Instructor Activity Expected

Expected Plant/Student Response

Comments

1. Power Reduction to 90%

CREW will be provided with a OP-AP-300-1004 filled out with correct information for power reduction boration

IO.Z.Z-0004 will be entered but no major action is required until 85%

- CRS briefs crew on evolution
- CRS implements S2.OP-IO.ZZ-0004
- CRS directs RO/PO to commence a power reduction to 90% at 30% per hour
- PO sets-up DEHC for correct reduction and rate IAW S2.OP-SO.TRB-0002
- CRS directs RO to commence a boration at rate and gallon amount as determined during brief IAW S2.OP-SO.CVC-0006
- RO monitors reactor parameters to maintain Tavg within programmed value
- PO monitors main turbine response
- PO monitors SGFP suction pressure to ensure it remains greater than 320 psig
- PO monitors condenser Delta T's
- RO commences boration IAW S2.OP-SO.CVC-0006
- PO informs CRS when CRS when power has reduced to 90%
- RO informs CRS when boration has been completed and returns boration control to automatic

Proceed to next event when the power reduction has proceeded to the satisfaction of the lead evaluator CREW reviews S2.OP-SO.TD-0001 to remove 22 Heater Drain Pump from service

SH.OP-AP.ZZ-

0102 rules of

usage

 Evaluator/Instructor Activity
 Expected Plant/Student Response
 Comments

 service

2. Pressurizer Pressure Channel 1 Fails High

Enter ET-1, PZR PR Channel 1 fails to 2500 Crew may decide to suspend load reduction if not completed until PZR pressure is stabilized

- RO reports that Pressurizer Pressure Channel 1 has failed high and requests permission to take master pressure controller to manual
- CRS concurs with RO assessment and directs master pressure controller placed in manual
- CRS enters S2.OP-AB.PZR-0001
- CRS directs PO to implement CAS
- RO reports POPS is not in service
- RO reports that controlling pressurizer pressure channel is failed
- RO adjust master pressure controller to be consistent with attachment 2
- RO selects channel 3 for controlling channel
- RO returns master pressure controller to Auto
- CRS conducts brief and discusses contingent actions. Also during brief informs crew that TSAS 3.3.2.1 b 19, 3.3.1.1. act 6 and 3.4.5b are applicable.
- CRS directs RO to close 2PR6 to comply with technical specifications

RO may request permission to wait until pressure has returned to normal operating control band. This is an acceptable alternative. Brief may occur after PR6 has been closed and S2.OP-SO.RPS-0003 has been implemented. Either time is acceptable

Evaluator/Instructor Activity Expected Plant/Student Response Comments

• RO closes 2PR6

•

- 3 minutes after requested, call for 1st check and then enter RT-10 to open breaker
- CRS directs WCC to have breaker opened IAW SH.OP-AP.ZZ-0103
- CRS directs PO to implement S2.OP-SO.RPS-0003
- PO initiates S2.OP-SO.RPS-0003

Proceed to next event when PO has initiated

Continue to next page

Comments

3. SW Bay Leak

	· · · · · · · · · · · · · · · · · · ·	2010/00/00/00/00/00/00/00/00/00/00/00/	and the second	
The second	10.4 WATE T WATE TO DE		27 A Y / A Y / Y / Y / Y / Y / A OHOODO / OHOODOO	00000 / 1000 / 1000 m / 1000 / 2007
	100000 m 6 in dia 400 100	2722 / AUTO 1025 / AUTO 2000 000 000 000 000 000 000 000 000 0		the second se
second seco		the second se		
	op provide "Manage for a production of and		Contraction and Contraction of the	
	M 404000 102 1 A 1000000 10 10			~~~~~
2000000 25 2 2 3 3 3 3 4 4 8000 h 9000 400 - 0	A 27 50000 A 200 A 200000 75 P	4 55 '00000 000'1 000'2 S 1 000		and a second second second second
PODDATE MARK IN THE COMPANY AND ADDRESS	- COR VO 200, DO 200000 W J	1 CA 20035 307 5 772 7 5 5 5 55		24. A 22 23 40 40 40 40 40 40 40 40 40 40 40 40 40
	and a second of the April Control is an and the		7 T T A T COV COMO COM / COULCE	
Conception of the second				
the second se				and a second
I y y y y y y hand a state of a state of the state of	· · · · · · · · · · · · · · · · · · ·		CHORD FOR ANTIPOLY AND CONTRACTOR	
			and the second	CONC.2. # 4400 (CONC. A. 2000)
				The second s
the second se	Contraction of the second s second second s second second se			, , , , , , , , , , , , , , , , , , ,
		7 6 4 1 8 5 3 8 5 6 W 8 6		COM 200 200 200 200 200 200 200 200 200 20
	1 199003 MINON - Ser & Ma 2000 - 1			202000 C.
	and control of the second s		· / · / · / · / · / · / · / · / · / · /	20020.2020.2020.000.000.000.0000.000
	5 ACCOR 100 A 1 A 1 A 1 A 10 A 10 A 10 A 10 A	AN 68	1000 M. G. J. D. J. M. M. M. M. M.	
	CONTRACTOR OF A		the second se	
12.5.15			50000000000000000000000000000000000000	PARTY SPARITON AND STREET
 Contraction of the second secon	<pre>cit_dit_dit_dit_cit_cit_cit_cit_cit_cit_cit_cit_cit_c</pre>			1. 11 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1
		5 00 0 1 1 2 0 1 1 1 1 1 1 1 1 1 1 1 1 1	and an and a second the second of the	and the second secon
Provide and the control of the second s	Contraction of the second s		2. March 1997 Contract Contra	6 CECCOLO E COLO E A COLO UN
	Care and the second of the second	and a second to a second s	······································	· · · · · · · · · · · · · · · · · · ·
Exception of a second sec	00000 Creacororco C x 1 C C 7 A A MARIN		0.000000000000000000000000000000000000	
	CONTRACTOR OF A DESCRIPTION OF A DESCRIP		CONTRACTOR AND A CONTRACTOR OF A CONTRACTOR OF A CONTRACTOR AND A	
Entry of the second s	and the second second second second		······································	
		and the second se	200000000000000000000000000000000000000	Contractive strategic fraction in the
- Contract of the second s	**************************************			
	2/11/10/07/07/07/07/07/07/07/07/00/00/05		the second s	1 (1) (1) (1) (1) (1) (1) (1) (1) (1) (1
Construction of the second se second second se second second s		00000000000000000000000000000000000000	200	1011.022.0246.01.04046.000
Control of the second control of the second seco	a 1999 a 1999 a 1999 a 1997			CONTRACTOR OF A DESCRIPTION OF A
Construction of the second sec	0.00000.0000/pr*/2.017*-en-001000000			
Logical statements and an analysis of the second statement of the second st			2222442222222424242222424222242422424222	and a second
	1 Con 1 C 1 C 1 C 1 C 1 C 1 C 1 C 1 C 1 C 1	00000000 - 206 CALINE CALINE (2010) - 5000		
Environment of the second s	CAN AT ME SHARE THE OWNER OF COMPANY		\$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000 \$2,000	2. CO. J. C. C. C. A. C. A. C. A. C. A. C. A.
	1271 A 257 St. 215 SZ & AS AMARINA	5 C 2 C 2 SO A ST 11. ST 11. ST 12. ST 1. CO. CO. CO. CO.	and the second state of the second	Contraction and the second second
E. C.	2022 CONTENT CONTRACTOR AND A 12 M 12		0.00000.000.000.00.00.00.00.000.000.000.000	
 A set a provide the approximation of a place the two set of the set of the	and the second sec		27000 C 66 1 7 1 3 7 1 1 7	1997 - 2020 A.
Environmental and a consistence of the constraint of the second secon	Standard and the stand second correspondence of the	0.00 mm / 1.00 mm / 1	and the second statement of the second se	
		19979-11-1-11-11-1-1-1-1-1-1-1-1-1-1-1-1	Contraction of the second second	the second s
the second			00000000000000000000000000000000000000	LAND THE REPORT OF A COMPANY OF A
1	Carried and the second s	200001010101010000000000000000000000000	CONTRACTOR OF THE OWNER OWNER OF THE OWNER OWNE	
Enclose and a second	28/8282828999922299		N 10 10 10 10 10 10 10 10 10 10 10 10 10	
Contraction of the contraction o		1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	00000000000000000000000000000000000000	and and the second second
	Contract and the second contract of the second s			CONTRACTOR CONTRA
	Martin CAN TANK & CAN AND AND AND AND AND AND AND AND AND A	NAA 2011 12 12 12 12 12 12 12 12 12 12 12 12 1	Contraction Contactor method and and	
	59447 A 104 P 112 C 114 C 12 C 10 C 10 C 10 C		a second s	e 944.0624.0000000000000000000000000
	Contract Street and Street and Street and Street	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		
The second	**************************************		· · · · · · · · · · · · · · · · · · ·	Setting and the set of the set

ROLE PLAY: After ~ 3 minutes report water level in #2 SW Bay is about 2' and rising,

Simulator Operator: When requested turn 125 VDC control power off to #2 SW Bay Pumps using the following remotes: Perform 1st check <u>RT-11</u>, SW23D, 21 SW Pump Final Value = Off <u>RT-11</u>, SW27D, 22 SW Pump Final Value = Off, 30 sec TD <u>RT-11</u>, SW32D, 23 SW Pump Final Value = Off, 60 sec TD CREW responds to OHA alarms
 o B-13 and 14: 21 and 22 SW
 HDR Press LO

Evaluator/Instructor Activity Expected Plant/Student Response

- B-29: 21-23 SW Pmp Sump Area Lvl HI.
- RO acknowledges standby SW Pump start.
- CRS enters AB.SW-0001 or goes directly to AB.SW-0003.
- Crew monitors AB.SW-0003 CAS.
- CREW dispatches operator to investigate.
- RO opens 21 & 22SW23, Nuc Hdr Xover MOVs.
- RO closes 21 & 22SW17, Pump Disch X-over MOVs.
 - Crew isolates 2 SW Bay:
 - RO starts 24 SW Pump.
 - RO stops 21&23 SW Pumps.
 - CRS directs NEO to open 125 VDC Control Power to 2 Bay SW Pumps.
 - RO closes 21SW22, NucHdr Inlet.
 - RO closes 21SW20, TurbHdr Supply.

Comments Evaluator/Instructor Activity Expected Plant/Student Response

- Crew initiates actions to remove 1 CCHX from service IAW S2.OP-SO.CC-0002 IAW CAS 4.0.
 - SM contacts maintenance services to assist with dewatering
- CRS enters AB-ZZ-0002 for flooding •
- CRS refers to Tech Specs and ٠ determines that TS 3.8.1.1.b, action b.2 and 3.7.4 for 1 SW header inoperable
- RO reports OHA A-8 verifies on CRT 2R53A in alarm
 - CRS directs monitoring of 2R19A to confirm status of SGTL
- PO informs CRS that 2R19A is rising as expected for tube leak
- CRS enters S2.OP-AB.SG-0001
- CRS directs RO to implement Attachment 1 CAS
- CRS directs NEO to de-energize turbine and polisher area sumps
- RO reports PZR level lowering slowly
- CRS directs a swap to centrifugal charging pump
- RO places a centrifugal charging pump in service by performing the following:
 - Closing CV55

RO may initially report PZR level as stable due to slow ramp of SGTL

ROLE PLAY: If requested, NEO

rising

reports #2 SW Bay level has stopped

With 2 Bay inoperable, 24 SW pump

does not have diesel back-up, so only

ENTER RT-3 21 SGTL, 25 GPM

after TSAS determination as directed by Lead evaluator

C bus pumps are operable

4. Tube Leak on 21 SG

Evaluator/Instructor Activity Expected Plant/Student Response Comments

- Starts 21 or 22 CV Pump 0
- Places 23 CV pump in manual and lowers speed
- Adjust CV55 to maintain stable charging flow and seal injection flow
- Stops 23 CV Pump
- Places CV55 in automatic
- CRS directs letdown flow to minimum
- RO reduces letdown to minimum
- RO adjusts charging to stabilize Pressurizer level and estimate leak rate

Leak rate is >140 gpd Once shut down determination is made, when directed by the lead examiner, Modify SG0078B to 900 gpm no ramp Record Time:

- SM/CRS/STA determine that Action level 3 is met and Unit must be in Mode 3 in the next 6 hours
- RO informs CRS that leak rate has increased and PZR level is lowering rapidly
- CRS briefs crew that leak is beyond capacity of makeup system and directs a Rx trip and SI
- RO trips reactor, confirms Rx trip and initiates SI
- RO performs I/As of EOP-TRIP-1
- **CRS** enters EOP-TRIP-1
- CRS confirms immediate actions
- RO announces reactor trip and request

Due to small size of leak, PZR level can be stabilized and CRS may decide to not reduce letdown

At some point during performance of AB.SG-0001 the CRS may stop to have a brief and discuss actions and contingencies

5. SGTR

Note: Loss of Off-Site power Malf: EL0134 will auto enter 30 sec after Rx Trip as will loss of "B" vital bus

Evaluator/Instructor Activity Expected Plant/Student Response Comments

CAS item to isolate 21 SG SH.OP-AP.ZZ-0102 rules of usage for AFW

CT#1 (E-3 -A) Close 21AF11 and 21within 10 min on identification offault and complete isolation ofRuptured Steam GeneratorTime of Isolation:SATUNSAT

SM and STA report to control room

- When Immediate Actions are complete PO requests permission to throttle AFW and isolate 21 SG by closing 21AF11 and 21
- CRS directs action as requested
- CREW continues with EOP-TRIP-1
- PO evaluates AFW status and SEC Loading and reports that 22 AFW Pump is unavailable and that all equipment is loaded as expected except that 2B Vital Bus de-energized due to 2B EDG tag-out
- 2SW26 on "B" bus, thus no power Crew may decide to start 26 SW pump due to low pressure. This pump should not be started due to concern for overloading EDG. 1 pump is sufficient if the turbine header is isolated.

CT#2 (E-0 -L): Manually start and align the minimum ESW pumps in an operating safeguard train prior to transition from EOP-TRIP-1 SAT UNSAT

Should be 23 CC Pump since 22 is

unavailable

- PO determines that valves 2SW26 and 23SW20 have not closed as required and SW header pressure is <30psig
- CRS directs 23SW20 closed since 2SW26 has no power
- RO determines containment pressure has remained less than 15 psig
- CRS conducts brief to discuss plant status and minimizes length due to time critical nature of SGTR
- CRS directs RO/PO to start one CCW pump IAW EOP-APPX-1

Evaluator/Instructor Activity Expected Plant/Student Response Comments



- RO starts 23 CCW Pump by blocking 2C SEC
- Verifying 22CS Pump is stopped and 22CS2 is closed
- Sends and operator to place 21 CCHX in service
- o Closes 22CC3
- RO evaluates SI status as within limits, however, BIT flow is zero.
- CREW validates that charging pumps have correct amps and valve lineup is correct
- PO maintains AFW flow >22E4 lbm/hr until 1 SG is greater than 9% and then throttles to maintain 9-33%
- RO informs CRS that RCS temperature is stable at 547°F
- RO reports Reactor Trip Breakers are open
- RO reports both Pressurizer PORVs are closed, however, only 2PR7 is open
- PO evaluates all steam generator pressure are stable or rising and no faulted steam generator exist
- CREW transitions to SGTR-1 based on 21 SG Level rising in an uncontrolled manner
- CREW identifies 21 SG as ruptured SG
- PO adjusts 21MS10 setpoint to 1045 psig
- PO closes 21MS7, 18, 167 and GB4
- PO determines 23 AFW pump is not required to maintain feed flow since 21

Evaluator/Instructor Activity Expected Plant/Student Response **Comments**

AFW pump feeds 23/24 SGs and can provide sufficient AFW flow for cooldown

- PO trips and stops 23 AFW pump
- CRS dispatches and NEO to close 21MS45
- CRS dispatches an operator to close 2SS321
- PO determines 21 SG is isolated from intact SGs and feed flow should remain isolated
- RO determines 2PR6 is closed with power removed
- CRS directs power restored to 2PR6 • UNTAGGED, 3 mins after requested
 - PO determines no SG is faulted
 - CREW resets safeguards
 - RO stops both RHR pumps
 - PO evaluates 21 SG as greater than 375 and not faulted
 - CRS dispatches operator to shift Gland seal supply to U1
 - CREW determines target temperature is . 503°F
 - CREW commences rapid cooldown to • target temperature

CT#3 (E-3-B): Establish/maintain an RCS temperature so that a transition from SGTR-1 does not occur

REMOTES - PR34D to

PO cools down at max rate using ٠ available MS10s

15 of 24

Evaluator/Instructor Activity Expected Plant/Student Response Comments

SAT UNSAT

PO must set MS10s to insure RCS temperature is maintained below target to insure Subcooling during coming depressurization

CT# 4 (E-3 --C): Depressurize RCS until Ruptured SG and RCS pressure are equal and PZR level is ≥ 11% with Subcooling >0, before water release from ruptured SGPORV or Safety valve SAT UNSAT

- PO stops cooldown when target temperature is reached and dumps steam to stabilize temp
- Crew determines normal spray is not available and depressurizes using 2PR2
- RO terminates depressurization when criteria of table F is met
- CREW terminates SI

Evaluator Note: ECG Classification is ALERT IAW EAL 3.2.3.a. SW bay leak is a UE EAL 9.7.1. This should NOT be upgraded to 9.7.2 with 2B EDG tagged, as 2nd train of SW is not affected by the flood.

Terminate scenario when Depressurization is complete or at discretion of lead evaluator

VI. SCENARIO REFERENCES

- A. Alarm Response Procedures (Various)
- B. Technical Specifications
- C. Emergency Plan (ECG)
- D. SC.OP-AP.ZZ-0102(Q), Use of Procedures
- E. S2.OP-SO.TD-0001 Bleed Steam Coil Drain Tank And Heater Drain Pump Operation
- F. S2.OP-SO.CVC-0006 Boron Concentration Control
- G. S2.OP-IO.ZZ-0004 Power Operation
- H. S2.OP-AB.PZR-0001 Pressurizer Pressure Malfunction
- I. S2.OP-SO.RPS-0003 Removing a Pressurizer Channel from Service
- J. S2.OP-AB.SW-0001 Loss of Service Water Header Pressure
- K. S2.OP-AB.SW-0003 Service Water Bay Leak
- L. S2.OP-AB.SG-0001 Steam Generator Tube Leak
- M. 2-EOP-TRIP-1 Reactor Trip or Safety Injection
- N. 2-EOP-SGTR-1 Steam Generator Tube Rupture

VII. ESG CRITICAL TASK RATIONAL

CT#1 (E-3 --A): Close 21AF11 and 21 within 10 min on identification of fault and complete isolation of Ruptured Steam Generator

Basis Failure to isolate the ruptured SG causes a loss of differential pressure between the ruptured SG and intact SGs. Upon loss of differential pressure the crew must transition to a contingency procedure that "necessitates the crew taking compensating action that complicates the event mitigation strategy..."

For feedwater, isolation must occur after ruptured SG level exceeds minimum indication (9%)...Any delay in the AFW isolation allows the ruptured SG level to increase as the AFW adds additional inventory along with the primary to secondary leakage. Too long a delay (>10 min) prevents the crew from depressurizing and terminating SI before excessive inventory seriously damages the SG as a fission product barrier.

CT#2 (E-0 --L): Manually start and align the minimum ESW pumps in an operating safeguard train

- **Basis** Failure to manually start and align the minimum required number of ESW pumps in an operating safeguards train represents a "demonstrated inability by the crew to:
 - Recognize a failure/incorrect auto actuation of and ESF system or component
 - Effectively direct/manipulate ESF controls."

CT#3 (E-3 --B) Establish/maintain an RCS temperature so that a transition from SGTR-1 does not occur

Basis Failure to establish and maintain correct RCS temperature during a SGTR leads to a transition from SGTR-1 to a contingency procedure, which constitutes an incorrect performance that "necessitates the crew taking compensating action that complicates the event mitigation strategy..."

CT#4 (E-3 --C) Depressurize RCS until Ruptured SG and RCS pressure are equal and PZR level is ≥ 11% with Subcooling >0, before water release from ruptured SG PORV or Safety valve

Basis Failure to stop reactor coolant leakage into a ruptured SG by depressurizing the RCS needlessly complicates mitigation of the event. It also constitutes a "significant reduction of safety margin beyond that irreparably introduced by the scenario

VIII. ESG - PSA RELATIONSHIP EVALUATION

S-ILT-2006 NRC ESG-1 SALEM ESG - PRA RELATIONSHIPS EVALUATION FORM

EVENTS LEADING TO CORE DAMAGE

<u>Y/N</u>	EVENT	<u>Y/N</u>	EVENT
Ν	TRANSIENTS with PCS Unavailable	Ν	Loss of Service Water
Y	Steam Generator Tube Rupture	N	Loss of CCW
Y	Loss of Offsite Power	N	Loss of Control Air
Ν	Loss of Switchgear and Pen Area Ventilation	Ν	Station Black Out
N	LOCA		

COMPONENT/TRAIN/SYSTEM UNAVAILABILITY THAT INCREASES CORE DAMAGE FREQUENCY

~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~			
<u>Y/N</u>	COMPONENT, SYSTEM, OR TRAIN	<u>Y/N</u>	COMPONENT, SYSTEM, OR TRAIN
N	Containment Sump Strainers	Ν	Gas Turbine
Y	SSWS Valves to Turbine Generator Area	Y	Any Diesel Generator
N	RHR Suction Line valves from Hot Leg	N	Auxiliary Feed Pump
	CVCS Letdown line Control and Isolation		_
Ν	Valves	N	SBO Air Compressor

### **OPERATOR ACTIONS IMPORTANT IN PREVENTING CORE DAMAGE**

- Y/N OPERATOR ACTION
- N Restore AC power during SBO
- N Connect to gas turbine
- N Trip Reactor and RCPs after loss of component cooling system
- N Re-align RHR system for re-circulation
- Y Un-isolate the available CCW Heat Exchanger
- N Isolate the CVCS letdown path and transfer charging suction to RWST
- Y Cooldown the RCS and depressurize the system
- Y Isolate the affected Steam generator which has the tube ruptures
- Y Early depressurize RCS
- N Initiate feed and bleed

Complete this evaluation form for each ESG.

				100 100 - 44 - 100 100 100		"I" ILT NRC-ESG-0	01
	Ū	NIT TW	O PLANT ST TODAY	FATUS			
MODE: 1	POWER:	100	RCS BORON:	73	1	MWe:1200	
SHUTDOWN SAF	ETY SYSTEM	I STATU	JS (5, 6 & DEI	FUELED):			
N/A REACTIVITY PAI	RAMETERS						
Core Burn-	up 10,500 MWI	D/MTU, re	eactivity plan p	rovided by rea	actor engin	neering	
MOST LIMITING 3.8.1.1.b ac	LCO AND DA	TE/TIM l C/T	E OF EXPIRA	ATION:			
EVOLUTIONS/PR	OCEDURES/S	URVEII	LLANCES IN	PROGRESS	3:		
Shutdown to service	o 90% at 30% p	oer hour t	o support rem	oval of 22 he	eater drain	n pump from	
ABNORMAL PLA	NT CONFIGU	RATION	IS:				
CONTROL ROOM Unit 1 and No penalty	I: Hope Creek at 1 minutes in the la	00% powe ast 24 hrs.	er.				
PRIMARY:							
NONE							
SECONDARY: Heating ste	am is aligned to	unit 1.					
RADWASTE:							
No discharg	es in progress						
CIRCULATING W	ATER/SERVI	CE WAT	ER:				

### SIMULATOR ESG REVIEW/VALIDATION CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

### EXAMINATION SCENARIO GUIDE (ESG) REVIEW/ VALIDATION

Note: This form is used as guidance for an examination team to conduct a review for the proposed exam scenario(s). Attach a separate copy of this form to each scenario reviewed.

SELF-CHECK ESG-____IT ILT NRC-ESG-001__

X.

**REVIEWER:** <u>Ed Gallagher</u>

### 1. THE SCENARIO HAS CLEARLY STATED OBJECTIVES IN THE SCENARIO.

- 2. The initial conditions are realistic, equipment and/or instrumentation may be out of service, but it does not cue the crew into expected events.
- 3. Each event description consists of:
  - The point in the scenario when it is to be initiated,
  - The malfunction(s) that are entered to initiate the event,
  - The symptoms/cues that will be visible to the crew,
  - The expected operator actions (by shift position), and
  - The event termination point.
- 4. The use of non-mechanistic failures (e.g. pipe break) should be limited to one or a credible preceding event has occurred.
- 5. The events are valid with regard to physics and thermodynamics.
- 6. Sequencing/timing of events is reasonable (e.g. the crew has time to respond to the malfunctions in an appropriate time frame and implements procedures and/or corrective actions).
- 7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
- 8. If time compression techniques are used, scenario summary clearly so indicates.
- 9. The simulator modeling is not altered.
- 10. All crew competencies can be evaluated.
- 11. Appropriate reference materials are available (SOERs, LERs, etc.).
- 12. If the sampling plan indicates that the scenario was used for training during the requalification cycle, evaluate the need to modify or replace the scenario.
- 13. Proper critical task methodology is used IAW NRC procedures.
- 14. ESG-PSA Evaluation Form is completed for the scenario at the applicable facility.

### ATTACHMENT 1 SIMULATOR READY-FOR-TRAINING CHECKLIST

- 1. Verify simulator is in correct load for training
- 2. All required computer terminals in operation
- 3. Simulator clocks synchronized
- 4. Required chart recorders advanced and ON (proper paper installed)
- 5. Rod step counters correct (channel check)
- 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- 7. DL-10 log up-to-date
- 8. Required procedures clean
- 9. All OHA lamps operating (OHA Test)
- 10. All printers have adequate paper AND functional ribbon
- 11. Procedure pens available
- 12. Procedures in progress open and signed-off to proper step
- 13. Shift manning sheet available
- 14. SPDS reset
- 15. Reference verification performed with required documents available
- 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- 17. Required keys available
- 18. Video Tape (if applicable)
- 19. Ensure ECG Classification is correct - 960502140 CRCA-03
- 20. Reset P-250 Rod Counters

### ATTACHMENT 2 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgment of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

- I. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
  - degradation of any barrier to fission product release
  - degraded emergency core cooling system (ECCS) or emergency power capacity
  - a violation of a safety limit
  - a violation of the facility license condition
  - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
  - a significant reduction of safety margin beyond that irreparably introduced by the scenario
  - A. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
  - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
  - recognize a failure or an incorrect automatic actuation of an ESF system or component.
  - take one or more actions that would prevent a challenge to plant safety.
  - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) or ESF actuation.

### **ATTACHMENT 3**

**ESG PRE-JOB BRIEF CHECKLIST** 

### **EXAMINATION SCENARIO GUIDE (ESG)** Pre-Job Brief Checklist

**Note:** This checklist is to be completed by the Lead Examiner prior to evaluating an ESG. The Lead Examiner should lead a pre-job brief with all the examiners and simulator operators that includes, but is not limited to the following:

ESG: "I" ILT NRC-ESG-001 Examiner:

- 1.ESG overview and sequence of major events.
- 2.Determine which optional events will be performed, if any.
- _____ 3.ESG summary of Critical Tasks.
- 4.Assign examiners to observe specific watch standers.
- 5.Assign examiner ownership for observing and documenting performance / non-performance of

Critical Tasks.

6.Review alternate path(s) identified by the ESG.

- 7.Assign examiner to document data related to the performance of Critical Tasks.
  - 8.Determines what parameters will be recorded in "Data Collection."

Ensure SOE recorder is recording.

### SIMULATOR EXAMINATION SCENARIO

SCENARIO TITLE:	LOCA
SCENARIO NUMBER:	I ILT NRC ESG-002
EFFECTIVE DATE:	12/4/6
<b>EXPECTED DURATION:</b>	1.5 hours
<b>REVISION NUMBER:</b>	00
PROGRAM:	L.O. REQUAL
	<b>X</b> INITIAL LICENSE
	STA
	OTHER

Revision Summary:

Rev 0: New Issue for I ILT NRC exam

PREPARED BY:	Paul Williams (INSTRUCTOR)	<u> </u>
APPROVED BY:		
	(OPERATIONS TRAINNG MANAGER OR DESIGNEE)	(DATE)
APPROVED BY:	OPERATIONS MANAGER OR	(DATE)
	DESIGNEE)	(DAIL)

### I. OBJECTIVES

### **Enabling Objectives**

- A. Given the unit in a start-up condition and the need to raise power, raise power to 18-20%, IAW approved station procedures.
- B. Given the unit at power with a loss of tripping capability on a reactor trip breaker, the crew will validate the alarm, IAW approved station procedures.
- C. Given the unit with a trip of the running charging pump, the crew will place another pump in service, IAW approved station procedures.
- D. Given the unit at power with a partial loss of off-site power, the crew will take actions to stabilize the unit, IAW approved station procedures.
- E. Given the unit with a LOCA in progress, the crew will take corrective actions to mitigate the accident, IAW approved station procedures.
- F. Given the unit with a total loss of off-site power and a LOCA in progress, the crew will take actions to restore safeguards equipment, IAW approved station procedures.

### MAJOR EVENTS

II.

- A. Raise power to place Turbine on Line
- B. Loss of Tripping Capability on RTB "B"
- C. 23 CV Pump Trip
- D. Loss of 3 SPT
- E. Small Break LOCA
- F. Loss of Off-Site Power

### III. SCENARIO SUMMARY

- A. The crew will receive the unit at 4.5% power returning from a forced outage to repair Digital EHC problems. All approvals and surveillances are complete and approval to proceed to mode 1 has been given. Order to the shift is to raise power to 18% in preparation for placing turbine on line.
- B. After the power ascension is in progress an electrical malfunction will cause the A Reactor Trip breaker to lose 125V DC causing the loss of Shunt trip capability. The CRS will evaluate the operability of the trip breaker and enter the tech spec action statement.
- C. After the tech spec is entered the in service charging pump will trip additionally the letdown orifice isolation valve will fail partially open. The crew will isolate letdown and place a standby charging pump in service IAW AB.CV-0001. Once charging is restored excess letdown will be placed in service.
- D. After excess letdown is in service 3 station power transformer will trip. This will cause a loss of 2 group busses and RCPs. No auto trip signal will occur at <P-10. The crew will enter AB.LOOP-0003, which will direct a Reactor Trip.
- E. After the crew has transitioned to EOP-TRIP-2, a LOCA will occur and Auto SI initiation will fail. The crew will manually initiate SI and re-enter the EOP network.
- F. After the crew has progressed to EOP-LOCA-1 and reset safeguards a loss of Off-site power will occur. The crew will reset the SECs and load the ECCS equipment required for the LOCA conditions. The scenario will end after safeguard loads are started.

### IV. INITIAL CONDITIONS

### Presnapped IC-192 from Exam Drive

MAL	FUNCTIONS:				
SELF-CHECK	Description	Delay	Ramp	Trigger	Severity
1.	CV0034 23 Charging Pump Trip	NA	NA	ET-2	
2.	VL0245 2CV4 Fails to Position	NA	NA	ET-2	50
3.	EL0102 Loss of 3 SPT-Diff	NA	NA	ET-3	
4.	RC0002 RCS Leak into Containment	NA	NA	ET-4	10000
5.	EL0134 Loss of Off-Site Power	NA	NA	ET-5	
6.	RP0108 Failure of Automatic SI	NA	NA	NA	NA
7.	RP0342 2SJ12 Fails to Open on SEC act	NA	NA	NA	NA
8.	RP0343 2SJ13 Fails to Open on SEC act	NA	NA	NA	NA
9.	AN0183 E37 Ch C Shutdown Margin	NA	NA	NA	1
10.	AN0191 E45 Ch D Shutdown Margin	NA	NA	NA	1

REMO	OTES:				
SELF-CHECK	Description	Delay	Ramp	Trigger	Condition
1.	MC12D Loss of Tripping Capability RTB "A"	NA	NA	ET-1	Alarm
2.	CV42A Minimum Flow Stop for 2CV55	NA	NA	ET-10	0
3.	MT03D Main Turb Turning Gear PB	NA	NA	NA	Dep PB
4.	DA033D DC breaker #14 A RX Trip Brkr	NA	NA	ET-1	Off

OVER	RIDES:				
SELF-CHECK	Description	Delay	Ramp	Trigger	Action

EVEN	T TRIGGE	IRS:		
SELF-CHECK	ET#n	Discription	Command	=
1.	None			

Tz	AGGED EQUIPMENT:
	Description
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	RH1 and RH2 VC 1-4 RH 18's RCPs (SELF CHECK) RT (SELF CHECK) MS 167s (SELF CHECK) 500 KV SWYD (SELF CHECK). 22 ABV Supply Fan 23 CV Pump (SELF CHECK)

•					O	ΤH	ER	CC	)N	Dľ	ΓIC	)N	S	, h		

Description

1. IOP-3 signed off thru step 5.4.14

lat di

### SEQUENCE OF EVENTS

V.

- A. State shift job assignments:
- B. Hold a shift briefing, detailing instruction to the shift: (provide CREW members a copy of the shift turnover sheet)
- C. Inform the crew "The simulator is running. You may commence panel walkdowns at this time. CRS please inform me when your crew is ready to assume the shift".
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.
- E. Do not review objectives with crew

### Evaluator/Instructor Activity Expected Plant/Student Response Comments

•

### **1.** Power Increase

Crew will receive the watch at 4.5% power with direction to raise power in preparation to place the main turbine on line. IOP-3 is signed off thru step 5.4.14

- CRS briefs crew on power increase
- RO withdraws rods to raise reactor power
- PO adjusts steam dumps to increase steam load and maintain Tavg on program

Proceed to next event when power reduction has progressed to the satisfaction of the Lead examiner but before 10% power

### 1. Loss of Tripping Capability on

"A"	KT.	в

Insert ET-1 at the direction of the • RO reports alarm to CRS Lead evaluator

٠

- CRS directs ROs to hold power increase
- PO reviews ARP and informs CRS
- CRS directs NEO to check 125VDC breaker

CRS enters TSAS 3.3.1.1 act 14

3 mins after request to check breaker inform CRS breaker is closed

Proceed to next event after TSAS determination or when directed by Lead Evaluator Evaluator/Instructor Activity Expected Plant/Student Response Comments

### 2.23 CV Pump Trip

the second s	and the second		
A COLUMN AND A COLUMNA AND A COLUMN AND A CO			
		<u>នៃ ដែលជាមួយ ដែល ដែល ដែល ដែល ដែល ដែល ដែល ដែល ដែល ដែល</u>	
			· · · · · · · · · · · · · · · · · · ·
÷			
077767 1 12 CD 0 CO 0			
661 wa wa 19 19 19 19 19 19 19 19 19 19 19 19 19	2017.00000000000000000000000000000000000	and the second	
	•	( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( )	
and the local sector of th		/5.52 C	
and the second	F		References and a second second second second

- RO responds to loss of seal injection flow console alarms, identifies 23 Charging Pump trip
- CRS enters AB-CVC-1
- Crew determines pump did not trip due to cavitation
- RO closes 2CV2 and 2CV277
- RO informs CRS that CV4 did not close fully
- CRS directs RO to attempt to close CV4 and RO reports that CV4 did not close
- CRS directs letdown isolated using the 2CV2 and 2CV277 to prevent flashing the Letdown Line
- Crew determines 23 CV pump not available
- CRS directs start of 21 or 22 Charging Pump IAW AB.CVC-1
- RO shifts CV55 to Manual CLOSED, starts a CCP
- CRS directs NEO to investigate cause of 23 Charging pump trip
- CRS directs Excess Letdown reestablished IAW SO.CVC-0003
  - RO establishes excess letdown

٠

CRS directs CV7 to be closed to isolate

### To place CV55 in Bypass REMOTES CV47A to 0.0

Evaluator/Instructor Activity Expected Plant/Student Response Comments

### penetration

Proceed to next event when TSAS is determined

### 3. 3 SPT Trip, SB LOCA

# Insert ET-3 on cue from Lead Evaluator.

CRS must prioritize multiple problems including loss of main feed, steam dumps and 2 group busses and their respective RCPs. The CRS may order a Reactor trip at this time due to loss of 2 RCPs or cycling of MS dumps. CRS may also enter AB.CN or AB.CW neither will direct a Reactor Trip at <P10

CAS of LOOP-3 directs implementing Attachment 2, Part A. This attachment directs opening of the Reactor Trip breakers

INSTRUCTOR NOTE: Insert ET-4 after Crew transitions to TRIP-2, at RCS Temp Control Step (Step-5)

- CRS enters TSAS 3.6.3 and contacts WCC to prepare a tagout for CV7
- Crew acknowledges multiple OH and console alarms
- PO informs CRS that 21 CN pump and 21 SGFP have tripped and AFW has started and is feeding the SGs
- CRS enters AB.LOOP-0003
- CRS initiates CAS of LOOP-3
- PO informs CRS that all vital buses are energized by off-site power
- CRS directs WCC to coordinate opening 500KV disconnects
  - Crew initiates Attach 2, Part A of LOOP-3 for loss of 2E and 2H group busses
- CRS directs a Reactor trip, enters Trip-1 requests assistance form WCC to continue with AB-LOOP-3
- RO initiates a MANUAL Rx trip
- RO performs TRIP-1 Immediate Actions, from memory:
  - 1. Trip reactor,
  - 2. Confirm reactor trip,
  - 3. Trip turbine,
  - 4. All 4 KV Vital Bus energized
  - 5. SI Actuation not required
- CRS enters TRIP-1 and reads Immed

Evaluator/Instructor Activity Expected Plant/Student Response Comments

Actions

- PO throttles AFW at completion of Immed actions
- CRS transitions to TRIP-2
- RO announces Reactor Trip
- PO throttles AFW

•

.

- RO reports rapidly lowering PZR pressure and level
  - RO initiates Safety Injection due to lowering Pressurizer Pressure
- CRS returns to Trip-1
- RO announces Rx Trip and Safety Injection and informs CRS that Auto SI failed to actuate
- RO/PO performs SEC loading verification
- PO ensures 21 and 22 AFW pumps are running and throttles AFW flow to maintain Steam Generator level >9% or >22E4 lbm/hr feed flow.
- PO checks Safeguards Valve Alignment and identifies 2SJ12 and 2SJ13 not open
- CRS directs RO to open 2SJ12 and 13
- RO opens valves and informs CRS BIT flow now established
- RO closes 21/22CA330.

CT-1 (E-0 --D) Manually actuate at least 1 train of Safety Injection before transition to LOCA-1, any FR procedure or completion of step 9 of Trip-2 SAT____UNSAT____

Depending on timing of manual SI crew may not identify failure of Auto SI if manual is initiated prior to auto setpoint. SI setpoint occurs in approx 14 sec

### Evaluator/Instructor Activity Expected Plant/Student Response Comments RO reports Containment Spray not required RO determines MSLI isolation is not required CREW closes CV139 and CV140 when RCS pressure is below 1500 psig with BIT Flow established CT #2 (E-1-C) Trip all RCPs prior to CREW secures remaining RCPs when • **RCS** inventory becoming depleted to RCS pressure is < 1350 with ECCS critical inventory. (Within 5 mins of flow established RCS pressure < 1350 with ECCS flow) SAT UNSAT Instructor note: RCPs must be PO verifies all 4KV vital busses stopped regardless of BIT flow, energized ECCS flow is established via the SI pumps RO reports Control Room Ventilation in Pressurized Mode RO reports proper Switchgear Room Ventilation lineup.

- RO reports 2 CCW pumps running
- RO evaluates ECCS flow alignment.
- RO/PO verifies AFW flow >22E04 lbm/hr or SG level >9%.
- Crew verifies RCS temperature control.
- RO/PO verifies reactor trip breakers open.
- RO verifies PORVs closed and stop

Evaluator/Instructor Activity Expected Plant/Student Response Comments

valves open

- CREW identifies PZR Sprays not available and RCPs secured.
- PO verifies no faulted SGs.
- PO verifies no SGTRs exist.
- RO/PO perform LOCA evaluation
- CREW transitions to LOCA-1.
- Crew performs verifications of FRCE-1 and return to LOCA-1 (Only of Purple path is met)
- PO verifies no faulted SGs.
- PO maintains SG levels
- PO verifies no ruptured SGs.
- RO/PO resets Safeguards:
  - Resets SI;
  - Resets Phase A;
  - Resets Phase B;
  - Opens 21 & 22CA330;
  - Resets each SEC; and
  - Resets 230V Control Centers.
- Crew evaluates SI flow reduction criteria
- CRS determines spray pumps and RHR pumps should not be stopped
- PO stops unloaded diesels
  - CRS refers to Step 5 Continuous Action "IF Blackout occurs…"

Depending on timing of scenario Containment spray may occur while the crew is in TRIP-1 or LOCA-1 and a purple path transition to FRCE may occur

Depending on timing of scenario RHR pumps may be stopped if RCS pressure has stabilized.

#### 5. Loss of Off-Site Power

Insert <u>ET-5</u> after 230V Control Centers are reset, or at Lead Evaluator's discretion.
#### Evaluator/Instructor Activity Expected Plant/Student Response Comments



- Crew performs actions of Table B of LOCA-1
- RO/PO verifies SEC loading complete
- PO resets all SECs.
- CRS directs restart of available Safeguards loads:
  - o 21 and 22 Charging Pump
  - o 21/22 SI Pump;
  - o 21-25 CFCU in slow speed;
  - Switchgear Room Exhaust Fans
  - Containment Spray pumps (If required)

Crew may decide not to start RHR pumps if they were previously stopped, RHR pumps are not required at this pressure

CT #3 (E-0-J) Start at least one Safety Injection Pump (Intermediate Head) prior to step 14 of LOCA-1 or prior to step 6 of FRCC-2.

SAT UNSAT

Evaluator Note: ECG classification is Alert EAL 3.2.2.b

Terminate scenario at the completion of the equipment restart or lead evaluators discretion

#### VI. SCENARIO REFERENCES

- A. Alarm Response Procedures (Various)
- B. Technical Specifications
- C. SC.OP-AP.ZZ-0102(Q), Use of Procedures
- D. S2.OP-AB.CVC-0001 Charging System Malfunction
- E. S2.OP-AB.LOOP-0003 Partial Loss of Off-Site Power
- F. EOP-TRIP-1 Reactor Trip or Safety Injection
- G. EOP-TRIP-2 Reactor Trip Response
- H. EOP-LOCA-1 Loss of Coolant
- I. EOP-FRCE-1 Response to Excessive Containment Pressure

# VII. ESG CRITICAL TASK RATIONAL

CT-1 (E-0 –D): Manually actuate at least 1 train of Safety Injection before transition to any LOCA, or FR procedure or completion of step 9 of Trip-2.

**BASIS:** Failure to manually actuate SI under postulated conditions constitutes "misoperation or incorrect crew performance that leads to degraded ECCS capacity" Additionally, failure to manually actuate SI (when it is possible to do so) results in a "significant reduction in safety margin beyond that irreparably introduced by the scenario." Finally, failure to manually actuate SI is a "violation of the facility license condition"

CT #2 (E-1-C): Trip all RCPs prior to RCS inventory becoming depleted to critical inventory. (within 5 mins of RCS pressure < 1350 with ECCS flow)

**BASIS:** Failure to trip the RCPs under the postulated plant conditions leads to core uncovery and to fuel cladding temperatures in excess of 2200°. Thus, failure to perform the task represents "mis-operation or incorrect crew performance which leads to the degradation of a barrier to fission product release.

WOG sponsored analysis to demonstrate that the operating crew would have sufficient time (from the point at which the criteria was met) to recognize the indications that the criteria are met and trip RCPs before the window for adverse consequence begins...The minimum response time for the operating crew is 5 minutes... if the RCPs are tripped within 5 minutes of the trip criteria being met, PCT remains below 2200

**CT#3:** Re-establish plant design basis conditions by starting at least one train of ECCS equipment after a loss of off-site power occurs with SI Reset.

**BASIS:** FSAR assumption of minimum ECCS flow per section 15.3.1.2.

# VIII. ESG - PSA RELATIONSHIP EVALUATION

#### I ILT NRC #2 SALEM ESG - PRA RELATIONSHIPS EVALUATION FORM

# EVENTS LEADING TO CORE DAMAGE

<u>Y/N</u>	EVENT	Y/N EVENT
Ν	TRANSIENTS with PCS Unavailable	N Loss of Service Water
N	Steam Generator Tube Rupture	N Loss of CCW
Y	Loss of Offsite Power	N Loss of Control Air
N Y	Loss of Switchgear and Pen Area Ventilation LOCA	N Station Black Out

# COMPONENT/TRAIN/SYSTEM UNAVAILABILITY THAT INCREASES CORE DAMAGE FREQUENCY

V/N	COMPONENT SYSTEM OF TRAIN	V/N	COMPONENT, SYSTEM, OR
1/11	COMPONENT, STSTEM, OK TRAIN	<u>1/1N</u>	TRAIN
 N	Containment Sump Strainers	N	Gas Turbine
N	SSWS Valves to Turbine Generator Area	N	Any Diesel Generator
Ν	RHR Suction Line valves from Hot Leg	N	Auxiliary Feed Pump
	CVCS Letdown line Control and Isolation		_
Y	Valves	Ν	SBO Air Compressor

## **OPERATOR ACTIONS IMPORTANT IN PREVENTING CORE DAMAGE**

- Y/N OPERATOR ACTION
- <u>N</u> Restore AC power during SBO
- N Connect to gas turbine
- N Trip Reactor and RCPs after loss of component cooling system
- N Re-align RHR system for re-circulation
- N Un-isolate the available CCW Heat Exchanger
- N Isolate the CVCS letdown path and transfer charging suction to RWST
- N Cooldown the RCS and depressurize the system
- N Isolate the affected Steam generator which has the tube ruptures
- N Early depressurize RCS
- N Initiate feed and bleed

Complete this evaluation form for each ESG.

						"I" ILT NRC	-ESG-002
							Signature P
		UNIT T	WO PLAN	T STATUS			
			ΤΟΦΑΥ				
MODE: 1	POWER	4 2	RCS	61	07	MWe: 0	Chernes .
	1000210	1.2	BORON:	0.	01		

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED):

N/A

#### **REACTIVITY PARAMETERS**

Core Burn-up 17,500 MWD/MTU, reactivity plan provided by reactor engineering is for initial power increase to 20% to be performed with control rods. Detailed plan for continued power ascension will be provide after Turbine is on line.

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

#### EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

Increase power to 18% in preparation for placing the main turbine on line. IOP-3 is complete thru step 5.4.14 and all approvals and surveillances for transition to Mode 1 are complete.

ABNORMAL PLANT CONFIGURATIONS:

#### CONTROL ROOM:

Unit 1 and Hope Creek at 100% power. No penalty minutes in the last 24 hrs.

#### PRIMARY:

NONE

#### SECONDARY:

Heating steam is aligned to unit 1.

#### RADWASTE:

No discharges in progress

#### CIRCULATING WATER/SERVICE WATER:

# SIMULATOR ESG REVIEW/VALIDATION CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

#### EXAMINATION SCENARIO GUIDE (ESG) REVIEW/ VALIDATION

Note: This form is used as guidance for an examination team to conduct a review for the proposed exam scenario(s). Attach a separate copy of this form to each scenario reviewed.

 SELF ESG-____TT ILT NRC-ESG-002_
 REVIEWER: ____Ed Gallagher

#### 1. THE SCENARIO HAS CLEARLY STATED OBJECTIVES IN THE SCENARIO.

- 2. The initial conditions are realistic, equipment and/or instrumentation may be out of service, but it does not cue the crew into expected events.
- 3. Each event description consists of:

X.

- The point in the scenario when it is to be initiated,
- The malfunction(s) that are entered to initiate the event,
- The symptoms/cues that will be visible to the crew,
- The expected operator actions (by shift position), and
- The event termination point.
- 4. The use of non-mechanistic failures (e.g. pipe break) should be limited to one or a credible preceding event has occurred.
- 5. The events are valid with regard to physics and thermodynamics.
- 6. Sequencing/timing of events is reasonable (e.g. the crew has time to respond to the malfunctions in an appropriate time frame and implements procedures and/or corrective actions).
- 7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
- 8. If time compression techniques are used, scenario summary clearly so indicates.
- 9. The simulator modeling is not altered.
- 10. All crew competencies can be evaluated.
- 11. Appropriate reference materials are available (SOERs, LERs, etc.).
- 12. If the sampling plan indicates that the scenario was used for training during the requalification cycle, evaluate the need to modify or replace the scenario.
- 13. Proper critical task methodology is used IAW NRC procedures.
- 14. ESG-PSA Evaluation Form is completed for the scenario at the applicable facility.

# ATTACHMENT 1 SIMULATOR READY-FOR-TRAINING CHECKLIST

- 1. Verify simulator is in correct load for training
- 2. All required computer terminals in operation
- 3. Simulator clocks synchronized
- 4. Required chart recorders advanced and ON (proper paper installed)
- 5. Rod step counters correct (channel check)
- 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- 7. DL-10 log up-to-date
- 8. Required procedures clean
- 9. All OHA lamps operating (OHA Test)
- 10. All printers have adequate paper AND functional ribbon
- 11. Procedure pens available
- 12. Procedures in progress open and signed-off to proper step
- 13. Shift manning sheet available
- 14. SPDS reset
- 15. Reference verification performed with required documents available
- 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- 17. Required keys available
- 18. Video Tape (if applicable)
- 19. Ensure ECG Classification is correct - 960502140 CRCA-03
- 20. Reset P-250 Rod Counters

#### ATTACHMENT 2 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgment of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

- I. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
  - degradation of any barrier to fission product release
  - degraded emergency core cooling system (ECCS) or emergency power capacity
  - a violation of a safety limit
  - a violation of the facility license condition
  - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
  - a significant reduction of safety margin beyond that irreparably introduced by the scenario
  - A. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
  - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
  - recognize a failure or an incorrect automatic actuation of an ESF system or component.
  - take one or more actions that would prevent a challenge to plant safety.
  - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) or ESF actuation.

# **ATTACHMENT 3**

**ESG PRE-JOB BRIEF CHECKLIST** 

#### **EXAMINATION SCENARIO GUIDE (ESG)** Pre-Job Brief Checklist

**Note:** This checklist is to be completed by the Lead Examiner prior to evaluating an ESG. The Lead Examiner should lead a pre-job brief with all the examiners and simulator operators that includes, but is not limited to the following:

ESG: <u>"I" ILT NRC-ESG-001</u> Examiner:

- 1.ESG overview and sequence of major events.
- 2.Determine which optional events will be performed, if any.
- _____ 3.ESG summary of Critical Tasks.
- 4.Assign examiners to observe specific watch standers.
- 5.Assign examiner ownership for observing and documenting performance / non-performance of

Critical Tasks.

6.Review alternate path(s) identified by the ESG.

- 7.Assign examiner to document data related to the performance of Critical Tasks.
  - 8.Determines what parameters will be recorded in "Data Collection."

Ensure SOE recorder is recording.

# SIMULATOR EXAMINATION SCENARIO

Loss of Heat Sink
I ILT NRC ESG-003
12/4/6
1.5 hours
00
L.O. REQUAL
X INITIAL LICENSE
STA
OTHER

Revision Summary:

Rev 0: New Issue for I ILT NRC exam

PREPARED BY:	Paul Williams	10/9/06
	(INSTRUCTOR)	(DATE)
<b>APPROVED BY:</b>		<u> </u>
	(OPERATIONS TRAINNG	(DATE)
	MANAGER OR DESIGNEE)	
APPROVED BY:		
	(OPERATIONS MANAGER OR DESIGNEE)	(DATE)

# OBJECTIVES

I.

#### **Enabling Objectives**

- A. Given the unit at power, with a sustained excessive U2 Main Power Transformer DC Ground Current, the crew will reduce power as required, IAW approved station procedures.
- B. Given the unit at power with a Thot Failure, the crew will place rods in manual and stabilize the plant, IAW approved station procedures.
- C. Given the unit at power with a leak in the CCW system, the crew will identify and isolate the leak, IAW approved station procedures.
- D. Given a situation with an OHA alarm, perform action(s) to investigate and correct the cause of the alarm, IAW approved station procedures.
- E. Given the unit with a loss of heat sink condition, the crew will restore feedwater, IAW approved station procedures.

# II. MAJOR EVENTS

- A. Abnormal Grid
- B. 22 Loop Tavg fails as is
- C. CCW Leak
- D. Main Power Transformer Failure
- E. Loss of Heat Sink

## III. SCENARIO SUMMARY

- A. The crew takes the watch at 100% power. 21 AFW Pump is tagged for bearing replacement.
- B. Once the crew assumes the watch the DC neutral ground current will rise to 25 amps. The crew will enter AB.GRID-0001 and reduce power to 942 MWe. During the power reduction 22 Loop Tavg will fail as is resulting in excessive rod motion. The crew will enter AB.ROD-0003 and remove the channel from service.
- C. After the channel is removed from service, a leak develops in the CCW system. The crew should implement AB.CC-0001 to establish makeup flow and isolate the leak.
- D. Following isolation of the CCW leak, an OHA alarm comes in on MPT Phase 1. The NEO will report a major oil leak on the MPT and a desire to leave the area because of electrical arcing noises. The CRS should order a manual reactor trip.
- E. The Turbine fails to trip on the reactor trip and MSLI fails to auto initiate. The crew should initiate a MSLI as part of immediate actions of EOP-TRIP-1. Safety Injection will occur based on the high steam flow.
- F. 23 AFWP trips when it auto starts and is not able to be reset. After AFW flow is throttled to 22e4, 22 AFWP breaker trips open. The crew should transition to FRHS-1 when the RED PATH conditions are met. In FRHS-1, the crew should stop the RCPs; select 1 SG for depressurization to allow feed using a Condensate pump.
- G. The Lead Evaluator can terminate the scenario any time after S/G WR level is observed rising.
- H. **NOTE:** Depending on timing of the MSLI and progress through the procedures, RCS Bleed and Feed criteria may be met before the Condensate pump is feeding the S/G. In that case, the crew will initiate RCS Bleed and Feed then feed the S/Gs via a Condensate Pump.

5,121

# IV. INITIAL CONDITIONS

# Pre-snapped IC-193 from portable exam drive

MALI	FUNCTIONS:		f seatter state and seatter state and seatter state		
SELF-CHECK	Description	Delay	Ramp	Trigger	Severity
1.	RP0069 MN Turb Trip Internal VIv Fail	N/A	N/A	N/A	N/A
2.	RP0073 MN Turb Trip Failures Various	N/A	N/A	N/A	4
3.	RP0279A Auto MSLI Fails to ACT Trn A	N/A	N/A	N/A	N/A
4.	RP0279B Auto MSLI Fails to ACT Trn B	N/A	N/A	N/A	N/A
5.	AF0183, 23 Aux FW Pmp Overspeed Trip	N/A	N/A	NA	NA
6.	RC0014B 22 Loop Tavg	2:00	NA	ET-1	As-Is
7.	CC0329 CC Leak at 21 Safety Rel Header	N/A	1:00	ET-2	30
8.	AN0529, SER 529:H15 MPT Sud Press	N/A	N/A	ET-3	On
9.	AF0181B, 22 Aux Feedwater Pump Trip	N/A	N/A	ET-4	True
10.	VL0464-467 21-24BF40 Fails (as directed)	NA	NA	NA	100

REMO	DTES:		Aller and a second	n de ser a la ser a La ser a la s	
SELF-CHECK	Description	Delay	Ramp	Trigger	Condition
1.	AF20D, 21 AFW Pump Bkr Control Power	N/A	N/A	N/A	Off
2.	AF21D, 21 AF Pump Rack Out	N/A	N/A	N/A	Tagged
3.	EL12A DC Neutral Ground Current	NA	2:00	ET-1	25

OVERRIDES:					
SELF-CHECK	Description	Delay	Ramp	Trigger	Action
1.	OVDI MSLI CH A Loop 1	NA	NA	NA	Off
2.	OVDI MSLI CH A Loop 2	NA	NA	NA	Off
3.	OVDI MSLI CH A Loop 3	NA	NA	NA	Off
4.	OVDI MSLI CH A Loop 4	NA	NA	NA	Off
5.	OVDI MSLI CH B Loop 1	NA	NA	NA	Off
6.	OVDI MSLI CH B Loop 2	NA	NA	NA	Off

7.OVDI MSLI CH B Loop8.OVDI MSLI CH B Loop		SLI CH B Loop 3 SLI CH B Loop 4		NA NA	NA NA	NA NA	Off Off
EVEN SELF-CHECK	TTRIGGE	IRS: Description		Comm	and		An
1. None							
TAGO De	GED EQUII	PMENT:					
Description           1.         RH1 and RH2           2.         VC 1-4           3.         RH 18's           4.         RCPs (SELF CHECK)           5.         RT (SELF CHECK)           6.         MS 167s (SELF CHECK)           7.         500 KV SWYD (SELF CHECK).           8.         22 ABV Supply Fan           9.         23 CV Pump (SELF CHECK)           10.         21 AFW Pump (C/T)							
	Descrip	otion	THER CONDI	TIONS:			

_____ 1. None

÷φ.

# V. SEQUENCE OF EVENTS

- A. State shift job assignments:
- B. Hold a shift briefing, detailing instruction to the shift: (provide CREW members a copy of the shift turnover sheet)
- C. Inform the crew "The simulator is running. You may commence panel walkdowns at this time. CRS please inform me when your crew is ready to assume the shift".
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.
- E. Do not review objectives with crew

#### Evaluator/Instructor Activity Expected Plant/Student Response

#### Comments

#### 1. Abnormal Grid

Enter ET-1 EL12A to 25

INSTRUCTOR NOTE: 2 minutes after modifying the remote, call as the Electric Systems Operator (ESO) and inform the Crew that the SMD has been upgraded to K-8 for the next 6 hours.

- PO acknowledges OHA H-23, MPT Ø2 TRBL
- PO determines CRT point 545 is in alarm and refers to alarm response
- CREW dispatches NEO to MPT Phase 2 to investigate and correct alarm
  - CREW monitors Computer point Y2107A and determines that MPT DC Ground Current is ≥15 amps
- PO informs CRS that MPT DC Ground Current is rising rapidly
- CREW determines that MPT DC Ground Current has been ≥ 17 amps for > 5 minutes.
- CRS enters S2.OP-AB.GRID-0001
- CREW initiates Attachment 1, Continuous Action Statements (CAS)
- CREW initiates Attachment 2, Solar Magnetic Disturbance.
- CREW holds brief discussing actions of AB.GRID-1 including reactivity and contingency actions
- CREW initiates a Generator Load reduction to <942 MW by:
  - PO selecting SMD #1 Runback of DEHC panel
  - PO selecting GO on DEHC panel
- CREW initiates S2.OP-AB.LOAD-0001
- CREW performs Continuous Actions

# Evaluator/Instructor Activity Expected Plant/Student Response Comments

Summary (Attachment 1) of S2.OP-AB.LOAD-0001.

- RO/PO maintain TAVG on program with rods, boration, or turbine load
- RO energizes Pressurizer heaters
- RO/PO initiates boration or Rapid Boration to maintain rods above RIL
- CREW determines AFD is outside the target band and begins accumulation of penalty minutes.

#### 2. 21 loop Tavg fails As Is

Failure of 21 loop Thot will become evident during down power

Crew should determine that the Rod insertion limits are not valid alarms due to the failed Thot channel. Depending on timing of 22 Loop Thot failure, crew may not enter AB-ROD-3 but may defeat the channel using console ARP. This will cause rods to withdraw rapidly when failed channel is removed from circuit

Proceed to next event when load is stable and level control has been returned to auto or at discretion of lead evaluator

- RO informs CRS that rods are inserting in Auto, with Tave lowering further than expected also 21 Tavg channel is higher than the others
- RO reports OHA for Rod insertion limit Lo and LO LO.
- CRS directs RO to place rods in manual

RO may request permission to place rods in manual prior to direction

CRS enters S2.OP-AB.ROD-0003

٠

- RO withdraws rods as required to control Tavg IAW Attachment 1 of S2.OP-AB.ROD-0003
- Crew identifies 21 loop Thot as failed
- RO adjusts charging flow as required to restore PZR level to program
- CRS directs RO to defeat failed channel

#### Evaluator/Instructor Activity Expected Plant/Student Response Comments

- RO returns PZR level and Rod control to Automatic
- CRS enters TSAS for 21 Loop Thot and requests assistance from I&C to remove channel from service TSAS 3.3.1.1 act 6, 3.3.2.1.b act 19

#### 3. CCW Leak



Role Play: ~2 minutes later, NEO reports CC145 is open, CC146 is closed.

- RO/PO report lowering level in CCW surge tank
- PO refers to console ARP and initiates makeup to CCW surge tank
- CREW enters AB.CC-001.
- PO opens 2DR107 to makeup to the system and determines level can be maintained
- RO directs NEO to verity CC145 or CC146 open.
- CRS directs NEOs to walkdown the system.
- Crew monitors sumps and WHUTs
- RO reports RHR sump pump run
- CRS initiates attachment 4 for locating leak.
- RO informs CRS 22CV pump not in service

•

- PO places 2CC31 in manual and starts 23 CC pump then stops 21 CC pump
- CRS returns to step 3.28 and refers to Attachment 3 for isolation of leak
- CRS directs NEO to isolate pump by closing 21CC2 and 21CC19

Role Play when 21 CC pump is stopped call as NEO and report: Large leak on 21 CC pump mechanical seal appears to have lessened when the pump was stopped. Modify MALF: CC0339A from 30 to 5 If asked: NEO states he can safely

close pump isolation valves with reduced leak rate

#### Evaluator/Instructor Activity Expected Plant/Student Response Comments

• CRS directs the WCC to have NEO deenergize control power for 21 CC pump to prevent auto start of isolated pump and requests tagging request for 21 CC pump.

Remote CC21D to off then report as NEO: 125V DC control power for 21 CC pump is off Delete MALF CC 0339A and report as NEO: 21CC2 and 21CC19 closed

CRS refers to Tech Specs and enter TSAS 3.7.3

### **3. MPT PHASE I Failure**

Insert ET-3 when directed by Lead Evaluator

Role Play: ~ 3 minutes after contacted, the NEO reports a major oil leak on the Main Power Transformer and the constant sound of electrical arcing.

4. Reactor Trip, Failure of Auto Turbine Trip, MSLI and Subsequent Loss of all Feedwater

Note: Trip of 23 AFW pump is preinserted. The pump will trip on overspeed when it starts.

CT#1(E-0 -P): Manually accomplish MSLI before a severe challenge develops to either subcriticality or integrity CSF or transition to LOSC SAT_____UNSAT____

- CREW responds to OHA H-15
- CREW implements OHA ARP and sends an NEO to investigate.
- CRS orders a MANUAL Reactor trip based on MPT problem.
- RO performs IA's for TRIP-1:
- 1) Trip Reactor.
- 2) Confirm Reactor trip.
- 3) Reports Turbine NOT Tripped.
- 4) Attempts Manual Turbine Trip
- 5) Attempts MSLI from safeguards bezel
- 6) Fast closes MS167s from CC3
- 7) Verifies 4kV Vital Bus energized.
- 8) Reports SI actuated.
- PO reports 23 AFW pump tripped

 PO report generator breakers did not open with turbine failing to trip

# Evaluator/Instructor Activity Expected Plant/Student Response Comments

- CRS directs generator breakers open
  - PO throttles 21/22AF21 to 22e4 to minimize cooldown.
- PO reports trip of 22 AFW Pump and loss of all AFW capability
- CREW dispatches NEO to investigate loss of 22 and 23 AFW pumps

Crew brief in TRIP-1 should be expedited due to degrading Heat Sink conditions

Insert RT-4 on que from lead

Role Play: ~ 2 minutes after

assistance

contacted, NEO reports the trip

linkage is bent and the 23 pump cannot be reset request maintenance

evaluator to trip 22 AFW pump

- CRS briefs crew on status and plan
- CREW transitions to FRHS-1 at step 20.1 of TRIP-1
  - CRS reviews Bleed and Feed criteria
- Crew determines Aux Feed Pumps are not available
- RO stops all RCPs.
- PO reports Condensate system is in operation
- Crew determines that SGFPs are not available due to SI actuation.
  - Crew verifies SI valve alignment.
- RO resets safeguards

Evaluators: If RCS Bleed and Feed criteria are met before feed is initiated from the CN system, Crew should IMMEDIATLY go to Bleed and Feed at step 23 See Page 13 of this guide.

# This was previously performed in EOP-TRIP-1

#### Evaluator/Instructor Activity Expected Plant/Student Response Comments

•

.

•

24 SG should be selected for depressurization as its level will be less than 22 SG due to the delayed trip of 22 AFW pump

Enter VI-464-467 to 100% as directed to open BF40

CT#2A (FR-H.1-E): Establish minimum required feedwater flow rate to the S/Gs before S/G dryout. SAT____UNSAT____

- Crew selects SG for depressurization
- CRS reviews depressurization termination criteria
  - PO reports Steam Dumps are NOT available (MSLI)
- PO fully opens selected MS10
- CRS dispatches an NEO to fully open selected BF40
- PO opens selected BF13
- PO releases selected BF22

Depressurization of selected SG should not be stopped until WR level is rising in that SG (FF>SF)

PO opens 21 and 22 CN48s and closes 21 and 22 CN32s

The Scenario can be terminated at the Lead Evaluator's discretion, after S/G WR level is observed to be raising.

~

Evaluator/Instructor Activity Expected Plant/Student Response Comments

USE this Section if RCS Bleed and	
Feed Initiation Criteria are met.	CREW goes to Step 23 of FRHS-1.
•	RO stops RCPs.
Crew may validate that SI is in	RO initiates SI.
•	RO verifies Charging pumps running and BIT flow established
CT#2B (FR-H.1B): Establish RCS Bleed and Feed before PZR PORVs open due to loss of heat sink.	RO opens both PZR PORVs and PORV Stop Valves.
If not previously completed •	CREW performs EOP-APPX-3.
•	RO/PO resets SI, Phase A, Phase B, opens 21 & 22CA330, resets each SEC and 230V Control Center.
•	At Step 35, CRS returns to Step 20 to align a Condensate Pump to feed at

least one S/G.

#### Evaluator/Instructor Activity Expected Plant/Student Response Comments

- CRS selects a S/G to be steamed.
- RO depressurizes and maintains selected S/G < 575 psig using steam dumps or MS10.
- PO positions selected S/G valves:
  - BF13 open,
  - BF19 or BF40 (local by NEO) open,
  - BF22 open,
  - 21 & 22 CN48 open, and
  - closes 21 & 22 CN32.

The Scenario can be terminated at the Lead Evaluator's discretion, after S/G WR level is observed to be raising.

• CREW establishes condensate flow to the selected S/G as evidenced by rising S/G WR level indication or lowering CETs.

# VI. SCENARIO REFERENCES

- A. Alarm Response Procedures (Various)
- B. Technical Specifications
- C. SC.OP-AP.ZZ-0102(Q), Use of Procedures
- D. S2.OP-AB.GRID-0001 Abnormal Grid
- E. S2.OP-AB.ROD-0003 Continuous Rod Motion
- A. S2.OP-AB.CC-0001 Component Cooling Abnormality
- B. 2-EOP-TRIP-1, Reactor Trip or Safety Injection
- C. 2-EOP-FRHS-1 Loss of Heat Sink
- D. 2-EOP-APPX-3 SI Verification

# VII. ESG CRITICAL TASK RATIONAL

CT#1(E-0 –P) Manually initiate MSLI before a severe challenge develops to either subcriticality or Integrity CSF or transition to LOSC

**BASIS:** Failure to close the MSIVs under the postulated plant conditions causes challenges to CSFs beyond those irreparably introduced by the postulated conditions. Additionally, such an omission constitutes a "demonstrated inability by the crew to recognize a failure of the auto actuation of an ESF system or component and to take action that would prevent a challenge to plant safety."

CT#2A (FR-H.1-A)Establish feedwater flow into at least one Steam Generator before RCS Bleed and Feed is required.

**BASIS:** Failure to establish feedwater flow to any SG results in the crew's having to rely upon the lower priority action of establishing RCS bleed and feed to minimize core uncovery. This constitutes incorrect performance that "leads to degradation of any barrier to fission product release."

**NOTE:** This Critical Task will be considered NOT satisfied if in the opinion of the Evaluators the bleed and feed criteria is reached due to mis-operation, inaction or delay by the crew. If the bleed and feed criteria is reached as a direct result of the failure of the automatic MSLI then the action of the crew will be based on CT-2B. "Thus, when the crew fails to simply establish available feedwater flow (as it could, given postulated conditions) before SG dryout occurs, it necessitates the crew taking compensating action which complicates the event mitigation strategy.

CT#2B (FR-H.1 --B) Establish RCS Bleed and Feed before PZR PORVs open due to loss of heat sink.

**BASIS:** Failure to establish RCS bleed and feed before automatic opening of the PORVs reduces the probability of success to establish a heat sink for the core. This constitutes a "significant reduction of the safety margin beyond that irreparably introduced by the scenario" **NOTE:** The PORV opening as stated in the critical task means opening caused by the RCS heatup from loss of heat sink. If the PORV opens for any other cause, it does not constitute a misoperation of the critical task.

# VIII. ESG - PSA RELATIONSHIP EVALUATION

#### "I" ILT NRC-ESG-003 SALEM ESG - PRA RELATIONSHIPS EVALUATION FORM

#### EVENTS LEADING TO CORE DAMAGE

<u>Y/N</u>	EVENT	<u>Y/N</u>	EVENT
N	TRANSIENTS with PCS Unavailable	Ν	Loss of Service Water
N	Steam Generator Tube Rupture	Y	Loss of CCW
N	Loss of Offsite Power	N	Loss of Control Air
<u>N</u> N	Loss of Switchgear and Pen Area Ventilation LOCA	<u>N</u>	Station Black Out

# COMPONENT/TRAIN/SYSTEM UNAVAILABILITY THAT INCREASES CORE DAMAGE FREQUENCY

<u>Y/N</u>	COMPONENT, SYSTEM, OR TRAIN
N	Containment Sump Strainers
Ν	SSWS Valves to Turbine Generator Area
N	RHR Suction Line valves from Hot Leg
	CVCS Letdown line Control and Isolation
N	Valves

ΔT	COMPONENT,	SYSTEM,	OR
/ 12 1			

- <u>Y/N</u> <u>TRAIN</u>
- N Gas Turbine
- N Any Diesel Generator
- N Auxiliary Feed Pump
- N SBO Air Compressor

#### **OPERATOR ACTIONS IMPORTANT IN PREVENTING CORE DAMAGE**

- Y/N OPERATOR ACTION
- N Restore AC power during SBO
- N Connect to gas turbine
- N Trip Reactor and RCPs after loss of component cooling system
- N Re-align RHR system for re-circulation
- N Un-isolate the available CCW Heat Exchanger
- N Isolate the CVCS letdown path and transfer charging suction to RWST
- N Cooldown the RCS and depressurize the system
- N Isolate the affected Steam generator which has the tube ruptures
- N Early depressurize RCS
- Y Initiate feed and bleed

Complete this evaluation form for each ESG.

		UNIT T	WO PLANT S' TODAV	TATUS		l
	DOWED	100	DOG	1100		ł,
MODE: 1	POWER:	100	RCS	1192	Mwe:1200	

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED):

N/A

#### **REACTIVITY PARAMETERS**

Core Burn-up 4000 MWD/MTU, reactivity plan provided by reactor engineering

#### MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

3.7.1.2a. (21 AFW Pump) entered last shift, 66 hours remaining

#### EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

21 AFW Pump C/Ted for Pump Inboard bearing Repair

#### ABNORMAL PLANT CONFIGURATIONS:

Currently K-3 in effect

#### CONTROL ROOM:

Unit 1 and Hope Creek at 100% power. No penalty minutes in the last 24 hrs.

#### PRIMARY:

NONE

#### SECONDARY:

Heating steam is aligned to unit 1.

#### RADWASTE:

No discharges in progress

#### CIRCULATING WATER/SERVICE WATER:

River grass loading very high, high tide in 2 hours

# SIMULATOR ESG REVIEW/VALIDATION CHECKLIST

ŧ

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

#### EXAMINATION SCENARIO GUIDE (ESG) REVIEW/ VALIDATION

Note: This form is used as guidance for an examination team to conduct a review for the proposed exam scenario(s). Attach a separate copy of this form to each scenario reviewed.

SELF-CHECK ESG-_<u>"I" ILT NRC-ESG-003</u>

Х.

**REVIEWER:** Ed Gallagher

#### 1. THE SCENARIO HAS CLEARLY STATED OBJECTIVES IN THE SCENARIO.

- 2. The initial conditions are realistic, equipment and/or instrumentation may be out of service, but it does not cue the crew into expected events.
- 3. Each event description consists of:
  - The point in the scenario when it is to be initiated,
  - The malfunction(s) that are entered to initiate the event,
  - The symptoms/cues that will be visible to the crew,
  - The expected operator actions (by shift position), and
  - The event termination point.
- 4. The use of non-mechanistic failures (e.g. pipe break) should be limited to one or a credible preceding event has occurred.
- 5. The events are valid with regard to physics and thermodynamics.
- 6. Sequencing/timing of events is reasonable (e.g. the crew has time to respond to the malfunctions in an appropriate time frame and implements procedures and/or corrective actions).
- 7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
- 8. If time compression techniques are used, scenario summary clearly so indicates.
- 9. The simulator modeling is not altered.
- 10. All crew competencies can be evaluated.
- 11. Appropriate reference materials are available (SOERs, LERs, etc.).
- 12. If the sampling plan indicates that the scenario was used for training during the requalification cycle, evaluate the need to modify or replace the scenario.
- 13. Proper critical task methodology is used IAW NRC procedures.
- 14. ESG-PSA Evaluation Form is completed for the scenario at the applicable facility.

# ATTACHMENT 1 SIMULATOR READY-FOR-TRAINING CHECKLIST

- 1. Verify simulator is in correct load for training
- 2. All required computer terminals in operation
- 3. Simulator clocks synchronized
- 4. Required chart recorders advanced and ON (proper paper installed)
- 5. Rod step counters correct (channel check)
- 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- _____ 7. DL-10 log up-to-date
- 8. Required procedures clean
- 9. All OHA lamps operating (OHA Test)
- 10. All printers have adequate paper AND functional ribbon
- 11. Procedure pens available
- 12. Procedures in progress open and signed-off to proper step
- 13. Shift manning sheet available
- 14. SPDS reset
- 15. Reference verification performed with required documents available
- 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- 17. Required keys available
- 18. Video Tape (if applicable)
- 19. Ensure ECG Classification is correct - 960502140 CRCA-03
- 20. Reset P-250 Rod Counters

#### ATTACHMENT 2 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgment of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

- I. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
  - degradation of any barrier to fission product release
  - degraded emergency core cooling system (ECCS) or emergency power capacity
  - a violation of a safety limit
  - a violation of the facility license condition
  - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
  - a significant reduction of safety margin beyond that irreparably introduced by the scenario
  - A. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
  - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
  - recognize a failure or an incorrect automatic actuation of an ESF system or component.
  - take one or more actions that would prevent a challenge to plant safety.
  - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) or ESF actuation.

# **ATTACHMENT 3**

# **ESG PRE-JOB BRIEF CHECKLIST**

## **EXAMINATION SCENARIO GUIDE (ESG)** Pre-Job Brief Checklist

**Note:** This checklist is to be completed by the Lead Examiner prior to evaluating an ESG. The Lead Examiner should lead a pre-job brief with all the examiners and simulator operators that includes, but is not limited to the following:

ESG: <u>"I" ILT NRC-ESG-003</u> Lead Examiner:

- 1.ESG overview and sequence of major events.
- 2.Determine which optional events will be performed, if any.
- _____ 3.ESG summary of Critical Tasks.
- 4.Assign examiners to observe specific watch standers.
- 5.Assign examiner ownership for observing and documenting performance / non-performance of

Critical Tasks.

6.Review alternate path(s) identified by the ESG.

_____7.Assign examiner to document data related to the performance of Critical Tasks.

8.Determines what parameters will be recorded in "Data Collection."

Ensure SOE recorder is recording.

# SIMULATOR EXAMINATION SCENARIO

LOPA
I ILT NRC ESG-004
12/4/6
1.5 hours
00
L.O. REQUAL
X INITIAL LICENSE
STA
OTHER

Revision Summary:

Rev 0: New Issue for I ILT NRC exam

PREPARED BY:	Paul Williams	10/9/06
	(INSTRUCTOR)	(DATE)
<b>APPROVED BY:</b>		
	(OPERATIONS TRAINNG	(DATE)
	MANAGER OR DESIGNEE)	
<b>APPROVED BY:</b>		
	(OPERATIONS MANAGER OR DESIGNEE)	(DATE)

;

## OBJECTIVES

I.

- A. Given the unit at power and a failure of a Power Range Nuclear Instruments, the crew will take corrective actions to stabilize the plant, IAW approved station procedures.
- B. Given a situation with an OHA alarm, perform action(s) to investigate and correct the cause of the alarm, IAW approved station procedures.
- C. Given the unit at power with a failed closed stop or governor valve, the crew will reduce load to <75% at 5%/min, AW approved station procedures.
- D. Given RCPs with a malfunction, the crew will take action to remove the RCPs from service, IAW approved station procedures.
- E. Given the unit with a loss of all vital busses, the crew will perform actions to attempt to recover vital busses and maintain RCP seal integrity, IAW approved station procedures.

# II. MAJOR EVENTS

- A. PR NIS Fails High
- B. 23 SW Pump Strainer Clogs
- C. Main Turbine Governor Valve Fails Closed
- D. Inadvertent Phase B
- E. LOPA

## III. SCENARIO SUMMARY

- A. The crew will receive the unit at 100% power with all systems in automatic. 2B D/G will be C/Ted. 2PR1 will be isolated due to a leak.
- B. Once the crew assumes the watch, 2N44 will fail high. The RO will place rods in manual and the CRS will enter AB.NIS-0001 to remove the channel from service.
- C. Before the channel is removed from service a high DP will occur on 23 SW strainer, header pressure will lower and the stand-by pump will fail to auto start. The crew will refer to the alarm response procedure stop the pump and start a stand-by pump.
- D. Once the service water issue is addressed, a main turbine governor valve will fail closed. The crew will reduce power at 5%/min to 75% power. When boration is started for the power reduction the auto boron setpoint will fail to 5 gpm, the RO will initiate a manual boration
- E. During the power reduction, an inadvertent Phase B will occur and the crew will trip the reactor and stop all RCPs IAW AB.RCP-0001.
- F. During the reactor trip response all vital busses will be deenergized. The crew will transition to EOP-LOPA-1 and perform a rapid RCS cooldown. Once the cooldown is established the only source of AFW will trip and all feedflow capability will be lost. The crew will stop the cooldown on all but one SG.
- G. Once the steaming strategy is established, the crew will be informed 2B D/G has been released and then they will start and load 2B Bus.
- H. The scenario will terminate once the vital bus is energized or at the lead evaluators discretion.

# IV. INITIAL CONDITIONS

# Pre-snapped IC-194 from portable exam drive

MALI	FUNCTIONS:				
SELF-CHECK	Description	Delay	Ramp	Trigger	Severity
1.	EL0273A 2A D/G breaker fails to close	NA	NA	NA	NA
2.	RP318Q1 2A D/G fails to start on SEC				
3.	SW0339E 25 SW Pump fails to auto start	NA	NA	NA	NA
4.	NI0193D 2N44 Fails High	NA	NA	RT-1	200
5.	SW0222C 23 SW Strainer Plugs	NA	1:30	RT-2	100
6.	TU0081H 24 Governor Valve Fails Closed	NA	NA	RT-3	NA
7.	CV0032 Boric Acid Flow Cntrlr Fails	NA	NA	RT-4	10
8.	VL0049 2CC117 Fails to Position	N/A	:10	RT-5	0
9.	VL0050 2CC118 Fails to Position	N/A	:10	RT-5	0
10.	VL0056 2CC190 Fails to Position	N/A	:10	RT-5	0
11.	VL0051 2CC187 Fails to Position	N/A	:08	RT-5	0
12.	VL0087 2CC131 Fails to Position	N/A	:09	RT-5	0
13.	VL0052 2CC136 Fails to Position	N/A	:10	RT-5	0
14.	AN0137 SER 137 :C16 Phase B	N/A	N/A	RT-5	2
15.	EL0134 Loss of Off-Site Power	1:00	NA	ET-6*	NA
16.	EL0146 2C Bus Fault	1:01	NA	ET-6*	NA
17.	VL0083 2SJ1 Fails to Position	NA	NA	RT-10	100
18.	VL0085 2CV40 Fails to Position	NA	NA	RT-10	0
19.	VL0053 2SW26 Fails to Position	NA	NA	RT-10	0
20.	VL0045 2CV116 Fails to Position	NA	NA	RT-10	0
21.	AF0183, 23 Aux FW Pmp Overspeed Trip	N/A	N/A	RT-7	False

REMO	DTES:			<b>65</b>	
SELF-CHECK	Description	Delay	Ramp	Trigger	Condition
1.	DG21D 2B DIG BKR RACK OUT	N/A	N/A	N/A	Tagged
2.	DG19D 2B DIESEL GEN LOCKED OUT	N/A	N/A	N/A	Yes
3.	DG20D 2B DG BKR CONTROL POWER	N/A	N/A	N/A	Off
4.	DG01D DEENERGIZE "A" SEC CABINET	N/A	N/A	RT-11	Off
5.	DG02D DEENERGIZE "B" SEC CABINET	:20	N/A	RT-11	Off
6.	DG03D DEENERGIZE "C" SEC CABINET	:45	N/A	RT-11	Off
7.	AF20D 21 AFW Pump Control Power	NA	NA	RT-12	Off
8.	AF25D 22 AFW Pump Control Power	30 secs	NA	RT-12	Off
9.	CV28A-31A 22-24CV98s	NA	NA	RT-13	0.0

OVEF	RIDES:			260 - 120 260 - 120 260 - 120	and the foregroup of the second
SELF-CHECK	Description	Delay	Ramp	Trigger	Action
1.	A503 OVLO TRAIN 'A' - SPRY ACT/ PH- B ISL	N/A	N/A	RT-5	On
2.	A503 OVLO TRAIN 'A' - SPRY ACT/ PH- B ISL	N/A	N/A	RT-5	On
3.	A503 OVLO Train A Cont Iso Ph B Reset	N/A	N/A	RT-5	Off
4.	4813 OVLO PHASE B ISOL - 2CC117	N/A	N/A	RT-5	Off
5.	4813 OVLO PHASE B ISOL - 2CC117	:08	N/A	RT-5	On
6.	4816 OVLO PHASE B ISOL - 2CC118	:09	N/A	RT-5	On
7.	4818 OVLO PHASE B ISOL - 2CC190	:10	N/A	RT-5	On
8.	4815 OVLO PHASE B ISOL - 2CC187	:06	N/A	RT-5	On
9.	4814 OVLO PHASE B ISOL - 2CC131	:08	N/A	RT-5	On
10.	4817 OVLO PHASE B ISOL - 2CC136	:09	N/A	RT-5	On
11.	4451 OVLO PERMISSIVE CONTAINMENT PHASE B	N/A	N/A	RT-5	On
12.	CB05 OVDI 2A DIESEL GEN-BREAKER CLOSE	N/A	N/A	N/A	Off
EVEN	T TRIGC	JERS:			
------------	---------	-------------	---------		
SELF-CHECK	ET#n	Description	Command		
1.	6	MONP254<10			

6 of 24

AT -	GGED EQUIPMENT: Description
1.      2.      3.      4.      5.      6.      7.      8.      9.      10.	RH1 and RH2 VC 1-4 RH 18's RCPs (SELF CHECK) RT (SELF CHECK) MS 167s (SELF CHECK) 500 KV SWYD (SELF CHECK). 22 ABV Supply Fan 23 CV Pump (SELF CHECK) <b>2B D/G (C/T)</b>
<b>X</b>	OTHER CONDITIONS:

_____ 1. Close 2PR6

# SEQUENCE OF EVENTS

V.

- A. State shift job assignments:
- B. Hold a shift briefing, detailing instruction to the shift: (provide CREW members a copy of the shift turnover sheet)

- extern

- C. Inform the crew "The simulator is running. You may commence panel walkdowns at this time. CRS please inform me when your crew is ready to assume the shift".
- D. Allow sufficient time for panel walk-downs. When informed by the CRS that the crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.
- E. Do not review objectives with crew

.

•

# 1. N-44 Fails High

Income D'I 1			
			Contraction of the
	Contraction (1997)		
Contraction of the second s			CEL CONTRACTOR
	a telever.	· · · · · · · · · · · · · · · · · · ·	
1565			
		1997 - 1997 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 - 1998 -	200 200 200 200 200 200 200 200 200 200
and the second	100 C		Zime restriction of the
in the second	the state of the second se		
and the second se	C	1	Sec. 2017.001
to display the second s			
		1. (a) (b) (b) (b) (b) (b) (b) (b) (b) (b) (b	
Charles Contract New Second		1000	3
	and the second		
and the second			1.1.256.0.23
and the second		25 P 1 1 1 1	
and the second			

#### RO responds to the following:

- E-15 PR Flux Hi;
- E-31 PR OVRPWR Rod Stop;
- E-39 PR Ch Dev; and
- E-47 PR Neutron Flux Rate Hi
- RO verifies no runback in progress and places Rods in Manual with concurrence from the CRS
- CRS enters S2.OP-AB.NIS-0001.
- PO verifies no load change.
- Crew identifies that N-44 failed high.
- CRS notifies I&C of failed channel and requests assistance.
- RO/PO reviews OHAs in alarm and refers to ARP.

• CRS initiates S2.OP-SO.RPS-0001.

- CRS briefs crew on inability to withdraw control rods and determines contingent actions based on this inability
  - SRO reviews Tech Specs and enters 3.3.1.1, Action 2

EVALUATOR NOTE: Crew may enter procedure S2.OP-AB.ROD-0003 first, but will transition to S2.OP-AB.NIS-0001

**EVALUATOR NOTE:** Do not wait for channel to be taken out of service prior to moving to next event.

**EVALUATOR NOTE: Proceed to next event after the Tech Specs has** been determined or as directed by the Lead Evaluator.

# 2. 23 Service Water Strainer dp High



CRS may direct 25 SW pump started in manual or may direct another pump started

Role Play: 4 minutes after dispatched call as NEO and inform Control Room that 23 SW strainer is not turning, motor is on and gear box is making a grinding sound

When requested REMOTES SW:32D to off for 23 SW Pump Control Power

Crew should discuss configuration control for 23 SW pump and control power breaker

Proceed to next event after TSAS determination or at lead evaluators discretion

- Crew acknowledges OHA B-8, 21-23 SW Strain Trbl followed by B13 and 14 for SW header Pressure LO
- PO verifies SW header pressure lowering and notes that 25 SW pump did not Auto Start
- CRS directs standby SW pump started
- PO informs CRS of lowering amps on 23 SW pump
  - Crew dispatches NEO to investigate strainer trouble

.

•

•

- Crew directs NEO to collect data IAW Observation Data Sheet
  - CRS directs 23 SW pump stopped
  - CRS directs control power removed from 23 SW pump
- CRS/STA refer to TS and enter tracker for 3.7.4

Evaluator/Instructor Activity Expected Plant/Student Response Comments 

#### 3. Main Turbine Governor Valve 24MS29 (GV-4) Fails Closed



Insert RT-4 after boration is started

**ROLE PLAY: After several minutes,** NEO reports EHC fluid leak on fittings of 24MS29.

- Crew identifies loss of turbine load by: Lowering Mwe,

  - o Rising Tavg/ PZR pressure, • OHA E-28, PZR HTR ON
  - PRESS LO
  - Tave-Tref console alarm.
- RO controls Tavg with rods in manual
- PO identifies 24MS29 Closed using • DEHC HMI indications.
  - CRS dispatches NEO to investigate cause of valve closure.

•

- CRS reviews S2.OP-SO.TRB-0001 . precautions and limitations and determines load limitation of < 75%with failed governor valve.
- CRS orders a turbine load reduction at 5%/minute IAW S2.OP-SO.TRB-001.
- RO/PO coordinate actions to reduce • turbine load to < 75% power.
- CRS directs entry into S2.OP-• AB.LOAD-1.
- CRS initiates Attachment 1 (CAS).
- RO initiates boration for Tavg and  $\Delta I$ control
- RO informs CRS boric acid flow controller has failed
- CRS directs RO to perform manual

#### boration

- RO starts manual boration IAW
  SO.CVC-0006
- RO energizes PZR heaters.

#### 4/5. Inadvertent Phase B Actuation and Loss of All AC Power

Evaluator. Insure E	T-6 enters when
Reactor is tripped.	

CT#1: Manually trip the reactor and stop RCPs from the control room within 5 minutes of OHA C-16

TIME:	:	:	of C-16
TIME:		:	of RCP stop

SAT UNSAT

NOTE: OHA C-16 directs attempted reset of Phase B to restore CCW; loss of CCW is also entry condition for AB-RCP. Crew may not attempt to reset Phase B and may go directly to Reactor Trip

- RO identifies Phase B Actuation
- RO identifies loss of CCW to RCPs
- CRS implements ARP for OHAs
- CRS implements AB.RCP-0001

•

- RO reports Phase B is invalid based on Containment pressure
- CRS directs RO to reset Phase B
- RO attempts to reset Phase B and reports it cannot be reset
- CRS directs RO to manually trip the reactor and stop all RCPs
- RO trips the reactor and stops all RCPs
- RO completes IA's of TRIP -1
  - Verifies Rx Trip
  - Trips turbine
  - Verifies NO Vital Bus energized
  - CRS directs entry into TRIP-1

#### Evaluator/Instructor Activity Expected Plant/Student Response Comments

- CRS transitions to EOP-LOPA-1
- CRS verifies IA's of LOPA-1 complete
- RO verifies both PZR PORVs closed
- RO Isolates Letdown
- PO verifies AFW >22E04 lbm/hr
- RO makes page announcement
- CRS directs operators to perform Attachment 2, Part A of AB.LOOP-1
- CRS dispatches NEO to deenergize all SEC's
- CRS briefs crew and SM contacts Maintenance Groups
- CREW performs manual Vital Bus stripping IAW LOPA-1, Table A
- CRS directs PO to attempt to start 2A EDG
- PO reports 2A EDG has started
- PO reports 2A EDG output breaker will not close
- SM/CRS request assistance from maintenance with 2A EDG breaker
- PO secures 2A and 2B EDGs since they has no SW
- CRS dispatches NEO to OPEN 2SJ1 or 2 and CLOSE 2CV40 and 41

ROLE PLAY: Three minutes later insert RT-11 then report all SECs deenergized

After 5 mins report as Maintenance that the 2A EDG HL limit switch is not made up and the breaker is jammed in the cubical

ROLE PLAY: Ten minutes after contacted report valves positions Enter RT-10

. ......

Evaluator/Instructor Activity	Expected Plant/Student Response Comments
	CRS dispatches NEO to isolate SW to Turbine Area by closing 2SW26
•	CRS directs initiation of Safety Injection
•	CRS directs closure of Phase A valves and CVI valves
• NOTE: CRS may delay stopping 2A EDG for several minutes until report on breaker condition is given.	RO/PO close valves as directed
• CT#2: Stop any EDG running w/o SW prior to engine overheating. SAT UNSAT	RO resets Safeguards and opens 21/22CA330
ROLE PLAY: Five minutes after contacted report control power to 21 and 22 AFW Pp removed and breakers open (if req) (RT-12)	CRS directs NEO to remove 125VDC Control Power from 21 and 22 AFW Pps
ROLE PLAY: NEO reports 2C bus locked out on Diff	
•	CRS directs CREW to take actions to restore power IAW AB.LOOP-1 concurrent with continuing with LOPA-1
ROLE PLAY: 10 minutes after contacted but not before restoration and loading of 2B EDG report 2CV83, 2CV89, 2CV95, 2CV116 and 2CC131 closed	CRS directs RCP Seal Cooling isolation
CT#3: (ECA-0.0-H) Isolate RCP seal injection before a Charging Pp starts or is started	PO initiates MSLI, MFW isolation, and SG Blowdown isolation/sampling
• SatUnsat•	PO evaluates for a faulted SG
•	PO evaluates for a ruptured SG
•	PO maintains maximum AFW flow

until at least one SG is >9%

• CRS assigns a NCO Checkoff sheet 3

#### NOTE: Once SG depressurization is established, trip 23 AFW Pp Enter RT-7

- PO commences SG depressurization once one SG is >9% to 235 psig
- CRS reviews Cautions, Notes and Termination Criteria for SG depressurization

CT#4: (ECA-0.0-G) Depressurize intact SGs at max rate as long as one intact SG can be maintained >9%

Sat____ Unsat____

- PO identifies loss of 23 AFW Pp
- CRS briefs crew on strategy for continuing SG depressurization and maintaining at least 1 SG greater than 9%

NOTE: Depending on timing of scenario and rate of AFW addition maintaining 1 SG >9% may not be possible

When the Crew has demonstrated a

steaming strategy to the satisfaction

that 2B EDG has been released and is

NOTE: If breaker for 22 AFW pump

was not opened then the pump will

start when bus is energized. If

of the lead evaluator; Restore 2B EDG remotes and report as Maint

ready for service

- PO adjusts steaming rates to maintain 1 SG>9%
- PO terminates SG depressurization if all SG NR levels go <9%</li>
- CRS directs an NEO/Maintenance to investigate the loss of 23 AFW Pp
- CRS directs PO to start 2B EDG and close the output breaker
- CRS direct the RO to start 23 or 24 SW pump and verify/close 2SW26
- CRS directs control power restored to 22AFW pump and directs pump started

# Evaluator/Instructor Activity Expected Plant/Student Response Comments

breaker was tripped then will need to cycle control power to get pump to start.

> PO recommences depressurization of • all SGs when SG levels in one intact SG is >9%

NOTE: Scenario can be terminated when SG depressurization/AFW flow is restored, or at the discretion of the Lead Evaluator

# VI. SCENARIO REFERENCES

- A. Alarm Response Procedures (Various)
- B. Technical Specifications
- C. SC.OP-AP.ZZ-0102(Q), Use of Procedures
- D. S2.OP-AB.NIS-0001 NIS Malfunction
- E. S2.OP-AB.ROD- 0003 Continuous Rod Motion
- F. S2.OP-SO.RPS-0001, Nuclear Instrumentation Channel Trip/Restoration
- G. S2.OP-AB.SW-0001 Loss of SW Header Pressure
- H. S2.OP-SO.SW-0001 Service Water System operation
- I. S2.OP-AB.RCP-0001, Reactor Coolant Pump Abnormality
- J. S2.OP-AB.LOOP-0001, Loss of Off Site Power
- K. 2-EOP-TRIP-1, Reactor Trip or Safety Injection
- L. 2-EOP-LOPA-1 Loss of All AC Power

# VII. ESG CRITICAL TASK RATIONAL

CT# 1: Manually trip the reactor from the control room within 5 minutes of OHA C-16 BASIS: Conditions requiring immediate attention for operation of the RCPs. These recommendations are incorporated from Westinghouse Tech Bulletin 93-01-R1

ESBU-TB-

CT# 2: (LOPA-1 CAS) Stop any EDG running w/o SW

**BASIS:** Running the EDG without ESW cooling leads to a high temperature condition that can result in EDG failure due to damage caused by engine overheating. (WOG ERG Based Critical tasks)

IF a Diesel is started and can not be promptly supplied with SW cooling, it is tripped to prevent damage until SW cooling is available (LOPA-1 Basis Document)

CT# 3: (ECA-0.0-H) Isolate RCP seal injection before a Charging Pp starts or is started
 BASIS: Failure to isolate RCP seal injection before starting a charging pump, under the postulated plant conditions, can result in unnecessary and avoidable degradation of the RCS fission-product barrier. (WOG ERG Based Critical tasks)

CT# 4: (ECA-0.0-G) Depressurize intact SGs at max rate such that <u>all</u> of the following limiting conditions are met:

- SG depressurization is <u>not</u> initiated until narrow range level in at least one intact SG is >9%
- If narrow range level cannot be maintained >9% in at least one intact SG, then depressurization is stopped until narrow range is restored to >9% in at least one intact SG
- SG pressure does not lower to <135 psig
- RCS cold leg temperature does not lower to <310°F
- If positive SUR is indicated on either the source range or intermediate range, then the depressurization is stopped and the RCS is allowed to heat up

**BASIS:** Failure to depressurize the secondary and cool down the RCS, under the postulated plant conditions, results in a greater possibility for core damage. The intact SGs should be depressurized as quickly as possible to minimize RCS inventory loss, but within the constraint of controllability.... The PORVs on all intact SGs should be wide open, provided that none of the limiting conditions associated with this critical task are violated. (WOG ERG Based Critical tasks)

# VIII. ESG - PSA RELATIONSHIP EVALUATION

## "I" ILT NRC-ESG-004 SALEM ESG - PRA RELATIONSHIPS EVALUATION FORM

# EVENTS LEADING TO CORE DAMAGE

<u>Y/N</u>	<u>EVENT</u>	<u>Y/N</u> <u>EVENT</u>
N	TRANSIENTS with PCS Unavailable	N Loss of Service Water
N	Steam Generator Tube Rupture	Y Loss of CCW
Y	Loss of Offsite Power	<u>N</u> Loss of Control Air
Ν	Loss of Switchgear and Pen Area Ventilation	Y Station Black Out
N	LOCA	
	-	

## COMPONENT/TRAIN/SYSTEM UNAVAILABILITY THAT INCREASES CORE DAMAGE FREQUENCY COMPONENT, SYSTEM, OR

<u>Y/N</u>	<u>COMPONENT, SYSTEM, OR TRAIN</u>	<u>Y/N</u>	TRAIN
Ν	Containment Sump Strainers	N	Gas Turbine
N	SSWS Valves to Turbine Generator Area	Y	Any Diesel Generator
N	RHR Suction Line valves from Hot Leg	N	Auxiliary Feed Pump
<u></u>	CVCS Letdown line Control and Isolation		
<u>N</u>	Valves	<u>N</u>	SBO Air Compressor

# **OPERATOR ACTIONS IMPORTANT IN PREVENTING CORE DAMAGE**

## Y/N OPERATOR ACTION

- Y Restore AC power during SBO
- N Connect to gas turbine
- Y Trip Reactor and RCPs after loss of component cooling system
- N Re-align RHR system for re-circulation
- N Un-isolate the available CCW Heat Exchanger
- N Isolate the CVCS letdown path and transfer charging suction to RWST
- Y Cooldown the RCS and depressurize the system
- N Isolate the affected Steam generator which has the tube ruptures
- N Early depressurize RCS
- N Initiate feed and bleed

Complete this evaluation form for each ESG.



SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED):

N/A

#### REACTIVITY PARAMETERS

Core Burn-up 10,500 MWD/MTU

## MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

3.8.1.1b – 2B D/G C/Ted for generator brush inspection

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

# ABNORMAL PLANT CONFIGURATIONS:

Currently K-3 in effect

CONTROL ROOM:

Unit 1 and Hope Creek at 100% power. No penalty minutes in the last 24 hrs. Winter Storm Alert for next 24 hours

#### PRIMARY:

NONE

SECONDARY:

Heating steam is aligned to unit 1.

#### RADWASTE:

No discharges in progress

## CIRCULATING WATER/SERVICE WATER:

# SIMULATOR ESG REVIEW/VALIDATION CHECKLIST

Note: Attach a separate copy of this form to each scenario reviewed. This form is used as guidance for the examination team as they conduct their review for the proposed scenarios.

# EXAMINATION SCENARIO GUIDE (ESG) REVIEW/ VALIDATION

Note: This form is used as guidance for an examination team to conduct a review for the proposed exam scenario(s). Attach a separate copy of this form to each scenario reviewed.

SELF-CHECK ESG-____IT ILT NRC-ESG-004__

Χ.

**REVIEWER:** Paul Williams

# 1. THE SCENARIO HAS CLEARLY STATED OBJECTIVES IN THE SCENARIO.

- 2. The initial conditions are realistic, equipment and/or instrumentation may be out of service, but it does not cue the crew into expected events.
- 3. Each event description consists of:
  - The point in the scenario when it is to be initiated,
  - The malfunction(s) that are entered to initiate the event,
  - The symptoms/cues that will be visible to the crew,
  - The expected operator actions (by shift position), and
  - The event termination point.
- 4. The use of non-mechanistic failures (e.g. pipe break) should be limited to one or a credible preceding event has occurred.
- 5. The events are valid with regard to physics and thermodynamics.
- 6. Sequencing/timing of events is reasonable (e.g. the crew has time to respond to the malfunctions in an appropriate time frame and implements procedures and/or corrective actions).
- 7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
- 8. If time compression techniques are used, scenario summary clearly so indicates.
- 9. The simulator modeling is not altered.
- 10. All crew competencies can be evaluated.
- 11. Appropriate reference materials are available (SOERs, LERs, etc.).
- 12. If the sampling plan indicates that the scenario was used for training during the requalification cycle, evaluate the need to modify or replace the scenario.
- 13. Proper critical task methodology is used IAW NRC procedures.
- 14. ESG-PSA Evaluation Form is completed for the scenario at the applicable facility.

# ATTACHMENT 1 SIMULATOR READY-FOR-TRAINING CHECKLIST

- 1. Verify simulator is in correct load for training
- 2. All required computer terminals in operation
- 3. Simulator clocks synchronized
- 4. Required chart recorders advanced and ON (proper paper installed)
- 5. Rod step counters correct (channel check)
- 6. All tagged equipment properly secured and documented (TSAS Log filled out)
- _____ 7. DL-10 log up-to-date
- 8. Required procedures clean
- 9. All OHA lamps operating (OHA Test)
- 10. All printers have adequate paper AND functional ribbon
- 11. Procedure pens available
- 12. Procedures in progress open and signed-off to proper step
- 13. Shift manning sheet available
- _____14. SPDS reset
- _____15. Reference verification performed with required documents available
- 16. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter with Baseline Data filled out
- _____ 17. Required keys available
- _____18. Video Tape (if applicable)
- 19. Ensure ECG Classification is correct - 960502140 CRCA-03
- 20. Reset P-250 Rod Counters

#### ATTACHMENT 2 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgment of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

- I. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
  - degradation of any barrier to fission product release
  - degraded emergency core cooling system (ECCS) or emergency power capacity
  - a violation of a safety limit
  - a violation of the facility license condition
  - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
  - a significant reduction of safety margin beyond that irreparably introduced by the scenario
  - A. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
  - effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
  - recognize a failure or an incorrect automatic actuation of an ESF system or component.
  - take one or more actions that would prevent a challenge to plant safety.
  - prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) or ESF actuation.

# ATTACHMENT 3

# **ESG PRE-JOB BRIEF CHECKLIST**

## **EXAMINATION SCENARIO GUIDE (ESG)** Pre-Job Brief Checklist

**Note:** This checklist is to be completed by the Lead Examiner prior to evaluating an ESG. The Lead Examiner should lead a pre-job brief with all the examiners and simulator operators that includes, but is not limited to the following:

ESG: <u>"I" ILT NRC-ESG-004</u> Examiner: _____

- 1.ESG overview and sequence of major events.
- 2.Determine which optional events will be performed, if any.
- _____ 3.ESG summary of Critical Tasks.
- 4.Assign examiners to observe specific watch standers.
- 5.Assign examiner ownership for observing and documenting performance / non-performance of

Critical Tasks.

6.Review alternate path(s) identified by the ESG.

_____7.Assign examiner to document data related to the performance of Critical Tasks.

8.Determines what parameters will be recorded in "Data Collection."

Ensure SOE recorder is recording.