Monticello Nuclear Generating Plant



Operated by Nuclear Management Company, LLC

January 29, 2007

L-MT-07-008 10 CFR 50.90

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

Monticello Nuclear Generating Plant Docket 50-263 License No. DPR-22

Response to Request for Additional Information for a License Amendment Request for Contingent Installation of a Temporary Fuel Storage Rack in the Spent Fuel Pool (TAC No. MD0302)

- References: 1) NMC letter to U.S. NRC, "License Amendment Request for Contingent Installation of a Temporary Spent Fuel Storage Rack," (L-MT-06-013), dated March 7, 2006.
  - 2) NMC letter to U.S. NRC, "Supplement to a License Amendment Request for Contingent Installation of a Temporary Fuel Storage Rack in the Spent Fuel Pool (TAC No. MD0302)," (L-MT-06-044), dated May 30, 2006.
  - NMC letter to U.S. NRC, "Response to Request for Additional Information for a License Amendment Request for Contingent Installation of a Temporary Fuel Storage Rack in the Spent Fuel Pool (TAC No. MD0302)," (L-MT-06-058), dated September 7, 2006.
  - 4) NMC letter to U.S. NRC, "Response to Request for Additional Seismic Information for a License Amendment Request for Contingent Installation of a Temporary Fuel Storage Rack in the Spent Fuel Pool (TAC No. MD0302)," (L-MT-06-087), dated January 2, 2007.

On March 7, 2006, as supplemented on May 30, 2006, the Nuclear Management Company, LLC (NMC) submitted a license amendment request for the Monticello Nuclear Generating Plant (References 1 and 2) to revise the licensing basis to allow temporary installation of a Programmed and Remote Systems Corporation 8x8 (64 cell) high-density fuel storage rack in the spent fuel pool to maintain full core off-load capability. USNRC Page 2

On September 7, 2006, (Reference 3) the NMC provided additional information on the structural, seismic and thermal hydraulic design of the proposed temporary high-density fuel storage rack. On December 8, 2006, the U.S. Nuclear Regulatory Commission (NRC) requested additional information (RAI) on the seismic design of the fuel storage rack during a teleconference. A response to this RAI on January 2, 2007, (Reference 4) provided an independent calculation performed by Stevenson & Associates on behalf of NMC entitled, "Evaluation of the 8X8 Spent Fuel Storage Rack to Determine the Natural Frequencies," which confirmed the natural frequency of the PaR 8x8 fuel storage rack and the validity of the simplified PaR models. During teleconferences on January 5, 2007, and January 22, 2007 the NRC requested clarification for several items and additional information concerning this calculation. Enclosure 1 provides Revision 2 to this calculation, which addresses these requests.

This letter makes no new commitments or changes to any existing commitments.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on January <u>19</u>, 2007.

AmT. Comm John T. Conway

Site Vice President, Monticello Nuclear Generating Plant Nuclear Management Company, LLC

Enclosure: (1)

cc: Administrator, Region III, USNRC Project Manager, Monticello, USNRC Resident Inspector, Monticello, USNRC Minnesota Department of Commerce

### **ENCLOSURE 1**

## REVISED EVALUATION OF THE 8X8 SPENT FUEL STORAGE RACK TO DETERMINE THE NATURAL FREQUENCIES

BY

**STEVENSON & ASSOCIATES** 

**REVISION 2** 

1

NMC	Calculation Signature Sheet

## **Document Information**

Revision: 2
e the natural
it: 🛛 1 🗌 2
es only)

**NOTE:** Print and sign name in signature blocks, as required.

## **Major Revisions**

EC Number: 10036	🛛 Vendor Calc			
Vendor Name or Code:Stevenson & Associates	Vendor Doc No: 06Q4646-C-001 rev 2			
Description of Revision:Added clarification	on on p7 & 9			
Prepared by: VENBOR		Date:		
Reviewed by: DENNIS ZERCHON Confuctor		Date: 1-26-2007		
Type of Review: 🗌 Design Verification 🔲 Tech Review 🖂 Vendor Acceptance				
Method Used (For DV Only): Review Alternate Calc Test				
Approved by: Todd Hurrle / John Ahul. Date: 1-26-0				

## **Minor Revisions**

EC No:	Vendor Calc:	
Minor Rev. No:		
Description of Change:		
Pages Affected:		
Prepared by:	Da	ate:
Reviewed by:	Da	ate:
Type of Review: 🗌 Design Verification [	Tech Review 🗌 Ve	endor Acceptance
Method Used (For DV Only): Review Alternate Calc Test		
Approved by:	Da	ate:

1

Calculation Signature Sheet	
-----------------------------	--

(continued on next page)

Т

NMC	Calculation Signature Sheet

EC No:	Vendor Calc:		
Minor Rev. No:			
Description of Change:			
Pages Affected:			
Prepared by:	Date:		
Reviewed by:	Date:		
Type of Review: Design Verification Tech Review Vendor Acceptance			
Method Used (For DV Only): Review Alternate Calc Test			
Approved by:	Date:		

EC No:	Vendor Calc:		
Minor Rev. No:			
Description of Change:			
Pages Affected:			
Prepared by:	Date:		
Reviewed by:	Date:		
Type of Review: Design Verification	Tech Review 🗌 Vendor Acceptance		
Method Used (For DV Only): Review Alternate Calc Test			
Approved by:	Date:		

EC No:	Uendor Calc:		
Minor Rev. No:			
Description of Change:			
Pages Affected:			
Prepared by:		Date:	
Reviewed by:		Date:	
Type of Review: Design Verification	Tech Review	Vendor Acceptance	
Method Used (For DV Only): Review Alternate Calc Test			
Approved by:		Date:	

1

Calculation Signature Sheet	
This table is used for data entry into the PassPort Controlled Documents Module, reference tables. If the	]

calculation references and inputs are all listed in the calculation directly, then only the inputs and outputs
need to be listed here. If the calculation invokes this form for the list of references and inputs, then list them
all here. Only the input and output references need to be entered in PassPort.

## Associated Document References:

#	Document Name	Document Number	Doc Revision	Control Doc and Doc Type (i.e. in Pass-Port) :	Type (input, output, general ref):
1	Fuel Storage System Design Report	none	3		input
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					

Add additional lines if needed.

NMC	Calculation Signature Sheet	

# Associated Equipment or System References:

#	Facility	Unit	System	Equipment Type	Equipment Number
1	Monticello	1	FPC	Spent fuel storage rack	
2					
3					
4					
5					
6					
7					
8					
9					
10					

Add additional lines if needed.

## **Superseded Calculations**

Facility	Calc Document Number	Title
mt	CA 06-114 rev 1	Evaluation of the 8X8 spent fuel storage rack to determine the natural frequencies

Add additional lines if needed.

Client:	Monticello Nu	Iclear Gener	ating Plant	(MNGP)	Calculation N	o06C	24646-C-001	
Title:	Evaluation of	the 8X8 spe	nt fuel stora	age rack to	determine the r	atural frequ	uencies	
Project:	Evaluation	of the 8X8 s	spent fuel si	torage rac	k to determine th	e natural fr	equencies	
Method:	Explained	within						
Acceptan	ce Criteria:	Explained	d within					
Remarks:								
Verificatio Results:	n Method See body	<ul><li>☑ Design</li><li>☑ Other</li><li>of calculation</li></ul>	Review Met	hod 🗖	Alternate Calcu No Verification	lation Necessary	D Quali	fication Test
Computer Programs Used	Program N	rogram Name		Version/Revision		Release Date		QA Verifie
				10.0.2				
		Ī		REVISIO	ONS	<u></u>	<u> </u>	
Revision N Description	<u>o.</u>	0	0 priginal Issue		1 Included 10x10	rack model	Modifie	2 dpg7&9
Total Page	s (Cumulative)	and the second	partie		15		15	
By/Date		Sung-June I	Kim / 12/18/6	SE-1-	Sung-June Kim	1/10/07	Sung <sup>1</sup> June	Kim 1/22/07
Checked/D	late	Violeta Med	ina Andres /	12/18/06	Tsiming Tseng /	1/10/07	Tsiming Tse	ing 1/22/07
Approved/I	Date	Walter Digit	evic / 12/18	/06	Walter Djordjevid	/ 1/10/07	Walter Djolk	jevic 1/22/0
			С	ALCULA COVE SHEE FIGURE	ATION ER ET E 2.9		CONTRAC <sup>®</sup>	г NO. 5 <b>46</b>



JOB NO.: 06Q4646

Calculation: C-001

Client: Monticello Nuclear Generating Plant (MNGP)

Sheet 2 of 15 Date: 1/22/2007 Revision: 2

SUBJECT: Evaluation of the 8X8 spent fuel storage rack to determine the natural frequencies

By: SJK Check: TMT

2 pg

# **TABLE OF CONTENTS**

1.	OBJE	OBJECTIVE4						
2.	EXECUTIVE SUMMARY4							
3.	REFE	RENCES	4					
4.	METH	ODOLOGY	. 5					
5.	GENE	RAL DESIGN INPUTS FOR COMPUTER MODELS	5					
6.	CALC	ULATION	6					
6	.1 S	AP2000 MODEL – 8X11 FUEL RACK	6					
	6.1.1	Properties and Input	6					
	6.1.2	Joint Coordinates	6					
	6.1.3	Distributed Mass	7					
	6.1.4	Model Results and Comparisons	7					
6	.2 S	AP2000 MODEL – 10 X 10 FUEL RACK	7					
	6.2.1	Properties and Input	7					
	6.2.2	Joint Coordinates	. 9					
	6.2.3	Distributed Mass	. 9					
	6.2.4	Model Results and Comparisons	. 9					
6	.3 S	AP 2000 MODEL - 8X8 RACK MODEL	10					
	6.3.1	Properties and Inputs	10					
	6.3.2	Joint Coordinates	11					
	6.3.3	Distributed Mass	11					
	6.3.4	Model Results and Comparisons	11					
6	.4 S	IMPLIFIED MODEL VALIDATION	12					
7.	CONC	LUSION	12					
AT	ГАСНМ	ENT						

A Time History Response Spectrum Comparison

Т

STEVENSON & ASSOCIATES a structural-mechanical consulting engineering firm	JOB NO.: 06Q4646 Calculation: C-001 Client: Monticello Nuclear Generating Plant (MNGP) SUBJECT: Evaluation of the 8X8 spent fuel storage rack to determine the natural frequencies	Sheet 3 of 15 Date: 1/22/2007 Revision: 2 By: SJK Check: TMT
Figure 1: Single Rack Atta	Table of Figures	6

Т



#### 1. OBJECTIVE

The existing 8x8 spent fuel storage rack was obtained from Duane Arnold which procured the rack from PAR Systems in 1977 with seismic qualification. The seismic evaluation portion of the referenced report evaluates 8x12, 9x12, 8x11 and 10x11 rack configurations, and determines the lateral and vertical fundamental frequencies to be 8 Hz and 14 Hz.

The objective of this calculation is to determine the natural frequency of the 8x8 spent fuel storage rack and show that the dynamic characteristics of the 8x8 fuel rack are within the range of the PAR Systems qualification.

#### 2. EXECUTIVE SUMMARY

The objective of this calculation is to determine the natural frequency of the 8x8 spent fuel storage rack, which was obtained from Duane Arnold which procured the rack from PAR Systems in 1977 with seismic qualification. The simplified 2D dynamic model presented in the PAR Systems qualification report [1], was recreated and validated by comparing the results of current runs using the same rack models (8x11 and 10x10 fuel racks) as given in the aforementioned report [1].

The 8x8 fuel rack was then modeled by amending the input properties of the SAP2000 model. The properties were computed following the same methodology presented in referenced report [1]. The 1<sup>st</sup> horizontal natural frequency is found to be at 9.0 Hz. The "*Casting Bottom*" vertical mode is approximately 23 Hz.

Comparison between the Iowa Spec. M-303 response spectrum and the MNGP time history response spectrum at 5% damping shows that the Iowa Spec. M-303 envelopes the MNGP response spectrum both vertically and horizontally in frequency ranges that are approximately higher than 5 Hz and 2.5 Hz, respectively. Since the 8x8 fuel rack natural frequency lies within this range, it can be concluded that the Iowa Spec. M-303 Ioads shall always be larger than MNGP. Thus, the original qualification report [1] should insure the seismic qualification of the 8x8 fuel rack configuration as well.

#### 3. REFERENCES

- PAR Systems Report Sect. 5.3., "Model Description, Formulation and Assumptions for the Seismic Analysis of BWR Spent Fuel Racks at DAEC, JAF and Peach Bottom", Rev. 3, March 27,1978
- Roark's Formulas for Stress and Strain, Warren C. Young, 6<sup>th</sup> Edition, McGraw-Hill International Editions, 1989
- 3. CSI, SAP2000, Integrated Software for Structural Analysis and Design, Version 10.0.2.



#### 4. METHODOLOGY

The rack structure is a large rectangular tube enveloped by the side panels with no structural stiffness added for either the poison cans or fuel assemblies. Dynamic analysis of a detailed SAP IV model have determined a lower bound horizontal frequency for the 4 fuel rack configurations to be approximately at 8 Hz with a vertical diaphragm fundamental frequency of the bottom casting to be at 14 Hz [1].

A simplified ANSYS model (see Fig. 2 of [1]), consisting of a cantilever beam extending the height of the racks, attached to a horizontal beam at the base bottom casting elevation with leg beams connecting the ends of this member to the floor, show that the fundamental frequencies of this idealized system agree quite closely with the detailed model. Thus, this simplified model will be used to determine the natural frequency of the 8x8 rack.

The methodology consists of the steps outlined below. The detailed calculations, organized according to these steps, are provided in Sect. 6. The coordinate system used in the calculations follows the right hand rule, where the XY plane = floor plane and Z = Vertical.

- 1. Recreate and match the dynamic characteristics of the simplified dynamic ANSYS model (Fig. 2 of [1]) with the new SAP2000 model
- 2. Model a 8x8 fuel rack by amending the properties of the SAP2000 model; follow the same procedures presented in [1] for consistency
- 3. Perform a modal analysis in order to obtain the natural frequencies of the 8x8 fuel rack

Note that two fuel rack configurations, 8x11 and 10x10, were chosen for comparison of the simplified model to the detailed model for the following reasons:

- The 8x11 fuel rack was determined to have the lowest 1<sup>st</sup> horizontal frequency mode of all 4 fuel rack configurations.
- The 10x10 fuel rack was chosen because it matches the configuration of the detailed 10x10 SAPIV model shown in Figure 1 of the PaR report [Ref. 1].

#### 5. GENERAL DESIGN INPUTS FOR COMPUTER MODELS

Metal Plate Properties [1]

Young's Modulus: Shear Modulus:	E = 10300 ksi G = 3800 ksi		
Cavity Loads [1]			
Dry Module Mass Dry Fuel & Channel Mass Entrapped Water Mass	136 lbf 745 lbf 181 lbf	Wet Module Weight Wet Fuel & Channel	78 lbf 672 lbf
Total Horizontal Mass	1062 lbf/cavity	Total Wet Wt.	750 lbf/cavity



#### 6. CALCULATION

The simplified models for an 8x11, 10x10 and 8x8 are constructed based on the data provided in Reference [1]. In this section, a modal analysis is performed for each of the simplified models and compared to the detailed model reported frequency results

#### 6.1 SAP2000 Model – 8x11 Fuel Rack

#### 6.1.1 Properties and Input

First recreate the original 8x11 fuel rack model in SAP2000. The following properties are presented in Reference [1].

Module size	= 8 x 11			
Rack height	= 167 in			<u>↑</u> Ζ
No. Cavity	= 88			
M2	= 32780 lbf			<del>&lt;γ</del> >1
M1	= 22374 lbf			
X	= 23.2 in			b
12	= 66520 in^4			
A2	= 126 in^2			
A2s	$= 63 in^{2}$			-72s
13	$= 388000 \text{ in}^{4}$	1		$\rho_1 \propto \rho_2$
A3	= 167 in^2	•		<→ 3 <sup>1</sup> 5, A <sub>5</sub> , A <sub>5s</sub>
A3s	$= 167 \text{ in}^2 (\text{us})$	se total area [1])		$I_3, A_3, A_{3s}$ at same elevation as
14	$= 280 \text{ in}^{4}$			\ / / member 3 and pinned
ΔΛ	$= 38 in^{2}$			the strends
Δ <i>Λ</i> ε	= 10 in^2		I4, A4, A4s	
15	= 211  in  14			$5 \longrightarrow 6 \longrightarrow X$
15	$= 211 \text{ m}^{-4}$ = 152 in A2			877 M2 77.9
AD	- 100 III''Z			
Abs	= 76.5 m·2		Figure 1:	: Single Rack Attached Fuel Model (Fig. 2 [1])
Total weight of accordingly (in	f Section 2 is rea clude weight of	computed Sect. 1),		
Total weight fo Total weight fo	or Sect. 1 W1 or Sect. 2 W2	= 65560 lbf [1] = 27896 lbf [1]		
Total weight	Ws	= 93456 lbf = W	1 <b>+ W</b> 2	
6.1.2 Joint (	Coordinates			
Joint ID	X (in)	<u>Y (in)</u> Z	. (in)	
1	0	0	167	
2	0	0 11	1.33	
3	0	0 5	5.67	
4	0	0	0	
5	-23.2	0	0	
6	23.2	0	_0	
7	-23.2	1	0	
8	-23.2	0	-10	
i () ()	020	0.1	3/1 1	



Joint ID	X (in)	Y (in)	Z (in)
10	23.2	1	0
11	0	1	0

Per Reference 1, Section 5, which represents the vertical diaphragm of the "bottom casting", is located at the same elevation as Section 3 but is not attached to it. However, SAP2000 does not allow two different nodes to be assigned at the same location, therefore Section 5 is offset 1" in the Y – direction. Joints 5 & 7 and 6 & 10 are assigned *rigid body* constraints.

It is noted that nodes 2 & 3 are equally spaced between nodes 1 & 4 in order to have a more uniform distribution, which gives a better representation of the model. This minor adjustment is carried throughout this calculation.

6.1.3 Distributed Mass

Concentrated fuel, racks and water mass at nodes 1 and 4 in X-direction only	= 40.33 lbf-s^2/in	= Ws / g / 6
Concentrated fuel, racks and water mass at	= 80.66 lbf-s^2/in	= Ws / g / 3

nodes 2 and 3 in X-direction only

Concentrated fuel mass at node 11 = 84.9 lbf-s<sup>2</sup>/in = M2 / g In Z-direction only

Concentrated masses at nodes 5 and 6 = 57.9 lbf-s^2/in = M1 / g In Z-direction only

6.1.4 Model Results and Comparisons

The results of the SAP2000 model for the 8x11 rack is presented in the following. The 1<sup>st</sup> and 2<sup>nd</sup> horizontal natural frequencies are given at 8.2 Hz and 33.7 Hz, respectively. The "Casting Bottom" vertical mode is approximately 17.2 Hz.

Mode	Frequency	Description
1	8.2	1 <sup>st</sup> horizontal mode
2	17.2	"Casting Bottom" vertical mode
3	33.7	2 <sup>nd</sup> horizontal mode
4	61.4	3 <sup>rd</sup> horizontal mode

Reference [1] determined the lower bound for the fuel rack configurations to be approximately 8 Hz. The results of the SAP2000 model validates the reports statement. Also, the vertical diaphragm frequency of the bottom casting was computed to be at 17.7 Hz [1] (for the 8x11 fuel rack), which is also close to the recreated model 17.2 Hz (~ 3% difference).

#### 6.2 SAP2000 Model – 10 x 10 Fuel Rack

#### 6.2.1 Properties and Input

.

The following properties are calculated based on information presented in Reference [1] for the 6-5/8" cell size.

	JOB NO.: 06Q4646	C-001	Sheet 8 of 15				
	Client: Monticello Nuc	Client: Monticello Nuclear Generating Plant (MNGP)					
	SUBJECT: Evaluation	of the 8X8 snor	nt fuel et	orage rack to			
STEVENSON &	determine the natural from	etermine the natural frequencies					
ASSOCIATES a structural-mechanical					Check: TMT		
consulting engineering firm					<u> </u>		
Module 10x10 fuel rack	(						
<u>Properties</u>							
elastic modulus	E =	10300000	psi	given			
# of cavities in X direc	tion Nx =	10		given			
# of cavities in Y direc	tion Ny =	10		given			
center to center distar between fuel channels	s c.c =	6.625	in	for types similar	to those in IOWA		
outside length of fuel	channel lout =	5.494	in	given			
inside length of fuel ch	nannel lin =	5.273	in	given			
rack height	L =	167	in	given			
weight / cavity	Wt/cavity	745	lbf	given			
area of fuel channel	A =	2.38	in^2	= lout^2 - lin^2			
moment of inertia of c	hannel i =	11.50	in^4	= (lout^4 - lin^4	) / 12		
shear area	As =	1.19	in2	= A / 2			
Module Section Proporti	<b>6</b> 5						
total # of cavities	<u>55</u> N =	100		= Ny y Ny			
distance between sun	norts X1 =	29.8	in	$= (N_{X} - 1) \times c c$	12		
		20.0		- (11x - 1) x 0.0	, 2		
Section 2							
rack depth	b =	66.3	in	= Ny x c.c.			
rack width	h =	66.3	in	= Nx x c.c.			
area	A2 =	132.5	in^2	= (2/2) x b + (2/	/2) x h		
moment of inertia	12 =	100254	in^4	= h^3/12 + b x	(h/2 + 0.75)^2		
shear area	A2s =	66	in^2	= A2 / 2			
Section 3							
moment of inertia	13 =	388000	in^4	given			
area	A3 =	167	in^2	given			
Section 4							
moment of inertia	I4 =	280	in^4	aiven			
area	A4 =	38	in^2	aiven			
shear area	A4s =	19	in^2	= A4 / 2			
Continu F							
<u>Section 5</u>	۸ <i>۵</i> –	٥	in^?	aiven			
ucayn alea	Au -	9	111 2		a Na a Na a Aka		
mid span deflection [1	] $\Delta =$	0.055	in	- 1.36 x (10'-5)) 1)^2 x (Ny - 1)^2 / 1)^2)	/ ((Nx - 1)^2 + (Ny -		
moment of inertia	leff =	362	in^4	= 5 x Wt/cavity x x c.c^3 / (384 x E	Nx x Ny x (Nx - 1)^3 x D)		
frequency of bottom c	asting fw =	15.007	Hz	= π / (2 x (Nx - 1) x g / (N x Wt/cavit	) x c.c.) x sqrt(E x leff ty x (Nx - 1) x c.c.))		

	JOB NO.: 06Q4646 Calculation: C-001					Sheet 9 of 15
R.	Client: Montic	Client: Monticello Nuclear Generating Plant (MNGP)				
STEVENSON & ASSOCIATES a structural-mechanical consulting engineering firm	SUBJECT: Evaluation of the 8X8 spent fuel storage rack to determine the natural frequencies					By: SJK Check: TMT
area shear area		A5 = A5s =	162 81	in^2 in^2	= ((Nx - 1) + (N = A5 / 2	ly - 1)) x Ad
6.2.2 Joint Coordinate	s					
Joint ID         X (i           1         2           3         -           4         -           5         -29           6         29           7         -29           8         -29           9         29           10         29           11         -	n) Y (in) 0 0 0 0 0 0 0 0 0 0 0 0 8 0 8 0	Z (in) 167 111.33 55.67 0 0 0 0 -10 -10 0 0 0 0 0 0 0 0 0 0 0 0 0				
Total weight for Sect. 1 W1 = 74500 lbf = N x 745 lbf Total weight for Sect. 2 W2 = 31700 lbf = N x (181 lbf + 136 lbf)						
Total weight Ws = 106200 lbf = W1 + W2						
Concentrated fuel, racks and water mass at = 45.9 lbf-s^2/in = Ws / g / 6 nodes 1 and 4 in X-direction only						
Concentrated fuel, racks and water mass at = 91.7 lbf-s^2/in = Ws / g / 3 nodes 2 and 3 in X-direction only						
Concentrated fuel mass at node 11 InM2= $37250$ lbf= $\frac{1}{2} \times 100 \times 745$ lbfZ-direction only,m2= 96.5 lbf-s^2/in= M2 / g						
Concentrated masses at In Z-direction only	nodes 5 and 6 I r	M1 = 25425   m1 = 65.9 lbf	bf -s^2/in	= ½ x 1) = M1 / g	00 x 136 lbf + ¼	x 100 x 745 lbf
6.2.4 Model Results and Comparisons						
The results of the SAP2000 model for the 10x10 rack are presented below The simplified model frequencies are 8.9 Hz for the fundamental horizontal mode, 14.5 Hz for the vertical diaphragm mode and 34.2 Hz for the 2 <sup>nd</sup> horizontal mode. The simplified model's fundamental horizontal frequency is within about 10% of that of the detailed model and the fundamental vertical frequency is within about 3%.						
Mode	Description					
1 8 2 14 3 34	.9 1 <sup>st</sup> horizonta .5 "Casting Bot .2 2 <sup>nd</sup> horizonta	l mode tom" vertical n Il mode	node			



#### 6.3 SAP 2000 Model - 8x8 Rack Model

Т

#### 6.3.1 Properties and Inputs

The methodology in computing the following properties closely follows that presented in Reference [1]. This will ensure consistency between the models.

#### Module 8x8 fuel rack

<u>Properties</u>				
elastic modulus	E =	10300000	psi	given
# of cavities in X direction	Nx =	8		given
# of cavities in Y direction	Ny =	8		given
center to center distance between fuel channels	c.c =	6.625	in	for types similar to those in IOWA
outside length of fuel channel	lout =	5.494	in	given
inside length of fuel channel	lin =	5.273	in	given
rack height	L =	167	in	given
weight / cavity	Wt/cavity	745	lbf	given
area of fuel channel	A =	2.38	in^2	= lout^2 - lin^2
moment of inertia of channel	=	11.50	in^4	= (lout^4 - lin^4) / 12
shear area	As =	1.19	in2	= A / 2
Module Section Properties				
total # of cavities	N =	64		= Nx x Nv
distance between supports	X1 =	23.2	in	= (Nx - 1) x c.c / 2
Section 2				
rack depth	b =	53.0	in	= Ny x c.c.
rack width	h =	53.0	in	= Nx x c.c.
area	A2 =	106.0	in^2	= (2/2) x b + (2/2) x h
moment of inertia	12 =	51762	in^4	= h^3/12 + b x (h/2 + 0.75)^2
shear area	A2s =	53	in^2	= A2 / 2
o " o				
<u>Section 3</u>	13 -	388000	in^4	aiven
	13 = A3 =	167	in^2	given
area	A3 -	107	111 24	given
Section 4				
moment of inertia	4 =	280	in^4	given
area	A4 =	38	in^2	given
shear area	A4s =	19	in^2	= A4 / 2
Section 5		-		
design area	Ad =	9	in^2	given

	JOB NO.: 06Q4646 Calculation: C-001			Sheet 11 of 15		
	Client: Monticello Nuclea	Date: 1/22/2007 Revision: 2				
STEVENSON &	SUBJECT: Evaluation of t	D. 0.14				
ASSOCIATES	determine the natural frequ	IENCIES			By: SJK Check: TMT	
consulting engineering firm						
mid span deflection [	] ∆=	0.021	in	= 1.36 x (10^-5) 1)^2 x (Ny - 1)^2 1)^2)	x Nx x Ny x (Nx - / ((Nx - 1)^2 + (Ny -	
moment of inertia	leff =	282	in^4	= 5 x Wt/cavity x x c.c^3 / (384 x E	Nx x Ny x (Nx - 1)^3 x Δ)	
frequency of bottom of	easting fw =	24.118	Hz	$= \pi / (2 \times (Nx - 1))$ leff x g / (N x Wt/c c.c.))	) x c.c.) x SQRT(E x cavity x (Nx - 1) x	
area shear area	A5 = A5s =	126 63	in^2 in^2	= ((Nx - 1) + (N = A5 / 2	ly - 1)) x Ad	
6.3.2 Joint Coordinates						
The same coordinates are	e used as in the previous 8>	(11 model.				
6.3.3 Distributed Mass						
Total weight for Sect. 1 W1 = 47680 lbf = N $\times$ 745 lbf Total weight for Sect. 2 W2 = 20288 lbf = N $\times$ (181 lbf + 136 lbf)						
Total weight V	Vs = 67968 lbf = W	/1 + W2				
Concentrated fuel, racks and water mass at = $29.33$ lbf-s <sup>2</sup> /in = Ws / g / 6 nodes 1 and 4 in X-direction only						
Concentrated fuel, racks and water mass at = 58.65 lbf-s^2/in = Ws / g / 3 nodes 2 and 3 in X-direction only						
Concentrated fuel mass a Z-direction only,	t node 11 In M2 = 2384 m2 = 61.7	0 lbf = ½ x lbf-s^2/in =	64 x 74 M2 / g	15 lbf		
Concentrated masses at nodes 5 and 6 M1 = $16272 \text{ lbf} = \frac{1}{2} \times 64 \times 136 \text{ lbf} + \frac{1}{4} \times 64 \times 745 \text{ lbf}$ In Z-direction only m1 = $42.144 \text{ lbf-s}^2/\text{in} = \text{M1}/\text{g}$						
6.3.4 Model Results and Comparisons						
The results of the SAP2000 model for the 8x8 rack are presented below The 1 <sup>st</sup> and 2 <sup>nd</sup> horizontal natural frequencies are given at 9.0 Hz and 36.3 Hz, respectively. The "Casting Bottom" vertical mode is approximately 23 Hz, which is greater than the 14 Hz mode reported for the 10x10 rack due to the overall difference in vertical mass (64 fuel cells compared to 100 fuel cells in the 10x10 rack)						
Mode         Frequency           1         9.0           2         23.0           3         36.3	<b>Description</b> D 1 <sup>st</sup> horizontal mode Casting Bottom" vertica 2 <sup>nd</sup> horizontal mode	ıl mode				

.



#### 6.4 Simplified Model Validation

8x8 Simplified Model

The 10x11 rack configuration [1] was also investigated simply for the purpose of additional model comparisons. The results of the SAP2000 simplified models for the 8x11, 10x10 and 10x11 racks, as well as the results of the 8x8 simplified rack model, are compared in Table 1 below to the frequency response data given in the PaR report [Ref. 1] for the detailed 10x10 model:

Comparison of Simplified vs. Detailed Model Results							
Rack Configuration	Fundamental Horizontal Frequency (Hz)	Fundamental Vertical Frequency (Hz)	Second Horizontal Frequency (Hz)				
10x10 Detailed Model	8	14	>28				
10x10 Simplified Model	8.9	14.5	34.2				
10x11 Simplified Model	8.6	13.2	33.4				
8x11 Simplified Model	8.2	17.2	33.7				

9

 Table 1

 Comparison of Simplified vs. Detailed Model Results

The results for the 10x10 simplified model compare well with the results reported for the detailed model. The fundamental horizontal and vertical frequencies are within about 10% of one another. The fundamental vertical mode is a diaphragm mode of the casting bottom. The second horizontal mode is 34.2 Hz, which is greater than 28 Hz. This difference has no effect on the load and stress evaluations of the racks since the Artificial Time History Response Spectrum used in the PaR analysis and the Monticello 5% Response Spectrum amplitudes effectively do not vary at frequencies greater than 28 Hz.

23

36.3

The 10x11, 8x11 and the 8x8 simplified model results also compare well thus supporting the statement made in the PaR report that the simplified model is a reasonable model for similar but different rack configuration combinations varying from 8 to 12 fuel cells on a side.

It is reasonably concluded that the SAP2000 simplified model is validated and is capable of capturing the dynamic properties of the 8x8 rack.

### 7. CONCLUSION

The simplified 2D dynamic model presented in PAR Systems qualification report [1], was recreated in SAP2000. Comparison of the results of current runs using the same rack models, an 8x11 and a 10x10 fuel rack, as given in the aforementioned report [1] showed that the models matched well. The conclusions drawn from the table are:

- The frequency results of the 10x10 simplified model agree very well with detailed 10x10 model results
- The 10x11, 8x11 and 8x8 rack configurations also agree well, even though they are slightly
  different rack configurations, which indicates that the variability of frequency results is not
  large even for slightly different rack configurations. This supports the PaR report conclusion
  that the "simplified" model is representative for all of the rack configurations varying from 8 to
  12 fuel cells on a side.



 Since the fundamental frequencies are in good agreement for all rack configurations, the conclusion that the 8x8 rack is bounded by the results contained in the PaR report is further substantiated.

The vertical and horizontal response spectra for 6% damping of Iowa Spec. M-303 overlaid with the MNGP response spectra at 5% damping are presented in Attachment A. Note that the racks have been qualified under the 6% Iowa Spec. M-303 response spectrum curves. The comparison shows that the Iowa Spec. M-303 envelopes the MNGP response spectrum both vertically and horizontally in frequency ranges that are higher than 5 Hz and 2.5 Hz, respectively. Since the 8x8 fuel rack natural frequency is higher than 5 Hz, it can be concluded that the Iowa Spec. M-303 loads shall always be larger than MNGP. Thus, the original qualification report [1] insures the seismic suitability of the 8x8 fuel rack configuration as well.





ł