

December 4, 2006

DISTRIBUTION CONTROL LIST

Document Name: **IP3 ITS / BASES**

CC#	NAME	DEPARTMENT	LOCATION
1	OPS PROC GP SUPERVISOR	OPS PROCEDURE GROUP	IP2
5	CONTROL ROOM	OPERATIONS	IP3
11	RES DEPARTMENT MGR	RES	45-4-A
19	STEWART, ANN	LICENSING	GSB-2D
20	CHEMISTRY SUPERVISOR	CHEMISTRY DEPARTMENT	45-4-A
21	TSC (IP3)	53' ELEVATION	IP2
22	SHIFT MANAGER	OPERATIONS	IP3
23	LIS	LICENSING & INFO SERVICE	OFFSITE
25	SIMULATOR	TRAINING	48-2-A
28	RESIDENT INSPETOR	US NRC 88' ELEVATION	IP2
32	EOF	E-PLAN	EOF
47	CHAPMAN, N	BECHTDL	OFFSITE
50	HAAS, CHERYL A	WESTINGHOUSE ELECTRIC	OFFSITE
61	SIMULATOR	TRAINING	48-2-A
69	CONROY, PAT	LICENSING / ROOM 205	GSB/2D
99	BARANSKI J	ST. EMERGENCY MGMT. OFFICE	OFFSITE
106	SIM INSTRUCT AREA	TRAINING	#48
164	CONTROL ROOM	OPERATIONS	IP3
273	FAISON, CHARLENE	NUCLEAR LICENSING	WPO-12
319	GRANT, LEAH	LRQ TRAINING	#48
354	GRANT, LEAH	LRQ TRAINING	#48
357	GRANT, LEAH	ILO TRAINING	48-2-A
424	GRANT, LEAH	TRAINING	#48
474	OUELLETTE P	ENG, PLAN & MGMT INC	OFFSITE
489	CLOUGHNESSY, PAT	PLANT SUPPORT TEAM	GSB/3B
492	WORK CONTROL	OPERATION 72' ELEVATION	IP2
493	OPERATIONS FIN TEAM	33 TURBIN DECK	45-1-A
494	AOEF / A. GROSSJEAN	E-PLAN	WPO/12-D
496	GRANT, LEAH	LRQ TRAINING	#48
497	GRANT, LEAH	LRQ TRAINING	#48
500	GRANT, LEAH	LRQ TRAINING	#48
501	GRANT, LEAH	LRQ TRAINING	#48
512	GRANT, LEAH	LRQ TRAINING	#48
513	GRANT, LEAH	LRQ TRAINING	#48
518	DOC CONTROL DESK	NRC	OFFSITE

A001



IPEC SITE
MANAGEMENT
MANUAL

QUALITY RELATED
ADMINISTRATIVE PROCEDURE

IP-SMM-AD-103 Revision 0

INFORMATIONAL USE

Page 13 of 21

ATTACHMENT 10.1

SMM CONTROLLED DOCUMENT TRANSMITTAL FORM

SITE MANAGEMENT MANUAL CONTROLLED DOCUMENT TRANSMITTAL FORM - PROCEDURES

Page 1 of 1



CONTROLLED DOCUMENT
TRANSMITTAL FORM - PROCEDURES

TO: DISTRIBUTION

DATE: 12/21/06

PHONE NUMBER: 271-7057

FROM: IPEC DOCUMENT CONTROL

The Document(s) identified below are forwarded for use. In accordance with IP-SMM-AD-103, please review to verify receipt, incorporate the document(s) into your controlled document file, properly disposition superseded, void, or inactive document(s). Sign and return the receipt acknowledgement below within fifteen (15) working days.

AFFECTED DOCUMENT:

IP3 ITS/BASES/TRM

DOC #

REV #

TITLE

INSTRUCTIONS

***** FOLLOW THE ATTACHED INSTRUCTIONS*****

*****PLEASE NOTE EFFECTIVE DATE*****

RECEIPT OF THE ABOVE LISTED DOCUMENT(S) IS HEREBY ACKNOWLEDGED. I CERTIFY THAT ALL SUPERSEDED, VOID, OR INACTIVE COPIES OF THE ABOVE LISTED DOCUMENT(S) IN MY POSSESSION HAVE BEEN REMOVED FROM USE AND ALL UPDATES HAVE BEEN PERFORMED IN ACCORDANCE WITH EFFECTIVE DATE(S) (IF APPLICABLE) AS SHOWN ON THE DOCUMENT(S).

NAME (PRINT)

SIGNATURE

DATE

CC#

Distribution of IP3 Technical Specification Amendment 232
 (Approved by NRC December 13 2006)

Pages are to be inserted into your controlled copy of the IP3 Improved Technical Specifications following the instructions listed below. The **TAB** notation indicates which section the pages are located.

REMOVE PAGE	INSERT PAGE
TAB – Facility Operating License	
FOL Page 3, Amd 231	FOL Page 3, Amd 232
TAB – List of Effective Pages	
Pages 1 through 3, (Amd 231)	Pages 1 through 3, (Amd 232)
TAB – List of Amendments	
	Page 14
TAB 5.0 – Administrative Controls	
5.0-3, Amd 205	5.0-3, Amd 232
5.0-4, Amd 205	5.0-4, Amd 232
5.0-5, Amd 205	5.0-5, Amd 232
5.0-10, Amd 205	5.0-10, Amd 232
5.0-11, Amd 221	5.0-11, Amd 232
5.0-26, Amd 205	5.0-26, Amd 232
5.0-37, Amd 205	5.0-37, Amd 232
5.0-38, Amd 205	5.0-38, Amd 232
	5.0-39, Amd 232
	5.0-40, Amd 232
	5.0-41, Amd 232

- (4) ENO pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; Amdt. 203
11/27/00
- (5) ENO pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility. Amdt. 203
11/27/00

C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

ENO is authorized to operate the facility at steady state reactor core power levels not in excess of 3216 megawatts thermal (100% of rated power).

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 232 are hereby incorporated in the License. ENO shall operate the facility in accordance with the Technical Specifications.

(3) (DELETED) Amdt. 205
2-27-01

(4) (DELETED) Amdt. 205
2-27-01

D. (DELETED) Amdt.46
2-16-83

E. (DELETED) Amdt.37
5-14-81

F. This amended license is also subject to appropriate conditions by the New York State Department of Environmental Conservation in its letter of May 2, 1975, to Consolidated Edison Company of New York, Inc., granting a Section 401 certification under the Federal Water Pollution Control Act Amendments of 1972.

INDIAN POINT 3
 TECHNICAL SPECIFICATIONS - APPENDIX A
 LIST OF EFFECTIVE PAGES
 Page 1 of 3

Page	Amend
Table of Contents	
i	227
ii	228
iii	227
iv	227
Section 1.1	
1	205
2	205
3	224
4	205
5	225
6	205
7	205
8	205
Section 1.2	
1	205
2	205
3	205
Section 1.3	
1	205
2	205
3	205
4	205
5	205
6	205
7	205
8	205
9	205
10	205
11	205
12	205
13	205
Section 1.4	
1	205
2	205
3	205
4	205
Section 2.0	
1	225

Section 3.0	
1	229
2	226
3	229
4	212
5	226
Section 3.1.1	
1	205
Section 3.1.2	
1	205
2	205
Section 3.1.3	
1	205
2	205
Section 3.1.4	
1	205
2	205
3	205
4	205
5	205
Section 3.1.5	
1	205
2	205
Section 3.1.6	
1	205
2	205
3	205
Section 3.1.7	
1	205
2	205
3	205
4	205
Section 3.1.8	
1	205
2	205
Section 3.2.1	
1	205
2	205
3	205
Section 3.2.2	
1	205

2	205
3	205
Section 3.2.3	
1	205
2	205
3	205
4	205
Section 3.2.4	
1	205
2	205
3	205
4	205
Section 3.3.1	
1	205
2	205
3	205
4	205
5	205
6	205
7	205
8	205
9	205
10	205
11	205
12	205
13	225
14	205
15	225
16	205
17	205
18	205
19	225
20	225
Section 3.3.2	
1	205
2	205
3	205
4	205
5	205
6	205
7	205

8	225
9	213
10	205
11	225
12	205
13	205
Section 3.3.3	
1	226
2	211
3	205
4	228
5	228
Section 3.3.4	
1	226
2	205
Section 3.3.5	
1	205
2	231
Section 3.3.6	
1	205
2	205
3	205
4	205
5	205
Section 3.3.7	
1	224
2	205
3	205
Section 3.3.8	
1	215
2	205
Section 3.4.1	
1	225
2	225
Section 3.4.2	
1	205
Section 3.4.3	
1	205
2	205
3	220
4	220

The latest amendment reflected in this list is: **Amendment 232**

INDIAN POINT 3
 TECHNICAL SPECIFICATIONS - APPENDIX A
 LIST OF EFFECTIVE PAGES
 Page 2 of 3

5	220
Section 3.4.4	
1	205
Section 3.4.5	
1	205
2	205
3	205
Section 3.4.6	
1	205
2	205
3	205
Section 3.4.7	
1	205
2	205
3	205
Section 3.4.8	
1	205
2	205
Section 3.4.9	
1	225
2	225
Section 3.4.10	
1	205
2	205
Section 3.4.11	
1	226
2	205
3	205
Section 3.4.12	
1	205
2	226
3	205
4	205
5	205
6	205
7	205
8	205
9	220
10	220
11	220
12	220

Section 3.4.13	
1	205
2	205
Section 3.4.14	
1	205
2	205
3	205
4	205
5	205
Section 3.4.15	
1	226
2	205
3	205
4	205
Section 3.4.16	
1	226
2	205
3	205
4	205
Section 3.5.1	
1	222
2	205
3	205
Section 3.5.2	
1	205
2	205
3	230
4	205
Section 3.5.3	
1	226
2	205
Section 3.5.4	
1	205
2	205
Section 3.6.1	
1	205
2	205
Section 3.6.2	
1	205
2	205
3	205

4	205
5	205
Section 3.6.3	
1	205
2	205
3	205
4	205
5	205
6	205
Section 3.6.4	
1	205
Section 3.6.5	
1	205
Section 3.6.6	
1	205
2	205
3	205
4	205
Section 3.6.7	
1	205
2	205
Section 3.6.8	
1	228
Section 3.6.9	
1	205
2	205
Section 3.6.10	
1	205
2	205
3	205
4	205
Section 3.7.1	
1	205
2	205
3	225
4	205
Section 3.7.2	
1	205
2	205
3	205

Section 3.7.3	
1	207
2	207
3	207
Section 3.7.4	
1	226
2	205
Section 3.7.5	
1	226
2	205
3	205
4	205
Section 3.7.6	
1	205
2	205
Section 3.7.7	
1	205
2	218
Section 3.7.8	
1	205
2	205
Section 3.7.9	
1	205
2	205
3	205
Section 3.7.10	
1	205
Section 3.7.11	
1	223
2	224
Section 3.7.12	
1	205
Section 3.7.13	
1	215
2	205
Section 3.7.14	
1	205
Section 3.7.15	
1	205
2	205

The latest amendment reflected in this list is: **Amendment 232**

INDIAN POINT 3
 TECHNICAL SPECIFICATIONS - APPENDIX A
 LIST OF EFFECTIVE PAGES
 Page 3 of 3

Section 3.7.16	
1	205
2	205
3	205
Section 3.7.17	
1	205
Section 3.8.1	
1	226
2	205
3	205
4	205
5	205
6	205
7	205
8	205
9	205
10	205
Section 3.8.2	
1	205
2	205
3	205
4	205
Section 3.8.3	
1	205
2	205
3	205
4	205
5	205
Section 3.8.4	
1	216
2	216
3	216
Section 3.8.5	
1	205
2	205
Section 3.8.6	
1	205
2	205
3	205
4	205

Section 3.8.7	
1	205
2	205
3	205
Section 3.8.8	
1	205
2	205
Section 3.8.9	
1	205
2	205
Section 3.8.10	
1	205
2	205
Section 3.9.1	
1	205
Section 3.9.2	
1	205
2	205
Section 3.9.3	
1	215
2	215
3	215
Section 3.9.4	
1	205
2	205
Section 3.9.5	
1	205
2	205
Section 3.9.6	
1	205
Section 4.0	
1	205
2	205
3	205
Section 5.0	
1	205
2	205
3	232
4	232
5	232
6	205

7	205
8	205
9	210
10	232
11	232
12	205
13	205
14	205
15	205
16	205
17	205
18	205
19	205
20	205
21	224
22	224
23	224
24	224
25	224
26	232
27	205
28	205
29	205
30	206
31	225
32	227
33	227
34	225
35	225
36	205
37	232
38	232
39	232
40	232
41	232

The latest amendment reflected in this list is: **Amendment 232**

Entergy Nuclear Operations, Inc
Indian Point 3 Nuclear Power Plant
License Amendments Page 14

AMENDMENT	SUBJECT	LETTER DATE
232	Adoption of TSTF-258, TSTF-308, and Related Administrative Control Changes Based on NUREG-1431	12/13/2006

5.2 Organization

5.2.2 Unit Staff

The unit staff organization shall include the following:

- a. A non-licensed operator shall be assigned to each reactor containing fuel and an additional non-licensed operator shall be assigned for each control room from which a reactor is operating in MODES 1, 2, 3, or 4.

- b. Shift crew composition may be less than the minimum requirement of 10 CFR 50.54(m)(2)(i) and 5.2.2.a and 5.2.2.f for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.

- c. A radiation protection technician shall be on site when fuel is in the reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.

- d. Administrative procedures shall be developed and implemented to limit the working hours of personnel who perform safety related functions (e.g., licensed Senior Reactor Operators (SROs), licensed Reactor Operators (ROs), health physicists, auxiliary operators, and key maintenance personnel).

(continued)

5.2 Organization

5.2.2 Unit Staff (continued)

The controls shall include guidelines on working hours that ensure adequate shift coverage shall be maintained without routine heavy use of overtime.

Any deviation from the above guidelines shall be authorized in advance by the plant manager or the plant manager's designee, in accordance with approved administrative procedures, and with documentation of the basis for granting the deviation.

Routine deviation from the working hour guidelines shall not be authorized.

Controls shall be included in the procedures to require a periodic independent review be conducted to ensure that excessive hours have not been assigned.

- e. The operations manager or assistant operations manager shall hold an SRO license.
- f. An individual shall provide advisory technical support to the unit operations shift crew in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. This individual shall meet the qualifications specified by the Commission Policy Statement on Engineering Expertise on Shift. This position must be manned in Mode 1, 2, 3 or 4 only.

5.0 ADMINISTRATIVE CONTROLS

5.3 Unit Staff Qualifications

- 5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions, except for the following:
- a. The radiation protection manager shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975; and
 - b. The operations manager shall meet or exceed the minimum qualifications of ANSI N18.1-1971 except for the SRO license requirement which shall be in accordance with Technical Specification 5.2.2.e.
- 5.3.2 For the purpose of 10 CFR 55.4, a licensed Senior Reactor Operator (SRO) and a licensed Reactor Operator (RO) are those individuals who, in addition to meeting the requirements of TS 5.3.1, perform the functions described in 10 CFR 50.54(m).
-

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas, conforming to 10 CFR 50, Appendix I;
- e. Determination of cumulative dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days. Determination of projected dose contributions from radioactive effluents in accordance with the methodology in the ODCM at least every 31 days;
- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents from the site to areas at or beyond the site boundary shall be limited to the following:
 - a. For noble gases: Less than or equal to a dose rate of 500 mrem/yr to the whole body and less than or equal to a dose rate of 3000 mrem/yr to the skin, and
 - b. For iodine-131, tritium, and for all radionuclides in particulate form with half-lives greater than 8 days: Less than or equal to dose rate of 1500 mrem/yr to any organ.
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I; and
- j. Limitations on the annual dose or dose commitment to any member of the public, beyond the site boundary due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Radioactive Effluents Controls Program surveillance frequency.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the FSAR, Section 4.1.5, cyclic and transient occurrences to ensure that components are maintained within the design limits.

5.5.6 Reactor Coolant Pump Flywheel Inspection Program

This program shall provide for the inspection of each reactor coolant pump flywheel. The program shall include inspection frequencies and acceptance criteria. The inspection frequency will ensure that each reactor coolant pump flywheel is surface and volumetrically inspected at 20-year intervals.

(continued)

5.5 Programs and Manuals

5.5.11 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the Waste Gas Holdup System, the quantity of radioactivity contained in gas storage tanks, and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks. The gaseous radioactivity quantities shall be determined following the methodology in Branch Technical Position (BTP) ETSB 11-5, "Postulated Radioactive Release due to Waste Gas System Leak or Failure." The liquid radwaste quantities shall be determined in accordance with Standard Review Plan, Section 15.7.3, "Postulated Radioactive Release due to Tank Failures."

The program shall include:

- a. The limits for concentrations of hydrogen and oxygen in the Waste Gas Holdup System and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion);
- b. A surveillance program to ensure that the quantity of radioactivity contained in each gas storage tank shall be limited to less than the amount that would result in a whole body exposure of ≥ 0.5 rem to any individual in an unrestricted area, in the event of an uncontrolled release of the tanks' contents; and
- c. A surveillance program to ensure that the quantity of radioactivity contained in all outdoor liquid radwaste tanks that are not surrounded by liners, dikes, or walls, capable of holding the tanks' contents and that do not have tank overflows and surrounding area drains connected to the Liquid Radwaste Treatment System is less than the amount that would result in concentrations less than the limits of 10 CFR 20, Appendix B, Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area, in the event of an uncontrolled release of the tanks' contents.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Explosive Gas and Storage Tank Radioactivity Monitoring Program surveillance frequencies.

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

As provided in paragraph 20.1601(c) of 10 CFR Part 20, the following controls shall be applied to high radiation areas in place of the controls required by paragraph 20.1601(a) and (b) of 10 CFR Part 20:

5.7.1 High Radiation Areas with Dose Rates Not Exceeding 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation

- a. Each entryway to such an area shall be barricaded and conspicuously posted as a high radiation area. Such barricades may be opened as necessary to permit entry or exit of personnel or equipment.
- b. Access to, and activities in, each such area shall be controlled by means of Radiation Work Permit (RWP) or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.
- c. Individuals qualified in radiation protection procedures and personnel continuously escorted by such individuals may be exempted from the requirement for an RWP or equivalent while performing their assigned duties provided that they are otherwise following plant radiation protection procedures for entry to, exit from, and work in such areas.
- d. Each individual or group entering such an area shall possess:
 1. A radiation monitoring device that continuously displays radiation dose rates in the area; or
 2. A radiation monitoring device that continuously integrates the radiation dose rates in the area and alarms when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint, or
 3. A radiation monitoring device that continuously transmits dose rate and cumulative dose information to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area, or

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.1 High Radiation Areas with Dose Rates Not Exceeding 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation (continued)

4. A self-reading dosimeter (e.g., pocket ionization chamber or electronic dosimeter) and,
 - (i) Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring device that continuously displays radiation dose rates in the area; who is responsible for controlling personnel exposure within the area, or
 - (ii) Be under the surveillance as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with individuals in the area who are covered by such surveillance.
- e. Except for individuals qualified in radiation protection procedures, or personnel continuously escorted by such individuals, entry into such areas shall be made only after dose rates in the area have been determined and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation, but less than 500 rads/hour at 1 Meter from the Radiation Source or from any Surface Penetrated by the Radiation

- a. Each entryway to such an area shall be conspicuously posted as a high radiation area and shall be provided with a locked or continuously guarded door or gate that prevents unauthorized entry, and, in addition:
 1. All such door and gate keys shall be maintained under the administrative control of the shift supervisor, radiation protection manager, or his or her designee.
 2. Doors and gates shall remain locked except during periods of personnel or equipment entry or exit.
- b. Access to, and activities in, each such area shall be controlled by means of an RWP or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.
- c. Individuals qualified in radiation protection procedures may be exempted from the requirement for an RWP or equivalent while performing radiation surveys in such areas provided that they are otherwise following plant radiation protection procedures for entry to, exit from, and work in such areas.
- d. Each individual or group entering such an area shall possess:
 1. A radiation monitoring device that continuously integrates the radiation rates in the area and alarms when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint, or
 2. A radiation monitoring device that continuously transmits dose rate and cumulative dose information to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area with the means to communicate with and control every individual in the area, or

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation, but less than 500 rads/hour at 1 Meter from the Radiation Source or from any Surface Penetrated by the Radiation (continued)

3. A self-reading dosimeter (e.g., pocket ionization chamber or electronic dosimeter) and,
 - (i) Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring device that continuously displays radiation dose rates in the area; who is responsible for controlling personnel exposure within the area, or
 - (ii) Be under the surveillance as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with and control every individual in the area.
4. In those cases where options (2) and (3), above, are impractical or determined to be inconsistent with the "As Low As is Reasonably Achievable" principle, a radiation monitoring device that continuously displays radiation dose rates in the area.
- e. Except for individuals qualified in radiation protection procedures, or personnel continuously escorted by such individuals, entry into such areas shall be made only after dose rates in the area have been determined and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

(continued)

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour at 30 Centimeters from the Radiation Source or from any Surface Penetrated by the Radiation, but less than 500 rads/hour at 1 Meter from the Radiation Source or from any Surface Penetrated by the Radiation (continued)

- f. Such individual areas that are within a larger area where no enclosure exists for the purpose of locking and where no enclosure can reasonably be constructed around the individual area need not be controlled by a locked door or gate, nor continuously guarded, but shall be barricaded, conspicuously posted, and a clearly visible flashing light shall be activated at the area as a warning device.
-