



**U.S. NUCLEAR REGULATORY COMMISSION**  
**STANDARD REVIEW PLAN**

**15.2.1–15.2.5 LOSS OF EXTERNAL LOAD; TURBINE TRIP; LOSS OF CONDENSER VACUUM; CLOSURE OF MAIN STEAM ISOLATION VALVE (BWR); AND STEAM PRESSURE REGULATOR FAILURE (CLOSED)**

**REVIEW RESPONSIBILITIES**

**Primary -** Organization responsible for review of transient and accident analyses for PWRs/BWRs

**Secondary -** None

**I. AREAS OF REVIEW**

A number of initiating events that occur with moderate frequency result in unplanned decreases in heat removal by the secondary system. Each event covered in this Standard Review Plan (SRP) section should be addressed in individual sections of the safety analysis report (SAR) or design control document (DCD) as specified in Regulatory Guide (RG) 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants" and Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)." The specific areas of review are as follow:

1. Loss of External Load: In a loss of external load event, an electrical disturbance causes loss of a significant portion of the generator load. This loss of load situation is different from the loss of alternating current (AC) power condition considered in SRP Section 15.2.6 in that offsite AC power remains available to operate the station

Revision 2 - March 2007

---

**USNRC STANDARD REVIEW PLAN**

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to [NRR\\_SRP@nrc.gov](mailto:NRR_SRP@nrc.gov).

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov). Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML070300702.

---

auxiliaries (e.g., reactor coolant pumps). Onsite emergency diesel generators are therefore not required for the loss of external load event. Immediate fast closure of the turbine control valves (TCVs) is initiated for a loss of generator load. For a boiling water reactor (BWR), a fast (0.15–0.20 second) TCV closure causes a sudden reduction in steam flow and results in a reactor pressure surge. For a BWR without select rod insert, reactor scram occurs. For a pressurized water reactor (PWR), there is also a sudden reduction in steam flow causing the pressure and temperature in the shell side of the steam generator to increase. The latter effect, in turn, results in an increase of reactor coolant temperature, a decrease in coolant density, an increase of water volume in the pressurizer, and an increase in reactor coolant pressure; depending on reactor design and the size of load rejection, a reactor scram may occur. For a PWR with an integrated control system, reactor power can run on a lower level upon TCV closure.

In all light-water-cooled reactors, sensible and decay heat can be removed through actuation of one or several of the following systems: steam relief system, steam bypass to the condenser, reactor core isolation cooling system (BWR), emergency core cooling systems, and auxiliary feedwater system (PWR).

2. Turbine Trip: In a turbine trip event, a malfunction of a turbine or reactor system causes the turbine to trip off the line by abruptly stopping steam flow to the turbine. This event is different from the loss of external load condition in that fast closure of the turbine stop valves (TSVs) is initiated. The TSV closure times are faster (0.10 second) than those of the TCVs, resulting in more severe transients. For typical BWR and PWR plants, position switches on the TSVs sense the trip and initiate reactor scram. The remainder of this transient is similar to the loss of external load.
3. Loss of Condenser Vacuum: A loss of condenser vacuum event is a malfunction that can result in a turbine trip; thus, the remarks in paragraph 2 apply to this event. In addition, due to system interaction, the loss of condenser vacuum event also causes the feedwater pumps to trip due to low suction pressure. The corresponding peak pressure in the primary and secondary systems requires separate analysis because the initial conditions that lead to peak pressure are different for the primary and secondary systems.
4. Main Steam Isolation Valve (MSIV) Closure: MSIV closure for BWRs can be initiated by various steam line or reactor system malfunctions and operator actions. As the MSIVs close, position switches initiate a reactor scram when valves in three or more steam lines are less than 90 percent open, the reactor pressure is above 4140 kPa (600 psi), and the reactor mode switch is in the “RUN” position. The effect of MSIV closure is limited steam flow to the turbine. The results are similar to those addressed in paragraph 1 but less severe because the MSIV closure time is longer than that of the TCVs.
5. Steam Pressure Regulator Failure: Steam pressure regulator failure in a closed position yields a transient similar to those previously addressed. Generally, the rate of change of system parameters is slower for a steam pressure regulator failure and a less severe transient results.

6. Review of these five described transients includes the sequence of events, the analytical models, the values of parameters in the analytical models, and the predicted consequences of the transients.
  - A. The sequence of events described in the SAR (or DCD) analysis is reviewed by the organization responsible for reactor systems in consultation with the organization responsible for instrumentation and control. The reactor systems reviewer concentrates on the assumptions for the reactor protection system, the engineered safety systems, and required operator actions to secure and maintain the reactor in a safe condition.
  - B. The organization responsible for reactor systems reviews the analytical methods for whether all mathematical models and computer codes have been reviewed and accepted by the staff. If a referenced analytical method or code has not been reviewed, the reviewer requests a generic evaluation of the new analytical model or code by the appropriate code review organization.
  - C. The results of the analyses are reviewed for whether predicted values of pertinent system parameters are within expected ranges for the type and class of reactor under review. The predicted results of the transient analyses then are reviewed for whether the consequences meet the acceptance criteria of subsection II of this SRP section.
  - D. The organization responsible for reactor systems reviews the values of all parameters in the analytical models, including the initial conditions of the core and systems. In addition, this organization reviews core physics, fuel design, and core thermal-hydraulics data in the SAR (or DCD) analysis as part of its primary review responsibility for SAR sections corresponding to SRP Sections 4.2 through 4.4. Finally, the organization responsible for reactor systems reviews SAR (or DCD) Section 5.2.2 for adequacy of the overpressure protection of the reactor coolant pressure boundary (RCPB).
7. COL Action Items and Certification Requirements and Restrictions. For a DC application, the review will also address COL action items and requirements and restrictions (e.g., interface requirements and site parameters).

For a COL application referencing a DC, a COL applicant must address COL action items (referred to as COL license information in certain DCs) included in the referenced DC. Additionally, a COL applicant must address requirements and restrictions (e.g., interface requirements and site parameters) included in the referenced DC.

### Review Interfaces

Other SRP sections interface with this section as follows:

1. General information on transient and accident analyses is provided in SRP Section 15.0.
2. Design basis radiological consequence analyses associated with design basis accidents are reviewed under SRP Section 15.0.3.

3. Aspects of the transient sequences described in the SAR (or DCD) are evaluated to determine whether the reactor and plant protection and safeguards controls and instrumentation systems will function as assumed in the safety analysis with regard to automatic actuation, remote sensing, indication, control, and interlocks with auxiliary or shared systems under SRP Sections 7.2 and 7.3.
4. Potential bypass modes and the possibility of manual control by the operator are reviewed under SRP Sections 7.2 through 7.5.
5. Technical specifications are reviewed under SRP Section 16.0.

The specific acceptance criteria and review procedures are contained in the referenced SRP sections.

## II. ACCEPTANCE CRITERIA

### Requirements

Acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

1. General Design Criterion (GDC) 10, as to reactor coolant system design with appropriate margin so specified acceptable fuel design limits (SAFDLs) are not exceeded during normal operations, including anticipated operational occurrences (AOOs).
2. GDC 13, as to the availability of instrumentation to monitor variables and systems over their anticipated ranges to assure adequate safety, and of appropriate controls to maintain these variables and systems within prescribed operating ranges.
3. GDC 15, as to design of the reactor coolant system and its auxiliaries with appropriate margin so the pressure boundary is not breached during normal operations, including AOOs.
4. GDC 17, as to onsite and offsite electric power systems so safety-related structures, systems, and components (SSCs) function during normal operation, including AOOs. The safety function for each power system (assuming the other system is not functioning) is to provide sufficient capacity and capability so SAFDLs and RCPB design conditions are not exceeded during AOOs.
5. GDC 26, as to the control of reactivity changes so SAFDLs are not exceeded during AOOs. This control is accomplished by provisions for appropriate margin for malfunctions (e.g., stuck rods).

### SRP Acceptance Criteria

Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are as follows for the review described in this SRP section. The

SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.

1. The basic objectives of the review of the initiating events listed in subsection I of this SRP section:
  - A. To identify which moderate-frequency event that results in an unplanned decrease in secondary system heat removal is the most limiting, in particular as to primary pressure, secondary pressure, and long-term decay heat removal.
  - B. To verify whether the predicted plant response for the most limiting event satisfies the specific criteria for fuel damage and system pressure.
  - C. To verify whether the plant protection systems setpoints assumed in the transients analyses are selected with adequate allowance for measurement inaccuracies as delineated in RG 1.105.
  - D. To verify whether the event evaluation considers single failures, operator errors, and performance of nonsafety-related systems consistent with the RG 1.206 regulatory guidelines.
2. With the ANS standards as guidance, specific criteria meet the relevant requirements of GDCs 10, 13, 15, 17, and 26 for events of moderate frequency.
  - A. Pressure in the reactor coolant and main steam systems should be maintained below 110 percent of the design values.
  - B. Fuel cladding integrity must be maintained by the minimum departure from nucleate boiling ratio (DNBR) remaining above the 95/95 DNBR limit for PWRs and the critical power ratio (CPR) remaining above the minimum CPR safety limit for BWRs based on acceptable correlations (see SAR (or DCD) Section 4.4) and by satisfaction of any other SAFDL applicable to the particular reactor design.
  - C. An incident of moderate frequency should not generate an aggravated plant condition without other faults occurring independently.
  - D. The requirements in RG 1.105, "Instrument Spans and Setpoints," are used for their impact on the plant response to the type of AOOs addressed in this SRP section.
  - E. The most limiting plant system single failure, as defined in "Definitions and Explanations," 10 CFR Part 50, Appendix A, must be assumed in the analysis according to the guidance of RG 1.53 and GDC 17.
  - F. Performance of nonsafety-related systems during transients and accidents and single failures of active and passive systems (especially as to the performance of

check valves in passive systems) must be evaluated and verified according to the guidance of SECY 77-439, SECY 94-084, and RG 1.206

3. The applicant should analyze these events using an acceptable analytical model. Any other analytical method proposed by the applicant is evaluated by the staff for acceptability. For new generic methods, the reviewer requests an evaluation by the appropriate organization for reactor systems.

The values of the parameters in the analytical model should be suitably conservative. The following values are acceptable:

- A. The reactor is initially at 102 percent of the rated (licensed) core thermal power (to account for a 2 percent power measurement uncertainty unless a lower number can be justified through measurement uncertainty methodology and evaluation or unless the uncertainty otherwise is accounted for (see SAR (or DCD) Section 4.4)), and primary loop flow is at the nominal design flow less the flow measurement uncertainty.
- B. Conservative scram characteristics are assumed (*i.e.*, for a PWR maximum time delay with the most reactive rod held out of the core, for a BWR a 0.8 design conservatism multiplier on the predicted reactivity insertion rate) unless (i) a different conservatism factor can be justified through the uncertainty methodology and evaluation or (ii) the uncertainty is otherwise accounted for (see SAR (or DCD) Section 4.4).
- C. The core burn-up is selected to yield the most limiting combination of moderator temperature coefficient, void coefficient, Doppler coefficient, axial power profile, and radial power distribution.
- D. Mitigating systems should be assumed to be actuated in the analyses at setpoints with allowance for instrument uncertainty in accordance with Regulatory Guide 1.105.

#### Technical Rationale

The technical rationale for application of these acceptance criteria to the areas of review addressed by this SRP section is discussed in the following paragraphs:

1. GDC 10 requires design of reactor core and its coolant, control, and protection systems with appropriate margin so SAFDLs are not exceeded during any conditions of normal operation, including the effects of AOOs.

GDC 10 applies to this section because the reviewer evaluates the consequences of AOOs that could decrease heat removal by the secondary system and result in the fuel cladding thermal design criteria to be exceeded. RG 1.105 provides guidance for keeping instrument setpoints within technical specification limits.

GDC 10 requirements provide assurance that SAFDLs are not exceeded for initiating events that decrease heat removal by the secondary system.

2. GDC 13 requires the provision of instrumentation that is capable of monitoring variables and systems over their anticipated ranges to assure adequate safety, and of controls that can maintain these variables and systems within prescribed operating ranges.

GDC 13 applies to this section because the reviewer evaluates the sequences of events, including automatic actuations of protection systems, and manual actions, and determines whether the sequence of events is justified, based upon the expected values of the relevant monitored parameters and instruments indications.

3. GDC 15 requires design of the reactor coolant system and its auxiliary, control, and protection systems with sufficient margin so RCPB design conditions are not exceeded during any conditions of normal operation, including AOOs.

GDC 15 applies to this section because the reviewer evaluates the consequences of AOOs that could decrease heat removal by the secondary system and lead to an increase in the reactor coolant temperature and pressure.

GDC 15 requirements provide assurance that RCPB design conditions are not exceeded for initiating events that decrease heat removal by the secondary system.

4. GDC 17 requires onsite and offsite electrical power systems for safety-related SSCs to perform intended functions. Each power system (assuming the other system is not functioning) must provide sufficient capacity and capability so SAFDLs and RCPB design conditions are not exceeded in AOOs.

GDC 17 applies to this SRP section because it governs review of the analysis of abnormal operating occurrences to which it must be applied.

GDC 17 requirements provide assurance that SAFDLs and RCPB design conditions are not exceeded in initiating events that decrease heat removal by the secondary system, concurrent with a loss of offsite power (LOOP).

5. GDC 26 requires two independent reactivity control systems with different design principles to control reactivity changes so acceptable fuel design limits are not exceeded.

GDC 26 applies to this section because the reviewer evaluates the consequences of AOOs that could decrease heat removal by the secondary system and lead to reactivity changes within the core causing the fuel cladding thermal design criteria to be exceeded. GDC 26 requires reactivity control systems to control reactivity changes reliably with appropriate margin for malfunctions (*i.e.*, stuck control rods) so that under conditions of normal operation, including AOOs, SAFDLs are not exceeded. Where applicable, the reviewer examines these margins for whether thermal criteria are satisfied.

GDC 26 requirements provide assurance that SAFDLs are not exceeded, ensuring an appropriate margin for malfunctions of the reactivity control system.

### III. REVIEW PROCEDURES

The reviewer will select material from the procedures described below, as may be appropriate for a particular case.

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the applicant's evaluation of how the proposed alternatives provide an acceptable method of complying with the relevant NRC requirements identified in Subsection II.

The procedures are used for the design certification (DC) application review, the construction permit (CP), operating license (OL), and COL reviews. During below the CP review, the values of system parameters and setpoints in the analysis are preliminary and subject to change. At the OL or COL review stage, final values should be in the analysis, and the reviewer should compare these to the limiting safety system settings in the proposed technical specifications.

1. The SAR (or DCD) description of these transients is reviewed for the occurrences leading to the initiating event. The sequence of events from initiation until a stabilized condition is reached is reviewed for:
  - A. The extent to which normally operating plant instrumentation and controls are assumed to function.
  - B. The extent to which plant and reactor protection systems are required to function.
  - C. The extent to which credit is taken for the functioning of normally operating plant systems.
  - D. The extent to which operation of engineered safety systems is required.
  - E. The extent to which operator actions are required.
  - F. Appropriate margin for malfunctions (*e.g.*, stuck rods).
  - G. Appropriate accounting for instrumentation uncertainties of system and operating parameters.
2. If the SAR (or DCD) states that one of these transients is not as limiting as other similar transients, the reviewer evaluates the applicant's justification. The SAR (or DCD) must present a quantitative analysis of the most limiting reduction-of-heat-removal transient. For this transient, the reactor systems reviewer, in consultation with the instrumentation and controls reviewer, reviews the timing of the initiation of protection, engineered safety, and other systems needed to limit the consequences of the transient adequately to an acceptable level. The reactor systems reviewer compares the predicted variation of system parameters with various trip and system initiation setpoints. The instrumentation and controls reviewer consults on automatic initiation, actuation delays, possible bypass modes, interlocks, and the feasibility of manual operation if the SAR (or DCD) states that operator action is needed or expected.



3. To the extent deemed necessary, the reviewer evaluates the effect of single active system or component failures that may affect the course of the transient. For new applications, LOOP should not be considered a single failure; each of the reduction-of-heat-removal transients should be analyzed with and without a LOOP in combination with a single active failure. This phase of the review uses the system review procedures described in the SRPs for SAR (or DCD) Chapters 5, 6, 7, and 8.
4. The applicant's mathematical models to evaluate core performance and to predict system pressure in the reactor coolant system and main steam line are reviewed by the organization responsible for reactor systems for whether these models have been reviewed and accepted by the staff. If not, the organization responsible for reactor systems initiates a generic review of the applicant's proposed model.
5. The values of system parameters and initial core and system conditions as input to the model are reviewed by the organization responsible for reactor systems. Of particular importance are (A) the values of reactivity coefficients and control rod worths in the applicant's analysis and (B) the variations of moderator temperature, void, and Doppler coefficients of reactivity with core life. The reviewer evaluates the applicant's justification showing that the core burn-up selected yields the minimum safety margins.
6. The results of the analysis are reviewed and compared to the acceptance criteria of subsection II of this SRP section for fuel integrity, the possibility of the event becoming more serious, and the maximum pressure in the reactor coolant and main steam systems. The following parameters are reviewed:
  - A. reactor power;
  - B. heat fluxes (average and maximum);
  - C. reactor coolant system pressure;
  - D. minimum DNBR (PWR) or CPR (BWR);
  - E. core and recirculation loop coolant flow rates (BWR);
  - F. coolant conditions (inlet temperature, core average temperature (PWR), core average steam volume fraction (BWR), average exit and hot channel exit temperatures, and steam fractions);
  - G. steam line pressure;
  - H. containment and suppression pool (if applicable) pressures and temperatures;
  - I. maximum pressurizer water volume (PWR);
  - J. pressure safety and relief valve flow rates; and
  - K. flow rate from the reactor coolant system to the containment system (if applicable).

The more important parameters for the limiting transient are compared to those predicted for similar plants for whether they are within expected range.

7. For review of a DC application, the reviewer should follow the above procedures to verify that the design, including requirements and restrictions (e.g., interface requirements and site parameters), set forth in the final safety analysis report (FSAR) meets the acceptance criteria. DCs have referred to the FSAR as the design control document (DCD). The reviewer should also consider the appropriateness of identified COL action items. The reviewer may identify additional COL action items; however, to ensure these COL action items are addressed during a COL application, they should be added to the DC FSAR.

For review of a COL application, the scope of the review is dependent on whether the COL applicant references a DC, an early site permit (ESP) or other NRC approvals (e.g., manufacturing license, site suitability report or topical report).

#### IV. EVALUATION FINDINGS

The reviewer verifies that the applicant has provided sufficient information and that the review and calculations (if applicable) support conclusions of the following type to be included in the staff's safety evaluation report. The reviewer also states the bases for those conclusions.

The staff concludes that the plant design is acceptable as to transients resulting in unplanned decreases in heat removal by the secondary system, transients expected with moderate frequency, and transients where the predicted response meets the requirements of GDCs 10, 13, 15, 17, and 26. This conclusion is based on the following findings:

1. The applicant meets the requirements of GDCs 10 and 26 by demonstrating that SAFDLs are not exceeded for this event. The applicant also meets GDC 15 requirements by preventing plant transients from resulting in unplanned decreases in heat removal by the secondary system and demonstrating reactor coolant pressure limits not exceeded by these events and resultant leakage within acceptable limits.
2. The applicant meets GDC 13 requirements by demonstrating that all credited instrumentation was available, and the actuations of protection systems, automatic and manual, occurred at values of monitored parameters that were within the instruments' prescribed operating ranges.
3. The transient initiating events that might occur with moderate frequency are:
  - A. turbine trip,
  - B. loss of external load,
  - C. steam pressure regulator malfunctions,
  - D. main steam isolation valve closure (in BWRs),
  - E. loss of condenser vacuum,

- F. loss of nonemergency AC power to the station auxiliaries,
  - G. loss of normal feedwater flow.<sup>1</sup>
4. In a review of the transients that could result from these postulated events, it was found that the most limiting in regard to core thermal margins and pressure within the reactor coolant and main steam systems was the \_\_\_\_\_ transient. This transient was evaluated by the applicant using a mathematical model that had been previously reviewed and found to be acceptable by the staff. The parameters used as input to this model were reviewed and found to be suitably conservative and in accordance with the recommendation of RG 1.105. The results of the analysis of the transient showed that cladding integrity was maintained by ensuring that the minimum departure from nucleate boiling ratio (or minimum critical power ratio for a BWR) did not decrease below \_\_\_\_\_ and that the maximum pressure within the reactor coolant and main steam systems did not exceed 110% of their design pressures.
  5. The applicant meets the requirements of GDCs 17 and 26 by demonstrating that SAFDLs are not exceeded for this event. In addition, the applicant meets GDC 15 requirements by demonstrating that the reactor coolant pressure limits are exceeded by this event and that resultant leakage is within acceptable limits.
  6. The applicant meets the positions of RG 1.53, SECY 77-439, SECY 94-084 and RG 1.206 on the single-failure criterion and RG 1.105 on instrument actuations of safety-related systems and components.

For DC and COL reviews, the findings will also summarize the staff's evaluation of requirements and restrictions (e.g., interface requirements and site parameters) and COL action items relevant to this SRP section.

## V. IMPLEMENTATION

The staff will use this SRP section in performing safety evaluations of DC applications and license applications submitted by applicants pursuant to 10 CFR Part 50 or 10 CFR Part 52. Except when the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the staff will use the method described herein to evaluate conformance with Commission regulations.

The provisions of this SRP section apply to reviews of applications submitted six months or more after the date of issuance of this SRP section, unless superseded by a later revision.

---

<sup>1</sup> The SER should present one statement for moderate frequency transients involving unplanned decrease in heat removal by the secondary system; thus, the results of reviews under SRP Sections 15.2.6 and 15.2.7 are included in this statement.

VI. REFERENCES

1. 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities."
2. 10 CFR Part 50, Appendix A, GDC 10, "Reactor Design."
3. 10 CFR Part 50, Appendix A, GDC 13, "Instrumentation and Control."
4. 10 CFR Part 50, Appendix A, GDC 15, "Reactor Coolant System Design."
5. 10 CFR Part 50, Appendix A, GDC 17, "Electric Power Systems."
6. 10 CFR Part 50, Appendix A, GDC 26, "Reactivity Control System Redundancy and Capability."
7. 10 CFR Part 52, "Early Site Permits; Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."
8. RG 1.53, "Application of the Single-Failure Criterion to Nuclear Power Plant Protection Systems."
9. RG 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants."
10. RG 1.105, "Instrument Spans and Setpoints."
11. NUREG-0718, "Licensing Requirements for Pending Applications for Construction Permits and Manufacturing Licenses."
12. NUREG-0737, "Clarification of TMI Action Plan Requirements."
13. SECY-77-439, "Single Failure Criterion."
14. SECY-94-084, "Policy and Technical Issues Associated With the Regulatory Treatment of Non-Safety Systems in Passive Plant Designs."
15. RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."
16. ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," Article NB-7000, "Protection Against Overpressure," American Society of Mechanical Engineers.
17. ANSI/ANS-51.1-1983, "Nuclear Safety Criteria for the Design of Stationary Pressurized Water Reactor Plants," (replaced ANSI N18.2-1974; reaffirmed 1988; withdrawn 1998).

18. ANSI/ANS-52.1-1983, "Nuclear Safety Criteria for the Design of Stationary Boiling Water Reactor Plants," (replaced ANS Trial Use Standard N212-1974; reaffirmed 1988; withdrawn 1998).

---

**PAPERWORK REDUCTION ACT STATEMENT**

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

**PUBLIC PROTECTION NOTIFICATION**

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

---