

3.10 SPECIAL OPERATIONS

3.10.1 System Leakage and Hydrostatic Testing Operation

LCO 3.10.1 The average reactor coolant temperature specified in Table 1.1-1 for MODE 4 may be changed to "NA," and operation considered not to be in MODE 3; and the requirements of LCO 3.4.8, "Residual Heat Removal (RHR) Shutdown Cooling System — Cold Shutdown," may be suspended, to allow reactor coolant temperature > 212°F:

- For performance of a system leakage or hydrostatic test,
- As a consequence of maintaining adequate pressure for a system leakage or hydrostatic test, or
- As a consequence of maintaining adequate pressure for control rod scram time testing initiated in conjunction with a system leakage or hydrostatic test,

provided the following MODE 3 LCOs are met:

- a. LCO 3.3.6.2, "Secondary Containment Isolation Instrumentation," Functions 1, 3, and 4 of Table 3.3.6.2-1;
- b. LCO 3.6.4.1, "Secondary Containment";
- c. LCO 3.6.4.2, "Secondary Containment Isolation Valves/Dampers (SCIV/Ds)"; and
- d. LCO 3.6.4.3, "Standby Gas Treatment (SBGT) System."

APPLICABILITY: MODE 4 with average reactor coolant temperature > 212°F.