



FPL Energy
Seabrook Station

FPL Energy Seabrook Station
P.O. Box 300
Seabrook, NH 03874
(603) 773-7000

February 2, 2007

Docket No. 50-443

SBK-L-07024

United States Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, D.C. 20555-0001

Seabrook Station
Inservice Inspection Examination Report

Enclosed is the FPL Energy Seabrook, LLC Inservice Inspection Examination Report for inspections conducted prior to and during the eleventh refueling outage that concluded on November 10, 2006. The enclosed report is submitted pursuant to the requirements of paragraph IWA-6240 of the 1995 Edition (including the 1996 addenda) of Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code and approved ASME Code Case N-532-1. Additionally, a copy of this letter and the enclosed report are being submitted to the State of New Hampshire.

Should you have any questions regarding this information, please contact Mr. Michael Ossing, Engineering Support Manager, at (603) 773-7512.

Very truly yours,

FPL Energy Seabrook, LLC

A handwritten signature in cursive script, reading "Gene F. St. Pierre", written over a horizontal line.

Gene F. St. Pierre
Site Vice President

A047

United States Nuclear Regulatory Commission
SBK-L-07024/Page 2

cc: S. J. Collins, NRC Region I Administrator
G. E. Miller, NRC Project Manager, Project Directorate I-2
G.T. Dentel, NRC Senior Resident Inspector

Wayne Brigham, Boiler Inspector
New Hampshire Department of Labor
Inspection Division
PO Box 2076
Concord, NH 03302-2076

Enclosure to SBK-L-07024

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: ISI-SBK-2006

Owner: FPL Energy Seabrook, LLC
 P.O. Box 14000
 700 Universe Boulevard
 Juno Beach, FL 33408-0420

Plant: FPL Energy Seabrook
 P.O. Box 300
 Seabrook, NH 03874

Unit No. 1 **Commercial service date** August 19, 1990 **Refueling outage no.** OR11
(if applicable)

Current inspection interval 2nd Interval
(1st, 2nd, 3rd, 4th, other)

Current inspection period 2nd Period
(1st, 2nd, 3rd)

Edition and Addenda of Section XI applicable to the inspection plan 1995 Edition with 1996 Addenda

Date and revision of inspection plan August 28, 2006 Revision 10

Edition and Addenda of Section XI applicable to repairs and replacements, if different than the inspection plan _____
Same as inspection plan.

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented in this report conform to the requirements of Section XI.

Certificate of Authorization No. N/A **Expiration Date** N/A
(if applicable)
Signed Kevin A. Whitney, Sr. Engineer **Date** January 17, 2007
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of NH and employed by HSB CT of Hartford CT have inspected the items described in this Owner's Activity Report, during the period 5-3-05 to 11-10-06, and state that to the best of my knowledge and belief, the

Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] **Commissions** NB 4372 (A, MI) NH 751
Inspector's Signature National Board, State, Province, and Endorsements
Date 1-17-07

TABLE 1
ABSTRACT OF EXAMINATIONS AND TESTS

SBK – 2nd Interval, 2nd Period

Examination Category	Total Examinations Required for The Interval	Total Examinations Credited for This Period	Total Examinations Credited (%) For The Period	Total Examinations Credited (%) To Date for The Interval	Remarks
B-A	24	2	100%	25%	Percentage acceptable per IWB-2412 (a)(2). Relief Request 2IR-1 applied.
B-B	5	1	100%	60%	Relief Request 2IR-2 applied.
B-D	44	10	100%	36%	Percentage acceptable per IWB-2412 (a)(2). Relief Request 2IR-2 applied.
B-F	Included in the Risk-Informed ISI Program.				See Category R-A.
B-G-1	241	108	100%	67%	
B-G-2	74	21	100%	62%	
B-H	Category B-H items are included with Category B-K.				
B-J	Included in the Risk-Informed ISI Program.				See Category R-A.
B-K	1	0	0%	0%	Percentage acceptable per IWB-2412 (a)(5). Relief Request 2IR-12 applied.
B-L-1	There are no B-L-1 pump casing welds.				
B-L-2	1	0	0%	0%	Percentage acceptable per IWB-2412 (a)(4).
B-M-1	There are no B-M-1 valve body welds.				
B-M-2	6	0	100%	50%	Percentage acceptable per IWB-2412 (a)(4). One of each group required when disassembled.
B-N-1	3	1	0%	67%	Percentage acceptable per IWB-2412 (a)(1).
B-N-2	6	0	0%	0%	Percentage acceptable per IWB-2412 (a)(3).
B-N-3	1	0	0%	0%	Percentage acceptable per IWB-2412 (a)(3).
B-O	2	0	0%	50%	Percentage acceptable per IWB-2412 (a)(1).
B-P	7	1	100%	71%	Required each refueling outage.
B-Q	Steam Generator tubing is examined in accordance with Plant Technical Specifications.				
C-A	16	5	100%	56%	

TABLE 1
ABSTRACT OF EXAMINATIONS AND TESTS (continued)

SBK – 2nd Interval, 2nd Period

Examination Category	Total Examinations Required for The Interval	Total Examinations Credited for This Period	Total Examinations Credited (%) For The Period	Total Examinations Credited (%) To Date for The Interval	Remarks
C-B	7	3	100%	71%	Required percentage amended by Code Case N-598.
C-C	5	0	0%	40%	
C-D	There are no category C-D items.				
C-F-1	140	49	100%	62%	
C-F-2	157	26	100%	46%	
C-G	There are no category C-G items.				
C-H	25	24	96%	65%	Required each Period. One test scheduled in Feb. '07 to complete period requirement.
D-A	11	6	100%	55%	
D-B	17	17	100%	67%	Required each Period. Code Case N-498-4 applied to hydrostatic tests.
E-A	161	161	100%	67%	Required each Period per 10CFR50.55a(b)(ix)(E).
E-C	6	6	100%	50%	Locations identified in Period 1 and require examination in Period 2 and Period 3.
E-D	3	1	100%	67%	
E-G	15	3	100%	73%	Required percentage amended by Code Case N-598.
F-A	202	71	100%	75%	Required percentage amended by Code Case N-598.
L-A	24	24	100%	67%	Required every 5 years per IWL-2410(a).
R-A	72	24	100%	67%	Risk-Informed Relief Request approved by NRC TAC No. MB1799.

TABLE 2
ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT
REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled Section XI Examination or Test (Yes or No)
-------------------------	----------------	---------------------	--	--

There were no flaws or relevant conditions that required evaluation for continued service.

TABLE 3
ABSTRACT OF REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES
REQUIRED FOR CONTINUED SERVICE

SBK – 2nd Interval, 2nd Period

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Flaw or Relevant Condition Found During Scheduled Section XI Examination or Test (Yes/No)	Date Completed	Repair/ Replacement Plan Number
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CC-V-266	Replacement of Valve	CHECK IF YES <input type="checkbox"/>	10/11/2006	0204672
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-P-110A	Replacement of Cap Screw	CHECK IF YES <input type="checkbox"/>	5/10/2006	0207051
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	FW-P-37B	Machining of Stuffing Box Extension	CHECK IF YES <input type="checkbox"/>	1/12/2006	0211276
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CC-V-171	Replacement of Safety Valve	CHECK IF YES <input type="checkbox"/>	11/15/2005	0233872
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	WLD-V-213	Replacement of Safety Valve	CHECK IF YES <input type="checkbox"/>	11/15/2005	0233934
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-24	Replacement of Nozzle and Bonnet Nuts	CHECK IF YES <input type="checkbox"/>	11/15/2005	0244301
2	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-89	Machining of Nozzle	CHECK IF YES <input type="checkbox"/>	11/15/2005	0244302
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-89	Replacement of Bonnet Nuts	CHECK IF YES <input type="checkbox"/>	11/15/2005	0244302
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RMW-1109	Modification of RMW Piping	CHECK IF YES <input type="checkbox"/>	1/12/2006	0304469
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-V-23B	Modification of Valve Disc	CHECK IF YES <input type="checkbox"/>	11/15/2005	0321823
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-V-1	Replacement of Valve	CHECK IF YES <input type="checkbox"/>	1/12/2006	0324442
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-V-7B	Replacement of Valve	CHECK IF YES <input type="checkbox"/>	1/12/2006	0343235
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-V-23B	Replacement of Valve	CHECK IF YES <input type="checkbox"/>	11/15/2005	0401815

TABLE 3
ABSTRACT OF REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES
REQUIRED FOR CONTINUED SERVICE

SBK – 2nd Interval, 2nd Period

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Flaw or Relevant Condition Found During Scheduled Section XI Examination or Test (Yes/No)	Date Completed	Repair/ Replacement Plan Number
1	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-115	Replacement of Code Safety Valve	CHECK IF YES <input type="checkbox"/>	9/6/2005	0404392
1	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-116	Replacement of Code Safety Valve	CHECK IF YES <input type="checkbox"/>	9/6/2005	0404392
1	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-117	Replacement of Code Safety Valve	CHECK IF YES <input type="checkbox"/>	9/6/2005	0404392
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-EP-23B	Replacement of Expansion Bellows	CHECK IF YES <input type="checkbox"/>	11/15/2005	0404447
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-V-118	Replacement of Relief Valve	CHECK IF YES <input type="checkbox"/>	11/14/2005	0404763
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-24	Replacement of Valve	CHECK IF YES <input type="checkbox"/>	11/15/2005	0404788
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-V-89	Replacement of Valve	CHECK IF YES <input type="checkbox"/>	11/15/2005	0404794
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11B	Replacement of Secondary Handhole Bolting on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/15/2005	0404826
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11C	Replacement of Secondary Handhole Bolting on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/15/2005	0404827
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11A	Replacement of Secondary Handhole Bolting on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/15/2005	0404828
2	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11A	Machining of Secondary Handhole Covers on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/15/2005	0417253
2	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11A	Machining of Secondary Handhole Flanges on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/15/2005	0417253
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-V-29B	Diesel Generator Lube Oil Temperature Control Valve Enhancements	CHECK IF YES <input type="checkbox"/>	11/15/2005	0420473

**TABLE 3
ABSTRACT OF REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES
REQUIRED FOR CONTINUED SERVICE**

SBK – 2nd Interval, 2nd Period

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Flaw or Relevant Condition Found During Scheduled Section XI Examination or Test (Yes/No)	Date Completed	Repair/ Replacement Plan Number
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CC-E-17A	Bolting Replacement on Heat Exchanger	CHECK IF YES <input type="checkbox"/>	10/25/2006	0433587
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CC-E-17B	Bolting Replacement on Heat Exchanger	CHECK IF YES <input type="checkbox"/>	10/25/2006	0433588
2	<input checked="" type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	MS-V-393	Replacement of Valve Trim and Weld Buildup of Seat	CHECK IF YES <input type="checkbox"/>	1/12/2006	0442021
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	MS-V-393	Replacement of Valve Plug Assembly and Seat Ring	CHECK IF YES <input type="checkbox"/>	1/12/2006	0442021
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CC-E-17B	Replacement of Channel Head Bolting	CHECK IF YES <input type="checkbox"/>	11/15/2005	0443526
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CS-F-4B	Replacement of Bolt Assembly / Trunion on Filter	CHECK IF YES <input type="checkbox"/>	1/12/2006	0502456
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CS-V-273	Replacement of Valve Bolting	CHECK IF YES <input type="checkbox"/>	1/12/2006	0502494
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-EP-46	Replacement of Bolting	CHECK IF YES <input type="checkbox"/>	10/26/2005	0508483
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	CS-E-3	Replacement of Pipe Flange Bolting to Heat Exchanger	CHECK IF YES <input type="checkbox"/>	5/18/2005	0511138
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11C	Replacement of Secondary Handhole Bolting on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/6/2006	0516311
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11D	Replacement of Secondary Handhole Bolting on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/6/2006	0516345
1	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	RC-E-11D	Replacement of Primary Manway Bolting on Steam Generator	CHECK IF YES <input type="checkbox"/>	11/6/2006	0520584
2	<input checked="" type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	MS-PV-3004	Replacement and Machining of Plug Assembly	CHECK IF YES <input type="checkbox"/>	11/6/2006	0521386

**TABLE 3
ABSTRACT OF REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES
REQUIRED FOR CONTINUED SERVICE**

SBK – 2nd Interval, 2nd Period

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Flaw or Relevant Condition Found During Scheduled Section XI Examination or Test (Yes/No)	Date Completed	Repair/ Replacement Plan Number
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	810-RM-001	Replacement of Pipe Snubber	CHECK IF YES <input type="checkbox"/>	10/24/2005	0522057
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input checked="" type="checkbox"/> Corrective Measure	160-RM-24	Replacement of Hydraulic Pipe Snubber	CHECK IF YES <input checked="" type="checkbox"/>	10/14/2006	0522098
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input checked="" type="checkbox"/> Corrective Measure	158-RM-31 202-RM-10	Replacement of Hydraulic Pipe Snubber	CHECK IF YES <input checked="" type="checkbox"/>	10/19/2006	0522107
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	1307-RM-009	Replacement of Pipe Snubber	CHECK IF YES <input type="checkbox"/>	10/20/2006	0522111
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	1310-RM-006	Replacement of Pipe Snubber	CHECK IF YES <input type="checkbox"/>	10/20/2006	0522112
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-V-127	Encapsulation of Valve	CHECK IF YES <input type="checkbox"/>	8/8/2006	0522187
2	<input checked="" type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	MS-V-26	Repair / Replacement of Valve	CHECK IF YES <input type="checkbox"/>	11/6/2006	0522820
2	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	MS-V-26	Replacement of Valve Nuts	CHECK IF YES <input type="checkbox"/>	11/6/2006	0522820
2	<input checked="" type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	MS-PV-3003	Replacement And Machining of Plug Assembly	CHECK IF YES <input type="checkbox"/>	11/6/2006	0528118
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-1810	Replacement of Bolting on Pipe Flanges at JTR-0101	CHECK IF YES <input type="checkbox"/>	10/25/2006	0538655
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-1810	Replacement of Pipe Spool	CHECK IF YES <input type="checkbox"/>	10/23/2006	0540128
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-P-41C	Replacement of Stuffing Box and Bearing	CHECK IF YES <input type="checkbox"/>	4/3/2006	0543635
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-P-41D	Replacement of Stuffing Box	CHECK IF YES <input type="checkbox"/>	9/21/2006	0546715

TABLE 3
ABSTRACT OF REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES
REQUIRED FOR CONTINUED SERVICE

SBK – 2nd Interval, 2nd Period

Code Class	Repair, Replacement, or Corrective Measure	Item Description	Description of Work	Flaw or Relevant Condition Found During Scheduled Section XI Examination or Test (Yes/No)	Date Completed	Repair/ Replacement Plan Number
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-P-41C	Replacement of Pump	CHECK IF YES <input type="checkbox"/>	2/13/2006	0602087
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-1817	Attachment of Pipet	CHECK IF YES <input type="checkbox"/>	2/13/2006	0602941
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-1801 & 1827	Repair of Service Water Piping	CHECK IF YES <input type="checkbox"/>	10/31/2006	0605838
3	<input checked="" type="checkbox"/> Repair <input type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	SW-1802	Attachment of Pipet	CHECK IF YES <input type="checkbox"/>	8/8/2006	0615037
3	<input type="checkbox"/> Repair <input checked="" type="checkbox"/> Replacement <input type="checkbox"/> Corrective Measure	DG-E-42A	Replacement of Heat Exchanger Bolting	CHECK IF YES <input type="checkbox"/>	10/30/2006	0632972