

L. William Pearce
Vice President

440-280-5382
Fax: 440-280-8029

February 1, 2007
PY-CEI/ODNR-0045L

Ohio Department of Natural Resources
Division of Water
Water Resources Section
2045 Morse Road, Bld. B-2
Columbus, Ohio 43229-6605


Re: Perry Nuclear Power Plant
Water Withdrawal Facility Registration Number: 01483

Ladies and Gentlemen:

Enclosed is the State of Ohio Water Withdrawal Facility Registration Annual Report for the Perry Nuclear Power Plant.

If you have questions or require additional information, please contact Mrs. Liz Ryan at (440) 280-5536.

Very truly yours,



Enclosure

cc: NRC Region III
NRC Resident Inspector
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

C001

ODNR REPORT DATA

Month	Total Days in Month	Days in Month that Water Withdrawals Occurred	Gross Capacity Factor (GR MDC)	NPDES Total Discharge Volume MG	Monthly Daily Maximum Discharge MGD	Monthly Daily Minimum Discharge MGD
January	31	31	0.147	2537.6	96.0	62.9
February	28	28	0.652	1965.8	92.0	59.6
March	31	31	0.000	2870.1	100.2	78.0
April	30	30	0.000	2562.7	106.1	69.8
May	31	31	0.693	2714.4	114.4	62.2
June	30	30	0.993	3017.7	121.6	62.4
July	31	31	0.993	3409.7	122.2	89.2
August	31	31	0.990	3219.0	124.7	85.7
September	30	30	0.994	3210.2	125.6	77.3
October	31	31	0.977	3184.7	131.1	50.1
November	30	30	0.996	2431.7	96.6	57.0
December	31	31	1.000	2473.6	87.1	59.8
Totals:				33597.2	1317.6	814.0

ODNR REPORT CALCULATIONS

Monthly Evaporative Loss	Total Intake Flow	Average Daily Loss	Actual Maximum Intake	Actual Minimum Intake
95.70	2633.30	3.09	99.09	65.99
383.38	2349.18	13.69	105.69	73.29
0.00	2870.10	0.00	100.20	78.00
0.00	2562.70	0.00	106.10	69.80
451.14	3165.54	14.55	128.95	76.75
625.59	3643.29	20.85	142.45	83.25
646.44	4056.14	20.85	143.05	110.05
644.49	3863.49	20.79	145.49	106.49
626.22	3836.42	20.87	146.47	98.17
636.03	3820.73	20.52	151.62	70.62
627.48	3059.18	20.92	117.52	77.92
651.00	3124.60	21.00	108.10	80.80
5387.47	38984.67	177.14	1494.74	991.14