

MANUAL HARD COPY DISTRIBUTION
DOCUMENT TRANSMITTAL 2007-3731

USER INFORMATION:

GERLACH*ROSE M EMPL#:028401 CA#: 0363
Address: NUCSA2
Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO: GERLACH*ROSE M 01/30/2007

LOCATION: USNRC

FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)

THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.

ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TRM2 - TECHNICAL REQUIREMENTS MANUAL UNIT 2

REMOVE MANUAL TABLE OF CONTENTS DATE: 12/19/2006

ADD MANUAL TABLE OF CONTENTS DATE: 01/29/2007

CATEGORY: DOCUMENTS TYPE: TRM2

ADD

ID: TEXT 3.0
REMOVE: REV:1

ADD: REV: 2 .

CATEGORY: DOCUMENTS TYPE: TRM2
ID: TEXT B3.0
REMOVE: REV:1

ADD: REV: 2

CATEGORY: DOCUMENTS TYPE: TRM2
ID: TEXT LOES
REMOVE: REV:30

ADD: REV: 31

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 3 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

Table Of Contents

Issue Date: 01/29/2007

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES Title: LIST OF EFFECTIVE SECTIONS	31	01/29/2007		
TEXT TOC Title: TABLE OF CONTENTS	9	12/14/2006		
TEXT 1.1 Title: USE AND APPLICATION DEFINITIONS	0	11/19/2002		
TEXT 2.1 Title: PLANT PROGRAMS AND SETPOINTS PLANT PROGRAMS	1	02/04/2005		
TEXT 2.2 Title: PLANT PROGRAMS AND SETPOINTS INSTRUMENT TRIP SETPOINT TABLE	5	11/22/2005		
TEXT 3.0 Title: APPLICABILITY TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY	2	01/29/2007		
TEXT 3.1.1 Title: REACTIVITY CONTROL SYSTEMS ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION	0	11/19/2002		
TEXT 3.1.2 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD DRIVE (CRD) HOUSING SUPPORT	0	11/19/2002		
TEXT 3.1.3 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD BLOCK INSTRUMENTATION	2	11/22/2005		
TEXT 3.1.4 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE	0	11/19/2002		
TEXT 3.2.1 Title: CORE OPERATING LIMITS CORE OPERATING LIMITS REPORT (COLR)	5	10/12/2006		

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.3.1 0 11/19/2002
Title: INSTRUMENTATION RADIATION MONITORING INSTRUMENTATION

TEXT 3.3.2 1 04/26/2006
Title: INSTRUMENTATION SEISMIC MONITORING INSTRUMENTATION

TEXT 3.3.3 1 04/26/2006
Title: INSTRUMENTATION METEOROLOGICAL MONITORING INSTRUMENTATION

TEXT 3.3.4 2 06/13/2006
Title: INSTRUMENTATION TRM POST-ACCIDENT MONITORING INSTRUMENTATION

TEXT 3.3.5 0 11/19/2002
Title: INSTRUMENTATION THIS PAGE INTENTIONALLY LEFT BLANK

TEXT 3.3.6 2 10/19/2005
Title: INSTRUMENTATION TRM ISOLATION ACTUATION INSTRUMENTATION

TEXT 3.3.7 0 11/19/2002
Title: INSTRUMENTATION MAIN TURBINE OVERSPEED PROTECTION SYSTEM

TEXT 3.3.8 1 10/22/2003
Title: INSTRUMENTATION TRM RPS INSTRUMENTATION

TEXT 3.3.9 1 11/22/2004
Title: INSTRUMENTATION LPRM UPSCALE ALARM INSTRUMENTATION

TEXT 3.3.10 1 12/14/2004
Title: INSTRUMENTATION REACTOR RECIRCULATION PUMP MG SET STOPS

TEXT 3.3.11 1 10/22/2003
Title: INSTRUMENTATION MVP ISOLATION INSTRUMENTATION

TEXT 3.4.1 1 04/26/2006
Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM CHEMISTRY

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.4.2	0	11/19/2002	Title: REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY
TEXT 3.4.3	0	11/19/2002	Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM (RCS)
TEXT 3.4.4	1	12/14/2004	Title: REACTOR COOLANT SYSTEM REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT
TEXT 3.4.5	1	04/26/2006	Title: REACTOR COOLANT SYSTEM REACTOR VESSEL MATERIALS
TEXT 3.5.1	1	02/04/2005	Title: ECCS AND RCIC ADS MANUAL INHIBIT
TEXT 3.5.2	0	11/19/2002	Title: ECCS AND RCIC ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION
TEXT 3.5.3	0	11/19/2002	Title: ECCS AND RCIC LONG TERM NITROGEN SUPPLY TO ADS
TEXT 3.6.1	0	11/19/2002	Title: CONTAINMENT VENTING OR PURGING
TEXT 3.6.2	0	11/19/2002	Title: CONTAINMENT SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION
TEXT 3.6.3	0	11/19/2002	Title: CONTAINMENT SUPPRESSION POOL ALARM INSTRUMENTATION
TEXT 3.6.4	0	11/19/2002	Title: CONTAINMENT PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES
TEXT 3.7.1	0	11/19/2002	Title: PLANT SYSTEMS EMERGENCY SERVICE WATER SYSTEM (ESW) SHUTDOWN

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.2 0 11/19/2002
Title: PLANT SYSTEMS ULTIMATE HEAT SINK (UHS) AND GROUND WATER LEVEL

TEXT 3.7.3.1 1 04/26/2006
Title: PLANT SYSTEMS FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT 3.7.3.2 2 04/26/2006
Title: PLANT SYSTEMS SPRAY AND SPRINKLER SYSTEMS

TEXT 3.7.3.3 2 08/18/2005
Title: PLANT SYSTEMS CO2 SYSTEMS

TEXT 3.7.3.4 1 04/26/2006
Title: PLANT SYSTEMS HALON SYSTEMS

TEXT 3.7.3.5 1 04/26/2006
Title: PLANT SYSTEMS FIRE HOSE STATIONS

TEXT 3.7.3.6 1 04/26/2006
Title: PLANT SYSTEMS YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT 3.7.3.7 1 04/26/2006
Title: PLANT SYSTEMS FIRE RATED ASSEMBLIES

TEXT 3.7.3.8 6 12/14/2006
Title: PLANT SYSTEMS FIRE DETECTION INSTRUMENTATION

TEXT 3.7.4 1 04/26/2006
Title: PLANT SYSTEMS SOLID RADWASTE SYSTEM

TEXT 3.7.5.1 0 11/19/2002
Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT 3.7.5.2 0 11/19/2002
Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.5.3	1	04/26/2006	Title: PLANT SYSTEMS LIQUID HOLDUP TANKS
TEXT 3.7.6	1	03/01/2005	Title: PLANT SYSTEMS ESSW PUMPHOUSE VENTILATION
TEXT 3.7.7	0	11/19/2002	Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION
TEXT 3.7.8	5	10/12/2006	Title: PLANT SYSTEMS SNUBBERS
TEXT 3.7.9	1	08/28/2006	Title: PLANT SYSTEMS CONTROL STRUCTURE HVAC
TEXT 3.7.10	1	12/14/2004	Title: PLANT SYSTEMS SPENT FUEL STORAGE POOLS (SFSPS)
TEXT 3.8.1	2	02/04/2005	Title: ELECTRICAL POWER PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES
TEXT 3.8.2.1	1	12/14/2004	Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS
TEXT 3.8.2.2	2	12/14/2004	Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC
TEXT 3.8.3	0	11/19/2002	Title: ELECTRICAL POWER DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES
TEXT 3.8.4	1	02/04/2005	Title: ELECTRICAL POWER 24 VDC ELECTRICAL SUBSYSTEM
TEXT 3.8.5	0	11/19/2002	Title: ELECTRICAL POWER DEGRADED VOLTAGE PROTECTION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.8.6	0	11/19/2002	Title: ELECTRICAL POWER EMERGENCY SWITCHGEAR ROOM COOLING
TEXT 3.8.7	0	12/14/2006	Title: BATTERY MAINTENANCE AND MONITORING PROGRAM
TEXT 3.9.1	0	11/19/2002	Title: REFUELING OPERATIONS DECAY TIME
TEXT 3.9.2	0	11/19/2002	Title: REFUELING OPERATIONS COMMUNICATIONS
TEXT 3.9.3	0	11/19/2002	Title: REFUELING OPERATIONS REFUELING PLATFORM
TEXT 3.10.1	1	04/26/2006	Title: MISCELLANEOUS SEALED SOURCE CONTAMINATION
TEXT 3.10.2	0	11/19/2002	Title: MISCELLANEOUS SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT 3.10.3	1	04/26/2006	Title: MISCELLANEOUS INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT 3.10.4	1	08/28/2006	Title: MISCELLANEOUS LEADING EDGE FLOW METER (LEFM)
TEXT 3.11.1.1	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS CONCENTRATION
TEXT 3.11.1.2	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS DOSE
TEXT 3.11.1.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS LIQUID WASTE TREATMENT SYSTEM

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.1.4	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT 3.11.1.5	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT 3.11.2.1	3	04/26/2006	Title: RADIOACTIVE EFFLUENTS DOSE RATE
TEXT 3.11.2.2	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS DOSE - NOBLE GASES
TEXT 3.11.2.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATE FORM
TEXT 3.11.2.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS GASEOUS RADWASTE TREATMENT SYSTEM
TEXT 3.11.2.5	3	11/14/2006	Title: RADIOACTIVE EFFLUENTS VENTILATION EXHAUST TREATMENT SYSTEM
TEXT 3.11.2.6	2	12/14/2004	Title: RADIOACTIVE EFFLUENTS RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
TEXT 3.11.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS TOTAL DOSE
TEXT 3.11.4.1	3	04/26/2006	Title: RADIOACTIVE EFFLUENTS MONITORING PROGRAM
TEXT 3.11.4.2	2	04/26/2006	Title: RADIOACTIVE EFFLUENTS LAND USE CENSUS
TEXT 3.11.4.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS INTERLABORATORY COMPARISON PROGRAM

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.12.1 0 11/19/2002
Title: LOADS CONTROL PROGRAM CRANE TRAVEL-SPENT FUEL STORAGE POOL

TEXT 3.12.2 1 10/12/2006
Title: LOADS CONTROL PROGRAM HEAVY LOADS REQUIREMENTS

TEXT 3.12.3 0 11/19/2002
Title: LOADS CONTROL PROGRAM LIGHT LOADS REQUIREMENTS

TEXT B3.0 2 01/29/2007
Title: APPLICABILITY BASES TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TEXT B3.1.1 0 11/19/2002
Title: REACTIVITY CONTROL SYSTEM BASES ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION

TEXT B3.1.2 0 11/19/2002
Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD DRIVE (CRD) HOUSING SUPPORT

TEXT B3.1.3 2 11/22/2005
Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD BLOCK INSTRUMENTATION

TEXT B3.1.4 0 11/19/2002
Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE

TEXT B3.2.1 0 11/19/2002
Title: CORE OPERATING LIMITS BASES CORE OPERATING LIMITS REPORT (COLR)

TEXT B3.3.1 0 11/19/2002
Title: INSTRUMENTATION BASES RADIATION MONITORING INSTRUMENTATION

TEXT B3.3.2 0 11/19/2002
Title: INSTRUMENTATION BASES SEISMIC MONITORING INSTRUMENTATION

TEXT B3.3.3 1 02/04/2005
Title: INSTRUMENTATION BASES METEOROLOGICAL MONITORING INSTRUMENTATION

ESSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.4.5	0	11/19/2002	Title: REACTOR COOLANT SYSTEM BASES REACTOR VESSEL MATERIALS
TEXT B3.5.1	0	11/19/2002	Title: ECCS AND RCIC BASES ADS MANUAL INHIBIT
TEXT B3.5.2	0	11/19/2002	Title: ECCS AND RCIC BASES ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION
TEXT B3.5.3	0	11/19/2002	Title: ECCS AND RCIC BASES LONG TERM NITROGEN SUPPLY TO ADS
TEXT B3.6.1	0	11/19/2002	Title: CONTAINMENT BASES VENTING OR PURGING
TEXT B3.6.2	0	11/19/2002	Title: CONTAINMENT BASES SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION
TEXT B3.6.3	0	11/19/2002	Title: CONTAINMENT BASES SUPPRESSION POOL ALARM INSTRUMENTATION
TEXT B3.6.4	1	12/14/2004	Title: CONTAINMENT BASES PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES
TEXT B3.7.1	0	11/19/2002	Title: PLANT SYSTEMS BASES EMERGENCY SERVICE WATER SYSTEM (SHUTDOWN)
TEXT B3.7.2	0	11/19/2002	Title: PLANT SYSTEMS BASES ULTIMATE HEAT SINK (UHS) GROUND WATER LEVEL
TEXT B3.7.3.1	1	04/26/2006	Title: PLANT SYSTEMS BASES FIRE SUPPRESSION WATER SUPPLY SYSTEM
TEXT B3.7.3.2	2	04/26/2006	Title: PLANT SYSTEMS BASES SPRAY AND SPRINKLER SYSTEMS

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.3.3	0	11/19/2002	Title: PLANT SYSTEMS BASES CO2 SYSTEMS
TEXT B3.7.3.4	1	04/26/2006	Title: PLANT SYSTEMS BASES HALON SYSTEMS
TEXT B3.7.3.5	1	04/26/2006	Title: PLANT SYSTEMS BASES FIRE HOSE STATIONS
TEXT B3.7.3.6	1	04/26/2006	Title: PLANT SYSTEMS BASES YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES
TEXT B3.7.3.7	0	11/19/2002	Title: PLANT SYSTEMS BASES FIRE RATED ASSEMBLIES
TEXT B3.7.3.8	1	01/12/2004	Title: PLANT SYSTEMS BASES FIRE DETECTION INSTRUMENTATION
TEXT B3.7.4	0	11/19/2002	Title: PLANT SYSTEMS BASES SOLID RADWASTE SYSTEM
TEXT B3.7.5.1	0	11/19/2002	Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS HYDROGEN MONITOR
TEXT B3.7.5.2	0	11/19/2002	Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE
TEXT B3.7.5.3	0	11/19/2002	Title: PLANT SYSTEMS BASES LIQUID HOLDUP TANKS
TEXT B3.7.6	1	03/01/2005	Title: PLANT SYSTEMS BASES ESSW PUMPHOUSE VENTILATION
TEXT B3.7.7	0	11/19/2002	Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.8 2 10/12/2006
Title: PLANT SYSTEMS BASES SNUBBERS

TEXT B3.7.9 1 12/14/2004
Title: PLANT SYSTEMS BASES CONTROL STRUCTURE HVAC

TEXT B3.7.10 1 12/14/2004
Title: PLANT SYSTEMS BASES SPENT FUEL STORAGE POOLS

TEXT B3.8.1 1 02/04/2005
Title: ELECTRICAL POWER BASES PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

TEXT B3.8.2.1 0 11/19/2002
Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS

TEXT B3.8.2.2 1 09/17/2004
Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC

TEXT B3.8.3 0 11/19/2002
Title: ELECTRICAL POWER BASES DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

TEXT B3.8.4 0 11/19/2002
Title: ELECTRICAL POWER BASES 24 VDC ELECTRICAL POWER SUBSYSTEM

TEXT B3.8.5 0 11/19/2002
Title: ELECTRICAL POWER BASES DEGRADED VOLTAGE PROTECTION

TEXT B3.8.6 1 02/04/2005
Title: ELECTRICAL POWER BASES EMERGENCY SWITCHGEAR ROOM COOLING

TEXT B3.8.7 0 12/14/2006
Title: BATTERY MAINTENANCE AND MONITORING PROGRAM

TEXT B3.9.1 0 11/19/2002
Title: REFUELING OPERATIONS BASES DECAY TIME

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.9.2	0	11/19/2002	Title: REFUELING OPERATIONS BASES COMMUNICATIONS
TEXT B3.9.3	0	11/19/2002	Title: REFUELING OPERATIONS BASES REFUELING PLATFORM
TEXT B3.10.1	0	11/19/2002	Title: MISCELLANEOUS BASES SEALED SOURCE CONTAMINATION
TEXT B3.10.2	0	11/19/2002	Title: MISCELLANEOUS BASES SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT B3.10.3	0	11/19/2002	Title: MISCELLANEOUS BASES INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT B3.10.4	0	11/19/2002	Title: MISCELLANEOUS BASES LEADING EDGE FLOW METER (LEFM)
TEXT B3.11.1.1	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS CONCENTRATION
TEXT B3.11.1.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS DOSE
TEXT B3.11.1.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID WASTE TREATMENT SYSTEM
TEXT B3.11.1.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT B3.11.1.5	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT B3.11.2.1	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS BASES DOSE RATE

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.11.2.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES DOSE - NOBLE GASES
TEXT B3.11.2.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATES FORM
TEXT B3.11.2.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES GASEOUS RADWASTE TREATMENT SYSTEM
TEXT B3.11.2.5	4	11/14/2006	Title: RADIOACTIVE EFFLUENTS BASES VENTILATION EXHAUST TREATMENT SYSTEM
TEXT B3.11.2.6	1	01/27/2004	Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
TEXT B3.11.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES TOTAL DOSE
TEXT B3.11.4.1	2	01/06/2006	Title: RADIOACTIVE EFFLUENTS BASES MONITORING PROGRAM
TEXT B3.11.4.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LAND USE CENSUS
TEXT B3.11.4.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES INTERLABORATORY COMPARISON PROGRAM
TEXT B3.12.1	0	11/19/2002	Title: LOADS CONTROL PROGRAM BASES CRANE TRAVEL-SPENT FUEL STORAGE POOL
TEXT B3.12.2	0	11/19/2002	Title: LOADS CONTROL PROGRAM BASES HEAVY LOADS REQUIREMENTS
TEXT B3.12.3	0	11/19/2002	Title: LOADS CONTROL PROGRAM BASES LIGHT LOADS REQUIREMENTS

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 4.1 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS ORGANIZATION

TEXT 4.2 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS REPORTABLE EVENT ACTION

TEXT 4.3 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS SAFETY LIMIT VIOLATION

TEXT 4.4 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS PROCEDURES & PROGRAMS

TEXT 4.5 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS REPORTING REQUIREMENTS

TEXT 4.6 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS RADIATION PROTECTION PROGRAM

TEXT 4.7 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS TRAINING

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
TOC	TABLE OF CONTENTS	11/29/2006
1.0	USE AND APPLICATION	
	Page TRM / 1.0-1	08/31/1998
	Page TRM / 1.0-2	10/04/2002
	Page TRM / 1.0-3	08/31/1998
2.0	PLANT PROGRAMS	
	Page 2.0-1	08/31/1998
	Pages TRM / 2.0-2 and TRM 2.0-3	01/28/2005
	Page TRM / 2.0-4	06/25/2002
	Page TRM / 2.0-5	04/12/1999
	Pages TRM / 2.0-6 and TRM / 2.0-7	11/15/2004
	Page TRM / 2.0-8	12/03/2004
	Pages TRM / 2.0-9 through TRM / 2.0-11	11/15/2004
	Pages TRM / 2.0-12 through TRM / 2.0-15	11/15/2005
3.0	APPLICABILITY	
	Pages TRM / 3.0-1 and TRM / 3.0-2	01/10/2007
	Page TRM / 3.0-3	03/15/2002
	Page TRM / 3.0-4	11/30/2005
3.1	REACTIVITY CONTROL SYSTEMS	
	Pages 3.1-1 through 3.1-6	08/31/1998
	Pages TRM / 3.1-7 and TRM / 3.1-8	11/15/2005
	Pages TRM / 3.1-9 and TRM / 3.1-9a	02/18/1999
	Page TRM / 3.1-10	02/18/1999
3.2	CORE OPERATING LIMITS REPORT	
	Page 3.2-1	08/31/1998
	Pages TRM / 3.2-2 through TRM / 3.2-39	10/05/2006
3.3	INSTRUMENTATION	
	Pages TRM / 3.3-1 through TRM / 3.3-3	07/16/1999
	Page TRM / 3.3-4	03/31/2006
	Pages 3.3-5 and 3.3-6	08/31/1998
	Page TRM 3.3-7	03/31/2006
	Page 3.3-8	08/31/1998
	Pages TRM / 3.3-9 and TRM / 3.3-9a	12/17/1998
	Page TRM / 3.3-10	05/30/2006
	Page TRM / 3.3-11	06/02/2005
	Page TRM / 3.3-11a	05/30/2006
	Page TRM / 3.3-12	03/30/2001
	Page TRM / 3.3-13	09/13/2005
	Page TRM / 3.3-14	12/14/1998
	Page TRM / 3.3-15	10/22/2003

CONTROLLED

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 31

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / 3.3-16	06/27/2001
	Pages TRM / 3.3-17 and TRM / 3.3-18	06/14/2002
	Pages TRM / 3.3-19 and TRM / 3.3-20	10/22/2003
	Page TRM / 3.3-21	11/15/2004
	Pages TRM /3.3-21a through TRM / 3.3-21d	11/15/2004
	Page TRM / 3.3-22	12/03/2004
	Pages TRM / 3.3-23 and TRM / 3.3-24	05/16/2003
	Page TRM / 3.3-25	10/22/2003
3.4	REACTOR COOLANT SYSTEM	
	Page TRM / 3.4-1	03/31/2006
	Pages 3.4-2 through 3.4-5	10/23/1998
	Pages 3.4-6 through 3.4-11	08/31/1998
	Page TRM / 3.4-12	12/03/2004
	Page TRM / 3.4-13	03/31/2006
3.5	EMERGENCY CORE COOLING AND RCIC	
	Page TRM / 3.5-1	01/28/2005
	Pages 3.5-2 and 3.5-3	08/31/1998
	Page TRM / 3.5-4	04/17/2000
	Pages 3.5-5 through 3.5-7	08/31/1998
3.6	CONTAINMENT	
	Pages 3.6-1 through 3.6-4	08/31/1998
	Page TRM / 3.6-5	01/07/2002
	Page 3.6-6	08/31/1998
	Pages TRM / 3.6-7 through TRM / 3.6-9	12/31/2002
3.7	PLANT SYSTEMS	
	Pages TRM / 3.7-1 and TRM / 3.7-2	07/29/1999
	Page 3.7-3	08/31/1998
	Pages TRM / 3.7-4 and TRM / 3.7-5	03/31/2006
	Pages TRM / 3.7-6 through TRM / 3.7-8	08/02/1999
	Page TRM / 3.7-9	03/31/2006
	Page TRM / 3.7-10	08/16/2005
	Page TRM / 3.7-11	01/21/2000
	Pages TRM / 3.7-12 and TRM / 3.7-13	08/02/1999
	Page TRM / 3.7-14	08/09/2005
	Pages TRM / 3.7-15 and TRM / 3.7-16	08/02/1999
	Page TRM / 3.7-17	03/31/2006
	Page TRM / 3.7-18	08/02/1999
	Page TRM / 3.7-19	03/31/2006
	Pages TRM / 3.7-20 through TRM / 3.7-22	08/02/1999
	Pages TRM / 3.7-23 and TRM / 3.7-24	03/31/2006
	Pages TRM / 3.7-25 through TRM / 3.7-27	08/02/1999
	Page TRM / 3.7-28	11/29/2006

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 31

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / 3.7-29	11/16/2001
	Page TRM / 3.7-30	11/30/2005
	Page TRM / 3.7-31	11/16/2001
	Page TRM / 3.7-32	01/09/2004
	Page TRM / 3.7-33	10/05/2002
	Page TRM / 3.7-34	03/31/2006
	Pages TRM / 3.7-35 and TRM / 3.7-36	02/01/1999
	Pages 3.7-37 through 3.7-38	08/31/1998
	Page TRM / 3.7-39	03/31/2006
	Pages TRM / 3.7-40 and TRM / 3.7-40a	02/14/2005
	Pages 3.7-41 and 3.7-42	08/31/1998
	Pages TRM / 3.7-43 through TRM / 3.7-48	10/05/2006
	Pages TRM / 3.7-48a and TRM / 3.7-48b	10/05/2006
	Page TRM / 3.7-49	03/09/2001
	Page TRM / 3.7-50	08/16/2006
	Page TRM / 3.7-51	12/03/2004
	Page TRM / 3.7-52	04/15/2003
	Page TRM / 3.7-53	07/29/1999
3.8	ELECTRICAL POWER	
	Page TRM / 3.8-1	04/02/2002
	Pages TRM / 3.8-2 and TRM / 3.8-3	01/28/2005
	Page TRM / 3.8-4	01/31/2005
	Pages TRM / 3.8-5 and TRM / 3.8-6	04/02/2002
	Pages TRM / 3.8-7 through TRM / 3.8-10	12/03/2004
	Page TRM / 3.8-11	08/10/2004
	Page TRM / 3.8-12	12/03/2004
	Pages 3.8-13 and 3.8-14	08/31/1998
	Page TRM / 3.8-15	01/28/2005
	Pages TRM / 3.8-16 and TRM / 3.8-17	04/02/2002
	Page 3.8-18	02/01/1999
	Page TRM / 3.8-19	04/02/2002
	Page TRM / 3.8-20	02/01/1999
	Pages TRM / 3.8-21 through TRM / 3.8-23	06/06/1999
	Pages 3.8-24 and 3.8-25	08/31/1998
	Pages TRM / 3.8-26 through TRM / 3.8-29	11/29/2006
3.9	REFUELING OPERATIONS	
	Pages 3.9-1 through 3.9-3	08/31/1998
3.10	MISCELLANEOUS	
	Page TRM / 3.10-1	03/31/2006
	Pages 3.10-2 through 3.10-4	08/30/1998
	Page TRM / 3.10-5	03/08/2003
	Page TRM / 3.10-6	06/05/2002
	Page TRM / 3.10-7	03/31/2006
	Page TRM / 3.10-8	08/16/2006

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.11	RADIOACTIVE EFFLUENTS	
	Page TRM / 3.11-1	03/31/2006
	Pages 3.11-2 through 3.11-3	08/31/1998
	Page TRM / 3.11-4	03/31/2006
	Page 3.11-5	08/31/1998
	Page TRM / 3.11-6	03/31/2006
	Pages 3.11-7 through 3.11-9	08/31/1998
	Page TRM / 3.11-10	12/03/2004
	Pages 3.11-11 and 3.11-12	08/31/1998
	Page 3.11-13	09/01/1998
	Page TRM / 3.11-14	12/03/2004
	Pages 3.11-15 and 3.11-16	09/01/1998
	Page TRM / 3.11-17	03/31/2006
	Page 3.11-18	08/31/1998
	Page TRM / 3.11-19	08/15/2005
	Pages TRM / 3.11-20 and TRM / 3.11-21	03/31/2006
	Page TRM / 3.11-22	04/02/2002
	Page TRM / 3.11-23	11/14/2006
	Page TRM / 3.11-24	05/13/2005
	Page 3.11-25	09/01/1998
	Pages TRM / 3.11-26 through TRM / 3.11-28	01/21/2004
	Page TRM / 3.11-29	12/03/2004
	Pages TRM 3.11-30 through TRM / 3.11-32	01/21/2004
	Page TRM / 3.11-33	03/31/2006
	Page 3.11-34	08/31/1998
	Page TRM / 3.11-35	03/31/2006
	Pages TRM / 3.11-36 through TRM / 3.11-39	11/30/2005
	Pages 3.11-40 through 3.11-44	08/31/1998
	Page TRM / 3.11-45	03/31/2006
	Page 3.11-46	08/31/1998
	Page TRM / 3.11-47	03/31/2006
3.12	LOADS CONTROL PROGRAM	
	Pages TRM / 3.12-1 through TRM / 3.12-3	02/05/1999
	Page TRM / 3.12-4	09/30/2006
	Page TRM / 3.12-5	02/05/1999
4.0	ADMINISTRATIVE CONTROLS	
	Pages 4.0-1 through 4.0-8	08/31/1998

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 31

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.0	APPLICABILITY BASES	
	Pages TRM / B 3.0-1 through TRM / B 3.0-3	08/31/1998
	Page TRM / B 3.0-4	01/10/2007
	Pages TRM / B 3.0-5 through TRM / B 3.0-10	08/31/1998
	Pages TRM / B 3.0-11 and TRM / B 3.0-12	03/15/2002
	Pages TRM / B 3.0-13 and TRM / B 3.0-14	11/30/2005
	Page TRM / B 3.0-15	03/15/2002
B 3.1	REACTIVITY CONTROL SYSTEMS BASES	
	Pages TRM / B 3.1-1 through TRM / B 3.1-3	07/13/1999
	Page B 3.1-4	08/31/1998
	Pages TRM / B 3.1-5 through TRM / B 3.1-7	11/15/2005
	Page TRM / B 3.1-8	02/18/1999
B 3.2	CORE OPERATING LIMITS BASES	
	Page B 3.2-1	08/31/1998
B 3.3	INSTRUMENTATION BASES	
	Page TRM / B 3.3-1	04/07/2000
	Page B 3.3-2	08/31/1998
	Pages TRM / B 3.3-3 and TRM / B 3.3-3A	01/31/2005
	Pages TRM / B 3.3-4 through TRM / B 3.3-7	05/30/2006
	Pages TRM / B 3.3-8 and TRM / B 3.3-9	03/30/2001
	Page B 3.3-10	08/31/1998
	Pages TRM / B 3.3-11 and TRM / B 3.3-12	09/13/2005
	Page TRM / B 3.3-13	12/03/2004
	Page TRM / B 3.3-14	06/25/2002
	Page TRM / B 3.3-14a	06/14/2002
	Page TRM / B 3.3-14b	06/14/2002
	Page TRM / B 3.3-15	10/22/2003
	Page TRM / B 3.3-16	10/22/2003
	Page TRM / B 3.3-17	10/22/2003
	Pages TRM / B 3.3-18 and TRM / B 3.3-19	11/15/2004
	Pages TRM / B 3.3-19a through TRM / B 3.3.19e	11/15/2004
	Pages TRM / B 3.3-20 and TRM / B 3.3-21	05/16/2003
	Page TRM / B 3.3-22	10/22/2003
	Page TRM / B 3.3-23	05/16/2003
B 3.4	REACTOR COOLANT SYSTEM BASES	
	Pages B 3.4-1 through B 3.4-4	08/31/1998
	Page TRM / B 3.4-5	10/15/1999
	Page B 3.4-6	08/31/1998
B 3.5	ECCS AND RCIC BASES	
	Pages B 3.5-1 through B 3.5-5	08/31/1998
B 3.6	CONTAINMENT BASES	
	Page TRM / B 3.6-1	07/26/2001
	Page TRM / B 3.6-2	02/01/1999

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page B 3.6-3	08/31/1998
	Page TRM / B 3.6-4	09/23/1999
	Page TRM / B 3.6-5	01/07/2002
	Page TRM / B 3.6-6	12/03/2004
	Pages TRM / B 3.6-7 through TRM / B 3.6-11	12/31/2002
B 3.7	PLANT SYSTEMS BASES	
	Pages B 3.7-1 and B 3.7-2	08/31/1998
	Page TRM / B 3.7-3	08/02/1999
	Page TRM / B 3.7-4	03/31/2006
	Page TRM / B 3.7-5	08/02/1999
	Pages TRM / B 3.7-6 and TRM / B 3.7-6a	03/31/2006
	Pages TRM / B 3.7-7 and TRM / B 3.7-7a	08/02/1999
	Page TRM / B 3.7-8	08/02/1999
	Page TRM / B 3.7-9	03/31/2006
	Page TRM / B 3.7-10	08/02/1999
	Pages TRM / B 3.7-10a through TRM / B 3.7-11a	03/31/2006
	Pages TRM / B 3.7-12 through TRM / B 3.7-14	08/02/1999
	Pages TRM / B 3.7-14a and TRM / B 3.7-14b	01/09/2004
	Pages TRM / B 3.7-15 and TRM / B 3.7-16	02/01/1999
	Pages B 3.7-17 through B 3.7-20	08/31/1998
	Pages TRM / B 3.7-21 and TRM / B 3.7-21a	02/14/2005
	Pages TRM / B 3.7-22 and TRM / B 3.7-23	04/07/2000
	Pages TRM / B 3.7-24 through TRM / B 3.7-30	10/05/2006
	Pages TRM / B 3.7-30a and TRM / B 3.7-30b	10/05/2006
	Page TRM / B 3.7-31	12/03/2004
	Page TRM / B 3.7-32	03/09/2001
	Page TRM / B 3.7-33	04/15/2003
	Page TRM / B 3.7-34	12/03/2004
	Page TRM / B 3.7-35	07/05/2000
B 3.8	ELECTRICAL POWER BASES	
	Page TRM / B 3.8-1	04/02/2002
	Pages TRM / B 3.8-2 and TRM / B 3.8-2a	01/28/2005
	Page TRM / B 3.8-3	04/02/2002
	Page TRM / B 3.8-3a	04/02/2002
	Page TRM / B 3.8-4	04/02/2002
	Page TRM / B 3.8-4a	08/10/2004
	Page TRM / B 3.8-5	08/31/1998
	Pages TRM / B 3.8-6 through TRM / B 3.8-16	04/02/2002
	Page TRM / B 3.8-17	01/28/2005
	Pages TRM / B 3.8-18 through TRM / B 3.8-24	11/29/2006

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B.3.9	REFUELING OPERATIONS BASES Pages B 3.9-1 and B 3.9-2 Pages B 3.9-3 through B 3.9-7	08/31/1998 10/23/1998
B 3.10	MISCELLANEOUS BASES Pages B 3.10-1 through B 3.10-2 Page TRM / B 3.10-3 Pages TRM / B 3.10-4 and TRM / B 3.10-5 Pages TRM / B 3.10-6 and TRM / 3.10-7	08/31/1998 03/08/2003 08/23/1999 04/17/2002
B 3.11	RADIOACTIVE EFFLUENTS BASES Pages B 3.11-1 through B 3.11-9 Page TRM / B 3.11-10 Pages TRM/B 3.11-11 and TRM/B 3.11-11a Pages TRM/B 3.11-12 and TRM/B 3.11-13 Page TRM / B 3.11-14 Page TRM / B 3.11-15 Pages B 3.11-16 through B 3.11-19 Page TRM / B 3.11-20 Page TRM / B 3.11-20a Page TRM / B 3.11-21 Pages TRM / B 3.11-22 and TRM / B 3.11-23 Page TRM / B 3.11-23a Pages TRM / B 3.11-24 and TRM / B 3.11-25 Pages B 3.11-26 through B 3.11-27 Pages TRM / B 3.11-28 and TRM / B 3.11-29 Page TRM / B 3.11-30 Pages B 3.11-31 through B 3.11-35 Page TRM / B 3.11-36	08/31/1998 02/01/1999 04/07/2000 02/01/1999 12/03/2004 02/01/1999 08/31/1998 04/02/2002 04/02/2002 05/13/2005 11/14/2006 05/13/2005 01/21/2004 08/31/1998 11/30/2005 12/03/2004 08/31/1998 02/12/1999
B.3.12	LOADS CONTROL PROGRAM BASES Pages TRM / B 3.12-1 through TRM / B 3.12-3	02/05/1999

TRM2 text LOES.doc
1/4/07

3.0 TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TRO 3.0.1 TROs shall be met during the MODES or other specified conditions in the Applicability, except as provided in TRO 3.0.2.

TRO 3.0.2 Upon discovery of a failure to meet an TRO, the Required Actions of the associated Conditions shall be met, except as provided in TRO 3.0.5 and TRO 3.0.6.

If the TRO is met or is no longer applicable prior to expiration of the specified Completion Time(s), completion of the Required Action(s) is not required, unless otherwise stated.

TRO 3.0.3 When a TRO is not met, and the associated ACTIONS are not met, an associated ACTION is not provided, or if directed by the associated ACTIONS, the following actions shall be taken:

1. Take compensatory actions as warranted for exiting TRO 3.0.3 commensurate with the safety significance of the condition. Development and implementation of the compensatory actions and plan for exit of TRO 3.0.3 shall be pursued without delay and in a controlled manner and shall be documented in the TRO 3.0.3 entry Condition Report.
2. Initiate a TRO 3.0.3 entry Condition Report that is coded Level 3 Evaluation to determine possible changes to the TRO that would preclude future entry into TRO 3.0.3.

When corrective measures are completed that permit operation in accordance with the TRO or the TRO actions, completion of the compensatory actions and plan for exiting TRO 3.0.3 is not required.

TRO 3.0.4 When a TRO is not met, entry into a MODE or other specified condition in the Applicability shall not be made except when the associated ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time. If such situations are discovered and a different action is deemed appropriate, issue a change to the appropriate TRM sections to describe committed actions to be taken.

Exceptions to this Requirement are stated in the individual Requirements. These exceptions allow entry into MODES or other specified conditions in the Applicability when the associated ACTIONS to be entered allow unit operation in the MODE or other specified condition in the Applicability only for a limited period of time. TRO 3.0.4 is only applicable for entry into a MODE or other specified condition in the Applicability in MODES 1, 2, and 3.

(continued)

3.0 TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TRO 3.0.4 (continued) This Specification shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS or that are part of a shutdown of the unit.

TRO 3.0.5 Equipment removed from service or declared inoperable to comply with ACTIONS may be returned to service under administrative control solely to perform testing required to demonstrate its OPERABILITY, the OPERABILITY of other equipment or variables to be within limits. This is an exception to TRO 3.0.2 for the system returned to service under administrative control to perform the testing required to demonstrate OPERABILITY.

TRO 3.0.6 When a supported system TRO is not met solely due to a support system TRO not being met, the Conditions and Required Actions associated with this supported system are not required to be entered. Only the support system TRO ACTIONS are required to be entered. This is an exception to TRO 3.0.2 for the supported system.
When a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system. The applicable Conditions and Required Actions shall be entered in accordance with TRO 3.0.2.

3.0 Technical Requirement Surveillance (TRS) Applicability

TRS 3.0.1 TRS shall be met during the MODES or other specified conditions in the Applicability for individual TROs, unless otherwise stated in the TRS. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the TRO. Failure to perform a Surveillance within the specified Frequency shall be failure to meet the TRO except as provided in TRS 3.0.3. Surveillances do not have to be performed on inoperable equipment or variables outside specified limits.

TRS 3.0.2 The specified Frequency for each TRS is met if the Surveillance is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

If a Completion Time requires periodic performance on a "once per . . ." basis, the above Frequency extension applies to each performance after the initial performance.

Exceptions to this Requirement are stated in the individual Requirements.

TRS 3.0.3 If it is discovered that a Surveillance was not performed within its specified Frequency, then compliance with the requirement to declare the TRO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. In the event it is determined that a Surveillance cannot be performed within its specified Frequency, compliance with the requirement to declare the TRO not met may be delayed, from the expiration of the current Surveillance test interval, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. This delay period is permitted to allow performance of the Surveillance. A risk evaluation shall be performed for any Surveillance delayed greater than 24 hours and the risk impact shall be managed.

(continued)

3.0 Technical Requirement Surveillance (TRS) Applicability

TRS 3.0.3 (continued) If the Surveillance is not performed within the delay period, the TRO must immediately be declared not met, and the applicable Condition(s) must be entered.

When the Surveillance is performed within the delay period and the Surveillance is not met, the TRO must immediately be declared not met, and the applicable Condition(s) must be entered.

Exceptions to this Requirement are stated in the individual Requirements.

TRS 3.0.4 Entry into a MODE or other specified condition in the Applicability of a TRO shall not be made unless the TRO's Surveillances have been met within their specified Frequency. This provision shall not prevent entry into MODES or other specified conditions in the Applicability that are required to comply with Actions or that are part of a shutdown of the unit.

TRS 3.0.4 is only applicable for entry into a MODE or other specified condition in the Applicability in MODES 1, 2, and 3.

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TROs TRO 3.0.1 through TRO 3.0.6 establish the general requirements applicable to all Requirements and apply at all times, unless otherwise stated.

TRO 3.0.1 TRO 3.0.1 establishes the Applicability statement within each individual Requirement as the requirement for when the TRO is required to be met (i.e., when the unit is in the MODES or other specified conditions of the Applicability statement of each Requirement).

TRO 3.0.2 TRO 3.0.2 establishes that upon discovery of a failure to meet a TRO, the associated ACTIONS shall be met. The Completion Time of each Required Action for an ACTIONS Condition is applicable from the point in time that an ACTIONS Condition is entered. The Required Actions establish those remedial measures that must be taken within specified Completion Times when the requirements of a TRO are not met. This Requirement establishes that:

- a. Completion of the Required Actions within the specified Completion Times constitutes compliance with a Requirement; and
- b. Completion of the Required Actions is not required when a TRO is met within the specified Completion Time, unless otherwise specified.

There are two basic types of Required Actions. The first type of Required Action specifies a time limit in which the TRO must be met. This time limit is the Completion Time to restore an inoperable system or component to OPERABLE status or to restore variables to within specified limits. If this type of Required Action is not completed within the specified Completion Time, a shutdown may be required to place the unit in a MODE or condition in which the Specification is not applicable.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.2
(continued) Whether stated as a Required Action or not, correction of the entered Condition is an action that may always be considered upon entering ACTIONS. The second type of Required Action specifies the remedial measures that permit continued operation of the unit that is not further restricted by the Completion Time. In this case, compliance with the Required Actions provides an acceptable level of safety for continued operation.

Completing the Required Actions is not required when a TRO is met or is no longer applicable, unless otherwise stated in the individual Requirements.

The nature of some Required Actions of some Conditions necessitates that, once the Condition is entered, the Required Actions must be completed even though the associated Conditions no longer exist. The individual TRO's Actions specify the Required Actions where this is the case. An example of this is in Technical Requirement TRO 3.4.1, "Chemistry."

The Completion Times of the Required Actions are also applicable when a system or component is removed from service intentionally. The reasons for intentionally relying on the ACTIONS include, but are not limited to, modifications, performance of Surveillances, preventive maintenance, corrective maintenance, or investigation of operational problems. Entering ACTIONS for these or for any other reasons must be done in a manner that does not compromise safety.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.2 Individual Requirements may specify a time limit for performing a TRS when equipment is removed from service or bypassed for testing. In this case, the Completion Times of the Required Actions are applicable when this time limit expires, if the equipment remains removed from service or bypassed.

When a change in MODE or other specified condition is required to comply with Required Actions, the unit may enter a MODE or other specified condition in which another Requirement becomes applicable. In this case, the Completion Times of the associated Required Actions would apply from the point in time that the new Requirement becomes applicable and the ACTIONS Condition(s) are entered.

TRO 3.0.3 TRO 3.0.3 establishes the actions that must be implemented when a TRO is not met and:

- a. An associated Required Action and Completion Time is not met and no other Condition applies; or
- b. The condition of the unit is not specifically addressed by the associated ACTIONS. This means that no combination of Conditions stated in the ACTIONS can be made that exactly corresponds to the actual condition of the unit. Certain combinations of Conditions may exist such that entering TRO 3.0.3 is warranted; in such cases, the Actions specifically state a Condition corresponding to such combinations and also that TRO 3.0.3 be entered immediately.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.3 (continued) Because entry into the 3.0.3 ACTION is an escalation of the system, structure, component, or unit condition, a Condition Report is required. The Condition Report will address plant safety given the nonconformance with the Technical Requirement. TROs which affect OPERABILITY of TS Functions will have an assessment of TS OPERABILITY.

Compensatory actions and a plan for exiting TRO 3.0.3 shall be developed and implemented in a timely manner commensurate with the safety significance of the entry condition. This will allow for an orderly development of actions and plans providing for time to coordinate any actions deemed unwarranted with the station work schedule.

TRO 3.0.3 entries are undesirable and should be avoided whenever possible. Thus, it is important to evaluate the TRO 3.0.3 entry circumstances to determine if changes to the TRO not met can be made that would preclude the need for future TRO 3.0.3 entries. Completion of the evaluation is not required to exit TRO 3.0.3. The evaluation shall be performed even though TRO 3.0.3 has been/will be exited.

TRO 3.0.4 TRO 3.0.4 establishes limitations on changes in MODES or other specified conditions in the Applicability when a TRO is not met. It precludes placing the unit in a MODE or other specified condition stated in that Applicability (e.g., Applicability desired to be entered) when the following exist:

- a. Unit conditions are such that the requirements of the TRO would not be met in the Applicability desired to be entered; and
- b. Continued noncompliance with the TRO requirements, if the Applicability were entered, would result in the unit being required to exit the Applicability desired to be entered to comply with the Required Actions.

Compliance with Required Actions that permit continued operation of the unit for an unlimited period of time in a MODE or other specified condition provides an acceptance level of safety for continued operation. This is without regard to the status of the unit before or after the MODE change. Therefore, in such cases, entry into a MODE or other specified condition in the Applicability may be made in accordance with the provisions of the Required Actions. The provisions of this Requirement should not be interpreted as endorsing the failure to exercise the good practice of restoring systems or components to OPERABLE status before entering an associated MODE or other specified condition in the Applicability.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.4 (continued) The provisions of TRO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS. In addition, the provisions of TRO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that result from any unit shutdown.

TRO 3.0.4 is not applicable to TROs that are identified as APPLICABLE "At all times." This term is considered to constitute one inclusive operating condition that corresponds to and encompasses all MODES as defined in the Technical Specification, as well as all special operating conditions, including when the reactor vessel is defueled. Entry into any MODE or other special condition is done within the context of "all times," and, therefore, is not a change within the Applicability to which TRO 3.0.4 applies.

Other exceptions to TRO 3.0.4 are stated in the individual Requirements. Exceptions may apply to all the ACTIONS or to a specific Required Action of a Requirement. TRO 3.0.4 is only applicable when entering MODE 3 from MODE 4, MODE 2 from MODE 3 or 4, or MODE 1 from MODE 2. Furthermore, TRO 3.0.4 is applicable when entering any other specified condition in the Applicability only while operating in MODE 1, 2, or 3. The requirements of TRO 3.0.4 do not apply in MODES 4 and 5, or in other specified conditions of the Applicability (unless in MODE 1, 2, or 3) because the ACTIONS of individual Requirements sufficiently define the remedial measures to be taken.

Surveillances do not have to be performed on the associated inoperable equipment (or on variables outside the specified limits), as permitted by TRS 3.0.1. Therefore, changing MODES or other specified conditions while in an ACTIONS Condition, either in compliance with TRO 3.0.4 or where an

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.4 (continued) exception to TRO 3.0.4 is stated, is not a violation of TRS 3.0.1 or TRS 3.0.4 for those surveillances that do not have to be performed due to the associated inoperable equipment. However, TRSs must be met to ensure OPERABILITY prior to declaring the associated equipment OPERABLE (or variable within limits) and restoring compliance with the affected TRO.

TRO 3.0.5 TRO 3.0.5 establishes the allowance for restoring equipment to service under administrative controls when it has been removed from service or declared inoperable to comply with ACTIONS. The sole purpose of this Requirement is to provide an exception to TRO 3.0.2 (e.g., to not comply with the applicable Required Action(s) to allow the performance of TRSs to demonstrate:

- a. The OPERABILITY of the equipment being returned to service; or
- b. The OPERABILITY of other equipment; or
- c. That variables are within limits

The administrative controls ensure the time the equipment is returned to service in conflict with the requirements of the ACTIONS is limited to the time absolutely necessary to perform the allowed TRSs. This Requirement does not provide time to perform any other preventive or corrective maintenance.

An example of demonstrating the OPERABILITY of the equipment being returned to service is reopening a containment isolation valve that has been closed to comply with Required Actions and must be reopened to perform the TRSs.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.5 (continued) An example of demonstrating the OPERABILITY of other equipment is taking an inoperable channel or trip system out of the tripped condition to prevent the trip function from occurring during the performance of a TRS on another channel in the other trip system. A similar example of appropriate response during the performance of an TRS on another channel in the same trip system.

TRO 3.0.6 TRO 3.0.6 establishes an exception to TRO 3.0.2 for support systems that have a TRO specified in the Technical Requirement Specifications (TRS). This exception is provided because TRO 3.0.2 would require that the Conditions and Required Actions of the associated inoperable supported system TRO be entered solely due to the inoperability of the support system. This exception is justified because the actions that are required to ensure the plant is maintained in a safe condition are specified in the support system TRO's Required Actions. These Required Actions may include entering the supported system's Conditions and Required Actions or may specify other Required Actions.

When a support system is inoperable and there is a TRO specified for it in the TRS, the supported system(s) are required to be declared inoperable if determined to be inoperable as a result of the support system inoperability. However, it is not necessary to enter into the supported systems' Conditions and Required Actions unless directed to do so by the support system's Required Actions. The potential confusion and inconsistency of requirements related to the entry into multiple support and supported systems' TROs' Conditions and Required Actions are eliminated by providing all the actions that are necessary to ensure the plant is maintained in a safe condition in the support system's Required Actions.

(continued)

B 3.0 Technical Requirement for Operation (TRO) Applicability

BASES

TRO 3.0.6 (continued) However, there are instances where a support system's Required Action may either direct a supported system to be declared inoperable or direct entry into Conditions and Required Actions for the supported system. This may occur immediately or after some specified delay to perform some other Required Action. Regardless of whether it is immediate or after some delay, when a support system's Required Action directs a supported system to be declared inoperable or directs entry into Conditions and Required Actions for a supported system, the applicable Conditions and Required Actions shall be entered in accordance with TRO 3.0.2.

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS TRS 3.0.1 through TRS 3.0.4 establish the general requirements applicable to all Requirements and apply at all times, unless otherwise stated.

TRS 3.0.1 TRS 3.0.1 establishes the requirement that TRSs must be met during the MODES or other specified conditions in the Applicability for which the requirements of the TRO apply, unless otherwise specified in the individual TRSs. This Requirement is to ensure that Surveillances are performed to verify the OPERABILITY of systems and components, and that variables are within specified limits. Failure to meet a Surveillance within the specified Frequency, in accordance with TRS 3.0.2, constitutes a failure to meet a TRO.

Systems and components are assumed to be OPERABLE when the associated TRSs have been met. Nothing in this Requirement, however, is to be construed as implying that systems or components are OPERABLE when:

- a. The systems or components are known to be inoperable, although still meeting the TRSs; or
- b. The requirements of the Surveillance(s) are known to be not met between required Surveillance performances.

Surveillances do not have to be performed when the unit is in a MODE or other specified condition for which the requirements of the associated TRO are not applicable, unless otherwise specified.

Surveillances, including Surveillances invoked by Required Actions, do not have to be performed on inoperable equipment because the ACTIONS define the remedial measures that apply. Surveillances have to be met and performed in

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS 3.0.1 (continued) accordance with TRS 3.0.2, prior to returning equipment to OPERABLE status. Upon completion of maintenance, appropriate post maintenance testing is required to declare equipment OPERABLE. This includes ensuring applicable Surveillances are not failed and their most recent performance is in accordance with TRS 3.0.2. Post maintenance testing may not be possible in the current MODE or other specified conditions in the Applicability due to the necessary unit parameters not having been established. In these situations, the equipment may be considered OPERABLE provided testing has been satisfactorily completed to the extent possible and the equipment is not otherwise believed to be incapable of performing its function. This will allow operation to proceed to a MODE or other specified condition where other necessary post maintenance tests can be completed.

TRS 3.0.2 TRS 3.0.2 establishes the requirements for meeting the specified Frequency for Surveillances and any Required Action with a Completion Time that requires the periodic performance of the Required Action on a "once per ..." interval.

TRS 3.0.2 permits a 25% extension of the interval specified in the Frequency. This extension facilitates Surveillance scheduling and considers plant operating conditions that may not be suitable for conducting the Surveillance (e.g., transient conditions or other ongoing Surveillance or maintenance activities).

The 25% extension does not significantly degrade the reliability that results from performing the Surveillance at its specified Frequency. This is based on the recognition that the most probable result of any particular Surveillance being performed is the verification of conformance with the TRSs. The exceptions to TRS 3.0.2 are

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRO 3.0.2
(continued)

those Surveillances for which the 25% extension of the interval specified in the Frequency does not apply. These exceptions are stated in the individual Requirements. As stated in TRS 3.0.2, the 25% extension also does not apply to the initial portion of a periodic Completion Time that requires performance on a "once per ..." basis. The 25% extension applies to each performance after the initial performance. The initial performance of the Required Action, whether it is a particular Surveillance or some other remedial action, is considered a single action with a single Completion Time. One reason for not allowing the 25% extension to this Completion Time is that such an action usually verifies that no loss of function has occurred by checking the status of redundant or diverse components or accomplishes the function of the inoperable equipment in an alternative manner.

The provisions of TRS 3.0.2 are not intended to be used repeatedly merely as an operational convenience to extend Surveillance intervals (other than those consistent with refueling intervals) or periodic Completion Time intervals beyond those specified.

TRS 3.0.3

TRS 3.0.3 establishes the flexibility to defer declaring affected equipment inoperable or an affected variable outside the specified limits when a Surveillance has not been completed within the specified Frequency. A delay period of up to 24 hours or up to the limit of the specified Frequency, whichever is greater, applies from the point in time that it is discovered that the Surveillance has not been performed in accordance with TRS 3.0.2, and not at the time that the specified Frequency was not met.

If a Surveillance cannot be performed within its specified Frequency due to unusual conditions, such as a structure, system, or component configuration that prevents performance of a test, or performance of the test would have an adverse impact on plant risk, compliance with the requirement to declare the TRO not met may be delayed. This delay period starts at the expiration of the current Surveillance test interval. The delay can be up to 24 hours or up to the limit of the specified Frequency, whichever is greater.

This delay period provides adequate time to complete Surveillances that have been missed. This delay period permits the completion of a Surveillance before complying with Required Actions or other remedial measures that might preclude completion of the Surveillance.

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASESTRS 3.0.3
(continued)

The basis for this delay period includes consideration of unit conditions, adequate planning, availability of personnel, the time required to perform the Surveillance, the safety significance of the delay in completing the required Surveillance, and the recognition that the most probable result of any particular Surveillance being performed is the verification of conformance with the requirements.

When a Surveillance with a Frequency based not on time intervals, but upon specified unit conditions, operating situations, or requirements of regulations (e.g., prior to entering MODE 1 after each fuel loading, or in accordance with 10 CFR 50, Appendix J, as modified by approved exemptions, etc.) is discovered to not have been performed when specified, TRS 3.0.3 allows for the full delay period of up to the specified Frequency to perform the Surveillance. However, since there is not a time interval specified, the missed Surveillance should be performed at the first reasonable opportunity.

TRS 3.0.3 provides a time limit for, and allowances for the performance of, Surveillances that become applicable as a consequence of MODE changes imposed by Required Actions.

Failure to comply with specified Frequencies for TRSs is expected to be an infrequent occurrence. Use of the delay period established by TRS 3.0.3 is a flexibility which is not intended to be used as an operational convenience to extend Surveillance intervals. While up to 24 hours or the limit of the specified Frequency is provided to perform the missed Surveillance, it is expected that the missed Surveillance will be performed at the first reasonable opportunity. The determination of the first reasonable opportunity should include consideration of the impact on plant risk (from delaying the Surveillance as well as any plant configuration changes required or shutting the plant down to perform the Surveillance) and impact on any analysis assumptions, in addition to unit conditions, planning, availability of

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASESTRS 3.0.3
(continued)

personnel, and the time required to perform the Surveillance. This risk impact should be managed through the program in place to implement 10 CFR 50.65(a)(4) and its implementation guidance, NRC Regulatory Guide 1.182, "Assessing and Managing Risk Before Maintenance Activities at Nuclear Power Plants." This Regulatory Guide addresses consideration of temporary and aggregate risk impacts, determination of risk management action thresholds, and risk management action up to and including plant shutdown. The missed Surveillance should be treated as an emergent condition as discussed in the Regulatory Guide. The risk evaluation may use quantitative, qualitative, or blended methods. The degree of depth and rigor of the evaluation should be commensurate with the importance of the component. Missed Surveillances for important components should be analyzed quantitatively. If the results of the risk evaluation determine the risk increase is significant, this evaluation should be used to determine the safest course of action. All Surveillances whose Frequency has been extended in accordance with TRS 3.0.3 will be placed in the Corrective Action Program.

If a Surveillance is not completed within the allowed delay period, then the equipment is considered inoperable or the variable is considered outside the specified limits and the Completion Times of the Required Actions for the applicable TRO Conditions begin immediately upon expiration of the delay period. If a Surveillance is failed within the delay period, then the equipment is inoperable, or the variable is outside the specified limits and the Completion Times of the Required Actions for the applicable TRO Conditions begin immediately upon the failure of the Surveillance.

Completion of the Surveillance within the delay period allowed by this Requirement, or within the Completion Time of the ACTIONS, restores compliance with TRS 3.0.1.

Exceptions to TRS 3.0.3 are provided in instances where requiring equipment to be considered inoperable, in accordance with TRS 3.0.3, would not provide appropriate remedial measures for the associated condition. An example of this is in TRO 3.11.4.1, "Radiological Environmental Monitoring." TRO 3.11.4.1 has surveillances that implement required environmental sampling and analysis. If a portion of the sampling or analysis is not completed as required, the programmatic response is to report the condition to the Nuclear Regulatory Commission and in most instances describe the corrective actions taken to correct the condition. There are no result

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS 3.0.3 (continued) thresholds built into the monitoring and analysis program that would result in declaring equipment inoperable or in a plant shutdown. Therefore, it is appropriate that the provisions of TRO 3.0.3 be waived for this TRO. These exceptions are addressed in the individual Requirements.

TRS 3.0.4 TRS 3.0.4 establishes the requirement that all applicable TRSs must be met before entry into a MODE or other specified condition in the Applicability. This Requirement ensures that system and component OPERABILITY requirements and variable limits are met before entry into MODES or other specified conditions in the Applicability for which these systems and components ensure safe operation of the unit.

The provisions of this Requirement should not be interpreted as endorsing the failure to exercise the good practice of restoring systems or components to OPERABLE status before entering an associated MODE or other specified condition in the Applicability.

However, in certain circumstances, failing to meet a TRS will not result in TRS 3.0.4 restricting a MODE change or other specified condition change. When a system, subsystem, division, component, device, or variable is inoperable or outside its specified limits, the associated TRS(s) are not required to be performed per TRS 3.0.1, which states that Surveillances do not have to be performed on inoperable equipment. When equipment is inoperable, TRS 3.0.4 does not apply to the associated TRS(s) since the requirement for the TRS(s) to be performed is removed. Therefore, failing to perform the Surveillance(s) within the specified Frequency does not result in an TRS 3.0.4 restriction to changing MODES or other specified conditions of the Applicability. However, since the TRO is not met in this instance, TRO 3.0.4 will govern any restrictions that may (or may not) apply to MODE or other specified condition changes. The provisions of TRS 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that are required to comply with ACTIONS. In addition, the provisions of TRO 3.0.4 shall not prevent changes in MODES or other specified conditions in the Applicability that result from any unit shutdown. The precise requirements for performance of TRSs are specified such that exceptions to TRS 3.0.4 are not necessary. The specific time frames and conditions necessary for meeting the TRSs are specified in the Frequency, in the Surveillance, or both.

(continued)

B 3.0 TECHNICAL REQUIREMENT SURVEILLANCE (TRS) APPLICABILITY

BASES

TRS 3.0.4
(continued)

This allows performance of Surveillances when the prerequisite condition(s) specified in a Surveillance procedure require entry into the MODE or other specified condition in the Applicability of the associated TRO prior to the performance or completion of a Surveillance. A Surveillance that could not be performed until after entering the TRO Applicability would have its Frequency specified such that it is not "due" until the specific conditions needed are met. Alternately, the Surveillance may be stated in the form of a Note as not required (to be met or performed) until a particular event, condition, or time has been reached. Further discussion of the specific formats of TRS's annotation is found in Section 1.4, Frequency.

TRS 3.0.4 is only applicable when entering MODE 3 from MODE 4, MODE 2 from MODE 3 or 4, or MODE 1 from MODE 2. Furthermore, TRS 3.0.4 is applicable when entering any other specified condition in the Applicability only while operating in MODE 1, 2, or 3. The requirements of TRS 3.0.4 do not apply in MODES 4 and 5, or in other specified conditions of the Applicability (unless in MODE 1, 2, or 3) because the ACTIONS of individual Requirements sufficiently define the remedial measures to be taken.
