

**Southern Nuclear
Operating Company, Inc.**
Post Office Box 1295
Birmingham, Alabama 35201-1295
Tel 205.992.5000



February 19, 2007

Docket Nos.: 50-321
50-366

NL-07-0277

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Edwin I. Hatch Nuclear Plant
Technical Specifications Bases Changes for 2006

Ladies and Gentlemen:

Attached please find summaries for the Technical Specifications Bases changes that were made at Plant Hatch for the year 2006. These summaries are being provided in accordance with the provisions of the Technical Specifications Bases Control Program, 5.5.11.d.

This letter contains no NRC commitments. If you have any questions, please advise.

Sincerely,

A handwritten signature in black ink, appearing to read "B. J. George". The signature is fluid and cursive.

B. J. George
Manager, Nuclear Licensing

BJG/OCV/daj

Enclosure: Technical Specifications Bases Changes for 2006

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser, Executive Vice President
Mr. D. R. Madison, Vice President – Hatch
Mr. D. H. Jones, Vice President – Engineering
RTYPE: CHA02.004

U. S. Nuclear Regulatory Commission
Dr. W. D. Travers, Regional Administrator
Mr. R. E. Martin, NRR Project Manager – Hatch
Mr. D. S. Simpkins, Senior Resident Inspector – Hatch

Enclosure

**Edwin I. Hatch Nuclear Plant
Technical Specifications Bases Changes for 2006**

Edwin I. Hatch Nuclear Plant
Technical Specifications Bases Changes for 2006

Licensing Document Change Request (LDCR) 2005-063

This LDCR implemented the Bases changes resulting from a revision of LCO 3.0.4 to the Technical Specifications (TS). The new LCO 3.0.4 was implemented at Plant Hatch Units 1 and 2 under Amendments 246 and 190, respectively. The changes are a part of the BWR industry Risk Informed TS initiatives; they revise the conditions under which mode changes may be made while relying on ACTION statements. The new LCO provides for the performance of risk assessments to support such changes in modes. The corresponding Bases contains more detailed guidance on the performance of the actual risk assessments. These TS Bases changes were provided to the NRC as information with the TS submittal package and were then implemented under the provisions of 10 CFR 50.59.

LDCR 2005-064

This LDCR was implemented under the provisions of 10 CFR 50.59 and corrected a typographical error in Unit 1 Bases Section B 3.6.2.3, "Suppression Pool Cooling". A statement in the LCO paragraph referred to a suppression pool "spray" subsystem. The word "spray" was changed to "cooling".

LDCR 2006-003

The "Applicable Safety Analysis" section of Units 1 and 2 Bases sections B 3.1.7 was revised to update the natural boron concentration that must be injected into the reactor core following an Anticipated Transient Without Scram. The value was changed from 660 ppb to 800 ppb. This resulted from a TS change to Standby Liquid Control Figure 3.1.7-1, "Sodium Pentaborate Solution Volume vs Concentration Requirements," implemented under Amendments 247 and 191 to the Hatch Units 1 and 2 TS, respectively. The change was made to accommodate new, higher energy, fuel designs for Plant Hatch. These Bases changes were provided to the NRC as part of the TS submittal package and were implemented at Plant Hatch under the provisions of 10 CFR 50.59.

LDCR 2006-005

The Units 1 and 2 TS were changed via Amendments 248 and 192 respectively to eliminate Unit 1 Surveillance Requirement (SR) 3.6.1.3.11 and Unit 2 SR 3.6.1.3.12. These SRs dealt with primary containment isolation valves with resilient seats, and required replacing those seats every 24 months. The SRs were replaced with an Appendix J requirement to leak rate test the valves at a frequency of 30 months. The corresponding Bases changes eliminated the discussion of these SRs and were provided to the NRC in the TS revision request package as information. The changes were then implemented into the Hatch Bases via the provisions of 10 CFR 50.59.

Edwin I. Hatch Nuclear Plant
Technical Specifications Bases Changes for 2006

LDCR 2006-062

A section was added to the Units 1 and 2 TS Bases to support new TS LCO 3.0.8. This LCO was added to Section 3.0 of the Units 1 and 2 TS under Amendments 250 and 194, respectively, and provided an allowance for systems with non-functional snubbers. The changes are part of the BWR Industry Risk Informed TS initiatives. The LCO allows a delay time of 72 hours for snubbers associated with single subsystem components, and 12 hours for snubbers associated with dual subsystem components, prior to having to declare the associated LCO not met. This delay time is allowed only if "risk is assessed and managed." The LCO 3.0.8 Bases provides additional information on the performance of the risk evaluation, as well as information on the functional types of snubbers which are applicable to the LCO guidance. The corresponding Bases were provided to the NRC with the original submittal package and implemented at the plant under the provisions of 10 CFR 50.59.

LDCR 2006-067

This LDCR was implemented under the provisions of 10 CFR 50.59 and clarified the Standby Gas Treatment System (SBGT) drawdown requirements for the secondary containment. SR 3.6.4.1.3 requires the SBGT system to drawdown the secondary containment to $\geq .20$ inches of water vacuum gauge in ≤ 120 seconds. This change was made to the above listed SR Bases section to clarify that 13 seconds of diesel generator startup and breaker closing time is included in that 120 seconds.