



U.S. NUCLEAR REGULATORY COMMISSION

STANDARD REVIEW PLAN

9.5.3 LIGHTING SYSTEMS

REVIEW RESPONSIBILITIES

Primary - Organization Responsible for Electrical Engineering

Secondary - None

I. AREAS OF REVIEW

The branch with primary review responsibility will review the normal and emergency or supplementary plant lighting systems, including reference information associated with that review.

The specific areas of review are as follows:

1. The capability of the normal lighting system(s) to provide adequate lighting during all plant operating conditions.
2. The capability of the emergency lighting system to provide adequate lighting during all plant operating conditions, including fire, transient and accident conditions.
3. The effect of the loss of all alternating current (AC) power (i.e. during a station blackout) on the emergency lighting system.
4. The failure analysis of normal and emergency lighting systems.
5. Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC). For design certification (DC) and combined license (COL) reviews, the staff reviews the applicant's proposed ITAAC associated with the structures, systems, and components (SSCs) related to this

Revision 3 - March 2007

USNRC STANDARD REVIEW PLAN

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRR_SRP@nrc.gov.

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML070550036.

SRP section in accordance with SRP Section 14.3, "Inspections, Tests, Analyses, and Acceptance Criteria." The staff recognizes that the review of ITAAC cannot be completed until after the rest of this portion of the application has been reviewed against acceptance criteria contained in this SRP section. Furthermore, the staff reviews the ITAAC to ensure that all SSCs in this area of review are identified and addressed as appropriate in accordance with SRP Section 14.3.

6. COL Action Items and Certification Requirements and Restrictions. For a DC application, the review will also address COL action items and requirements and restrictions (e.g., interface requirements and site parameters).

For a COL application referencing a DC, a COL applicant must address COL action items (referred to as COL license information in certain DCs) included in the referenced DC. Additionally, a COL applicant must address requirements and restrictions (e.g., interface requirements and site parameters) included in the referenced DC.

Review Interfaces

Other SRP sections interface with this section as follows:

1. The review for lighting requirements for fire protection is coordinated and performed by the branch that has primary review responsibility for SRP Section 9.5.1.
2. The review of the adequacy of lighting systems and their power supplies with respect to security and physical protection requirements is coordinated and performed by the staff that has primary review responsibility for SRP Section 13.6.
3. The review of the adequacy of control room lighting systems and features related to their effectiveness to support reliable human performance, including evaluation with respect to the criteria specified in NUREG-0700 (Reference 1), is performed by the staff that has primary review responsibility for SRP Section 18.0.

Specific acceptance criteria and review procedures are contained in the referenced SRP sections.

II. ACCEPTANCE CRITERIA

Requirements

Acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

1. There are no general design criteria or other requirements that directly apply to the normal and emergency or supplementary plant lighting systems.
2. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC's regulations.

3. 10 CFR 52.80(a), which requires that a COL application contain the proposed inspections, tests, and analyses, including those applicable to emergency planning, that the licensee shall perform, and the acceptance criteria that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, the facility has been constructed and will operate in conformity with the combined license, the provisions of the Atomic Energy Act, and the NRC's regulations.

SRP Acceptance Criteria

Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are as follows for the review described in this SRP section. The SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.

1. Acceptance criteria of the design of the normal and emergency lighting systems, as described in the applicant's safety analysis report (SAR), is based in part on the degree of similarity of the systems design with those for previously reviewed plants with satisfactory operating experience.
2. The normal lighting system(s) is acceptable if the integrated design of the system(s) will provide adequate station lighting in all areas, from power sources described in Section 8.2 of the SRP that are required for control and maintenance of equipment and plant access routes during normal plant operations.
3. The emergency lighting system(s) is acceptable if the integrated design of the system(s) will provide adequate emergency station lighting in all areas, required for fire fighting, control and maintenance of equipment used for implementing safe shutdown of the plant during all plant operating conditions, and the access routes to and from these areas.
4. The lighting systems designs will be acceptable if they conform to the lighting levels recommended in NUREG-0700, which is based on the Illuminating Engineering Society of North America (IESNA) Lighting Handbook (Reference 2) as related to systems design and illumination levels recommended for industrial facilities.

III. REVIEW PROCEDURES

The reviewer will select material from the procedures described below, as may be appropriate for a particular case.

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the applicant's evaluation of how the proposed alternatives provide an acceptable method of complying with the relevant NRC requirements identified in Subsection II.

1. The information provided in the SAR pertaining to the designs of the normal and emergency lighting systems including failure analysis is evaluated to determine that the lighting in all plant areas and access routes to and from these areas is adequate. An

engineering assessment using the above acceptance criteria, in conjunction with a comparison to equipment and lighting systems provided on previously approved plants, is to be used as a basis for determining acceptability.

2. For review of a DC application, the reviewer should follow the above procedures to verify that the design, including requirements and restrictions (e.g., interface requirements and site parameters), set forth in the final safety analysis report (FSAR) meets the acceptance criteria. DCs have referred to the FSAR as the design control document (DCD). The reviewer should also consider the appropriateness of identified COL action items. The reviewer may identify additional COL action items; however, to ensure these COL action items are addressed during a COL application, they should be added to the DC FSAR.

For review of a COL application, the scope of the review is dependent on whether the COL applicant references a DC, an early site permit (ESP) or other NRC approvals (e.g., manufacturing license, site suitability report or topical report).

For review of both DC and COL applications, SRP Section 14.3 should be followed for the review of ITAAC. The review of ITAAC cannot be completed until after the completion of this section.

IV. EVALUATION FINDINGS

The reviewer verifies that the applicant has provided sufficient information and that the review and calculations (if applicable) support conclusions of the following type to be included in the staff's safety evaluation report. The reviewer also states the bases for those conclusions.

The normal and emergency lighting systems include all components necessary to provide adequate lighting during normal and emergency plant operating conditions. The scope of review of the lighting systems provided for the _____ plant included assessment of the systems designs, adequacy of the normal and emergency power sources, and verification of adequate lighting during fire, transient, and accident conditions.

The basis for acceptance of the normal and emergency lighting systems was conformance of the design, design criteria, and design bases to staff positions and industry standards and the ability of the emergency lighting system to provide adequate station lighting in all vital areas from onsite power sources during the full spectrum of accident and/or transient conditions and to the access routes to and from these areas.

The staff concludes that the design of the lighting system conforms to the applicable staff positions and industry standards and is therefore acceptable.

For DC and COL reviews, the findings will also summarize the staff's evaluation of requirements and restrictions (e.g., interface requirements and site parameters) and COL action items relevant to this SRP section.

In addition, to the extent that the review is not discussed in other SER sections, the findings will summarize the staff's evaluation of the ITAAC, including design acceptance criteria, as applicable.

V. IMPLEMENTATION

The staff will use this SRP section in performing safety evaluations of DC applications and license applications submitted by applicants pursuant to 10 CFR Part 50 or 10 CFR Part 52. Except when the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the staff will use the method described herein to evaluate conformance with Commission regulations.

The provisions of this SRP section apply to reviews of applications submitted six months or more after the date of issuance of this SRP section, unless superseded by a later revision.

VI. REFERENCES

1. NUREG-0700, "Human-System Interface Design Review Guidelines," Rev. 2, May, 2002.
2. NUREG-1793, "Final Safety Evaluation Report Related to Certification of the AP1000 Standard Design."
3. Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."
4. Standard Review Plan Section 8.2, "Offsite Power System."
5. Illuminating Engineering Society of North America Lighting Handbook.

PAPERWORK REDUCTION ACT STATEMENT

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.
