

Westinghouse Electric Company Nuclear Power Plants P.O. Box 355 Pittsburgh, Pennsylvania 15230-0355 USA

U.S. Nuclear Regulatory Commission ATTENTION: Document Control Desk Washington, D.C. 20555 Direct tel: 412-374-6306 Direct fax: 412-374-5005 e-mail: sterdia@westinghouse.com

Your ref: Project Number 740 Our ref: DCP/NRC1838

February 23, 2007

Subject: AP1000 COL Standard Technical Report Submittal of APP-GW-GLR-073, Revision 0

In support of Combined License application pre-application activities, Westinghouse is submitting AP1000 Standard Combined License Technical Report Number 93. This report identifies and justifies standard changes to the AP1000 Design Control Document (DCD). These changes impact DCD Tier 1, Table 2.2.1-1 and are related to changes to the Electrical Penetrations. The changes to the DCD identified in Technical Report 93 are intended to be incorporated into FSARs referencing the AP1000 Design Certification or incorporated into the design certification by an amendment to the design certification. This report is submitted as part of the NuStart Bellefonte COL Project (NRC Project Number 740). The information included in this report is generic and is expected to apply to all COL applications referencing the AP1000 Design Certification.

The purpose for submittal of this report was explained in a March 8, 2006 letter from NuStart to the NRC.

Pursuant to 10 CFR 50.30(b), APP-GW-GLR-073, Revision 0, "Tier 1, Table 2.2.1-1 Electrical Penetration Changes," (Technical Report Number 93), is submitted as Enclosure 1 under the attached Oath of Affirmation.

It is expected that when the NRC review of Technical Report Number 93 is complete, the changes to the DCD identified in Technical Report 93 will be considered approved generically for COL applicants referencing the AP1000 Design Certification.

Westinghouse is hereby requesting review and approval of the penetration number changes associated with the Electrical Penetrations.

Questions or requests for additional information related to content and preparation of this report should be directed to Westinghouse. Please send copies of such questions or requests for additional information to the prospective applicants for combined licenses referencing the AP1000 Design Certification. A representative for each applicant is included on the cc: list of this letter.

Very truly yours,

· ,

A. Sterdis, Mánager Licensing and Customer Interface Regulatory Affairs and Standardization

/Attachment

1. "Oath of Affirmation," dated February 23, 2007

/Enclosures

1. APP-GW-GLR-073, Revision 0, "Tier 1, Table 2.2.1-1 Electrical Penetration Changes," Technical Report Number 93

cc:	S. Bloom	-	U.S. NRC	1E	1A
	S. Coffin	-	U.S. NRC	1E	1A
	G. Curtis	-	TVA	1E	1A
	P. Grendys	-	Westinghouse	1E	1A
	P. Hastings	-	Duke Power	1E	1A
	C. Ionescu	-	Progress Energy	1E	1A
	D. Lindgren	-	Westinghouse	1E	1A
	A. Monroe	-	SCANA	1E	1 A
	M. Moran	-	Florida Power & Light	1E	1A
	C. Pierce	-	Southern Company	1E	1A
	E. Schmiech	-	Westinghouse	1E	1A
	G. Zinke	-	NuStart/Entergy	1E	1A

•

,

5

.

ATTACHMENT 1

"Oath of Affirmation"

ATTACHMENT 1

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the Matter of:)NuStart Bellefonte COL Project)NRC Project Number 740)

APPLICATION FOR REVIEW OF "AP1000 GENERAL COMBINED LICENSE INFORMATION" FOR COL APPLICATION PRE-APPLICATION REVIEW

W. E. Cummins, being duly sworn, states that he is Vice President, Regulatory Affairs & Standardization, for Westinghouse Electric Company; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission this document; that all statements made and matters set forth therein are true and correct to the best of his knowledge, information and belief.

W. E. Cummins Vice President Regulatory Affairs & Standardization

Subscribed and sworn to before me this **23**rd day of February 2007.

w (7

COMMONWEALTH OF PENNSYLVANIA Notarial Seal Debra McCarthy, Notary Public Monroeville Boro, Allegheny County My Commission Expires Aug. 31, 2009 Member, Pennsylvania Association of Notaries marthy

00083-psa.doc

.

ENCLOSURE 1

APP-GW-GLR-073, Revision 0

"Tier 1, Table 2.2.1-1 Electrical Penetration Changes"

Technical Report 93

.

AP1000 Standard Combined License Technical Report

Tier 1, Table 2.2.1-1 Changes

Technical Report 93

Revision 0

Westinghouse Electric Company LLC P.O. Box 355 Pittsburgh, PA 15230-0355

© 2006 Westinghouse Electric Company LLC All Rights Reserved

1.0 INTRODUCTION

During work to support the Combined Operating Licensing, Westinghouse has determined that the electrical penetration tag numbers in DCD Tier 1 Table 2.2.1-1 are not numbered in accordance with the AP1000 numbering system. According to the AP1000 numbering system, penetrations' tag numbers should start with the system designation code. For example, electrical penetration 21 is in the non-class 1E DC system (EDS); its penetration number should be EDS-EY-P21Z and not ECS-EY-P21Z as listed. Additionally, all penetrations are identified as being class 1E in Tier 1 Table 2.2.1-1 of the ITAAC. Some of the electrical penetrations are non-class 1E. The class 1E penetrations are those electrical penetrations carrying class 1E power or instrumentation signals, the rest of the penetrations are non-class 1E. The purpose of this technical report is to correct the penetrations' tag numbers and their classification to match the AP1000 design documentation. These changes do not change the AP1000 design; they correct Tier 1 Table 2.2.1-1 to meet the current design. The DCD markups are shown in Section three of this report. Additionally, a proposed Tier 1 change to add a new DAS penetration to Table 2.2.1-1 will be addressed in the technical report 97, APP-GW-GLN-022.

2.0 TECHNICAL BACKGROUND

The design of the AP1000 plant is such that the electrical penetrations required to be class 1E are those supporting the IDS (class 1E 125 VDC) system. The other electrical penetrations are classified as non-class 1E and are tagged as part of the ECS (main AC) system and EDS (non-class 1E 125 VDC) system.

The electrical penetrations connected to non-class 1E circuits need to be classified as non-class 1E to meet the independence requirements of IEEE 603. The electrical penetrations are designed in accordance with IEEE 317.

ITAAC 6b of section 2.2.1 requires that a simulated test signal exist at class 1E penetrations when the assigned class 1E Division is provided the test signal. The penetrations that carry the non-class 1E power would not pass the ITAAC.

3.0 DCD MARK-UP

			Table 2.2	.1-1 (cont.)					
Equipment Name	Tag No.	ASME Code Sectio n III	Seismic Cat. I	Remotely Operated Valve	Class 1E/ Qual. for Harsh Envir.	Safety- Related Display	Control PMS/ DAS	Active Function	Loss of Motive Power Position
Maintenance Hatch	CNS-MY-Y02	Yes	Yes	-	-/-	-	-/-	-	-
Personnel Hatch	CNS-MY-Y03	Yes	Yes	-	-/-	-	-/-	-	-
Personnel Hatch	CNS-MY-Y04	Yes	Yes	-	-/-	-	-/-	-	-
Containment Vessel	CNS-MV-01	Yes	Yes	-	-/-	-	-/-	-	-
Electrical Penetration P01	ECS-EY-P01X	Yes	Yes	-	No Yes /Y es	-	-/-		-
Electrical Penetration P02	ECS-EY-P02X	Yes	Yes	-	No Yes /Y es	-	-/-	-	-
Electrical Penetration P06	ECS-EY-P06Y	Yes	Yes	-	No Yes /Y es	-	-/-	-	
Electrical Penetration P09	ECS-EY-P09W	Yes	Yes	-	No Yes /Y es	-	-/-	-	-
Electrical Penetration P10	ECS-EY-P10W	Yes	Yes	-	No Yes /Y es	-	-/-	-	-
Electrical Penetration P11	IDSAECS-EY- P11Z	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P12	IDSAECS-EY- P12Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P13	IDSAECS-EY- P13Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P14	IDSDECS-EY- P14Z	Yes	Yes	-	Yes/Yes	-	-/-	-	-

Electrical Penetration P15	IDSDECS-EY- P15Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P16	IDSDECS-EY- P16Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P18	ECS-EY-P18X	Yes	Yes	-	No Yes /Ye s	-	-/-	-	-
Electrical Penetration P21	EDSCS-EY-P21Z	Yes	Yes	-	No Yes /Ye s	-	-/-	-	-
Electrical Penetration P22	ECS-EY-P22X	Yes	Yes	-	No Yes /Ye s	-	-/-	-	-
Electrical Penetration P23	ECS-EY-P23X	Yes	Yes	-	No Yes /Y es	-	-/-	-	-

.

Table 2.2.1-1 (cont.)									
Equipment Name	Tag No.	ASM E Code Sectio n III	Seismic Cat. I	Remotely Operated Valve	Class 1E/ Qual. for Harsh Envir.	Safety- Related Display	Control PMS/ DAS	Active Function	Loss of Motive Power Position
Electrical Penetration P24	ECS-EY-P24	Yes	Yes	-	No Yes /Y es	-	-/-	-	-
Electrical Penetration P25	ECS-EY-P25W	Yes	Yes	-	No Yes /Y es	-	-/-	-	-
Electrical Penetration P26	ECS-EY-P26W	Yes	Yes	-	No Yes /Y es	-	-/-	-	-
Electrical Penetration P27	IDSCECS-EY- P27Z	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P28	IDSC ECS -EY- P28Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P29	IDSC ECS -EY- P29Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P30	ECSIDSB-EY- P30Z	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P31	IDSBECS-EY- P31Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-
Electrical Penetration P32	IDSBECS-EY- P32Y	Yes	Yes	-	Yes/Yes	-	-/-	-	-

4.0 REGULATORY IMPACT

A	Does the proposed change include a change to:		
	1. Tier 1 of the AP1000 Design Control Document APP-GW-GL-700	🗌 NO 🛛 YES	(If YES prepare a report for NRC review of the changes)
	 Tier 2* of the AP1000 Design Control Document, APP-GW-GL-700 	🖾 NO 🗌 YES	(If YES prepare a report for NRC review of the changes)
	 Technical Specification in Chapter 16 of the AP1000 Design Control Document, APP- GW-GL-700 	🛛 NO 🗌 YES	(If YES prepare a report for NRC review of the changes)
В.	Does the proposed change involve:		
	1. Closure of a Combined License Information Item identified in the AP1000 Design Control Document, APP-GW-GL-700	🛛 NO 🗋 YES	(If YES prepare a COL item closure report for NRC review.)
	2. Completion of an ITAAC item identified in Tier 1 of the AP1000 Design Control Document, APP-GW-GL-700	NO 🗌 YES	(If YES prepare an ITAAC completion report for NRC review.)

The questions above are answered no, therefore the departure from the DCD in a COL application does not require prior NRC review unless review is required by the criteria of 10 CFR Part 52 Appendix D Section VIII B.5.b. or B.5c

C. FSER IMPACT

There is no impact on the FSER. The changes in Tier 1 Table 2.2.1-1 have no effect on design function.

- D. SCREENING QUESTIONS (Check correct response and provide justification for that determination under each response)
- 1. Does the proposed change involve a change to an SSC that adversely affects a DCD YES X NO described design function?

There is no change to a design function of any safety related equipment.

2. Does the proposed change involve a change to a procedure that adversely affects how YES NO DCD described SSC design functions are performed or controlled?

The proposed changes in Tier 1 Table 2.2.1-1 have no effect on operation of the reactor coolant system. The changes have no effect on the initiation or operation of the passive core cooling system.

3. Does the proposed activity involve revising or replacing an DCD described YES NO evaluation methodology that is used in establishing the design bases or used in the safety analyses?

The proposed changes in Tier 1 Table 2.2.1-1 do not require changes to the evaluation of the response to postulated accident conditions. The changes to the design do not require changes to the structural or safety analysis of any safety related equipment.

4. Does the proposed activity involve a test or experiment not described in the DCD, YES ⊠ NO where an SSC is utilized or controlled in a manner that is outside the reference bounds of the design for that SSC or is inconsistent with analyses or descriptions in the DCD?

The proposed changes in Table 2.2.1-1 do not require an additional test or experiment or changes to testing.

E. EVALUATION OF DEPARTURE FROM TIER 2 INFORMATION (Check correct response and provide justification for that determination under each response)

10 CFR Part 52, Appendix D, Section VIII. B.5.a. provides that an applicant for a combined licensee who references the AP1000 design certification may depart from Tier 2 information, without prior NRC approval, if it does not require a license amendment under paragraph B.5.b. The questions below address the criteria of B.5.b.

1.	Does the proposed activity result in more than a minimal increase in the frequency of \square YES \boxtimes NO occurrence of an accident previously evaluated in the plant-specific DCD?
	Since there is no change from the proposed changes in Tier 1 Table 2.2.1-1 that could affect the plant design or operations, there are no new accident initiators and no effect on the frequency of evaluated accidents.
2.	Does the proposed activity result in more than a minimal increase in the likelihood of UYES NO occurrence of a malfunction of a structure, system, or component (SSC) important to safety and previously evaluated in the plant-specific DCD?
	Since there is no change from the proposed changes in Tier 1 Table 2.2.1-1 that could affect the plant design or operations, there is no effect on malfunctions of structures, systems, or components. The operating conditions for the reactor coolant system and passive core cooling system are not altered.
3.	Does the proposed activity result in more than a minimal increase in the \Box YES \boxtimes NO consequences of an accident previously evaluated in the plant-specific DCD?
	The Proposed changes in Tier 1 Table 2.2.1-1 have no effect on the operation, performance, and pressure boundary integrity of the safety related equipment. Therefore, there is no increase in the calculated release of radioactive material during postulated accident conditions.
4.	Does the proposed activity result in more than a minimal increase in the YES NO consequences of a malfunction of an SSC important to safety previously evaluated in the plant-specific DCD?
	The Proposed changes in Tier 1 Table 2.2.1-1 have no effect on the design functions or reliability of the safety related equipment or other components and operation of the passive core cooling system. Therefore, there is no increase in the calculated release of radioactive material due to a malfunction of an SSC.
5.	Does the proposed activity create a possibility for an accident of a different type than YES X NO any evaluated previously in the plant-specific DCD?
	The proposed changes in Tier 1 Table 2.2.1-1 have no effect on the operation, performance, and pressure boundary integrity of the plant equipment. The response of the safety related equipment and the passive core cooling system to postulated accident conditions is not altered by the proposed changes. The proposed changes do not introduce any additional failure modes; therefore, there is no

	possibility of an accident of a different type than any evaluated previously in the DCD.	· · · · · · · · · · · · · · · · · · ·	
6.	Does the proposed activity create a possibility for a malfunction of an SSC important to safety with a different result than any evaluated previously in the plant-specific DCD?	🗌 YES 🛛] NO
	The design changes have no effect on the design functions of the safety related equipme of the passive core cooling system. There are no additional failure modes or the possib malfunction of an SSC important to safety with a different result than any evaluated pre-	ent or opera ility for a eviously.	tion
7.	Does the proposed activity result in a design basis limit for a fission product barrier as described in the plant-specific DCD being exceeded or altered?	YES 🛛] NO
	There is no change to the design function of the safety related equipment. The criteria pressure boundary integrity are not exceeded or altered.	to provide f	or
8.	Does the proposed activity result in a departure from a method of evaluation described in the plant-specific DCD used in establishing the design bases or in the safety analyses?	🗌 YES 🔯] NO
	The proposed changes in Tier 1 Table 2.2.1-1 will apply for all plants, They have no im design bases and the safety analyses.	pact on the	
	The answers to the evaluation questions above are "NO" and the proposed departure fr not require prior NRC review to be included in plant specific FSARs as provided in 10 Appendix D, Section VIII. B.5.b	om Tier 2 c CFR Part :	loes 52,
	One or more of the answers to the evaluation questions above are "YES" and the proper requires NRC review.	osed change	•
F.	IMPACT ON RESOLUTION OF A SEVERE ACCIDENT ISSUE		
	10 CFR Part 52, Appendix D, Section VIII. B.5.a. provides that an applicant for a com who references the AP1000 design certification may depart from Tier 2 information. NRC approval, if it does not require a license amendment under paragraph B.5.c. below address the criteria of B.5.c.	ibined licen , without p The questi	isee rior ons
1.	Does the proposed activity result in an impact features that mitigate severe accidents. If the answer is Yes answer Questions 2 and 3 below.	☐ YES NO	
	The systems and components identified in the DCD Subsection 1.9.5 and Appendix 19 severe accidents are not impacted by the alternate Steam and Power Conversion design.	B that mitig	gate
2.	Is there is a substantial increase in the probability of a severe accident such that a particular severe accident previously reviewed and determined to be not credible could become credible?	☐ YES NO ☐ N/A	
3.	Is there is a substantial increase in the consequences to the public of a particular severe accident previously reviewed?	YES NO	\boxtimes
	•		

.

- The answers to the evaluation questions above are "NO" or are not applicable and the proposed departure from Tier 2 does not require prior NRC review to be included in plant specific FSARs as provided in 10 CFR Part 52, Appendix D, Section VIII. B.5.c
- One or more of the he answers to the evaluation questions above are "YES" and the proposed change requires NRC review.

G. SECURITY ASSESSMENT

1. Does the proposed change have an adverse impact on the security assessment of the ☐ YES ⊠ NO AP1000.

The proposed changes in Tier 1 Table 2.2.1-1 will not alter barriers or alarms that control access to protected areas of the plant. The design changes will not alter requirements for security personnel; therefore, the proposed changes do not have an adverse impact on the security assessment of the AP1000.

5.0 REFERENCES

1. APP-GW-GL-700, AP1000 Design Control Document, Revision 15.