



FEB 20 2007

SERIAL: HNP-07-013

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
ANNUAL REPORT IN ACCORDANCE WITH TECHNICAL SPECIFICATION 6.9.1.2

Ladies and Gentlemen:

In accordance with Harris Nuclear Plant (HNP) Technical Specification 6.9.1.2, Carolina Power & Light Company, doing business as Progress Energy Carolinas, Inc., provides the following information regarding primary coolant specific activity limits for 2006.

During 2006, activity levels in the HNP primary coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131 or 100/E-bar  $\mu\text{Ci}/\text{gram}$  gross radioactivity as set forth in HNP Technical Specification 3.4.8.

If you have questions regarding this submittal, please contact me at (919) 362-3137.

Sincerely,

D. H. Corlett  
Supervisor – Licensing/Regulatory Programs  
Harris Nuclear Plant

DHC/mgw

- c: Mr. P. B. O'Bryan (NRC Senior Resident Inspector, HNP)
- Mr. C. P. Patel (NRR Project Manager, HNP)
- Dr. W. D. Travers (NRC Regional Administrator, Region II)

Progress Energy Carolinas, Inc.  
Harris Nuclear Plant  
P. O. Box 165  
New Hill, NC 27562

A001