ATTACHMENT 5

CONSUMERS ENERGY BIG ROCKPOINT

DOCKET NUMBERS 50-155 AND 72-043

TRANSMITTAL OF SURVEY PACKAGES IN SUPPORT OF BIG ROCK POINT PHASED LICENSE TERMINATION

CLASS 1 FINAL STATUS SURVEY RELEASE RECORD, 11C₁1, EAST PROTECTED AREA

October 27, 2006

37 Pages

Class 1 Final Status Survey Release Record North 11C₁1

North Radwaste Staging Area

CLIDVEY	n A			\sim 1	OCI	IDE
SURVEY	PA	LLA	AGE	LL	.USI	UKE

Final Status Survey Documentation is authorized for closure. All required reviews are complete and the evaluation of data results have satisfied the criteria established for unrestricted release.

 Signed: 10/25/06

 ESSG)

 Date: 10/25/06

 Signed: (ES Superintendent)

 Date: 10/25/06

 (RP & ES Manager)

Survey Area Requirements

Final Status Survey, Release Record North 11C₁1 North Radwaste Staging Area

Survey Description

Final Status Survey North 11C₁1 encompasses 1339 m² in the northern section of old radwaste staging area. No materials of plant origin remain in the survey area.

History

During power operations the Radwaste Staging Area was used to store, process, and prepare plant radioactive waste for offsite shipment. No materials of plant origin remain in this location. Surveys conducted following excavation and removal of foundations and subsurface components have determined that residual radioactivity does not exist in soils below grade elevation in this area (Survey 11C_{q1}1). A detailed review of the history and radiological characterization of Survey Unit North11 is provided in Appendix 2B and 2E of the LTP (License Termination Plan).

Current Radiological Status

Characterization surveys and radiological evaluations following removal of subsurface components and materials do not indicate the presence of elevated levels of residual radioactivity in this survey area. Based on operational history, process knowledge, and survey measurements, the radiological status of this survey unit is Class 1.

Post-Construction Expectations

Final Status Survey North 11C₁1 will be performed in the following activity sequence:

- 1. Walkdown: Environmental Services Survey Group (ESSG) personnel will perform a walkdown assessment to ensure survey area preparations are complete and confirm that the following post-construction expectations have been satisfied as applicable:
 - Groundwater and Surface water control is adequate
 - All construction debris has been removed from the survey area
 - The survey location status meets all applicable safety requirements
- Survey Area Isolation and Control: Control measures will be established to ensure that
 any potential ongoing decommissioning activities in adjacent locations do not impact the
 current survey area status. Isolation and control measures include postings, barriers,
 access points, and the evaluation of ongoing work activities in adjacent areas.

- 3. Survey Design and Execution: Survey design and execution will follow the Data Quality Objectives for North 11C₁1 in accordance with the survey requirements established in procedures RM-76, *Final Status Survey Design* and RM-77, *Final Status Survey Implementation*, and LTP, Chapter 5. Survey size will be based on the statistical requirements of the Sign Test for Class 1 areas with soil samples collected in random start, systematic data point locations. Surface scanning will be performed with 100% survey area coverage. This survey will be conducted in accordance with approved BRP procedures and follow the guidance of NUREG 1575.
- 4. Data Quality Assessment: Isolation and control of the survey area will be maintained until the survey Data Quality Assessment demonstrates that the regulatory requirements for unrestricted site release have been satisfied.

DATA QUALITY OBJECTIVES

Final Status Survey, Release Record North 11C₁1 North Radwaste Staging Area

STATE THE PROBLEM

The Problem:

To demonstrate that the level of residual radioactivity in Class 1 Survey Unit North 11 does not exceed the release criteria of 25 mrem/year Total Effective Dose Equivalent (TEDE) as specified in the License Termination Plan (LTP).

Stakeholders:

The primary stakeholders interested in the answer to this problem are Consumers Energy Co., and the general public as represented by the Michigan Department of Environmental Quality (MDEQ), and the US Nuclear Regulatory Commission (USNRC).

The Planning Team:

The planning team consists of members of the BRP Environmental Services Survey Group (ESSG). The primary decision maker will be the Final Status Survey Supervisor. The Final Status Survey Supervisor will obtain input from the site Construction Group and Scheduling Group for issues relating to schedule and costs.

Schedule:

Approximately five (5) working days are projected to implement the survey and to collect and analyze field data.

Resources:

The primary resources needed to determine the answer to the problem are two (2) technicians to perform fieldwork, one (1) technician to prepare the samples and conduct laboratory analyses, and two (2) survey team members to prepare and review the design, generate maps, coordinate field activities and evaluate data.

2. IDENTIFY THE DECISION

Several decisions need to be defined to address the stated problem.

Principal Study Question (1):

Does the mean concentration of residual radioactivity in the survey unit exceed the release criteria stated above?

Decision (1):

Determine whether the mean concentration of residual radioactivity in the survey exceeds the release criteria stated in the problem.

Actions (1):

Alternative actions include failure of the survey unit, remediation, or no action required.

Principal Study Question (2):

Do any areas of elevated activity in the survey unit exceed the release criteria?

The Decision (2):

Determine if any areas of elevated activity in the survey unit exceed the release criteria.

Actions (2):

Alternative actions include confirmation and investigation, performing the elevated measurement comparison (EMC), remediation, or no action required.

Principal Study Question (3):

Is the potential dose from residual radioactivity in the survey unit ALARA as stated?

The Decision (3):

Determine if the potential dose from residual radioactivity in the survey unit is ALARA. ALARA requirements for soil remediation are defined in Chapter 4 of the LTP.

Actions (3):

Alternative actions include remediation or no action required.

3. IDENTIFY INPUTS TO THE DECISION

Information Needed:

Characterization measurements are required to define the radionuclides present and determine the extent and variability of residual radioactivity in the survey area for design and implementation of the survey. Survey area classification, ALARA analysis, potential radionuclides of interest, and site-specific DCGL values are also required inputs to the decision process. The primary information required for evaluation is the analytical results of survey measurements.

Source of the Information:

The soil sample data to be used for survey development are the radionuclide-specific measurements of representative soil samples collected for radiological characterization and excavated soil surveys conducted to determine suitability for transport of excavated soil to the SVA. The soil samples obtained were judgmentally selected as a result of multiple surveys conducted during the excavation and transport process. The ALARA analysis for potential soil remediation is provided in LTP, Section 4.4. Site-specific DCGL values and BRP radionuclides of interest are defined in LTP Chapter 5, Table 5-1 and Procedure RM-76, *Final Status Survey Design*.

The survey will be conducted in accordance with applicable regulatory guidance as established in LTP Chapter 5 for Class 1 areas. Soil samples will be utilized for radionuclide-specific measurements in this evaluation.

4 BOUNDARIES OF THE STUDY

Boundaries of the Survey:

The target population for this survey is the total thickness of prepared soil in the survey area of 1339 m².

Temporal Boundaries:

Scanning and sampling in this survey unit will only be performed during daylight hours under dry weather conditions. Surface soils must be free of significant snow cover and standing water prior to surface scanning. Soils must be in a non-frozen state or fragmented for collection to satisfy BRP procedural sampling requirements. The anticipated start date for the survey is September 26, 2006.

Constraints:

Cold weather or rainy conditions may effect the operation of electronic equipment. Adverse weather conditions that include accumulations of rain or snow may limit area access and delay survey efforts.

DEVELOP A DECISION RULE

The following decision rules have been developed to define a logical process for choosing among alternative actions for the principal study questions associated with this survey area.

Decision Rule (1):

If all reported concentrations for residual radioactivity are less than the site-specific DCGL's and the unity rule has been satisfied for each sample, then the survey unit meets release criteria. No further action is required.

Decision Rule (2):

If the mean value of activity in the survey unit is greater than the DCGL, then the survey unit fails to meet the release criteria. Remediate, resurvey, and evaluate the results relative to the decision rule.

Decision Rule (3):

If the mean activity in the survey unit is less than the DCGL and any individual sample measurement exceeds this value, conduct the Sign Test and the elevated measurement comparison (EMC) per LTP, Chapter 5 and Procedure RM-76, *Final Status Survey Design*. If the EMC and the Sign Test have been satisfied then the survey unit meets the release criteria and no further action is required. If the EMC or the Sign Test has not been satisfied then remediate the area(s) of elevated activity, resurvey as appropriate, and evaluate the results relative to the decision rule.

Decision Rule (4):

If the potential dose from residual radioactivity in the survey unit is ALARA, then no further action is necessary. If the potential dose from residual radioactivity in the survey unit is not ALARA, then remediate and resurvey.

6. SPECIFY TOLERABLE LIMITS ON DECISION ERRORS

The Null Hypothesis:

It is assumed that residual radioactivity in the survey unit exceeds the release criterion.

¹ When multiple radionuclides are present the mean activity value is determined as the average of the weighted sum. The DCGL of the weighted sum is 1.

Type I Error (α):

The α error is the maximum probability of rejecting the null hypotheses when it is true. The α error is defined in the LTP at a value of 0.05 (5%) and cannot be changed to a less restrictive value unless prior approval is granted by the USNRC. The α error value of 0.05 will be used for survey planning and data assessment for this survey area.

Type II Error (β):

The β error is the probability of accepting the null hypothesis when it is false. A value of 0.05 (5%) will be used for survey planning and data assessment for this survey area.

The Lower Bound of the Gray Region (LBGR):

The LBGR is initially set at one-half the DCGL_w for this survey unit. The LBGR may be adjusted during survey design to achieve an optimum relative shift between 1.0 and 3.0.

Relative Shift (Δ/σ) :

The relative shift will be maintained within the range of 1.0 and 3.0 by adjusting the LBGR as appropriate.

7. OPTIMIZE DESIGN FOR OBTAINING DATA

Statistical Test

Sign Test:

Radionuclides of potential plant origin also present in soil as background activity resulting from fallout constitute only a small fraction of the DCGL. Therefore, the Sign Test will be used where applicable in the survey evaluation to determine if the survey area meets the requirements for unrestricted release.

Number of Samples Determined:

The number of samples required for this survey will be determined based on the relative shift as defined by the requirements of the Sign Test (LTP, Chapter 5.) and Procedure RM-76, Final Status Survey Design. The LBGR is initially set at one-half the DCGL_w and may be adjusted as necessary for optimizing the survey design to achieve a relative shift between 1.0 and 3.0. Sample point locations are to be determined using a random start, systematic square grid spacing.

Judgmental Sampling:

Co-60 is the most limiting radionuclide for identification by surface scanning; judgmental surface and subsurface core samples will be collected in any location that exceeds the scan investigation level.

Scan Coverage:

Scanning for this survey area will provide 100% coverage.

Number of Samples for Quality Control:

A minimum of 5% of the sample population will be collected for quality evaluation. These samples may include sample splits, sample recounts, or third party sample analysis. Quality analyses will be conducted as defined in LTP, Chapter 5 and Procedure RM-79, *Final Status Survey Quality Control*.

Additional Sample Analysis Requirements:

The area of soil excavation intersects the identified waterborne pathway for Tritium migration and shall require Tritium in soil analyses for a minimum of 10% of the sample population. Soil samples will be collected in the same random locations as those selected for QA/QC evaluation and sent to an independent laboratory for Tritium analysis. Data results will be provided in the survey package.

Investigation Levels:

Investigation levels defined in LTP, Chapter 5 and BRP Procedure RM-76, *Final Status Survey Design*, shall be conservatively established for this survey as shown below:

Investigation Levels for Survey North 11C₁1

Classification Scan Measurement		Soil Sample Analysis		
Class 1	> DCGL	> DCGL _w		

The investigation levels for soil sample measurements are meant to include any individual radionuclide result greater than the site-specific DCGL or where the combined radionuclide values exceed the unity rule. Co-60 is the most limiting radionuclide for identification by surface scanning; further investigation will be initiated at any location that exceeds the Co-60 Scan _{DCGL} of 1818 CPM above background as detailed in the survey design.

FINAL STATUS SURVEY DESIGN

Release Record North 11C₁1 North Radwaste Staging Area

Survey Unit Description

Survey North 11C₁1 encompasses an area of 1339 m² in the northern section of the Radwaste Staging Area. No materials of plant origin exist in this survey unit.

Soil Sample Design

Scoping Data

Scoping measurements and supporting surveys performed in the Radwaste Staging Area following removal of subsurface components and demolition debris do not indicate the presence of elevated levels of residual radioactivity in this survey area. Input data for survey design were conservatively estimated based on supporting surveys of excavated soils resulting from subsurface structure and component removal within the Protected Area.

Table 1
Input Data for Survey Design (pCi/g)

Radionuclides	Cs-137	Co-60
σ*	0.524	0.255
DCGL	11.93	3.21

^{*}Survey data detailed in Attachment 1

Sample Requirements

The number of sample data points for this survey is based on the requirements of the Sign Test. The Unity Rule is used for the presence of multiple radionuclides. The Standard Deviation of the weighted sum is described by the following:

$$\sigma = \sqrt{\left(\frac{\sigma_{\text{CS137}}}{\text{DCGL}_{\text{CS137}}}\right)^2 + \left(\frac{\sigma_{\text{CO60}}}{\text{DCGL}_{\text{CO60}}}\right)^2}$$

$$\sigma = \sqrt{\left(\frac{0.524}{11.93}\right)^2 + \left(\frac{0.255}{3.21}\right)^2}$$

$$\sigma = 0.091$$

Relative Shift

Relative Shift =
$$\frac{DCGLw-LBGR}{\sigma}$$
Relative Shift =
$$\frac{1-0.818}{0.091}$$

Relative Shift = 2.0

With α and β error levels set at 0.05 and the relative shift of 2.0, the Sign Test requires 15 sample data points (Table 5.5 NUREG 1575).

Sample Locations

Sample locations are selected in a random start, systematic square grid pattern with the southwest corner of the survey unit as origin (X=0, Y=0). Two numbers between 0 and 1 have been randomly selected and then applied to the survey unit maximum X and Y dimensions to determine the random start location as shown below:

Table 2
Random Numbers

Random #, X Axis	Random #, Y Axis
0.619105	0.748234

Survey Unit Dimensions:

X = 45 meters

Y = 30 meters

Random Start Location

X = (0.619105)(45) = 27.9 meters

With SW Corner Origin:

Y = (0.748234)(30) = 22.4 meters

Sample Spacing

As a conservative measure sample spacing will be calculated based on 18 samples for this survey. Samples are located in a systematic square grid pattern with sample spacing determined by the following:

$$L = \sqrt{\frac{A}{n}}$$

Where: A= area of survey unit, and

n = number of samples.

$$L = \sqrt{\frac{1339}{18}} = 8.6 \text{ meters}$$

With sample spacing established at 8.6 meters, 15 data points are available for this survey. Data point locations are identified in Attachment 2.

QA/QC Sampling

A minimum of 5% of the sample population and 5% of the scan survey area are required to be selected for QA/QC verification in accordance with BRP Procedure RM-79, *Final Status Survey Quality Control*. As a conservative measure, three (3) soil samples and 10% of the scan survey area will be selected for QA/QC evaluation. Data point locations for soil samples will be determined by random number selection.

The QA/QC scan starting point and track direction are also determined by random number selection. The first random data point selected will identify the scanning start point and the second random data point will determine the direction in which the scan will track. QA/QC location results are provided in Table 3 below:

Table 3
Random Numbers Generated for QA/QC

ICIA/CICE SOIL	Random Sample Number	Verification Scan	Random Sample Number
Split Sample:	3	Start Point:	6
Sample Recount:	- 6	Scan Toward:	13
Sample Recount:	12	Scan Area Requirement:	134 m ²

Surface Scanning

The coverage requirement for surface scanning in this Class 1 area is 100%. The Scan $_{MDC}$ has been established at fractional values of the $DCGL_{W}$ for typical background activity levels at Big Rock Point. Scan $_{MDC}$ values for varying backgrounds are provided in Attachment 3. The investigation level for identification of potential areas of elevated activity in this survey area will be the Scan $_{DCGL}$ as defined by the following:

Scan
$$_{DCGL}$$
 = Detector Rating $\frac{CPM}{uR/hr}$ * Exposure Model $\frac{uR/hr}{pCi/g}$ * $DCGL_w$

Scan _{DCGL} for Co-60 = 1818 CPM

Scan _{DCGL} for Cs-137 = 3518 CPM

Where:¹ Detector Rating =
$$\frac{1200 \text{ CPM}}{\text{uR/hr}} \text{Cs} - 137$$
 and $\frac{565 \text{ CPM}}{\text{uR/hr}} \text{Co} - 60$

Exposure Model =
$$\frac{1.229 \, uR/hr}{5 \, pCi/g} \, Cs - 137$$
 and $\frac{5.029 \, uR/hr}{5 \, pCi/g} \, Co - 60$

 $DCGL_w = 11.93 pCi/g Cs-137 and 3.21 pCi/g Co-60$

The DCGL_w for Co-60 is the most limiting value for scanning measurements performed to identify areas of potentially elevated activity. Scanning conducted for this survey will assume all residual radioactivity to originate from Co-60 and the instrument response at the Co-60 DCGL_w (1818 cpm) will be used as the scanning investigation level for FSS North 11C₁1.

¹ These values established in EA-BRP-SC-0201, Nal Scanning Sensitivity for Open Land Survey.

Attachment 1

Design Data - FSS North 11C₁1 Protected Area Supporting Surveys

Survey No.	Sequence No.	Cs-137 Activity (pCi/g)	Co-60 Activity (pCi/g)
HH060705	16538	1.26	0.66
HH060705	. 16539	0.06	0.06*
HH060705	16540	1.05	0.66
TB062805	16755	. 1.16⇒	- 3: 0.27
TB062805	16756	0.47	0.15*
TB062805	16774	0.19	;;


Mean: 0.698 Std Dev: 0.524 0.352

0.255

^{*} Measurement system MDA - Co-60 not identified in this sample

Attachment 2

Soil Sample Locations - Survey North 11C₁1 North Radwaste Staging Area



Survey	Unit	North	11C1	_1

Sample No.	Grid Number	X Coord.	Y Coord.	Sample No.	Grid Number	X Coord.	Y Coord.
1	436	7.1	5.2	9	445	5.7	3.8
2	446	5.7	5.2	10	435	7.1	3.8
3	451	4.3	5.2	11	434	7.1	2.4
4	456	2.9	5.2	12	444	5.7	2.4
5	461	1.5	5.2	13	449	4.3	2.4
6	460	1.5	3.8	14	454	2.9	2.4
7	455	2.9	3.8	15	459	1.5	2.4
8	450	4.3	3.8				

Sample spacing is 8.6 meters

Attachment 3
Scan MDC In Varying Backgrounds

				CPM	MDER	uR/hr	Scan MD	C pCi/g
Background	ď'	1	Si	MDCR _{surveyor}	Cs-137	Co-60	Cs-137	Co-60
2000	2.48	4	28.64	607.47	0.51	1.08	2.06	1.07
2500	2.48	4 %	32.02	679.18	0.57	1.20	2.30	1.20
3000	2.48	4	35.07	744.00	0.62	1.32	2.52	1.31
3500	2.48	4	37.88	803.61	0.67	1.42	2.72	1.41
4000	2.48	4	40.50	859.10	0.72	1.52	2.91	1.51
4500	2.48	4	42.95	911.21	0.76	1.61	3.09	1.60
5000,	2.48	4	- ,45.28	960.50	0.80	1.70	3.26	£1.69
5500	2.48	4	47.49	1,007.38	0.84	1.78	3.42	1.77
6000	2.48	4	49.60	1,052.17	0.88	1.86	3.57	1.85
6500	2.48	4	51.63	1,095.14	0.91	1.94	3.71	1.93
7000	2.48	4	53.57	1,136.48	0.95	2.01	3.85	2.00
7500	2.48	4	55.45	1,176.37	<i>3</i> 0.98 ∞ 3	2.08	3.99	2.07
8000	2.48	4	57.27	1,214.95	1.01	2.15	4.12	2.14
8500	2.48	4	59.04	1,252.34	1.04	2.22	4.25	2.20
9000	2.48	4	60.75	1,288.65	1.07	2.28	4.37	2.27
9500	2.48	4	62.41	1,323.96	1.10	2.34	4.49	2.33
10000	2:48	4	64.03	d,1,358:35 €	1.13	2.40	4.61	2.39
10500	2.48	4	65.61	1,391.90	1.16	2.46	4.72	2.45
11000	2.48	4	67.16	1,424.65	1.19	2.52	4.83	2.51
11500	2.48	4	68.67	1,456.67	1.21	2.58	4.94	2.56
12000	2.48	4	70.14	1,488.00	1.24	2.63	5.04	2.62
12500	2:48	4	71.59	1,518.68	1.27	<i>-</i> 2.69 ∵	5.15	×2.67
13000	2.48	4	73.01	1,548.76	1.29	2.74	5.25	2.73
13500	2.48	4	74.40	1,578.26	1.32	2.79	5.35	2.78
14000	2.48	4	75.77	1,607.22	1.34	2.84	5.45	2.83
14500	2.48	4	77.11	1,635.67	1.36	2.89	5.55	2.88
15000	2.48	4	78.42	1,663.63	1.39	2.94,	5.64	2.93
Modeled E	Exposure	(uR/hr) @) 5 pCi/g					
	Cs-137	1.23E+00						
	Co-60	5:03E+00						

Attachment 4

Area Factors for Open Land Survey Evaluation

04		Calculated Area Factors at Time of Peak Dose							
Contaminated Area (m²)	H-3	Mn-54	Fe-55	Co-60	Sr-90	Cs-137	Eu-152	Eu-154	Eu-155
8094	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
4047	1.00	1.01	1.00	1.01	1.00	1.02	1.02	1.01	1.02
2024	1.00	1.03	1.00	1.03	1.00	1.03	1.03	1.03	1.03
1012	1.35	1.04	1.00	1.04	1.00	1.04	1.05	1.04	1.04
506	2.91	1.09	1.98	1.08	1.98	1.13	1.07	1.07	1.06
253	6.05	1.14	3.95	1.13	3.94	1.20	1.11	1.11	1.09
126	12.4	1.20	7.93	1.20	7.87	1.29	1.17	1.16	1.14
63	24.9	1.30	15.8	1.30	15.6	1.41	1.27	1.26	1.23
32	49.2	1.49	31.2	1.49	30.5	1.62	1.44	1.45	1.39
16	98.9	1.78	62.0	1.78	59.9	1.93	1.72	1.73	1.63
8	198	2.38	123	2.38	117	2.58	2.30	2.31	2.14
4	397	3.61	243	3.62	230	3.91	3.49	3.52	3.19
2	794	5.68	473	5.75	452	6.14	5.48	5.55	4.90
1	1590	9.57	905	9.73	887	10.3	9.24	9.39	7.88

RM-76-5 FINAL STATUS SURVEY APPROVAL AND AUTHORIZATION FOR IMPLEMENTATION

Survey Code North 11	C ₁ 1					
			•			
				٠		
,						
Survey Area Description:						
Final Status Survey North	n 11C ₁ 1 encompasses 1	1339 m² in the sou	thern section of	the old		
radwaste staging area.	No materials of plant orig	gin remain in this (Class 1 survey u	<u>nit.</u>		
	·					
		·	·			
The survey area is author	ized for Final Status Su	rvey Implementati	on.			
A Komis L	9/22/06					
Designed by	Date					
J:00 € 200	9/25/06	·				
Technical Review by	Date					

RM-77-1 SURVEY IMPLEMENTATION CHECKLIST Page 1 of 3

<u>Step</u>		Initial	<u>Date</u>
1.0	PREPARATION FOR SURVEY North 11C Survey #		: :
1.1	Survey Area Status:		
	 Final Status Survey Design has been approved for implementation (see RM-76-5, Final Status Survey Approval and Authorization for Supplementation). 		
	 Survey area walkdown complete Survey area determined ready for FSS Decommissioning activities that may impact the environmental status of the survey area have been completed. 		
	 Survey area environment is controlled by barriers and postings or other approved method to restrict access. 	ESSG	09/25/06
<u>/</u>	 Survey area has been turned over to the Environmental Services Survey Group (ESSG) in acceptable condition for FSS. 	ESSG	9/25/06
1.2	Field Preparation:		
<u>J</u>	 a. Survey unit boundaries delineated (Step 6.1.1) b. Statistical soil samples predetermined in the survey design are located and marked within the survey unit. (Step 6.1.2) 		
	c. Soil sample locations verified (Step 6.1.2.c) d. Instruments and equipment have been collected and calibrated for data measurement and collection (Step 6.1.3)	J.R.	09/210/06
<u> </u>	e. Field documentation is prepared (Step 6.1.4)	ESSG	

RM-77-1 SURVEY IMPLEMENTATION CHECKLIST Page 2 of 3

		<u>Initial</u>	Date
2.0	DATA COLLECTION		
2.1	Soil Survey:		
	All soil samples collected and controlled (Step 6.2.1).	ESSG	<u>व्याचित्र</u>
2.2	Surface Scan:		
	Surface Scan complete. Action response requirements have been conducted on any identified areas exceeding the investigation level (Step 6.3).	OJA ESSG	<u> </u>
2.3	Judgmental Soil Samples:		
NA	 a. Judgmental soil samples have been collected and controlled (Step 6.2.3). b. Deep core profiles performed in areas identified to contain elevated residual activity (Step 6.2.3). 	AL ESSG	09/26/06
3.0	SAMPLE PREPARATION AND LABORATORY ANALYSIS		
3.1	Sample Preparation (Step 6.4.1):		
	 a. Soil samples are homogenous b. Soil samples are visibly dry prior to packing c. Non-soil materials have been removed from sample d. Soil samples have been transferred to one-liter Marinelli containers and are labeled and sealed. 	FSSG	09/29/04

Reviewed by

Revision 2 Page 10 of 12

RM-77-1 SURVEY IMPLEMENTATION CHECKLIST Page 3 of 3

3.2 Laboratory Analysis:

Isotopic analyses are complete. The spectroscopy report requires a signature of completion by the laboratory analyst and a signature of evaluation documenting that a second level review has been performed (Step 6.4.2).

3.3 Sample Control and Documentation:


Chain of custody documentation exhibits control of soil samples (Step 6.4.3).

ATTACHMENT RM-59-1 SAMPLING AND ANALYSIS REPORT

Date: 09-26-2006	Time: 1600	Lo	cation: N	lorth 11C₁1		ech: SSO/JHV	V/LED/WMH
	SURVEY ID	ENTIFICAT	ION / D	ESCRIP			
Survey North 11C ₁ 1 enc					in the no	orthern s	ection of the
old radwaste staging are							
						•	
							·
		SURVEY	TYPE			•	•
Survey Type:	Characteri			(Motive)			- · · · · · · · · · · · · · · · · · · ·
	Remediation			(**************************************			
	X Final		Scan	(Static)			
				ching and D	Digging (u	use RM-	59-4)
		SURVEY [
Sample Collection:	Judgmental	Random		ystematic		rae Con	tainer Assay
Scan Coverage: 100			<u> </u>	ysternauc		rge com	lainei Assay
Scall Coverage. 100	_/6		<u> </u>				
		ANALY					
Inst.SN/Cal Due <u>186192/0</u>		DAILY CHECK		_SAT _		JNSAT	INIT: sso
Inst.SN/Cal Due <u>186194/0</u>		DAILY CHECK		_SAT _		JNSAT	INIT: LED
Inst.SN/Cal Due <u>186201/0</u>		DAILY CHECK		_SAT _		JNSAT	INIT: <u>wmh</u>
Inst.SN/Cal Due <u>189086/0</u>		DAILY CHECK		_SAT _		JNSAT	INIT: JHW
Inst.SN/Cal Due Det. # 6		DAILY CHECK		_SAT _		JNSAT	INIT: <u>JP</u>
Investigation of Unidentifi			X	_SAT _		INSAT	INIT: <u>JLR</u>
Minimum Detectable Acti	vity (Section 5.3.	.2)	X	SAT		INSAT	INIT: JLR
		COMME	NTS				
Survey North 11C ₁ 1 was pe	erformed in a rand			tematic sam	pling patt	ern with	samples
collected at 15 data point lo	ocations. Laborato	ory analyses did	not identi	fy residual r	adioactivi	ty above	trace levels of
the DCGL value. Surface scanning identified no areas of elevated residual radioactivity. The results of the QA/QC							
verification scan (10%) were consistent with the findings of the primary survey scan.							
			<u></u>				
					<i></i>		
Technician Signature States Confer of Miller Date: 9/29/06							
Second Level Review	11/1/	70				-	,
Signature:	Maris	[E.	Date: 6	0/24/	06

Soil Sample Activity Summary

Release Record North 11C₁1 North Radwaste Staging Area




Sample	024#	X	Υ	Cs-137	(pCi/g)	Co-60	(pCi/g)
No.	Grid#	Coord.	Coord.	Activity	MDA	Activity	MDA
1	436	7.1	5.2	0.1070		*0.0060	0.0486
2	446	5.7	5.2	0.1581	"我看到这个人 "	*0.0456	0.0669
3	451	4.3	5.2	0.0462	STREET, STATE	*0.0188	0.0553
4	456	2.9	5.2	0.0580		*0.0062	0.0451
5	461	1.5	5.2	*0.0146	0.0505	*-0.0118	0.0561
6	460	1.5	3.8	0.0588		*0.0350	0.0715
7	455	2.9	3.8	0.0606		*0.0208	0.0601
8	450	4.3	3.8	*0.0177	0.0472	*0.0045	0.0506
9	445	5.7	3.8	0.0690	Tall Park Street	*0.0146	0.0626
10	435	7.1	3.8	0.0736		*0.0106	0.0520
11	434	7.1	2.4	0.0780	Extrapalation.	*-0.0113	0.0407
12	444	5.7	2.4	0.0457		*0.0092	0.0469
13	449	4.3	2.4	*0.0041	0.0394	*-0.0218	0.0204
14	454	2.9	2.4	*-0.0077	0.0341	*0.0287	0.0616
15	459	1.5	2.4	0.0504		*0.0033	0.0508

^{*}Forced-count values

Surface Scan Summary

Release Record North 11C₁1 North Radwaste Staging Area



RED Values are Average Mobile Scan General Area Activity (kcpm)
BLUE Values are Average Verification Scan General Area Activity (kcpm)
GREY Values are Average General Background Area Activity (kcpm)

Primary Scan:

Technician Signature: 🙎

Date: <u>9-26-06</u> Time: /400

QC Verification Scan: __/O %

Technician Signature: War Jus

Date: <u>09-26-06</u> Time: <u>4500</u>

RM-72-1 CHAIN-OF-CUSTODY RECORD

Sample Number	Sampling Location	Date	Time	Final Disposition of Sample
\	11C,1 North	9.26.06	1356	locked permenent storage
7		9.20.06	1357	
3		9.24-06	1359	
3 501:+		9.24.06	1359	
4		9.26.00	1400	
5		9.26.06	1401	
6 2		9.26.00	1401	
7		9.2606	1402	
8		9.26.06	1402	
9	1	9.26.00	1403	
10	/	9.26.06	1404	. \
1		9.26.06	1405	
12 R		9.26.06	1406	
13		9.2606	1407	
14		9.26.06	1407	
15	\checkmark	9.26.De	1408	
		.]		
	·			

(Samples may be analyzed and stored, shipped for offsite evaluation or analyzed and disposed of.)

1. Relinquished by: Jub. stor.	Date 9-26-06	Time 1428	Received in good condition by:
2. Relinquished by:	Date 9-29-00	Time	Received in good condition by:
3. Relinquished by:	Date	Time	Received in good condition by:
4. Relinquished by:	Date	Time	Received in good condition by:

RM-78-3 DATA ASSESSMENT REPORT Page 1 of 8

FINAL	STATUS SURVEY: North 1/C,	
0.1	DATA VERIFICATION	
.1	Data Acceptance	
	Review the Implementation Checklist (RM-77-1) to verify and control measures were executed prior to FSS and a	•
	Review RM-77, Final Status Survey Implementation, to vertechniques, and survey activities required for FSS have laccordance with the appropriate procedures.	•
2	Field QC Records:	
	Review all assessments, Condition Reports and audits to identified issues have been resolved.	ensure that
	Comments:	
	Verify scan instrumentation was in calibration and the QC were performed prior to and after surveys.	Source checks
	Verify daily QC source checks for Canberra gamma spec properly logged prior to soil sample analysis.	troscopy detector
	Review Verification:	
<u>/</u>	Verify that the Data Quality Objectives are complete.	
	Verify that the survey design has been technically reviewe	ed.

RM-78-3 DATA ASSESSMENT REPORT Page 2 of 8

	Verify that gamma spectroscopy results have received a technical review.
	Verify the Sample and Analysis Report (RM-59-1) is completed and reviewed.
Data Ver	ification Completed: Yes No
Commen	ts
	Assessor Date

RM-78-3 DATA ASSESSMENT REPORT Page 3 of 8

2.0	DATA	VAL	IDAT	ION
-----	------	-----	-------------	-----

2.1 Documentation Review:

	Perform documentation review for quality control purposes data collected is complete and appropriate for use as defir design. Documentation includes:	
	Field measurement records Chain-of-custody Quality Control (QC) measurement records Current qualification of survey personnel Corrective Action Reports Data inputs (laboratory spectroscopy) Sample preparation techniques	
2.2	Detection Limit Review:	
-	Scan MDCs are below established site DCGLs.	
	Forced-count values are assigned as necessary will detected in a sample.	nen activity is not
	Minimum Detectable Concentration (MDC) values of spectroscopy are below established DCGLs.	of gamma
2.3	Quality Control (QC) Data Review:	
	Quality Control (QC) data results have received require are complete and consistent.	uired reviews and
•	Results of judgmental samples have been reviewed	l and evaluated.
,	Review to ensure that the analytical results of judgmont impact the evaluation for unrestricted release of	

RM-78-3 DATA ASSESSMENT REPORT Page 4 of 8

2.4	Qua	lification of Data:
	the s	stical radionuclide-specific measurements for completeness. Evaluate survey for determination of data usability and confirm that sufficient ified data are present for the decision process.
	a.	Total number of statistical samples planned for the survey:
	b.	Total number of statistical samples determined as valid:
	C.	Calculate % Completeness: $\frac{b \times 120}{a} = \frac{120\%}{}$
		Qualified data are ≥100% completeness and are sufficient to support the Sign Test requirement for determination of unrestricted release.
Data Va Commer		Completed: Yes No
		John Led 10/24/06 Assessor Date

RM-78-3 DATA ASSESSMENT REPORT Page 5 of 8

3.0	DATA	QUALITY ASSESSMENT	
3.1	Reviev	v the DQOs and Survey Design:	
		Confirm that all inputs to the decision have been reviewed and are complete.	
		Verify that boundaries or constraints identified in the survey area have not affected the quality of the data.	
		Review the Statement of Hypothesis and confirm that it remains relevant.	
		Confirm that Type I and Type II error limits are consistent with DQO	•
		Confirm that the survey design is consistent with DQOs and that the appropriate number of data points were obtained.	;
3.2	Prelimi	nary Review:	
3.2.1	Prelimi	nary Evaluation:	
	MA	Quality Assessment (QA) reports consistent with procedure RM-79, Final Status Survey Quality Control.	
	<u></u>	Survey is of sufficient intensity to satisfy classification requirement.	
		Potential trends of radioactivity levels in the survey area do not impact a decision for unrestricted release.	
		Comments:	_
			_
		·	_

RM-78-3 DATA ASSESSMENT REPORT Page 6 of 8

3.2.2	Calculate Basic Statistical Quantities:	
*.	a. Number of qualified data points	_15
	b. Calculation of the Mean	0.0080 (SOR)
	c. Calculation of the Median	0.0083 (sof)
	d. Calculation Standard Deviation	0.0078 (SOR)
	Attach graphic representation of the measurements exceed 50% of the Sample QA/QC measurements cor	DCGL.
3.3	Statistical Evaluation:	
	NOTE: If all measurement data are less testing in not required and the sequirement for unrestricted rele	survey unit meets the regulatory
•	All survey measurements are below	the DCGL _w .
3.3.1	Verify Assumptions of the Survey Design	
	Review the posting plot to verify the independence. Spatial trends must to further assessment.	
	Review to verify dispersion symmet data must be investigated for cause assessment.	

RM-78-3 DATA ASSESSMENT REPORT Page 7 of 8

	Review the dataset standard deviation and range for data variance. Questionable data must be investigated for cause and documented prior to further assessment. Verify that the data exhibits adequate power and confirm that the sample size is sufficient to satisfy the DQOs.
3.4	Draw Conclusions from the Data:
3.4.1	Investigation Levels and Response Actions
	Determine if data results have exceeded any investigation level. Document findings. In investigation levels exceeded
3.4.2	Evaluation for Unrestricted Release
	Select applicable conclusion:
	Survey area <u>acceptance criteria met</u> and survey area satisfies the requirements for unrestricted release:
	All concentrations are less than the DCGL _w . The Null Hypothesis is rejected.
	The mean concentration of the survey area is below the DCGL _w but individual measurements in the survey unit exceed the DCGL _w . The Sign Test and EMC evaluation are successful and the Null Hypothesis is rejected.

RM-78-3 DATA ASSESSMENT REPORT Page 8 of 8

Ma Survey area acceptance criteria not met and survey area fails to

satisfy the requirements for unrestricted release:
The mean concentration in the survey area exceeds the DCGL _w . and the null hypothesis is confirmed.
The mean concentration of the survey area is below the DCGL but individual measurements in the Unit exceed the DCGLw The Sign Test and EMC evaluation are unsuccessful and the null hypothesis is confirmed.
Data Quality Assessment Completed: (Yes) No
Comments Statistical quantities are provided in
attachment!

Assessor Date
Reviews:
Technical Review Date 10 25 06
10-25-06

RM-78-3, Attachment 1 Statistical Quantities

Release Record North 11C₁1 North Radwaste Staging Area

Sample	Cs-137	Co-60	Weighted	**Weighted Sum		
Number	(pCi/gm)	(pCi/gm)	Sum (SOR)	<dcglw?< th=""><th>DCGL-W. Sum</th><th>Sign</th></dcglw?<>	DCGL-W. Sum	Sign
1	0.1070	0.0060	0.0108	yes	0.9892	+1
2	0.1581	0.0456	0.0275	yes	0.9725	+1
3	0.0462	0.0188	0.0097	yes	0.9903	+1
4	0.0580	0.0062	0.0068	yes	0.9932	+1
5	0.0146	-0.0118	-0.0025	yes	0.9975	+1
6	0.0588	0.0350	0.0158	yes	0.9842	+1
7	0.0606	0.0208	0.0116	yes	0.9884	+1
8	0.0177	0.0045	0.0029	yes	0.9971	+1
9	0.0690	0.0146	0.0103	yes	0.9897	+1
10	0.0736	0.0106	0.0095	yes	0.9905	+1
11	0.0780	-0.0113	0.0030	yes	0.9970	+1
12	0.0457	0.0092	0.0067	yes	0.9933	+1
13	0.0041	-0.0218	-0.0064	yes	0.9936	+1
14	-0.0077	0.0287	0.0083	yes	0.9917	+1
15	0.0504	0.0033	0.0053	yes	0.9947	+1

Std. Dev	0.0416	0.0179	0.0078
Mean	0.0556	0.0106	0.0080
Median	0.0580	0.0092	0.0083

Number of Positive Differences (S+):

n/a

Critical Value, k, Table I.3 of Marssim:

n/a

S+ > than k?:

n/a

Survey Unit Pass or Fail:

**Pass

*Note: Forced-Count values are used for samples with activity levels below the MDA.

**Note: If all measurement data are less than the DCGL w, then the Sign Test is not required.

RM-79-1 **FSS QUALITY CONTROL EVALUATION RESULTS**

FSS Package # North // C, / QC Package # North // C, /	
--	--

QC Measurement Type	Acceptance Criteria Met*?	Reference
1. Replicate Scan	Yes// No	Step 5.1.3
2. Sample Recounts		Step 5.1.4.1
a. In-house	(Yes) No	
MA b. Third party	Yes / No	
3. Split Samples	 	Step 5.1.4.2
c. In-house	Yes No	
<u>NA</u> d. Third party	Yes / No	

If Acceptance Criteria is not met, completion of Attachment RM-79-2, FSS Quality Control Investigation Results, is required.

Comments: Sample =	# 3 = QA/OC Sp	lit Sample #	· - /
Medunts	i. J. an ac espa	2. Jurgee +	
	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	
Reviews:	1=/25/06 Date		
Technical Review	10/25/06 Date		

QA Verification Sample Recount Analysis

Date:

9/26/2006

QA:

North 11C₁1 North Radwaste Staging Area

Type:

Sample Recounts

Lab:

In- House

Table 1

Acceptance Criteria					
Resolution	Ratio				
<4	N/A				
4-7	0.5-2.0				
8-15	0.6-1.66				
16-50	0.75-1.33				
51-200	0.8-1.25				
>200	0.85-1.18				



В

D E

			Α	В	С	D	E	F	G	
Sample	Radionuclide	BRP Result Below MDA	BRP Results (pCi/g)	BRP % Error (Sigma)	BRP Resolution	Acceptance Ratio (Table 1)	Recount Result Below MDA	Recount Results (pCi/g)	Comparison Ratio F/A	Results in Agreement Compare G with D)
6	Co-60	. <	0.0715	n/a	n/a	n/a	<	0.0491	0.69	YES
6	Cs-137		0.0588	19.61	5.10	0.5-2.0		0.0519	0.88	YES
12	Co-60	<	0.0469	n/a	n/a	n/a	<	0.0565	1.20	YES
12	Cs-137		0.0457	29.81	3.35	n/a		0.0465	1.02	YES
	*									
·										
	-									

Resolution C = $\frac{A}{(A)(B/100)}$

*Note Results are considered in agreement for MDA and near-MDA measurement comparisons Results fthat fail agreement must be investigated per RM-79.

< Indicates results less than the MDA.

QA Verification Split Sample Analysis

Date:

9/26/2006

QA:

North 11C₁1 North Radwaste Staging Area

Type:

Split Sample

Lab:

In-House

Table 1

Acceptance Criteria					
Resolution	Ratio				
<4	N/A				
4-7	0.5-2.0				
8-15	0.6-1.66				
16-50	0.75-1.33				
51-200	0.8-1.25				
>200	0.85-1.18				



			Α	В	C	ע	E	F	<u>G</u>	
Sample	Radionuclide	BRP Result Below MDA	BRP Results (pCi/g)	BRP % Error (Sigma)	BRP Resolution	Acceptance Ratio (Table 1)	Split Results Below MDA	Split Results (pCi/g)	Comparison Ratio F/A	Results in Agreement Compare G with D)
3	Co-60	'	0.0553	n/a	n/a	n/a	<	0.0531	0.96	YES
3	Cs-137		0.0462	33.33	3.00	n/a	<	0.0574	1.24	YES
									· · · · ·	
										
				***************************************	<u> </u>					
					<u> </u>					
	·									
·										
							<u> </u>			

Resolution $C = \frac{A}{(A)(B/100)}$

< Indicates results less than the MDA.

^{*}Note Results are considered in agreement for MDA and near-MDA measurement comparisons Results fihat fail agreement must be investigated per RM-79.

Tritium in Soil Data Results Final Status Survey North 11C₁1

Sample Number	Tritium in Soil pCi/q
3	0.056
. 6 .	0.039
12	0.027

Mean:

0.0407

Median:

0.0390

St. Dev:

0.0146

Note: The DCGL for Tritium is 327 pCi/g. Sample results are less than 0.02% of the DCGL



700 Landwehr Road • Northbrook, IL 60062-2310 ph. (847) 564-0700 • fax (847) 564-4517

Mr. David W. Parish Big Rock Point 10269 US-31 North Charlevoix, MI 49720 LABORATORY REPORT NO.

DATE:

SAMPLES RECEIVED: PURCHASE ORDER NO: 8022-100-246 10-06-2006 10-02-2006

Below are the results of the analyses for tritium on three soil samples.

Excavated Soil Survey: NORTH, 11C₁-1

Sample Description	Collection Date	Lab Code	Concentration (pCi/g of soil) H-3	MDA (pCi/g of soil)
3	09-26-06	BRSO-6706	0.056 ± 0.019	< 0.027
6	09-26-06	BRSO-6707	0.039 ± 0.011	< 0.015
12	09-26-06	BRSO-6708	0.027 ± 0.007	< 0.010

The error given is the probable counting error at 95 % confidence level. The less than, (<), value is based on 4.66 sigma counting error for background sample.

Sincerely,

Branie Gnoblas

Bronia Grob, Laboratory Manager

Tony Coorlim, **Quality Assurance**