



## U.S. NUCLEAR REGULATORY COMMISSION

# STANDARD REVIEW PLAN

### 5.2.5 REACTOR COOLANT PRESSURE BOUNDARY LEAKAGE DETECTION

#### REVIEW RESPONSIBILITIES

**Primary -** Organization responsible for the review of reactor coolant pressure boundary leakage detection.

**Secondary -** None

#### I. AREAS OF REVIEW

The reactor coolant pressure boundary (RCPB) leakage detection systems are designed to detect and, to the extent practical, identify the source of reactor coolant leakage. Safety analysis report (SAR) sections concerning system design are reviewed for the systems' capability to meet the requirements of General Design Criteria (GDC) 2 and 30.

The specific areas of review are as follows:

1. Whether the system can identify, to the extent practical, the location of the source of reactor coolant leakage.
2. Whether the system can separately monitor and collect leakage from both identifiable and unidentifiable sources.
3. Whether the system has adequate indicators and alarms for each leakage detection system in the main control room and readily permits interpretations of indicators related to leak rates.
4. Whether the system monitors systems connected to the RCPB for inter-system leakage.

Revision 2 - March 2007

---

### USNRC STANDARD REVIEW PLAN

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to [NRR\\_SRP@nrc.gov](mailto:NRR_SRP@nrc.gov).

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov). Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML070610277.

---

5. Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC). For design certification (DC) and combined license (COL) reviews, the staff reviews the applicant's proposed ITAAC associated with the structures, systems, and components (SSCs) related to this SRP section in accordance with SRP Section 14.3, "Inspections, Tests, Analyses, and Acceptance Criteria." The staff recognizes that the review of ITAAC cannot be completed until after the rest of this portion of the application has been reviewed against acceptance criteria contained in this SRP section. Furthermore, the staff reviews the ITAAC to ensure that all SSCs in this area of review are identified and addressed as appropriate in accordance with SRP Section 14.3.
6. COL Action Items and Certification Requirements and Restrictions. For a DC application, the review will also address COL action items and requirements and restrictions (e.g., interface requirements and site parameters).

For a COL application referencing a DC, a COL applicant must address COL action items (referred to as COL license information in certain DCs) included in the referenced DC. Additionally, a COL applicant must address requirements and restrictions (e.g., interface requirements and site parameters) included in the referenced DC.

### Review Interfaces

Other SRP sections interface with this section as follows:

1. Sections 3.2.1 and 3.2.2: review of the acceptability of the seismic and quality group classifications for system components.
2. Sections 3.9.1 through 3.9.3: review whether components and piping are designed in accordance with applicable codes and standards.
3. Section 3.10: review of the seismic qualification of Category I instrumentation of mechanical and electrical equipment.
4. Section 3.11: review of the environmental capability of system portions to perform their design safety functions in abnormal, accident, and post-accident environments.
5. Section 6.2.4: review of system containment isolation capability.
6. Section 6.6: review of whether inservice inspection requirements are met for system components and review of the compatibility of construction materials with service conditions.
7. Section 7.5: review of the adequacy of the design, installation, testing, and inspection of electrical components (sensing and control) necessary for proper operation.
8. Section 8.3: review of the adequacy of the design, installation, testing, and inspection of electrical components (power) necessary for proper operation.
9. Chapter 16: review for technical specifications.
10. Chapter 17: review for quality assurance.

The specific acceptance criteria and review procedures are contained in the referenced SRP sections.

## II. ACCEPTANCE CRITERIA

### Requirements

Acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

1. GDC 2, as it relates to SSC being designed to withstand the effects of natural phenomena, such as earthquakes, tornadoes, hurricanes, floods, seiches, and tsunami without loss of capability to perform their safety functions.
2. GDC 30, as it relates the components which are part of the RCPB being designed, fabricated, erected, and tested to the highest quality standards practical. Means shall be provided for detecting and, to the extent practical, identifying the location of the source of reactor coolant leakage.
3. 10 CFR 52.47(b)(1), which requires that a DC application contain the proposed inspections, tests, analyses, and acceptance criteria (ITAAC) that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, a plant that incorporates the design certification is built and will operate in accordance with the design certification, the provisions of the Atomic Energy Act, and the NRC's regulations;
4. 10 CFR 52.80(a), which requires that a COL application contain the proposed inspections, tests, and analyses, including those applicable to emergency planning, that the licensee shall perform, and the acceptance criteria that are necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed and the acceptance criteria met, the facility has been constructed and will operate in conformity with the combined license, the provisions of the Atomic Energy Act, and the NRC's regulations.

### SRP Acceptance Criteria

Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are as follows for the review described in this SRP section. The SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.

1. For GDC 2, acceptance is based on the guidelines of RG 1.29, Positions C.1 and C.2.
2. For GDC 30, acceptance is based on meeting the guidelines of RG 1.45.

### Technical Rationale

The technical rationale for application of these acceptance criteria to the areas of review addressed by this SRP section is discussed in the following paragraphs:

1. GDC 2 requires that safety-related SSCs be designed to withstand the effects of natural phenomena, including earthquakes, without loss of capability to perform intended safety functions. The RCPB leakage detection system detects leakage after an earthquake for

an early indication of degradation so that corrective action can be taken before such degradation becomes severe enough to result in a leak rate greater than the capability of the makeup system to replenish the coolant loss. RG 1.29 describes an acceptable method of identifying and classifying system portions that should be designed to withstand the effects of a safe shutdown earthquake. Application of GDC 2 and RG 1.29 to the RCPB leakage detection system ensures that plant operators have the capability to detect and respond to RCPB leakage after an earthquake. The prompt detection of, and response to, RCPB leakage after an earthquake reduces the possibility of a severe loss-of-coolant accident.

2. GDC 30 requires that systems be provided for detecting and, to the extent practical, identifying the location of the source of reactor coolant leakage. The RCPB leakage detection system detects and identifies RCPB leakage. RG 1.45 describes acceptable methods for implementing GDC 30 with respect to the selection of RCPB leakage detection systems. Compliance with GDC 30 and the guidance in RG 1.45 ensure that operators have an early indication of RCPB degradation, thus minimizing the likelihood that an RCPB leak may go undetected and result in a severe loss-of-coolant accident.

### III. REVIEW PROCEDURES

The reviewer will select material from the procedures described below, as may be appropriate for a particular case.

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the applicant's evaluation of how the proposed alternatives provide an acceptable method of complying with the relevant NRC requirements identified in Subsection II.

For the construction permit review, the review should determine whether the design criteria and bases and the preliminary design as set forth in the preliminary SAR meet the acceptance criteria of subsection II of this SRP section.

For an operating license review, the review should verify whether the initial design criteria and bases are implemented appropriately in the final design as set forth in the final SAR.

Upon request from the primary reviewer, the coordinating reviewers provide input for the areas of review stated in subsection I of this SRP section. The primary reviewer uses such input as required to complete the review procedures.

1. The reviewer verifies whether identified leakage is collected in tanks or sumps where its rate of accumulation is monitored for an identified leak rate. The reviewer should establish whether the leakage is collected and monitored to prevent it from masking unidentified leaks.
2. The reviewer verifies whether the provisions for collecting, detecting, and monitoring unidentified leakage are separate from those for identified leakage. The floor drainage system is reviewed for whether such leakage flows readily to the sump or tank for collection and is not held up in any "reservoirs." The containment air coolers are reviewed for whether leakage from "hot" systems flashing into water vapor is condensed readily and whether the condensate flows directly to the sump.

3. The reviewer determines whether the applicant identifies all potential inter-system leakage paths and whether the instrumentation for each path is appropriate and adequate for positive indication of inter-system leakage in the affected system and provides adequate monitoring capability so that the limits assumed in the accident analyses are not exceeded. Inter-system leak detection methods include radioactivity, pressure, temperature, flow and pressure relief valve actuation indications, and the water inventory balance method. Table I shows some of the systems that need inter-system leakage monitoring.
4. The reviewer verifies whether the leakage detection systems remain functional for all seismic events not requiring a shutdown and whether the airborne particulate radioactivity monitoring system remains functional when subjected to a safe shutdown earthquake.
5. The reviewer verifies whether all leakage detection systems have readouts in the control room and alarms. Direct reading systems, like sumps, normally indicate liters per minute (L/m) (gpm). Indirect reading systems, like the airborne particulate radioactivity monitoring system, indicate counts per minute. The reviewer determines whether control room operators have a chart or graph that permits rapid conversion of count rate into L/m (gpm), whether conversion procedures account for the isotope monitored and the activity of the primary coolant, and whether the plant maintains a running record of background leakage to factor its effect out from any sudden increases in leak indication, which may be "unidentified" leakage and to accordingly initiate prompt action. If monitoring is computerized, backup procedures should be available to the operator.
6. The reviewer verifies whether the detection system sensitivity and response are acceptable over the entire range of expected plant operating conditions monitored. The reviewer verifies whether the instrumentation and methodology for determining leak rates are adequate.
7. The reviewer determines whether the radiation monitoring systems have built-in radioactive sources (the FSAR refers to this feature as a "check source") for operability testing and calibration during operation. The reviewer determines whether there are provisions for testing and calibrating the sump level detection system, a method for calibrating the air cooler condensate flow system wherever radiation monitors are used, and a method for calibrating them to RCPB leakage. The frequency of testing and calibration should be justified. The reviewer also determines whether periodic testing of the floor drainage system checks for blockage and ensures operability.

For review of a DC application, the reviewer should follow the above procedures to verify that the design, including requirements and restrictions (e.g., interface requirements and site parameters), set forth in the final safety analysis report (FSAR) meets the acceptance criteria. DCs have referred to the FSAR as the design control document (DCD). The reviewer should also consider the appropriateness of identified COL action items. The reviewer may identify additional COL action items; however, to ensure these COL action items are addressed during a COL application, they should be added to the DC FSAR.

For review of a COL application, the scope of the review is dependent on whether the COL applicant references a DC, an early site permit (ESP) or other NRC approvals (e.g., manufacturing license, site suitability report or topical report).

For review of both DC and COL applications, SRP Section 14.3 should be followed for the review of ITAAC. The review of ITAAC cannot be completed until after the completion of this section.

#### IV. EVALUATION FINDINGS

The reviewer verifies that the applicant has provided sufficient information and that the review and calculations (if applicable) support conclusions of the following type to be included in the staff's safety evaluation report. The reviewer also states the bases for those conclusions.

The RCPB leakage detection system reliably monitors reactor coolant leakage from RCPB components by combinations of atmospheric particulate monitors, radio-gas monitors, and level, pressure, humidity, and temperature indicators.

The systems for detecting leakage from RCPB components furnish reasonable assurance that structural degradation, which may develop in pressure-retaining RCPB components and result in coolant leakage during service, will be detected promptly and that corrective actions will be made before such degradation becomes severe enough to jeopardize system safety or before the leakage increases to a level beyond the capability of the makeup system to replenish coolant loss.

The staff concludes that the RCPB leakage detection system design is acceptable and meets GDC 2 with respect to withstanding the effects of natural phenomena without loss of capability to perform its safety functions, and GDC 30 with respect to the detection and identification of the location of sources of reactor coolant leakage. This conclusion is based on the following findings:

1. The applicant has met the applicable GDC 2 requirements by meeting RG 1.29, Positions C.1 and C.2.
2. The applicant has met the applicable GDC 30 requirements by meeting RG 1.45.

For DC and COL reviews, the findings will also summarize the staff's evaluation of requirements and restrictions (e.g., interface requirements and site parameters) and COL action items relevant to this SRP section.

In addition, to the extent that the review is not discussed in other SER sections, the findings will summarize the staff's evaluation of the ITAAC, including design acceptance criteria, as applicable.

#### V. IMPLEMENTATION

The staff will use this SRP section in performing safety evaluations of DC applications and license applications submitted by applicants pursuant to 10 CFR Part 50 or 10 CFR Part 52. Except when the applicant proposes an acceptable alternative method for complying with specified portions of the Commission's regulations, the staff will use the method described herein to evaluate conformance with Commission regulations.

The provisions of this SRP section apply to reviews of applications submitted six months or more after the date of issuance of this SRP section, unless superseded by a later revision.

VI. REFERENCES

1. 10 CFR Part 50, Appendix A, General Design Criterion 2, "Design Basis for Protection Against Natural Phenomena."
2. 10 CFR Part 50, Appendix A, General Design Criterion 30, "Quality of Reactor Coolant Pressure Boundary."
3. Regulatory Guide 1.29, "Seismic Design Classification."
4. Regulatory Guide 1.45, "Reactor Coolant Pressure Boundary Leakage Detection Systems."

---

**PAPERWORK REDUCTION ACT STATEMENT**

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

**PUBLIC PROTECTION NOTIFICATION**

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

---

**Table I. Systems and Components Connected to Reactor Coolant System and Needing Inter-system Leakage Monitoring**

I. In pressurized-water reactors (PWRs):

1. Accumulators
2. Safety Injection Systems (High and Low Pressure)
3. Pressurizer Relief Tank
4. Secondary Side of Steam Generators
5. Residual Heat Removal System (Inlet and Discharge)
6. Secondary Side of Reactor Coolant Pump Thermal Barriers
7. Secondary Side of Residual or Decay Heat Removal Heat Exchangers
8. Secondary Side of Letdown Line Heat Exchangers
9. Secondary Side of Reactor Coolant Pump Seal Water Heat Exchangers

II. In boiling-water reactors (BWRs):

1. Safety Injection Systems (High and Low Pressure Core Spray and Coolant Injection Systems, High Pressure Core Flooder System)
2. Residual Heat Removal System (Inlet and Discharge)
3. Reactor Core Isolation Cooling System
4. Steam Side of High Pressure Coolant Injection (BWR-4)
5. Secondary Side of Reactor Water Cleanup System Heat Exchangers
6. Secondary Side of Reactor Coolant Pump Integral Heat Exchangers
7. Secondary Side of Residual Heat Removal Heat Exchangers