

Britt T. McKinney
Sr. Vice President & Chief Nuclear Officer

PPL Susquehanna, LLC
769 Salem Boulevard
Berwick, PA 18603
Tel. 570.542.3149 Fax 570.542.1504
btmckinney@pplweb.com



FEB 13 2007

Proprietary Information Enclosed

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop OP1-17
Washington, DC 20555

**SUSQUEHANNA STEAM ELECTRIC STATION
PROPOSED LICENSE AMENDMENT NO. 285
FOR UNIT 1 OPERATING LICENSE NO. NPF-14 AND
PROPOSED LICENSE AMENDMENT NO. 253
FOR UNIT 2 OPERATING LICENSE NO. NPF-22
CONSTANT PRESSURE POWER UPRATE -
SUPPLEMENT
PLA-6155**

**Docket Nos. 50-387
and 50-388**

*References: 1) PPL Letter PLA-6076, B. T. McKinney (PPL) to USNRC,
"Proposed License Amendment Numbers 285 for Unit 1 Operating
License No. NPF-14 and 253 for Unit 2 Operating License No. NPF-22
Constant Pressure Power Uprate," dated October 11, 2006.*

Pursuant to 10 CFR 50.90, PPL Susquehanna LLC (PPL) requested in Reference 1 approval of amendments to the Susquehanna Steam Electric Station (SSES) Unit 1 and Unit 2 Operating Licenses (OLs) and Technical Specifications (TS) to increase the maximum power level authorized from 3489 megawatts thermal (MWt) to 3952 MWt, an approximate 13% increase in thermal power. The proposed Constant Pressure Power Uprate (CPPU) represents an increase of approximately 20% above the Original Licensed Thermal Power (OLTP).

In a teleconference held January 31, 2007, the NRC staff requested PPL submit the enclosed reports to assist with the review of the Reference 1 application.

Enclosure 1 provides a proprietary version of the requested reports.

There are no new regulatory commitments associated with the submittal of these reports.

PPL has reviewed the "No Significant Hazards Consideration" and the "Environmental Consideration" submitted with Reference 1 relative to this supplemental information. We have determined that there are no changes required to either of these documents.

A001

The enclosed reports are considered to be proprietary by AREVA NP, Inc. As such, AREVA NP, Inc. requests that they be withheld from public disclosure in accordance with 10 CFR 2.390 (a) 4 and 9.17 (a) 4. An Affidavit supporting this request is provided in Enclosure 1.

If you have any questions or require additional information, please contact Mr. Michael H. Crowthers at (610) 774-7766.


B. T. McKinney

Enclosure 1: AREVA NP, INC. Reports

Copy: NRC Region I
Mr. C. R. Welch, NRC Sr. Resident Inspector
Mr. R. V. Guzman, NRC Project Manager
Mr. R. R. Janati, DEP/BRP