CAL No. NRR-07-005 March 12, 2007

Mr. Jeffrey T. Gasser
Executive Vice President
Southern Nuclear Operating Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: CONFIRMATORY ACTION LETTER, VOGTLE ELECTRIC GENERATING PLANT UNITS 1 AND 2

Dear Mr. Gasser:

This letter confirms commitments by Southern Nuclear Operating Company, Inc. in regard to Alloy 82/182 butt welds in the pressurizer at Vogtle Electric Generating Plant Units 1 and 2.

The discovery, in October 2006, of five circumferential indications in three dissimilar metal (DM) welds on the pressurizer at the Wolf Creek Generating Station (Wolf Creek) raised safety concerns based on the size and location of the indications. At Wolf Creek, three indications were in the pressurizer surge nozzle-to-safe end weld, and two separate indications were in the safety and relief nozzle-to-safe end welds. These findings also indicated that significant concerns might exist with the inspection schedules for addressing the pressurizer weld concerns issued by the industry-sponsored Materials Reliability Program (MRP), in "Primary System Piping Butt Weld Inspection and Evaluation Guideline (MRP-139)."

The Nuclear Regulatory Commission (NRC) is concerned about the pressurizer surge nozzle-to-safe end weld indications, as this is the first time that multiple circumferential primary water stress-corrosion cracking (PWSCC) indications have been identified in a weld. This condition calls into question the degree of safety margin present in past structural integrity evaluations for flawed DM welds susceptible to PWSCC, since multiple stress-corrosion cracking flaws may grow independently and ultimately grow together, significantly reducing the time from flaw initiation to leakage or rupture. The size of the relief nozzle-to-safe end flaw is also of concern, as this flaw has a much larger aspect ratio than those assumed in the estimates used to establish the basis for completing the baseline inspections required by the industry-sponsored MRP. Larger aspect ratios could result in achieving a critical flaw size and rupture before the onset of detectable leakage.

The long-term resolution of this issue is expected to involve changes to the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), and will involve changes to the NRC regulations in Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Section 50.55a, "Codes and standards." The development of the NRC regulations, whether the rule adopts the ASME Code standards or defines separate requirements, will likely benefit from additional operating experience, continuing assessments, and analysis being conducted by the NRC and the MRP.

Until NRC regulations are revised, it is necessary to establish a minimum set of enhanced

reactor coolant system (RCS) DM butt weld inspection expectations for nickel-based Alloy 82/182 pressurizer surge, spray, safety, and relief nozzle butt welds, including safe end welds, to supplement existing inspection and other requirements of the ASME Code and NRC regulations. In addition, enhanced monitoring of RCS leakage is needed to promptly identify any through-wall flaws in the pressurizer surge, spray, safety, or relief nozzle DM butt welds or safe end DM butt welds to prevent additional degradation from occurring. The above actions provide reasonable assurance that there is no undue risk to the health and safety of the public while the NRC regulations are revised.

The NRC communicated the need for near-term enhancements to the industry through public meetings held on November 30, 2006, December 20, 2006, and February 2, 2007. Licensees submitted letters voluntarily committing to the enhanced inspection and leakage monitoring requirements. After teleconferences with specific licensees held between February 12 through February 23, 2007, the licensees submitted supplemental commitment letters addressing the NRC staff's concerns regarding inspection, compensatory actions, and reporting.

In your letter dated March 6, 2007 (Agencywide Documents Access & Management System (ADAMS) ML070650572), you described actions you will take at Vogtle Electric Generating Plant, Units 1 and 2, for the pressurizer dissimilar metal butt welds containing Alloy 82/182 material. These commitments address: 1) completion schedules for inspection/mitigation of the welds; 2) RCS leak monitoring frequency, action levels, and actions; and 3) reporting requirements.

The NRC staff has reviewed these actions and commitments and agrees the actions and commitments are appropriate to address the potential of PWSCC of the applicable pressurizer dissimilar metal butt welds containing Alloy 82/182 material.

Pursuant to Section 182 of the Atomic Energy Act, 42 U.S.C. 2232, you are required to:

1) Notify me immediately if your understanding differs from that set forth above;

2) Notify me if for any reason you cannot complete the actions and commitments within the specified schedule and advise me in writing of your modified schedule in advance of the change; and

3) Notify me in writing when you have completed the actions and commitments addressed in this Confirmatory Action Letter.

Issuance of this Confirmatory Action Letter does not preclude issuance of an order formalizing the above commitments or requiring other actions on the part of the licensee; nor does it preclude the NRC from taking enforcement action for violations of NRC requirements that may have prompted the issuance of this letter. In addition, failure to take the actions addressed in this Confirmatory Action Letter may result in enforcement action.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and your response will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's ADAMS, accessible from the NRC Web site at http://www.nrc.gov/reading-rm/adams.html. To the extent possible, your response should not include any personal privacy, proprietary, or safeguards information so that it can be made

available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Sincerely,

/RA/

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425
License Nos. NPF-68 and NPF-81

cc: See next page

available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Sincerely,

/RA/

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425
License Nos. NPF-68 and NPF-81

cc: See next page

Distribution:

PUBLIC	RidsNrrPMBSingal	RidsNrrLAO'Brien
RidsNrrDorlLpl2-1(EMarinos)	RidsOgcRp	RidsAcrsAcnwMailCenter
RidsRgn2MailCenter	RidsNrrOd(JDyer)	RidsNrrDorlOd(CHaney)
RidsNrrDciOd(MEvans)	RidsNrrDirsOd(ECollins)	RidsOEMailCenter
RidsEdoMailCenter	SCampbell, EDO Region 2	KClark,OPA, Region 2
RTrojanowsy	TLupold, NRR	RidsNrrAdesOd(JGrobe)
ESullivan, NRR	RPascarelli	LPL2-1 R/F
RidsNrrDciCpnb	TChan	CCasto

ADAMS Accession No. ML070660103 *per e-mail

OFFICE	CPNB	DCI	LPL2-1/PM	LPL2-1/LA	LPL2-1/BC	TECH ED	DIRS/TA
NAME	TLupold	TSullivan	BSingal	MO'Brien	EMarinos LOlshan for	HChang	RPascarelli
DATE	3/09/07	3/09/07	3/08/07	3/04/07	3/09/07	2/28/07	3/09/07

OFFICE	CPNB/BC	DRP/D RGN 2	DORL/D	DCI/D	AD:DES	NRR/D
NAME	TChan JTsao for	CCasto*	CHaney JLubinski for	MEvans	JGrobe MEvans for	JDyer
DATE	3/09/07	3/09/07	3/09/07	3/09/07	3/09/07	3/12/07

OFFICIAL RECORD COPY

Vogtle Electric Generating Plant, Units 1 & 2

cc:

Mr. Tom E. Tynan
Vice President - Vogtle
Vogtle Electric Generating Plant
7821 River Road
Waynesboro, GA 30830

Mr. N. J. Stringfellow
Manager, Licensing
Southern Nuclear Operating Company, Inc.
P.O. Box 1295
Birmingham, AL 35201-1295

Mr. Jeffrey T. Gasser
Executive Vice President
Southern Nuclear Operating Company, Inc.
P.O. Box 1295
Birmingham, AL 35201-1295

Mr. Steven M. Jackson
Senior Engineer - Power Supply
Municipal Electric Authority of Georgia
1470 Riveredge Parkway, NW
Atlanta, GA 30328-4684

Mr. Reece McAlister
Executive Secretary
Georgia Public Service Commission
244 Washington St., SW
Atlanta, GA 30334

Mr. Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE, Suite 1252
Atlanta, GA 30334

Attorney General
Law Department
132 Judicial Building
Atlanta, GA 30334

Mr. Laurence Bergen
Oglethorpe Power Corporation
2100 East Exchange Place
P.O. Box 1349
Tucker, GA 30085-1349

Arthur H. Domby, Esquire
Troutman Sanders
Nations Bank Plaza
600 Peachtree Street, NE
Suite 5200
Atlanta, GA 30308-2216

Resident Inspector
Vogtle Plant
8805 River Road
Waynesboro, GA 30830

Office of the County Commissioner
Burke County Commission
Waynesboro, GA 30830