



U.S. NUCLEAR REGULATORY COMMISSION
STANDARD REVIEW PLAN

BRANCH TECHNICAL POSITION (BTP) 8-1

REQUIREMENTS ON MOTOR-OPERATED VALVES IN THE ECCS ACCUMULATOR LINES

REVIEW RESPONSIBILITIES

Primary - Organization responsible for electrical engineering

Secondary - None

A. BACKGROUND

For many postulated loss-of-coolant accidents, the performance of the emergency core cooling system (ECCS) in pressurized-water reactor plants depends upon proper functioning of the safety injection tanks (also referred to as "accumulators" or "flooding tanks" in some applications). In these plants, a motor-operated isolation valve (MOIV) and two check valves are provided in series between each safety injection tank and the reactor coolant (primary) system.

The MOIVs must be considered to be "operating bypasses" because, when closed, they prevent the safety injection tanks from performing the intended protective function. IEEE Std. 279 has a requirement for "operating bypasses" which states that the bypasses of a protective function will be removed automatically whenever permissive conditions are not met. This Branch Technical Position provides specific guidance in meeting the intent of IEEE Std. 279 for safety injection tank MOIVs. See Reference 3 for further background information regarding this issue.

Revision 3 - March 2007

USNRC STANDARD REVIEW PLAN

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRR_SRP@nrc.gov.

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML070710423.

B. BRANCH TECHNICAL POSITION

To meet the intent of IEEE Std. 279, the design of the MOIV system should incorporate the following features for safety injection tanks:

1. Automatic opening of the valves when either primary coolant system pressure exceeds a preselected value (to be specified in the technical specifications) or a safety injection signal is present. Both primary coolant system pressure and safety injection signals should be provided to the valve operator.
2. Visual indication in the control room of the open or closed status of the valve.
3. An audible and visual alarm, independent of item 2, above, that is actuated by a sensor on the valve when the valve is not in the fully open position.
4. Use of a safety injection signal to remove automatically (override) any bypass feature that may be provided to allow an isolation valve to be closed for short periods of time when the reactor coolant system is at pressure (in accordance with provisions of the technical specifications).

Conformance with the relevant criteria for operating bypasses described in IEEE Std. 603, as endorsed in RG 1.153, constitutes an acceptable alternative approach.

It should be noted that BTP 8-4 may also be applied to these isolation valves and should be used, when applicable, in conjunction with this Branch Technical Position.

It should also be noted that IEEE Std. 1290 provides information on motor-operated valve protection, control, and testing.

C. REFERENCES

1. Regulatory Guide 1.153, "Criteria for Power, Instrumentation, and Control Portions of Safety Systems."
2. BTP 8-4, "Application of the Single Failure Criterion to Manually Controlled Electrically Operated Valves."
3. Arkansas 1, Unit 1, Safety Evaluation Report, January 23, 1973.
4. IEEE Std. 603-1991, "Criteria for Safety Systems for Nuclear Power Generating Stations."
5. IEEE Std. 279-1971, "Criteria for Protection Systems for Nuclear Power Generating Stations."
6. IEEE Std. 1290-1996, "IEEE Guide for Motor Operated Valve (MOV) Motor Application, Protection, Control, and Testing in Nuclear Power Generating Stations," 1996.

PAPERWORK REDUCTION ACT STATEMENT

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.
