



U.S. NUCLEAR REGULATORY COMMISSION  
**STANDARD REVIEW PLAN**

**BRANCH TECHNICAL POSITION 11-3****DESIGN GUIDANCE FOR SOLID RADIOACTIVE WASTE MANAGEMENT SYSTEMS  
INSTALLED IN LIGHT-WATER-COOLED NUCLEAR POWER REACTOR PLANTS****REVIEW RESPONSIBILITIES**

**Primary** - Organization responsible for the review of effectiveness of radwaste systems.

**Secondary** - Organizations responsible for the review of (1) radwaste system design and performance, and (2) solid waste materials.

**A. Background**

During normal operation of a nuclear power plant, radioactive materials are generated in the form of "wet" and "dry" wastes. Wet wastes, including spent resins (bead or powdered), filter sludge, process and reverse osmosis concentrates, and spent cartridge filter elements, are normally byproducts of the operation of liquid waste processing systems. Dry wastes, including activated charcoal, HEPA filters, rags, paper, and clothing, are normally byproducts of the operation of ventilation air and gaseous waste processing systems and are generated during maintenance and refueling operations. Wet and dry wastes require processing by using appropriate waste management systems before shipment for offsite disposal.

Compressible dry wastes, such as contaminated rags, paper, and clothing, normally undergo a compaction process to reduce the volume of waste shipped off site. Special provisions are needed to assure that contaminated airborne radioactivity is not released to the process area during compaction.

Revision 3 - March 2007

---

**USNRC STANDARD REVIEW PLAN**

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to [NRR\\_SRP@nrc.gov](mailto:NRR_SRP@nrc.gov).

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov). Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS) at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML 070730202.

---

Liquid wet wastes, such as evaporator and reverse osmosis concentrates, are stabilized (i.e., combined with a suitable binder) before shipping to render the waste immobile and thereby mitigate the consequences of potential ruptures to shipping containers. Other wet wastes, such as spent resins (beads or powdered) and filter sludge, are either stabilized or dewatered before shipping. Spent cartridge filter elements are packaged with suitable absorbers in shielded containers or stabilized before shipping.

Although a number of available processes are capable of solidifying wet wastes under controlled conditions, free liquids can potentially remain in containers following stabilization, given widely varying chemical species encountered during power plant operations. For the purpose of this position paper, free liquid is defined as liquid that is still visible after stabilization or dewatering is complete, is drainable from the low point of a punctured container, or is drainable from a localized pool trapped within a waste matrix. Based on the NRC staff's judgment, vendors and operators need to implement certain measures to accomplish the following:

- Establish process parameters within which systems must be operated to obtain complete stabilization, encapsulation, solidification, as applicable
- Assure proper waste form properties are achieved
- Assure systems are operated within established process parameters
- Have provisions to detect free liquid in containers and waste matrix before shipment off site

Similar restrictions apply to dewatered products to provide greater assurance that these products meet the receiving burial site's free liquid restrictions at the time of receipt.

Following packaging, wastes are normally stored for decay of shorter lived radionuclides and to accumulate sufficient wastes for shipment off site. Insofar as the continuous operation of the SWMS is contingent on the availability of storage space for the interim period between waste packaging and shipment off site, the applicant should give consideration to providing ample storage capacity to accommodate wastes during periods when offsite shipments are not possible (e.g., during inclement weather, natural disasters, or labor strikes). Furthermore, in view of the reduced availability of burial site disposal capacity, it may be desirable to provide additional onsite short-term storage capacity to accommodate surges in solid waste volume resulting from interruption or limitations in offsite disposal services. Upon resumption of the disposal services, the stored wastes could then be shipped in an orderly fashion.

The criteria in Section II, below, provide adequate and acceptable design solutions for the concerns outlined above. Appendix 11.4-A to SRP section 11.4 provides further guidance and a list of supporting references.

This position paper sets forth minimum branch requirements and is not intended to prohibit the implementation of more rigorous design codes, standards, or quality assurance measures than those indicated herein.

## **B. BRANCH TECHNICAL POSITION**

### **1. Processing Requirements**

#### **A. Dry Wastes**

- i. Compaction devices for compressible dry wastes (rags, paper, and clothing) should include a ventilated shroud around the waste container to control the release of airborne radioactivity generated during the compaction process.
- ii. Activated charcoal, HEPA filters, and other dry wastes that do not normally require stabilization processing should be treated as radioactively contaminated solids and packaged for disposal in accordance with applicable Federal, State, and local regulations addressing the presence of other toxic and hazardous materials.

#### **B. Wet Wastes**

- i. Liquid wet wastes, such as evaporator and reverse osmosis concentrates, should be rendered immobile by combining with a suitable binding agent (e.g., cement, asphalt) to form a homogeneous solid matrix (absent of free water) before offsite shipment. Adsorbents such as vermiculite are not acceptable substitutes for binding agents.
- ii. Spent resins and filter sludge, if acceptable to the receiving burial site, may be shipped dewatered. These dewatered wastes are subject to (1) Subsections II.2.A.ii and II.2.B below, (2) to the receiving burial site's maximum free-liquid criteria (upon receipt at the burial site), and (3) applicable DOT regulations under 49 CFR Parts 171–180. Furthermore, the activity level of the dewatered wastes, subject to receiving burial site requirements, may dictate the type of container to be used. Stabilization or encapsulation of spent resins and filter sludge in a suitable binder is also an acceptable alternative.
- iii. Spent cartridge filter elements may be packaged in a shielded container with a suitably acceptable absorber, although solidifying the elements in a suitable binder is desirable.

### **2. Assurance of Complete Stabilization or Dewatering**

Operators should assure the complete stabilization or dewatering of wet wastes by implementing a PCP or by methods to detect free liquids within container contents before shipment.

#### **A. Process Control Program**

- i. Stabilization, encapsulation, or solidification (binding) agents and potential waste constituents should be tested and a set of process parameters (e.g., pH, ratio of waste to agent) should be established with

boundary conditions that reasonably assure that stabilization will be complete, with essentially zero free liquid and appropriate waste form characteristics.

- ii. Dewatering procedures, equipment, and potential waste constituents should be tested and a set of process parameters (e.g., settling time, drain time, drying time) should be established with boundary conditions that reasonably assure that dewatering will be complete, with essentially zero free liquid.
- iii. The solid waste processing system (or liquid waste processing system, as appropriate) should include appropriate instrumentation and wet waste sampling capability necessary to successfully implement and/or verify the PCP described in Subsections II.2.A.i and/or II.2.A.ii, above.
- iv. The plant operator should provide assurance that the process is run within the parameters established under Subsections II.2.A.i and/or II.2.A.ii, above. The licensee should maintain appropriate records for individual batches, showing conformance with the established parameters.

B. Free Liquid Detection

Using suitable methods, the operator should check each container filled with stabilized or dewatered wet wastes to verify the absence of free liquids using the PCP. An alternate method may be used if an offnormal condition exists during processing, but the alternate method must be documented and its effectiveness must be demonstrated using real or simulated waste material. Visual inspection of the upper surface of the waste in the container is not alone sufficient to ensure that free water is not present in the container. Provisions to be used to verify the absence of free liquids should consider actual stabilization procedures which may create a thin layer of encapsulation or solidifying agent on top without affecting the lower portion of the container, possibly leaving pools of free-standing liquids within the waste matrix.

3. Waste Storage

- A. Tanks accumulating spent resins from reactor water purification systems should be capable of accommodating at least 60 days of waste generation at normal generation rates. Tanks accumulating spent resins from other sources and tanks accumulating filter sludge should be able to accommodate at least 30 days of waste generation at normal generation rates.
- B. Storage areas for processed wet wastes (i.e., stabilized or dewatered wastes) should be capable of accommodating at least 30 days of waste generation at normal generation rates. These storage areas should be located indoors.
- C. Storage areas for dry wastes and packaged contaminated equipment should be capable of accommodating at least one full offsite waste shipment.

#### 4. Portable Solid Waste Systems

The following supplementary guidance should be incorporated into the design and use of portable (mobile) volume reduction, stabilization, and/or dewatering systems:

- A. Tanks containing wet wastes are limited to inplant installation and should not be part of the portable system.
- B. The use of flexible lines (hoses and connections) should be limited to necessary interfaces with plant systems. Pressure testing of all temporary and flexible lines, as connected to plant system piping embedded in concrete, and effluent discharge lines or piping buried in soils should be done. Such piping shall have a pressure rating equal to or greater than the system design pressure. Before its use, all flexible piping should be hydrostatically tested to at least 1.5 times the interfacing system design pressure and maintained for at least 30 minutes without leakage or structural deformation to ensure the integrity of the flexible piping and associated fittings.
- C. Corrosion-resistant properties should be used for all system piping and valves associated with transfer lines to storage tanks and discharge piping, including features designed for the early detection of leaks and spills.
- D. Portable systems should be located, as a minimum, on concrete pads with curbs and drainage provisions to process drains and drip pans or containment boxes to contain radioactive leaks. Provisions should be available for interfacing system drains with the plant's liquid radwaste system. Other safety features may include backflow preventers, siphon breakers, self-sealing quick-disconnects, and operational interlocks to prevent spills. Portable systems should have integral ventilation systems with self-contained filters or interface with the plant's ventilation exhaust system.
- E. Mobile liquid waste processing systems with interconnections to permanently installed plant liquid waste management subsystems should include provisions that (1) avoid the contamination of nonradioactive systems, (2) prevent uncontrolled and unmonitored releases of radioactive materials in the environment, and (3) avoid interconnections with potable and sanitary water systems.
- F. Designs should minimize the potential for spills and leaks to the extent practicable, consistent with maintaining radiation doses ALARA during operations and for the purpose of facilitating decommissioning.
- G. Regulatory Guide 1.143 seismic criteria for structures housing portable solid waste systems are not applicable.

#### 5. Additional Design Features

The following additional features should be incorporated into the design of the solid waste system.

- A. Process concentrate piping and tanks should have heat tracing if the concentrates are likely to solidify at ambient temperatures (indoor or outdoor).

- B. Components and piping that contain radioactive slurries should have flushing connections and piping runs that minimize the number of bends and traps that may retain radioactivity and lead to increased ambient external radiation exposure rates.
- C. Stabilization or encapsulation agents should be stored in low radiation areas, generally less than 0.025 mSv/hour (2.5 mrem/hour), with provisions for sampling.
- D. Tanks or equipment that use compressed gases for transport or drying of resins or filter sludge should be vented directly to the plant ventilation exhaust system, which includes HEPA filters, as a minimum, and charcoal filters for radioiodines. The vent design should prevent liquids and solids from entering the plant ventilation system.

---

**PAPERWORK REDUCTION ACT STATEMENT**

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

**PUBLIC PROTECTION NOTIFICATION**

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.

---