

## 5. REACTOR COOLANT SYSTEM AND CONNECTED SYSTEMS

### 5.1 Introduction

The reactor coolant system (RCS) includes those systems and components that contain or transport fluids coming from or going to the reactor core. These systems form a major portion of the reactor coolant pressure boundary (RCPB). This chapter of the safety evaluation report (SER) describes the U.S. Nuclear Regulatory Commission (NRC) staff evaluation of the RCS and the pressure-containing appendages out to and including outboard isolation valves. This grouping of components, defined as the RCPB, includes all pressure-retaining components such as pressure vessels, piping, pumps, and valves, which are part of the RCS or connected to the RCS. The RCPB includes any components up to and including the following:

- the outermost containment isolation valve in piping that penetrates containment
- the second of the two valves normally closed during normal reactor operation in system piping that does not penetrate containment
- the RCS safety/relief valve (SRV) piping and the depressurization valve (DPV) piping.

Section 5.4 of this chapter addresses various closely allied subsystems of the RCPB. The DPV is part of the automatic depressurization system (ADS) function of the emergency core cooling system (ECCS) discussed in Section 6.3. The nuclear boiler system (NBS) pressure relief system protects the RCPB from damage resulting from overpressure. To protect against overpressure, pressure-operated SRVs discharge steam from the NBS to the suppression pool or to the drywell. The pressure relief system also acts to automatically depressurize the NBS in the event of a loss-of-coolant accident (LOCA) in which the feedwater, isolation condenser (IC), and control rod drive (CRD) system high-pressure makeup fail to maintain the reactor vessel water level. Depressurization of the NBS by actuation of the DPV allows the gravity-driven cooling system (GDCS) to supply cooling water for the adequate cooling of the fuel in the core. Section 5.2.5 of this SER specifies the limits on NBS leakage inside the drywell so that operators can take appropriate action to prevent impairment of the integrity of the NBS process barrier.

Section 5.3 of this SER describes the reactor vessel and appurtenances. The major safety consideration for the reactor vessel is the ability of the vessel to function as a radioactive material barrier. The vessel design considers various combinations of loading. The design process considers the possibility of brittle fracture, addresses suitable design, material selection, and material surveillance activity, and establishes operational limits that avoid conditions where brittle fracture is possible.

The RCS provides coolant flow through the core by natural circulation within the reactor vessel. The core coolant flow rate changes with reactor power output. The control rods are adjusted either manually or automatically with the fine motion CRDs to adjust reactor power. The natural circulation within the reactor vessel eliminates the need for a recirculation system. Therefore, there are no large piping connections to the reactor vessel below the core, and there are no recirculation pumps.

Main steamline (MSL) flow restrictors of the venturi-type are part of the main steam nozzle on the reactor pressure vessel (RPV). The restrictors are designed to limit the loss of coolant resulting from a MSL break inside or outside the containment. The restrictors limit the reactor depressurization rate to a value that will ensure that the steam dryer and other reactor internal structures remain in place and limit the radiological release outside of containment before closure of the main steam isolation valves (MSIVs).

Two isolation valves are installed on each MSL. One is located inside the containment and the other is located outside the containment. If a MSL break occurs inside the containment, closure of the isolation valve outside the containment isolates the containment. The MSIVs automatically isolate the RCPB when a pipe break occurs outside containment. This action limits the loss of coolant and the release of radioactive materials from the NBS.

The CRD system high-pressure makeup provides water via the reactor water cleanup/shutdown cooling (RWCU/SDC) piping to the core any time feedwater flow is unavailable. The high-pressure makeup mode starts automatically upon receipt of a low reactor water level signal or the operator can start it manually. The CRD system is discussed in Section 4.6.

The RWCU/SDC system and the isolation condenser system (ICS) can be used to cool the NBS under a variety of situations. During normal shutdown and reactor servicing, the RWCU/SDC system removes residual and decay heat. The RWCU/SDC system, in conjunction with the ICS, allows decay heat to be removed whenever the main heat sink (main condenser) is not available (e.g., hot standby). The ICS provides cooling of the reactor if the RCPB becomes isolated following a scram during power operations. The ICS automatically removes residual and decay heat to limit reactor pressure when reactor isolation occurs. Over a longer duration, the ICS provides a way to remove excess heat from the reactor with minimal loss of coolant inventory, if the normal heat removal path is unavailable.

The GDCS is an ECCS for use during a postulated LOCA. The GDCS is operational at low reactor vessel pressure following pressure reduction by the ADS function of the ECCS. Section 6.3 describes the operation of the GDCS and ADS. The RWCU/SDC system recirculates a portion of reactor coolant through a demineralizer to remove dissolved impurities with their associated corrosion and fission products from the reactor coolant. It also removes excess coolant from the reactor system under controlled conditions.

## **5.2 Integrity of Reactor Coolant Pressure Boundary**

### **5.2.1 Compliance with Code and Code Cases**

General Design Criterion (GDC) 1, "Quality Standards and Records," in Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," requires that nuclear power plant structures, systems, and components (SSCs) important to safety be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function to be performed. This requirement applies to both pressure-retaining and nonpressure-retaining SSCs that are part of the RCPB, as well as to other systems important to safety. Where generally recognized codes and standards are used, they must be identified and evaluated to determine their adequacy and applicability.

### 5.2.1.1 Compliance with Title 10, Section 50.55a, of the Code of Federal Regulations

Pursuant to Title 10, Section 50.55a, “Codes and Standards,” of the *Code of Federal Regulations* (10 CFR 50.55a), components important to safety are subject to the following requirements:

- RCPB components must meet the requirements for Class 1 (Quality Group (QG) A) components specified in the American Society of Mechanical Engineers (ASME) Code, Section III, except for those components that meet the exclusion requirements of 10 CFR 50.55a(c)(2).
- Components classified as QG B and C must meet the requirements for Class 2 and 3 components, respectively, specified in ASME Code, Section III.

Design control document (DCD), Tier 2, Table 3.2-1, classifies the pressure-retaining components of the RCPB as ASME Code, Section III, Class 1 components. These Class 1 components are designated QG A in conformance with Regulatory Guide (RG) 1.26, “Quality Groups Classifications and Standards for Water-, Steam-, and Radioactive-Waste-Containing Components of Nuclear Power Plants,” Revision 3, issued February 1976. The staff evaluated the QG classifications discussed in Section 3.2.2 of this report and concludes that the economic simplified boiling-water reactor (ESBWR) mechanical and pressure-retaining components in the RCPB have been acceptably classified as QG A, in accordance with 10 CFR 50.55a.

In addition to the QG A components of the RCPB, certain lines that will perform a safety function and that meet the exclusion requirements of 10 CFR 50.55a(c)(2) are classified as QG B in accordance with Position C.1 of RG 1.26 and will be constructed as ASME Code, Section III, Class 2 components. The staff’s review of these components and other pressure-retaining components that will be constructed to ASME Code, Section III, Class 2 and Class 3 specifications, is discussed in Section 3.2.2 of this report.

SRP Section 5.2.1.1 recommends that safety analysis reports for both construction permits and operating licenses contain a table identifying the ASME component code, code edition, and applicable addenda for all ASME Code, Section III, Class 1 and 2, pressure vessel components, piping, pumps, and valves in the RCPB. DCD, Tier 2, Section 5.2.1.1, states that the ASME Code edition, applicable addenda, and component dates will be in accordance with 10 CFR 50.55a. DCD, Tier 2, Table 1.9-22 gives the specific edition and addenda. In request for additional information (RAI) 3.12-1, the staff requested that the applicant explain how it will satisfy the requirements of 10 CFR 50.55a(b). Section 3.12.3.1 of the SER discusses the resolution of this issue.

The ASME Code is considered Tier 1 information; however, the specific edition and addenda are considered Tier 2\* information partly because of the continually evolving design and construction practices (including inspection and examination techniques) of the ASME Code. Fixing a specific edition and addenda during the design certification stage might result in inconsistencies between design and construction practices during the detailed design and construction stages. The ASME Code involves a consensus process to reflect the evolving design and construction practices of the industry. Although reference to a specific edition of the ASME Code for the design of ASME Code Class components and their supports is suitable for reaching a safety finding during the design certification stage, the construction practices and

examination methods of an updated code that would be effective at the combined license (COL) stage must be consistent with the design practices established at the design certification stage.

To avoid this potential inconsistency for the ESBWR pressure-retaining components and their supports, it is appropriate that the ASME Code be specified as Tier 1 information and the specific edition and addenda as Tier 2\* information so that the COL applicant has the option to revise or supplement the referenced ASME Code edition with portions of the later editions and addenda and still ensure consistency between the design and construction practices. This procedure ensures consistency with the latest design, construction, and examination practices. However, the staff finds that there might be a need to fix certain design parameters from a specific ASME Code edition or addenda during its design certification review particularly when that information is important for establishing a significant aspect of the design or the staff uses it in reaching its final safety determination. The various sections of this report reflect such considerations where necessary. Therefore, all ASME Code Class 1, 2, and 3 pressure-retaining components and their supports shall be designed in accordance with the requirements of Section III of the ASME Code, using the specific edition and addenda given in the DCD.

The COL applicant should ensure that the design is consistent with the construction practices (including inspection and examination methods) of the ASME Code edition and addenda in effect at the time of the COL application, as endorsed in 10 CFR 50.55a. If the ASME Code edition and addenda differ from that specified in the DCD, the COL applicant should identify in its application the portions of the later code editions and addenda for NRC staff review and approval.

The staff concludes that the construction of all ASME Code Class 1, 2, and 3 components and their supports will conform to the appropriate ASME Code editions and addenda and the Commission's regulations and that component quality will be commensurate with the importance of the safety function of all such components and their supports. The staff finds this an acceptable basis for satisfying GDC 1.

#### 5.2.1.2 Applicable Code Cases

##### 5.2.1.2.1 Regulatory Criteria

The staff reviewed the DCD, Tier 2, (Revision 3), Section 5.2.1.2, "Applicable Code Cases," in accordance with the Standard Review Plan (SRP) Section 5.2.1.2. The staff's acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

- GDC 1 as it relates to the requirement that SSCs important to safety shall be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function to be performed.
- 10 CFR 50.55a as it relates to the rule that establishes minimum quality standards for the design, fabrication, erection, construction, testing, and inspection of certain components of boiling and pressurized water reactor (BWR and PWR) nuclear power plants by requiring conformance with appropriate editions of specified published industry codes and standards.

#### 5.2.1.2.2 Summary of Technical Information

DCD Section 5.2.1.2 states that the ESBWR meets the relevant requirements of GDC 1, as it relates to the requirement that safety-related SSCs are designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function to be performed, and 10 CFR 50.55a, as it relates to the rule that establishes minimum quality standards for the design, fabrication, erection, construction, testing, and inspection of certain components of BWR nuclear power plants by requiring conformance with appropriate editions of specified published industry codes and standards. To meet these requirements, GE-Hitachi Nuclear Energy Americas LLC (GEH) has identified in ESBWR DCD Table 5.2-1 various ASME Code Cases that are applicable to the component design, construction, and inspection. All ASME Code Cases identified in Table 5.2-1 are accepted or conditionally accepted per RG 1.84, "Design, Fabrication, and Materials Code Case Acceptability, ASME Section III," and RG 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1."

#### 5.2.1.2.3 Staff Evaluation

To meet the requirements of GDC 1 and 10 CFR 50.55a, the regulatory guides that identify the acceptability of ASME Code Cases that may be applied in the construction of pressure-retaining ASME Code, Section III, Class 1, 2, and 3 components, are RG 1.84, RG 1.147, and RG 1.192, "Operation and Maintenance Code Case Acceptability, ASME OM Code," issued June 2003. The only ASME Code Cases acceptable for use in the design of ASME Code Class 1, 2, and 3 piping systems in the ESBWR are those that are either conditionally or unconditionally approved in RG 1.84 and are in effect at the time of design certification.

DCD Table 5.2-1 identifies specific ASME Code Cases that will be applied in the construction of pressure-retaining Class 1, 2, and 3 components covered by ASME Code, Section III. The staff's review of this table is based on the guidelines in RG 1.84, which discusses the applicable ASME Code Cases that have been either conditionally or unconditionally endorsed by the staff. The staff has endorsed all of the 13 ASME Code Cases identified in Table 5.2-1 of the DCD and included in RG 1.84.

In RAI 5.2-32, the staff asked GEH to provide annulled ASME Code Cases that are not included in DCD, Tier 2, Table 5.2-1, or Code Cases that are under development, which will potentially be applied in the design and construction of ESBWR pressure-retaining Class 1, 2, and 3 components covered by ASME Code, Section III. In its response, GEH indicated that it is not planning to use any annulled ASME Code Cases that are not already included in DCD, Tier 2, Table 5.2-1. GEH is not aware of any Code Cases under development that would be needed for the RCPB. In RAI 5.2-33, the staff noted that DCD, Tier 2, Table 5.2-1 lists ASME Code Case N-71-17 for the design and construction of the ESBWR, while the current approved revision is Code Case N-71-18. The staff asked GEH to provide justification for the differences between the two revisions in the ESBWR design application. GEH responded that it will correct Table 5.2-1 to show the application of Code Case N-71-18. However, this ASME Code Case was subsequently deleted from Tier 2 in Revision 3. In response to the staff's RAI 5.2-34, GEH indicated that it will use only ASME Code Cases approved in RG 1.84 for the design of ASME Code Class 1, 2, and 3 components in the RCS. The Code Cases that pertain to ASME Code, Section XI, Division 1, as approved in RG 1.147, are used only as they pertain to preservice and inservice inspection of ASME components.

In RAI 5.2-50, the NRC requested that GEH provide a discussion of the ASME Code Cases listed in Table 5.2-1 that the NRC has not approved for use (i.e., N-634, N-491-2) and include a basis for their use. In its response (GEH letter MFN-6-290), GEH indicated that it would remove the reference to unapproved ASME Code Cases and provide a justification for the use of newer Code Cases (i.e., N-634) that are not yet in the regulatory guides. In addition, GEH stated that it would add a note referring to Code Case N-634 which would state, "this case allows attachment of non-pressure retaining materials meeting the requirements of NF-2000 to Subsection CC liners in the same manner as permitted under Subsection NE for MC components, except that welding and examination are required to meet the requirements of Subsection CC." Based on this response, the staff asked the applicant for a list of all materials that it intends to attach to the containment liner that do not meet the provisions of CC-2511 regarding liner attachment and a basis for using each of these materials. The GEH response to this supplemental request (MFN 06-290, Supplement 2) indicates that the ASME Code Case permits any steel to be used as a structural attachment to the containment liner provided that it is permitted to be attached to the ASME Section III, Division 1, containment vessel shell under the rules of ASME Section III, NE-2190(a). In addition, GEH indicated that it plans to pursue a new Code Case to include American Society for Testing and Materials (ASTM) A709 HPS 70W as a material that is used for containment internal structures as it does not meet CC-2511 requirements. The staff is currently reviewing this response, which is identified as **Open Item 5.2-50**.

On the basis of the above evaluation, the staff concludes that all of the ASME Code Cases in DCD Table 5.2-1 meet the guidelines of RG 1.84 in that the staff has reviewed and endorsed them. The staff considers that the applicant's compliance with the requirements of these ASME Code Cases will result in component quality that is commensurate with the importance of the safety functions of affected components.

#### 5.2.1.2.4 Conclusions

The NRC staff has reviewed the ASME Code Cases in Table 5.2-1 of ESBWR DCD, Tier 2 that meet the guidelines of RGs 1.84, 1.147, and 1.192. The specified ASME and American National Standards Institute (ANSI) Code Cases whose requirements will be applied in the construction of components covered by ASME Code, Section III, Division 1, Class 1, 2, and 3, and Class MC are in accordance with the rules of 10 CFR 50.55a, GDC 1, and the guidance provided in RGs 1.84, 1.147, and 1.192. Due to the open items that remain to be resolved for this section the staff was unable to finalize its conclusions regarding acceptability.

## 5.2.2 Overpressure Protection

### 5.2.2.1 Regulatory Criteria

The staff reviewed DCD, Tier 2, Section 5.2.2, "Overpressure Protection," in accordance with SRP Section 5.2.2, "Overpressure Protection," Revision 3.

During power operation, SRVs and the reactor protection system provide overpressure protection for the RCPB. For the ESBWR, the staff's review covered SRVs on the MSLs and piping from these valves to the suppression pool and the drywell. Acceptance criteria are based on GDC 15, "Reactor Coolant System Design," and GDC 31, "Fracture Prevention of

Reactor Coolant Pressure Boundary,” in Appendix A to 10 CFR Part 50. The acceptance criteria are also based on GDC 15 as it relates to the RCS and associated auxiliary, control, and protection systems being designed with sufficient margin to ensure that the design conditions of the RCPB are not exceeded during any condition of normal operation.

SRP Section 5.2.2 states that the acceptance criteria also are based on GDC 31 as it relates to the fracture behavior of the RCPB. Section 5.2.3 of this SER addresses this review area. Overpressure protection during low-temperature operation is not considered for the ESBWR, since there is a very low probability of the ESBWR operating in water-solid conditions. Hence, the SER does not address overpressure protection during low-temperature conditions for the ESBWR.

The ESBWR design must meet the requirements of 10 CFR 50.34(f)(2)(x, xi) [Three Mile Island - 2 (TMI-2) Action Items II.D.1 (SRV testing) and II.D.3 (SRV position indication in control room)].

#### 5.2.2.2 Summary of Technical Information

The NBS relief system consists of SRVs located on the MSL between the RPV and the inboard MSIV. The SRVs provide the two main protection functions of overpressure protection and ADS function.

The SRVs function as safety valves and open by steam pressure to prevent NBS overpressurization. The safety mode of operation is initiated when direct and increasing static inlet steam pressure overcomes the restraining spring and frictional forces acting against the inlet steam pressure at the valve disc. This moves the disc in the opening direction. The condition at which this actuation is initiated corresponds to the set-pressure value stamped on the nameplate of the valves.

The SRVs meet the requirements of Section III of the ASME Code. The rated capacity of the SRVs is sufficient to prevent a rise in pressure within the RPV to more than 110 percent of the design pressure during anticipated operational occurrences (AOOs).

Of the 18 SRVs, 10 are ADS valves and open automatically during a LOCA to depressurize the reactor vessel. The depressurization function is accomplished through the use of SRVs and eight squib-actuated DPVs.

The power supply to the solenoid valves which are used for ADS is from the 250-volt (V) direct current (dc), Class 1E system. The SRV controls are classified as Class 1E. Each SRV has one dedicated, independent pneumatic accumulator, which provides the safety-related nitrogen supply for opening the valve.

The SRVs are flange mounted onto forged outlet fittings located on the top of the main steamline piping in the drywell.

The SRVs are actuated in groups of valves at staggered times by delay timers as the reactor undergoes a relatively slow depressurization. This minimizes reactor level swell during the depressurization, thereby enhancing the passive resupply of coolant by the GDCS.

The use of a combination of SRVs and DPVs to accomplish the ADS function improves ADS reliability against common-mode failures. Because the SRVs serve two different purposes, overpressure protection and ADS, the number of required DPVs is minimized. By using DPVs for the additional depressurization capability needed beyond what the SRVs can provide, the total number of SRVs, SRV discharge lines, and quenchers in the suppression pool is minimized. This arrangement also minimizes the need for SRV maintenance, periodic calibration and testing, and the potential for simmering.

The ADS automatically actuates on a low RPV water level signal that persists for a preset time. Two-out-of-four logic is used to activate the SRVs and DPVs. The persistence requirement for the low RPV water level signal ensures that momentary system perturbations do not actuate ADS when it is not required. The two-out-of-four logic ensures that a single failure does not cause spurious system actuation, while also ensuring that a single failure cannot prevent initiation. The ADS may also be manually initiated from the main control room (MCR).

### 5.2.2.3 Staff Evaluation

The staff evaluation is based on Revision 3 of DCD, Tier 2. The staff assessed the design and function of the ESBWR overpressure protection system.

The pressure relief system for the RCPB does the following:

- prevents the pressure in the RCPB from rising beyond 110 percent of the design value
- provides automatic depressurization for breaks in the NBS so that the GDCS can operate to protect the fuel barrier

DCD, Tier 2, Section 5.2.2.1, "SRV Capacity," states, "The rated capacity of the pressure relieving devices shall be sufficient so that the rise in pressure within the protected vessel does not exceed 120 percent of the design pressure for pressurization events described in Chapter 15." Based on a review of Chapter 15, the staff's position is that the pressure limit for pressurization events is 110 percent of the design pressure. Hence, the DCD should be revised to show 110 percent instead of 120 percent. The staff identifies this as **Open Item 5.2.2-1** (RAIs 15.0-17 and 15.0-18).

For the pressure relief system to be acceptable, it must be possible to verify its operability and its ability to withstand adverse combinations of loadings and forces resulting from normal, upset, emergency, and faulted conditions.

For overpressure protection, the ICs have sufficient capacity to preclude actuation of the SRVs during normal operational transients. The SRVs limit the pressure to less than the RCPB design pressure during more severe transients.

Overpressure protection in the ESBWR is provided by 18 SRVs. The 18 SRVs are divided into ADS and non-ADS groups of nominal pressure setpoints of 8.618 MPa (1250 psig) and 8.756 MPa (1270 psig), respectively, and mounted on the four MSLs between the reactor vessel and the first isolation valve inside the drywell. Ten ADS SRVs discharge through piping to the suppression pool, and eight non-ADS SRVs discharge into the drywell. Two vacuum

relief valves on each SRV discharge line minimize the initial rise of water in the discharge piping. The ESBWR design meets the relevant requirements of GDC 15.

ADS SRVs are provided with nitrogen accumulators and check valves. These accumulators assure that the valves can be opened following the failure of the normal gas supply. The accumulator capacity is sufficient for one actuation at drywell design pressure.

The SRVs are classified as QG A and seismic Category I, as shown in DCD, Tier 2, Table 3.2. The SRVs are designed to meet RGs 1.26 and 1.29, "Seismic Design Classification" Revision 3, issued September 1978.

The ADS SRVs can also be operated in the relief mode by remote-manual controls from the MCR.

GDC 15 defines the basis for overpressurization protection in a nuclear reactor. It requires that the RCPB design conditions not be exceeded during any condition of normal operation, including AOOs. To satisfy this criterion, the overpressurization protection system for the ESBWR is designed in compliance with ASME Code, Section III, which requires that the maximum pressure reached during the most severe pressure transient be less than 110 percent of the design pressure. For the ESBWR, that pressure limit is 9.48 MPa (1375 psig). GEH used the computer simulation model TRACG to analyze a series of transients that would be expected to require SRV actuation to prevent overpressurization. GEH Topical Report NEDE-32176P, Revision 3, describes the TRACG model.

The staff reviewed the overpressure analyses and found that the applicant's assumptions are inconsistent with the assumptions given in SRP Section 5.2.2. For the most severe transient (i.e., closure of all MSIVs with a high neutron flux scram), the maximum vessel bottom pressure is calculated to be 8.71 MPa (1263 psig). The analysis assumed the plant was operating at a rated steam flow of 2433 kilograms per second (kg/s) (19.31 Mlbm/hr) and a vessel dome pressure of 7.17 MPa (1040 psig). The ESBWR RPV is larger than that in the currently operating BWRs and hence the reactor pressurization is slower. In general, RPV pressure ceases to increase once a single relief valve opens. This is because of the higher steam volume-to-power ratio of the ESBWR, which causes the pressure increase rate before a scram to be much lower than currently operating BWRs. After a scram, the pressure increase rates resulting from stored energy release are correspondingly lower.

GEH based the sizing of the SRVs on the initiation of a reactor scram by the high neutron flux scram, which is the second safety-grade scram signal from the reactor protection system following MSIV closure. The staff believes that the qualification and redundancy of reactor protection system equipment, coupled with the limitation of the reactor vessel pressure to less than 110 percent of design pressure, provide adequate assurance that the reactor vessel integrity will be maintained for the limiting transient event.

10 CFR 50.34 (f)(1)(vi), TMI-2 Action Item II.K.3.16, requires the performance of a study to identify practicable system modifications that would reduce challenges and failures of relief valves in BWRs, without compromising the performance of the valves or other systems. The SRVs are expected to open in the event of an anticipated transient without scram (ATWS) or beyond design-basis events. However, one of the key design criteria of the ESBWR is that SRVs should not need to open during most of the transients to protect against overpressure.

This is achieved through the use of the ICS. GEH and the BWR Owners' Group (BWROG) responded to this requirement for their earlier BWR models. Based on a review of the existing operating information on the challenge rate of relief valves, BWROG concluded that the BWR/6 product line had already achieved a level of reduction in the SRV challenge rate. The principal reason for this reduction is that the BWR/6 uses direct-acting SRVs, not the pilot-operated design used in some earlier BWRs. The ESBWR uses direct-acting SRVs. Designated SRV's that are actuated by the Automatic Depressurization System (ADS) use a pneumatic operator to initiate SRV opening at a setpoint lower than the mechanical lift setting. This provides a redundant means for SRV opening to depressurize the NBS and does not prevent SRV opening at the mechanical lift set pressure. The NRC staff finds that the ESBWR design complies with 10 CFR 50.34(f)(1)(vi) and TMI-2 Action Item II.K.3.16.

In Revision 2, the applicant deleted the following statement found in DCD, Revision 1, Section 5.2.6, without including a reason for the deletion:

The COL applicant is required to submit an overpressure protection analysis for core loadings different than the reference ESBWR core loading.

The staff believes that the COL action item should have been revised (rather than deleted) to state the following:

The COL applicant is required to submit an overpressure protection analysis for the actual core for the initial start-up.

The staff has identified this as **Open Item 5.2.2-3** (RAI 5.2-61).

10 CFR 50.34(f)(2)(x), TMI-2 Action Item II.D.1, requires licensees to provide a test program with associated model development and to conduct tests to qualify RCS relief and safety valves for all fluid conditions expected under operating conditions, transients, and accidents. The test program shall consider ATWS conditions. For currently operating plants, a generic test program for current valve designs and plant-specific responses for individual plant piping configurations and system responses resolved this issue. Confirmation is required to verify that the generic test program for the currently operating plants is applicable to ESBWR transients and accidents, or a commitment to perform the required testing and provide necessary plant-specific testing is needed. In response to RAI 5.2-7 (GEH letter MFN 06-178), GEH stated, "Consistent with past practice, a purchase specification for the SRV will be prepared that addresses the inspection and test requirements of the test program."

In accordance with the requirements of 10 CFR 50.34(f)(2)(xi), TMI-2 Action Item II.D.3, SRV position indications are provided in the control room.

SRV setpoint drift and seat leakage are generic problems. In the response to RAI 5.2-20 provided in GEH letter MFN 06-178 (June 16, 2006), GEH addressed (1) specific design features of the ESBWR SRVs, (2) comparison of the relative performance of ESBWR SRVs and SRVs currently installed in operating reactors, and (3) a detailed description of any improvements between ESBWR SRV designs and presently operating plant SRVs in the areas of seat-leakage, setpoint drift, and actuator reliability.

In the response to RAI 5.2-21 in GEH letter MFN 06-178 (June 16, 2006), GEH addressed (1) improvements in the air actuator, especially materials used for components such as diaphragms and seals, (2) safety margins associated with the air accumulator design, (3) pressure indications in the accumulator and how this information is relayed to the operator, and (4) provisions employed to ensure that valve and valve actuator specifications include design requirements for operation under expected environmental conditions (i.e., radiation, temperature, humidity, and vibration).

In the response to RAI 5.2-20 in GEH letter MFN 06-178 (June 16, 2006), GEH stated that it has not finalized the detailed design and selection of the ESBWR SRVs. In the response to RAI 5.2-22 in GEH letter MFN 06-178, GEH stated that it will prepare a purchase specification for the SRVs, which uses the GEH environmental qualification experience base. The SRVs will be subject to the environmental and dynamic qualification program. In the response to RAI 5.2-7 in GEH letter MFN 06-178, GEH stated that, consistent with past practice, it will prepare a purchase specification for the SRVs that addresses the inspection and test requirements of the program. In regard to RAIs 5.2-7, 5.2-20, and 5.2-22, the NRC staff is requesting that GEH specify its acceptance criteria for the design and qualification of the SRVs to be used in the ESBWR, including appropriate inspection, test, analysis and acceptance criteria (ITAACs). GEH responded that Item 1 in DCD, Tier 1, Revision 3, Table 2.1.2-2, contains an ITAAC to confirm the basic configuration for the nuclear boiler system (NBS) and that inspections shall be conducted with the acceptance criteria that the as-built NBS conforms to the basic configuration as defined in DCD, Tier 1, Section 2.1.2. The position of GEH is that this ITAAC includes programmatic reviews of SRV design and environmental qualifications, which meet the intent of the supplemental RAI for which the staff requested that GEH specify its acceptance criteria for the design and qualification of the SRVs to be used in the ESBWR, including appropriate ITAACs.

DCD, Tier 1, Revision 3, Section 1.2.2.1 (4), "Verifications for Basic Configuration for Systems," states that the basic configuration ITAAC includes the following:

Tests or type tests of active safety-related valves identified in the Design Description to demonstrate that the valves are qualified to perform their safety-related functions under design basis differential pressure, system pressure, fluid temperature, ambient temperature, minimum voltage, and minimum and/or maximum stroke times.

The NRC staff responded with the following supplemental request:

- A. The referenced ITAAC is not sufficient. Revise the ITAAC table to include verification for the SRV discharge capacity and setpoints to demonstrate that the as-built is consistent with the assumptions of the safety analyses.
- B. Include a COL Applicant or COL Holder Item to the DCD to ensure that operating experience, for example, issues identified in Regulatory Issue Summary 00-012, "Resolution of Generic Safety Issue B-55, 'Improved Reliability of Target Rock Safety Relief Valves,'" IE Circular 79-18, "Proper Installation of Target Rock Safety Relief Valves," Bulletin 74-04, "Malfunction of Target Rock Safety Relief Valves," and NUREG-0763,

“Guidelines for Confirmatory In-plant Tests of Safety Relieve Valve Discharges for BWR Plants” are addressed when the SRVs are procured.

- C. Revise the DCD, Tier 1, Section 1.2.2.1 to expand the environmental qualification verifications to include mechanical equipment such as seals and gaskets.

The applicant has not yet responded to this supplemental request, and the staff has identified it as **Open Item 5.2.2-2** (RAIs 5.2-20 and 5.2-22).

Operating experience has shown that SRV failure may be caused by exceeding the manufacturer’s recommended service life for the internals of the SRV or air actuator. In addition to periodic testing, the licensee should perform valve inspection and overhaul in accordance with the manufacturer’s recommendations. In response to RAI 5.2-25 (GEH letter MFN 06-178), GEH stated, “Every 5 years during reactor plant shutdown, the valves are subjected to a complete visual examination, set pressure testing and seat tightness testing.” The licensee will test SRVs in accordance with the IST program.

The effects of flow-induced SRV discharge line back pressure on the performance of the SRV are addressed by sizing the line to ensure that the steady-state back pressure does not exceed 40 percent of the SRV inlet pressure. This sizing criterion controls the effective back-pressure buildup and maintains the required force balance needed to keep the SRV open and to permit proper blowdown. The non-ADS SRVs discharge through the rupture discs to the drywell. In response to RAI 5.2-10 (GEH letter MFN 06-178), GEH stated that the design of the rupture disc will comply with ASME Code NB-7623.

Before the valves are installed, the SRV manufacturer will test the valves hydrostatically according to the requirements of ASME Code, Section III. During startup testing, opening response time and set-pressure tests will be conducted to verify that design and performance requirements have been met.

GEH submitted the design description and the ITAAC for SRVs. Section 14.3 of this SER evaluates the adequacy and acceptability of the ESBWR design descriptions and ITAAC.

#### 5.2.2.4 Conclusions

Section 14.3 of this report evaluates the adequacy and acceptability of the NBS design description and ITAAC.

Due to the open items that remain to be resolved for this section the staff was unable to finalize its conclusions regarding acceptability.

### **5.2.3 Reactor Coolant Pressure Boundary Materials**

#### 5.2.3.1 Regulatory Criteria

The staff reviewed DCD, Tier 2, Section 5.2.3, “Reactor Coolant Pressure Boundary Materials,” in accordance with the SRP Section 5.2.3. The materials specifications, compatibility of

materials with the reactor coolant, fabrication and processing of ferritic materials, and fabrication and processing of austenitic stainless steel within the RCPB are acceptable if they meet the relevant requirements set forth in 10 CFR 50.55a; GDC 1, 4, 14, 30, and 31 in Appendix A to 10 CFR Part 50; Appendix B, “Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants,” to 10 CFR Part 50; and Appendix G, “Fracture Toughness Requirements,” to 10 CFR Part 50. These requirements are discussed below.

- Compliance with GDC 1 and 10 CFR 50.55a requires that SSCs be designed, fabricated, erected, constructed, tested, and inspected to quality standards commensurate with the importance of the safety function to be performed.
- Compliance with GDC 4, “Environmental and Dynamic Effects Design Bases,” requires that SSCs important to safety be designed to accommodate the effects of and to be compatible with the environmental conditions associated with normal operations, maintenance, testing, and postulated accidents, including LOCAs.
- Compliance with GDC 14, “Reactor Coolant Pressure Boundary,” requires that the RCPB be designed, fabricated, erected, and tested so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture.
- Compliance with GDC 30, “Quality of Reactor Coolant Pressure Boundary,” requires that components of the RCPB be designed, fabricated, erected, and tested to the highest quality standards practical.
- Compliance with GDC 31 requires that the RCPB be designed with sufficient margin to assure that when stressed under operating, maintenance, testing, and postulated accident conditions (1) the boundary behaves in a nonbrittle manner and (2) the probability of rapidly propagating fracture is minimized.
- Compliance with Appendix B to 10 CFR Part 50 requires, in Criterion XIII, that measures be established to control the cleaning of material and equipment to prevent damage or deterioration.
- Compliance with Appendix G to 10 CFR Part 50 requires that the fracture toughness of RCPB ferritic materials be tested in accordance with the requirements of the ASME Code and that the pressure-retaining components of the RCPB that are made of ferritic materials meet requirements for fracture toughness during system hydrostatic tests and any condition of normal operation, including AOOs.

#### 5.2.3.2 Summary of Technical Information

DCD, Tier 2, Table 5.2-4, “Reactor Coolant Pressure Boundary Materials,” lists the principal pressure-retaining materials and material specifications for the RCPB components. This list includes the MSIVs, safety relief and depressurization valves, main steam piping, CRD components, RPV, IC piping, and feedwater (FW) piping.

The materials used in the RCPB, including materials that do not act as a pressure boundary, consist of austenitic wrought and cast stainless steel, nickel-based alloys, carbon and low-alloy steels, 400 series martensitic stainless steel, Colmonoy and Stellite hard-facing alloys, and

precipitation-hardened stainless steels. The applicant indicated that the ESBWR design has considered the compatibility of the materials of construction used in the RCPB with the reactor coolant, contaminants, or radiolytic products to which the system is exposed. All of the construction materials are resistant to stress-corrosion cracking (SCC) in the BWR environment. General corrosion of all materials, with the exception of carbon and low-alloy steel, is negligible. The applicant stated that the extent of the corrosion of ferritic low-alloy steels and carbon steels in contact with the reactor coolant was considered in the design.

The ESBWR design complies with RG 1.44, "Control of the Use of Sensitized Stainless Steel," issued May 1973; RG 1.36, "Nonmetallic Thermal Insulation for Austenitic Stainless Steel," issued February 1973; Generic Letter (GL) 88-01, "NRC Position on IGSCC in BWR Austenitic Stainless Steel Piping," dated January 25, 1988; and NUREG-0313, "Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping," Revision 2, issued January 1988.

Fracture toughness for ASME Code Class 1 ferritic materials used for the reactor piping, pumps, and valves meets the impact testing requirements of NB-2331 and NB-2332. Materials for bolting meet the requirements specified in NB-2333.

The ESBWR design provides alternatives to the guidelines in RG 1.50, "Control of Preheat Temperature Employed for Welding of Low-Alloy Steel," issued May 1973, and RG 1.71, "Welder Qualification for Areas of Limited Accessibility," Revision 1, issued March 2007.

Wrought tubular products that are used for pressure-retaining components of the RCPB are subject to the examination requirements of ASME Code, Section III, Subsection NB.

These RCPB components meet the requirements of Appendix B to 10 CFR Part 50 and the ASME Code, thus assuring adequate control of product quality.

### 5.2.3.3 Staff Evaluation

#### 5.2.3.3.1 Material Specifications

The specifications for pressure-retaining ferritic materials, nonferrous metals, and austenitic stainless steels, including weld materials, that are used for each component in the RCPB must meet GDC 1, GDC 30, and 10 CFR 50.55a, as they relate to quality standards for design, fabrication, erection, and testing. These requirements are met for materials specifications by complying with the appropriate provisions of the ASME Code, by applying the ASME Code Cases in RG 1.84, and by complying with the guidelines of NUREG-0313, Revision 2.

The staff reviewed DCD, Tier 2, Section 5.2.3.1, "Materials Specifications," to determine the suitability of the RCPB materials for this application. The staff has determined that the applicant's material specifications listed in DCD, Tier 2, Section 5.2.3 and Table 5.2-4, for the ESBWR design conform with the guidance in RG 1.84 and NUREG-0313, as well as the appropriate provisions of the ASME Code and other staff guidance except as noted below.

The staff notes that the material specifications and grades of some major components are not included in Table 5.2-4 and have not been presented to the staff. The table does not include isolation valves and check valves in the Class 1 portion of the FW piping. Table 5.2-4 must

include the material specifications for these components. The staff identifies this issue as **Open Item 5.2-36**.

In the applicant's response to RAI 5.2-37, dated August 7, 2006, the applicant indicated that the material specifications for carbon steel piping used in the ESBWR RCPB are SA-106, Gr. B or SA-333, Gr. 6, and that only seamless pipe will be used for the RCPB piping. DCD, Tier 2, Table 5.2-4, does not list SA-106, Gr. B as being used in the RCPB. Table 5.2-4 must list the material specifications for RCPB components. The staff identifies this issue as **Open Item 5.2-37**.

DCD, Tier 2, Table 5.2-4, indicates that there are cast austenitic stainless steel (CASS) components within the RCPB. CASS components used in light-water reactors (LWRs) can be susceptible to thermal aging embrittlement. In RAI 5.2-38, the staff asked the applicant to identify certain information for any CASS component that is part of the RCPB. The requested information includes (1) the impact of this aging effect on the integrity of the components, (2) the consideration of the thermal embrittlement mechanism in the design and material selection for RCPB components, (3) the need for inspections to detect this aging effect, and (4) verification that  $\delta$ -ferrite content is calculated using Hull's equivalent factors or a method producing an equivalent level of accuracy. The applicant, in its response dated August 7, 2006, referenced its response to RAI 4.5-3, dated June 16, 2006, for items 1, 2, and 3 above. The applicant stated that at the normal operating temperature of all BWRs of 550 °F, thermal aging of low carbon stainless steel castings with less than 20 percent ferrite is barely measurable. The applicant also stated that these materials have more than 35 years of operating experience with no problems or failures.

The applicant's responses to items 1, 2, and 3 above meet the staff's expectation that the applicant's screening process for the determination of CASS susceptibility to thermal aging embrittlement, for materials listed in Table 5.2-4, is consistent with the NRC staff position documented in a letter from Christopher I. Grimes of the NRC to Douglas J. Walters of the Nuclear Energy Institute, dated May 19, 2000 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML003717179). For item 4, the applicant stated that it intends to use ASTM A800 to determine  $\delta$ -ferrite content in lieu of Hull's equivalent factors. This is inconsistent with the staff's position that ferrite is calculated using Hull's equivalent factors as indicated in NUREG/CR-4513, "Estimation of Fracture Toughness of Cast Stainless Steels During Thermal Aging in LWR Systems," Revision 1, issued May 1994. For ferrite content above 12 percent, ASTM A800 may produce nonconservative ferrite levels lower than those calculated using Hull's equivalent factors. In response to RAI 6.1-15, by letter dated October 4, 2006, the applicant stated that use of a rigorous statistical analysis can demonstrate that the two methods are equally accurate. In supplemental RAI 5.2-38, the staff requested that the applicant provide a rigorous statistical analysis showing that the method to calculate ferrite using ASTM A800 and the method using Hull's equivalent factors are equally accurate. By letter dated June 6, 2006, the applicant provided its statistical analysis. The staff reviewed the applicant's statistical analysis and found it to be unacceptable because it does not show that ASTM A800 and Hull's equivalent factors are equally accurate. The applicant is currently exploring other alternatives to resolve the staff's concerns. The staff has identified this issue as **Open Item 5.2-38**.

Several operating experience issues have arisen related to the fabrication quality and inservice performance of dissimilar metal welds (DMWs) in LWRs. In RAI 5.2-40, the staff asked the

applicant to describe DMWs in the RCPB and discuss the selection of filler metals, welding processes, and process controls for DMWs in the ESBWR design.

The applicant, in its response dated August 7, 2006, indicated that DMWs are primarily used in the RCPB to join carbon steel to stainless steel piping components. These joints are generally made by applying a buttering layer or layers of 309L or 309MoL followed by completion of the groove weld using 308L, 316L, 309L, or 309MoL. Ferrite content in welds is controlled to between 8FN and 20FN. Post-weld heat treatment of the carbon steel after buttering is performed if dictated by ASME NB-4600. DMWs may also be made using Alloy 82 when welding nickel alloys to carbon steel, low-alloy steel, and stainless steel. Post-weld heat treatment of stainless steel components will not be allowed. The staff considers the applicant's proposed welding methods and selection of weld filler materials for DMWs to be acceptable. The applicant's statement that all of the aforementioned alloys are currently in BWR service with no observed incidences of SCC or other problems provides additional assurance that the welds will maintain structural integrity throughout the design life of the plant. In addition, the staff notes that the aforementioned weld filler materials are considered Category A materials per NUREG-0313 and provide an increased level of resistance to intergranular stress-corrosion cracking (IGSCC) when compared to non-low carbon stainless steel welding filler materials.

ASME Code, Section III, paragraph NB-3121, requires that material subject to thinning by corrosion, erosion, mechanical abrasion, or other environmental effects shall have provision made for these effects during the design or specified life of the component by a suitable increase in or addition to the thickness of the base metal over that determined by the design formulas. In DCD, Tier 2, Section 5.2.3.2, the applicant indicated that the design considers the extent of the corrosion of ferritic low-alloy steels and carbon steels in contact with the reactor coolant. In RAI 5.2-43, the staff asked the applicant to describe corrosion allowances for all unclad low-alloy and carbon steel surfaces in the RCPB. In a letter dated August 7, 2006, the applicant stated that corrosion allowances for unclad carbon and low-alloy steels are defined for both external (air exposure) and internal (wetted) surfaces. The 60-year allowance for external surfaces is 0.8 millimeters (mm) and the allowance for internal surfaces is 1.6 mm. In response to RAI 6.1-7, by letter dated October 4, 2006, the applicant provided additional information regarding its process for determining the corrosion allowance for RCPB ferritic materials. The corrosion allowance is primarily based on GEH internal testing. The allowances consider fluid velocity, oxygen content, and temperature, and include a safety margin over the actual measured corrosion rates of approximately a factor of 2. The same method, with corresponding allowances, has been applied to most operating BWRs (of GEH design), including the advanced boiling-water reactor (ABWR) design. The staff finds this acceptable, given that the applicant has considered the effect of corrosion, based on laboratory testing and operational experience, over the design life of the plant as required by ASME Code, Section III.

DCD, Tier 2, Table 5.2-4, indicates that E9018-B3L and ER90S-B3L will be used to weld components in the RCPB. The staff notes that ASME discontinued the aforementioned weld filler metal classifications several years ago and replaced them with classifications E8018-B3L and ER80S-B3L. The same issue exists in the applicant's proposed revision of Table 6.1-1, provided by letter dated May 3, 2007. In supplemental RAI 6.1-2 S02, the staff requested that the applicant modify Tables 5.2-4 and 6.1-1 to include the correct weld filler material classifications. Table 5.2-4 and the applicant's proposed version of Table 6.1-1 list the weld filler material that will be used to weld P5C, G1 materials. After reviewing the RCPB and ESF material specifications provided in the DCD and the applicant's May 3, 2007, letter, the staff is

unable to identify any materials that fall into the P5C, G1 category in accordance with ASME Code, Section IX, Table QW/QB-422. In supplemental RAI 6.1-2 S02, the staff requested that the applicant identify the P5C, Group 1 materials used in the ESBWR design for RCPB and ESF components or delete this information from the DCD if it does not apply. Table 5.2-4 and the applicant's proposed revision to Table 6.1-1 identify shielded manual arc welding filler material E8018-G for use in welding low-alloy steel in the ESBWR design. To complete its review and evaluate the applicant's compliance with 10 CFR 50.55a, the staff requested in supplemental RAI 6.1-2 S02 that the applicant provide the complete GEH specification that will be used to purchase E8018-G which will be used to fabricate ASME Code, Section III, Class 1, 2, and 3 components. In addition, the staff asked that the applicant provide a technical justification for using the GEH specification in lieu of using commercially available welding electrodes. The staff identifies this issue as **Open Item 6.1-2**.

Pending the resolution of RAIs 5.2-36, 5.2-37, 5.2-38, and 6.1-2, the staff finds that the applicant's selection of materials for use in the RCPB meets the requirements of the ASME Code or RG 1.84 and complies with the guidelines of NUREG-0313 and is therefore acceptable.

#### 5.2.3.3.2 Compatibility of Materials with the Reactor Coolant

The RCPB materials of construction that are in contact with the reactor coolant, contaminants, or radiolytic products must be compatible and must meet the requirements of GDC 4, as they relate to the compatibility of components with environmental conditions. The applicant stated that it has considered the compatibility of materials of construction used in the RCPB with reactor coolant, contaminants, or radiolytic products to which the RCPB is exposed.

The applicant stated that the materials of construction are compatible with primary coolant water, which is chemically controlled in accordance with the appropriate technical specifications, as discussed in Section 5.4.8 of this report. The applicant's selection of materials and control of water chemistry will ensure compatibility. Additionally, extensive testing and satisfactory performance of these materials in operating plants for several years have proven this compatibility. The materials meet the requirements of GDC 4 because the ESBWR design complies with the applicable provisions of the ASME Code, adheres to the guidance provided in RG 1.44, and conforms with the staff positions of GL 88-01, which are based on the technical information and recommendations provided in NUREG-0313. Therefore, material compatibility with primary water coolant will be assured.

#### 5.2.3.3.3 Fabrication and Processing of Ferritic Materials

The fracture toughness of ferritic materials in the RCPB must meet the requirements of Appendix G to 10 CFR Part 50. These criteria satisfy the requirements of GDC 14 and GDC 31 regarding prevention of fracture of the RCPB.

Appendix G to 10 CFR Part 50 requires the pressure-retaining components of the RCPB to be made of ferritic materials to meet the requirements for fracture toughness during system hydrostatic tests and any condition of normal operation, including AOOs. For piping, pumps, and valves, this requirement is met through compliance with the requirements of ASME Code, Section III, paragraph NB-2331 or NB-2332, and the  $C_v$  values specified in Table NB-2332(a)-1. Materials for bolting must meet the impact test requirements of ASME Code, Section III,

paragraph NB-2333. Calibration of temperature instruments and  $C_v$  impact test machines must meet the requirements of ASME Code, Section III, paragraph-2360. The staff reviewed DCD, Tier 2, Section 5.2.3.3.1, "Fracture Toughness," and verified that the ESBWR design meets the aforementioned requirements regarding fracture toughness of RCPB piping, components, and bolting and calibration of equipment. Section 5.3 of this report presents the staff's evaluation of the fracture toughness requirements of the RPV.

Control of ferritic steel welding by following NRC regulatory guides and adhering to the ASME Code satisfies the quality standards requirements of GDC 1, GDC 30, and 10 CFR 50.55a. Adherence to the guidance provided in RG 1.50, RG 1.43, "Control of Stainless Steel Weld Cladding of Low-Alloy Steel Components," issued May 1973, RG 1.34, "Control of Electroslag Weld Properties," issued December 1972, RG 1.71, and ASME Code nonmandatory Appendix D, "Nonmandatory Preheat Procedures," paragraph D-1210, satisfies the aforementioned quality standard requirements.

DCD, Tier 2, Section 5.2.3.3.2, discusses the use of RG 1.50 and preheat requirements when welding low-alloy steel in the ESBWR design. Low-alloy steel is used only in the RPV and FW piping. The applicant indicated that an alternative to RG 1.50 may be applied to the RCPB components. RG 1.50 requires that all low-alloy steel welds be maintained at the minimum preheat temperature until post-weld heat treatment is performed. In RAI 5.2-44, the staff asked the applicant to provide a description of the portions of RG 1.50 that will not be followed and a description of the steps that it will take to ensure that delayed cracking of the weld metal or weld heat affected zone will not occur. In a letter dated August 7, 2006, the applicant responded that in some cases the reactor vessel will be allowed to cool to ambient temperature after application of post-weld baking to remove any hydrogen that may be present. Previous BWR licensing documents, including the ABWR final SER, has included this same allowance, and it has been accepted. The applicant indicated that specific post-weld baking parameters are dictated by the type of weld involved, the welding process (e.g., inert gas shielded), and prior qualification testing. For example, drop of preheat is allowed for narrow gap, gas tungsten arc welding or gas metal arc welding joints where the weld is subjected to post-weld baking for 2 hours at 300 °C, or 4 hours at 200 °C. With gas-shielded welding, there is little potential for the introduction of hydrogen into the weld zone in any case. In accordance with RG 1.50, all such welds will be subjected to volumetric examination to confirm the absence of delayed cracking. All such joints will subsequently receive post-weld heat treatment. Therefore, the applicant contends that a combination of post-weld baking and inspection meets the intent of the regulatory guide. The applicant stated that this process has been successfully applied to operating BWR reactor vessels.

The staff considers the applicant's procedure to perform post-weld baking at the temperatures and times stated above for the referenced welding processes to fabricate RCPB components to be an acceptable alternative to the guidance in RG 1.50 which requires the maintenance of preheat until post-weld heat treatment is performed. In response to RAI 6.1-4 which references RAI 5.2-44 above, the applicant indicated that for welding processes such as flux-shielded welding, rigorous qualification of the effectiveness of the post-weld baking will be required.

The staff notes that this method has been successfully used in several other applications such as fossil fuel electric generation facilities, as well as petrochemical facilities, with materials that are much more sensitive to hydrogen cracking than those materials used within the RCPB of a nuclear power plant. Post-weld baking is an effective measure to prevent delayed hydrogen

cracking in welds that do not go directly from preheat temperature to post-weld heat treatment. The staff therefore considers the applicant's alternative to RG 1.50 acceptable given that it provides reasonable assurance that delayed hydrogen cracking will not occur in the time that a weld is completed through completion of post-weld heat treatment.

Although the staff considers the applicant's alternative to RG 1.50 acceptable, the staff requested, in supplemental RAI 10.3-4, that the applicant modify the DCD to include its alternative to RG 1.50 as it applies to all ASME Code Class 1, 2, and 3 piping and components. In addition, the staff asked that the applicant modify the DCD to include its response to RAI 6.1-4 in which it states that it will apply ASME Code, Section III, Appendix D, Article D-1000, minimum preheat recommendations, to all Class 1, 2, and 3 carbon steel and low-alloy steel piping and components in the ESBWR design. The staff requested that the applicant make the aforementioned modifications to DCD, Tier 2, Sections 5.2.3, 6.1.1, and 10.3.6. The staff identifies these issues as **Open Item 10.3-4**.

DCD, Tier 2, Section 5.2.3.3.2, states that electroslag welding is not allowed on structural weld joints of low-alloy steel. Therefore, RG 1.34 does not apply to the ESBWR design. RG 1.43 applies to clad low-alloy steel, and the only stainless steel clad low-alloy steel component in the RCPB identified in the DCD is the RPV. Section 5.3 of this report evaluates the applicant's adherence to the guidance in RG 1.43 related to RPV fabrication.

In DCD, Tier 2, Section 5.2.3.4.2, the applicant stated that the ESBWR design meets the intent of RG 1.71. In RAI 5.2-45, the staff asked the applicant to discuss its deviations from the specific portions of RG 1.71 and explain how those deviations meet the regulatory guide's intent. In a letter dated August 7, 2006, the applicant stated that restricted access qualifications are required when access to a nonvolumetrically examined production weld is less than 305 mm (about 12 inches) in any direction and allows welding from one access direction only. Requalification is required if the production weld is more restricted than the welder's performance qualification. The applicant provided the following rationale:

If a RCPB weld is subject to volumetric inspection, the inspection method and acceptance criteria will be according to ASME Section III, Subsection NB. If the weld passes this inspection, the weld quality is considered acceptable irrespective of the access restriction. Therefore, the intent of the RG is met by inspection. The fabricator or installer must produce welds that satisfy the Code irrespective of any access restrictions.

The RG indicates restrictions of 12 to 14 inches. Since this is insufficiently definitive from a specification and quality assurance point of view, GEH selected 12 inches as the defined limit.

Practically, even though a restriction may exist in one direction from the weld, this is not necessarily the only direction from which the welder may approach the weld. Therefore, if the welder can freely approach the weld from another direction with no access restrictions, the restricted access performance qualification is not required. It is further noted that in the ESBWR design, there are few, if any, RCPB welds that truly have restricted access. Additionally, much of the welding is performed with mechanized welding systems where physical access for a welder is not relevant to the ultimate weld quality.

The staff reviewed the applicant's alternative to RG 1.71 as stated in DCD, Tier 2, Section 5.2.3.4.2. The staff has determined that the applicant's alternative is consistent with the intent of RG 1.71. The applicant's alternative will provide reasonable assurance that welders working in restricted access positions will be appropriately qualified and thus produce sound welds.

For nondestructive examination (NDE) of ferritic steel and austenitic stainless steel tubular products, compliance with applicable provisions of the ASME Code meets the requirements of GDC 1, GDC 30, and 10 CFR 50.55a regarding quality standards. The applicable provisions of ASME Code, Section III, are paragraphs NB-2550 through NB-2570, which are discussed in Section 5.2.3.5 of this report.

#### 5.2.3.3.4 Fabrication and Processing of Austenitic Stainless Steel

Process control techniques must be included during all stages of component manufacturing and reactor construction to meet GDC 1, as it relates to nondestructive testing (i.e., examination) to quality standards; GDC 4; and Criterion XIII, "Handling, Storing, and Shipping," of Appendix B to 10 CFR Part 50. These requirements prevent severe sensitization of the material, by minimizing exposure of stainless steel to contaminants that could lead to SCC, and reduce the likelihood of component degradation or failure through contaminants.

The applicant meets the requirements of GDC 4 and Criterion XIII by complying with the applicable provisions of the ASME Code and with the regulatory positions of RG 1.31, "Control of Ferrite Content in Stainless Steel Weld Metal," Revision 3, issued April 1978; RG 1.36, "Nonmetallic Thermal Insulation for Austenitic Stainless Steel," issued February 1973; RG 1.37, "Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants," Revision 1, issued March 2007; RG 1.44, "Control of the Use of Sensitized Stainless Steel," issued May 1973; and RG 1.71.

The staff reviewed DCD, Tier 2, Section 5.2.3.4, "Fabrication and Processing of Austenitic Stainless Steel," to ensure that austenitic stainless steel RCPB components are compatible with environmental conditions to avoid sensitization and SCC, compatible with thermal insulation, have appropriate controls on welding and material preservation, and receive appropriate NDE. For NDE of ferritic steel and austenitic stainless steel tubular products, the applicant complies with the requirements of GDC 1, GDC 30, and 10 CFR 50.55a regarding quality standards by specifying the appropriate provisions of ASME Code. These provisions are in ASME Code, Section III, paragraphs NB-2550 through NB-2570. DCD, Tier 2, Section 5.2.3.3.3, states that seamless tubular products shall be examined according to NB-2550, welded tubular products according to NB-2560, and cast tubular products according to NB-2570.

The DCD indicates that all austenitic stainless steels are supplied in the solution heat-treated condition, and special sensitization tests are applied to confirm and assure proper heat treatment. In RAI 5.2-48, the staff asked the applicant to describe its "special sensitization test" that will be applied to ensure proper heat treatment. In a letter dated August 7, 2006, the applicant indicated that the test used to detect susceptibility to intergranular attack is a modified version of ASTM A 262, Practice A, wherein rejectable ditching is defined more strictly than in the ASTM version, and retest and acceptance by Practice E is not allowed. The staff considers limiting retest and acceptance by Practice E to be a conservative practice, and therefore, it meets the intent of RG 1.44.

In RAI 5.2-49, the staff asked the applicant to discuss its solution heat treatment requirements for austenitic stainless steel components and welds. In a letter dated August 7, 2006, the applicant explained its heat treatment requirements and stated that its solution heat treatment practice is consistent with that described in RG 1.44 and NUREG-0313. The staff finds the applicant's responses to RAI 5.2-48 and 5.2-49 acceptable because they conform with the guidance provided in RG 1.44 and NUREG-0313.

The ESBWR conforms with the guidance provided in RG 1.31, RG 1.44, and RG 1.36.

The applicant's acceptance criteria for cleaning and cleanliness controls meet the intent of RG 1.37, "Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants," Revision 1, issued March 2007. The applicant provided an alternative to RG 1.37 that is acceptable to the staff, which is discussed and evaluated in Section 4.5.1.2.5 of this safety evaluation.

#### 5.2.3.4 Conclusions

Due to the open items that remain to be resolved for this section the staff was unable to finalize its conclusions regarding acceptability.

### **5.2.4 RCS Pressure Boundary Inservice Inspection and Testing**

#### 5.2.4.1 Regulatory Criteria

The staff reviewed DCD, Tier 2, Section 5.2.4, "Preservice and Inservice Inspection and Testing of Reactor Coolant Pressure Boundary," in accordance with SRP Section 5.2.4, "Reactor Coolant Pressure Boundary Inservice Inspection and Testing."

The periodic inspection and testing of the RCPB required by GDC 32, "Inspection of Reactor Coolant Pressure Boundary," are specified in 10 CFR 50.55a and detailed in ASME Code, Section XI. As discussed below, compliance with preservice and inservice examinations of 10 CFR 50.55a, as detailed in ASME Code, Section XI, partially satisfies GDC 32.

- Compliance with GDC 32 requires, in part, that all components that are part of the RCPB be designed to permit periodic inspection and testing of important areas and features to assess structural and leak-tight integrity. Meeting the requirements of GDC 32 assures an effective periodic inspection program for the RCPB, so that the inspections identify aging effects or other incipient degradation phenomena and licensees can take prompt preventive measures to preclude potential loss of coolant or impaired reactor core cooling.
- Compliance with 10 CFR 50.55a requires that SSCs be designed, fabricated, erected, constructed, tested, and inspected to quality standards commensurate with the importance of the safety function they are intended to perform. By reference, 10 CFR 50.55a incorporates Section XI of the ASME Code.

#### 5.2.4.2 Summary of Technical Information

DCD, Tier 2, Section 5.2.4, describes the preservice and inservice inspection and system pressure test programs for NRC Quality Group A, ASME Code Class 1 items. It describes these programs' implementation of the requirements of Subsection IWB of the ASME Code, Section XI. The design to perform preservice inspection is based on the requirements of the ASME Code, Section XI, 2001 Edition through the 2003 Addenda, as specified in DCD, Tier 2, Table 1.9-22. The applicant indicated that the development of the preservice and inservice inspection program plans is the responsibility of the COL applicant/holder and shall be based on the ASME Code, Section XI, edition and addenda, specified in DCD, Tier 2, Table 1.9-22. The ASME Code requirements discussed in this section are provided for information.

#### 5.2.4.3 Staff Evaluation

As discussed above, the applicant stated that the development of the preservice and inservice inspection (PSI/ISI) program plans is the responsibility of the COL applicant/holder and shall be based on the ASME Code, Section XI, 2001 Edition through the 2003 Addenda. DCD, Tier 2, Section 6.6 indicates that the development of the ASME Code Class 2 and 3 PSI/ISI program plans will be the responsibility of the COL applicant/holder, and based on the ASME Code, Section XI, edition and addenda specified in accordance with 10 CFR 50.55a. DCD, Tier 2, Section 6.6 also states that the COL applicant/holder specifies the edition of ASME Code to be used, based on the date of issuance of the construction permit or license, per 10 CFR 50.55a. There appears to be an inconsistency in the DCD between the editions and addenda of ASME Code, Section XI, that the COL applicants will use to develop their PSI/ISI programs. In RAI 5.2-63, the staff requested that the applicant revise the DCD in Tier 2, Sections 6.6 and 5.2.4 to clearly and accurately state the requirements governing the applicable ASME Code edition and addenda used by the COL applicant to develop PSI/ISI programs. The staff identifies this issue as **Open Item 5.2-63**.

##### 5.2.4.3.1 System Boundary Subject to Inspection

The applicant's definition of the RCPB is acceptable if it includes all pressure vessels, piping, pumps, and valves that are part of the RCS, or connected to the RCS, up to and including the following:

- the outermost containment isolation valve in system piping that penetrates the primary reactor containment
- the second of two valves normally closed during normal reactor operation in system piping that does not penetrate primary reactor containment
- the RCS safety and relief valves

The applicant stated, in DCD, Tier 2, Section 5.2.4.1, that the Class 1 system boundary for both PSI/ISI programs and the system pressure test program includes all those items within the Class 1 and QG A boundary on the piping and instrumentation schematics. The applicant indicated that based on 10 CFR Part 50 and RG 1.26 the boundary includes the following:

- RPV

- portions of the main steam system
- portions of the feedwater system
- portions of the standby liquid control system
- portions of the RWCU/SDC system
- portions of the IC system
- portions of the GDCS

The staff reviewed the information provided in DCD, Tier 2, Section 5.2.4.1 and determined that the ASME Code Class 1 boundary requirements identified by the licensee are consistent with the acceptance criteria in SRP Section 5.2.4, Subsection II.1. Section 3.2 of this report presents a detailed staff review of the applicant's classification of ASME Code Class 1 components and piping.

#### 5.2.4.3 Accessibility

The design and arrangement of system components are acceptable if adequate clearance is provided in accordance with ASME Code, Section XI, Subarticle IWA-1500, "Accessibility."

In DCD, Tier 2, Section 5.2.4.2, the applicant stated that all items within the Class 1 boundary are designed to provide access for the examinations required by ASME Code, Section XI, IWB-2500. The applicant also stated that considerations for accessibility are defined in IWA-1500 of Section XI.

The staff issued several RAIs (6.6-1, 6.6-2, 6.6-3, 6.6-4, 5.2-51, 5.2-53, 5.2-54, 5.2-57, and 5.2-58) regarding accessibility of components to perform inspections required by ASME Code, Section XI, and 10 CFR 50.55a. The staff developed RAI 5.2-62, which supersedes the aforementioned RAIs, regarding accessibility and inspectability of welds and components. In RAI 5.2-62, the staff requested that the applicant modify the DCD to (1) specify the inspection methods that are practical to use for inservice inspection (ISI) of welds in ASME Code Class 1 and 2 austenitic and dissimilar metal welds, and (2) add COL action items to Sections 5.2.4 and 6.6 to ensure that a COL applicant referencing the ESBWR will provide a detailed description of its plans to incorporate, during design and construction, access to piping systems to enable NDE of such welds during ISI.

The ASME Code, Section XI, as incorporated into 10 CFR 50.55a(g), currently allows for either ultrasonic or radiographic examination of welds in ASME Code Class 1 and 2 piping systems. The staff asked that the applicant modify the DCD in Tier 1 to state that one or both of these types of examination are practical for ISI of austenitic and dissimilar metal welds. The staff notes that ultrasonic examination has advantages with respect to as low as reasonably achievable (ALARA) considerations, and with this change to the DCD, any design certification rule that might be issued for the ESBWR will preclude the granting of relief under 10 CFR 50.55a(g)(6) for ISI of such welds. The staff requested that the applicant confirm that austenitic or dissimilar metal welds in Class 1 and 2 piping systems will be accessible for examination by either ultrasonic or radiographic examination to satisfy 10 CFR 50.55a(g)(3).

In support of these DCD changes, a COL applicant referencing the ESBWR design certification application should inform the staff of how it plans to meet all access requirements during construction and operation as required by 10 CFR 50.55a(g)(3)(i) and (ii). The staff notes that the preservice inspection (PSI) requirements are known at the time a component is ordered,

and 10 CFR 50.55a(g) does not provide for consideration of relief requests for impractical examination during the construction phases of the component. The COL action items requested above should reflect these considerations. The staff identifies this issue as **Open Item 5.2-62**.

DCD, Tier 2, Section 5.2.4.2 references a formula,  $L=2T+152$  mm, that is used in the ESBWR design to determine the minimum length for spool pieces. In RAI 5.2-52, the staff asked the applicant to explain how it determined that the distance derived from the formula is adequate for the ESBWR design. In a letter dated August 28, 2006, the applicant stated that the basis for its minimum spool piece length of  $L=2T+152$  mm is Section XI, Appendix D, which specifies  $L=2T + 50.8$  mm. The 50.8-mm allowance is to accommodate the transducer footprint. The  $2T$  ( $T$ =thickness) distance allows for a full ultrasonic V-path for a 45-degree transducer. The additional 101.2 mm is an allowance for scanner tracks, other beam paths, etc. The staff finds this acceptable because the applicant has considered the necessary spool piece lengths to facilitate ultrasonic testing examinations.

DCD, Tier 2, Section 5.2.4.2, indicates that items such as nozzle-to-vessel welds often may have inherent access restrictions when vessel internals are installed. Therefore, preservice examination shall be performed as necessary to achieve the required examination volume on these items before installation of internals, which would interfere with examination. Section 5.2.4.2 further states that access is sufficient for the inservice examination of the volume described in Code Case N-613-1. The staff finds this acceptable, given that the preservice inspection will be performed in accordance with ASME Code, Section XI, and the ISI of these components will be able to be performed in accordance with Code Case N-613-1 which is endorsed by the NRC in Regulatory Guide 1.147, Revision 14. Use of NRC-endorsed ASME Code Cases is permitted by 10 CFR 50.55(g)(3)(i).

The staff reviewed DCD, Tier 2, Section 5.2.4.2, regarding accessibility of the RPV welds, RPV head, RPV studs, and RPV washers. The applicant has incorporated access for examinations of these components into the design of the RPV, biological shield, and vessel insulation to conduct the appropriate ultrasonic and visual examinations. This includes access for remotely operated ultrasonic examination devices and sufficient access to perform visual examination during system leakage and hydrostatic testing.

#### 5.2.4.4 Examination Categories and Methods

The examination categories and methods specified in the DCD are acceptable if they are in agreement with the criteria in the ASME Code, Section XI, Article IWB-2000, "Examination and Inspection." Every area subject to examination should fall within one or more of the examination categories in Article IWB-2000 and must be examined, at least to the extent specified. The requirements of Article IWB-2000 also identify the methods of examination for the components and parts of the pressure-retaining boundary.

The applicant's examination techniques and procedures used for PSI or ISI of the system are acceptable, if they conform with the following criteria:

- The methods, techniques, and procedures for visual, surface, or volumetric examination are in accordance with Article IWA-2000, "Examination and Inspection," and Article IWB-2000 of ASME Code, Section XI.

- The methods, procedures, and requirements regarding qualification of NDE personnel are in accordance with Article IWA-2300, "Qualification of Nondestructive Examination Personnel."
- The methods, procedures, and requirements regarding qualification of personnel performing ultrasonic examination reflect the requirements provided in Appendix VII, "Qualification of Nondestructive Examination Personnel for Ultrasonic Examination," to Division 1 of ASME Code, Section XI. In addition, the performance demonstration for ultrasonic examination systems reflects the requirements provided in Appendix VIII, "Performance Demonstration for Ultrasonic Examination Systems," to Division 1 of ASME Code, Section XI.

The staff reviewed DCD, Tier 2, Section 5.2.4.3.1, "Examination Categories," and Section 5.2.4.3.2, "Examination Methods," which discuss examination techniques, categories, and methods. The visual, surface, and volumetric examination techniques and procedures conform with the requirements of Subarticle IWA-2200 and Table IWB-2500-1 of ASME Code, Section XI, and are therefore acceptable to the staff.

The ASME Code requirements discussed in Section 5.2.4 of the DCD are based on the 2001 Edition of the ASME Code, Section XI, with 2003 Addenda. This edition and addenda of Section XI of the ASME Code requires the implementation of Appendix VII for qualification of NDE personnel for ultrasonic examination, and the implementation of Appendix VIII for performance demonstration for ultrasonic examination of RCPB piping and components identified in Table IWB-2500. The DCD indicates that ultrasonic examination systems shall be qualified in accordance with industry-accepted programs for implementation of the ASME Code, Section XI, Appendix VIII. The staff finds this acceptable.

#### 5.2.4.5 Inspection Intervals

The required examinations and pressure tests must be completed during each 10-year interval of service, hereafter designated as the inspection interval. In addition, the scheduling of the program must comply with the provisions of Article IWA-2000 concerning inspection intervals of the ASME Code, Section XI.

DCD, Tier 2, Section 5.2.4.4, discusses inspection intervals. Subarticles IWA-2400 and IWB-2400 of the ASME Code, Section XI, define inspection intervals. The inspection intervals specified for the ESBWR components are consistent with the definitions in Section XI of the ASME Code and, therefore, are acceptable.

#### 5.2.4.6 Evaluation of Examination Results

The standards for evaluation of examination results are acceptable if they conform with the requirements of ASME Code, Section XI, Article IWB-3000, "Acceptance Standards." The proposed program for repairs of unacceptable indications or replacement of components containing unacceptable indications is acceptable if in conformance with the requirements of ASME Code, Section XI, Article IWA-4000, "Repair/Replacement Activities." ASME Code, Section XI, Article IWB-3000, describes the criteria that establish the need for repair or replacement.

DCD, Tier 2, Section 5.2.4.5, "Evaluation of Examination Results," indicates that examination results are evaluated in accordance with ASME Code, Section XI, IWB-3000, with repairs based on the requirements of IWA-4000. The staff finds this acceptable as it meets the requirements of ASME Code, Section XI.

#### 5.2.4.7 System Leakage and Hydrostatic Pressure Tests

The pressure-retaining ASME Code Class 1 component leakage and hydrostatic pressure test program is acceptable if the program meets the requirements of ASME Code, Section XI, Article IWB-5000, "System Pressure Tests."

In DCD, Tier 2, Section 5.2.4.6, the applicant described the system leakage and hydrostatic pressure test requirements. The applicant discusses portions of IWA-5000, IWB-5000, and IWB-2500 to be applied to system leakage and hydrostatic tests. The staff concludes that the specific portions of ASME Code, Section XI, referenced by the applicant are acceptable. However, the staff requested that the applicant revise the DCD to clarify that all applicable requirements of IWA-5000 and IWB-5000 will apply to system leakage and hydrostatic pressure tests.

In RAI 5.2-65, the staff requested that the applicant revise DCD, Tier 2, Sections 5.2.4.6 and 6.6.6 to clarify that system leakage and hydrostatic pressure tests will meet all requirements of ASME Code, Section XI, IWA-5000, IWB-5000, IWC-5000, and IWD-5000. The staff identifies this issue as **Open Item 5.2-65**.

#### 5.2.4.8 Augmented ISI To Protect against Postulated Piping Failures

The augmented ISI program for high-energy fluid system piping between containment isolation valves is acceptable if the extent of ISI examinations completed during each inspection interval provides 100-percent volumetric examination of circumferential and longitudinal pipe welds with the boundary of these portions of piping. Section 6.6.3.7 of this report addresses this issue.

#### 5.2.4.9 COL Information

DCD, Tier 2, Section 5.4.6, provides the COL action item, "The COL holder is responsible for the development of the preservice and inservice inspection program plans that are based on the ASME Code, Section XI (Section 5.2.4)."

In RAI 5.2-64, the staff asked the applicant to revise DCD, Tier 2, Sections 5.2.4 and 6.6 to include a COL action item to provide a detailed description of the PSI/ISI programs, augmented inspection programs, and milestones for their implementation. The staff is concerned that the GEH reference to the COL applicant/holder does not make it clear that the COL applicant must provide in the COL application a description of its PSI/ISI program and augmented inspection programs with commitments for their scheduled implementation in the COL application. It is understood that the COL applicant/holder will fully develop and implement the actual programs. However, the COL applicant must fully describe the PSI/ISI and augmented inspection programs to allow the staff to make a reasonable assurance finding of acceptability. Applicants should always describe required programs at a functional level and at an increased level of detail where implementation choices could materially and negatively affect the program's effectiveness and acceptability. The staff identifies this issue as **Open Item 5.2-64**.

#### 5.2.4.10 Conclusions

Due to the open items that remain to be resolved for this section the staff was unable to finalize its conclusions regarding acceptability.

### 5.2.5 **Reactor Coolant Pressure Boundary Leakage Detection**

#### 5.2.5.1 Regulatory Criteria

The staff reviewed the RCPB leakage detection system in accordance with SRP Section 5.2.5 "Reactor Coolant Pressure Boundary Leakage Detection," Revision 1, July 1981. Staff acceptance of the leakage detection design is based on its meeting the requirements of the following criteria:

- GDC 2, "Design Basis for Protection Against Natural Phenomena," as it relates to the capability of the design to maintain and perform its safety function following an earthquake
- GDC 30 as it relates to the detection, identification, and monitoring of the source of reactor coolant leakage.

#### 5.2.5.2 Summary of Technical Information

In DCD, Tier 2, Section 5.2.5, "RCPB Leakage Detection," GEH describes the RCPB leakage detection systems and the design criteria to satisfy NRC regulatory requirements. The systems are designed to provide a means of detecting and, to the extent practical, identifying the source of the reactor coolant leakage.

The following are the primary detection methods used for monitoring small unidentified leaks:

- the drywell floor drain high-conductivity waste (HCW) sump pump activity
- the drywell sump level changes
- the drywell air coolers condensate flow rate
- the fission products' radioactivity

These parameters are continuously monitored and/or recorded in the MCR and alarmed on abnormal indications.

The secondary methods used to detect gross unidentified leakage are the pressure and temperature parameters of the drywell atmosphere. High atmospheric pressure in the drywell trips the reactor and initiates isolation of the containment isolation valves. The ambient temperature in the drywell is also monitored and alarmed.

Identified and unidentified leakages from sources within the drywell are collected and directed to separate sumps, the drywell equipment drain low-conductivity waste (LCW) sump for identified leakages and the drywell floor drain HCW sump for unidentified leakages.

### 5.2.5.3 Staff Evaluation

The staff reviewed RCPB leakage detection systems for the ESBWR in accordance with SRP Section 5.2.5, Revision 1, July 1981. Staff acceptance of the leakage detection design is based on the design's meeting the requirements of GDC 2 and GDC 30. Conformance with GDC 2 is on the basis of the leakage detection design's meeting the guidelines of RG 1.29, "Seismic Design Classification," Revision 4, dated March 2007, Positions C.1 and C.2. Conformance with GDC 30 is on the basis of the leakage detection design's meeting the guidelines of RG 1.45, "Reactor Coolant Pressure Boundary Leakage Detection Systems," issued May 1973, Positions C.1 through C.9.

By letter dated March 30, 2006 (ADAMS Accession No. ML060880217), the staff asked the applicant to provide the additional information requested in RAI 5.2.1 through RAI 5.2.5. In a letter dated May 12, 2006 (ADAMS Accession No. ML061390197), GEH responded to those RAIs. The staff reviewed the responses and discusses its evaluation below.

In RAI 5.2-1(a), the staff asked the applicant to clarify the statement in DCD, Tier 2, Section 5.2.5, Item (3), indicating that the system is equipped with indicators and alarms for each leakage detection system in the control room and permits only "qualitative" interpretations of such indicators. In its response, GEH stated that the information presented to the MCR operators will be "quantitative" such that the operator can convert the various readings to an equivalent leakage rate. GEH revised the statement in the DCD to reflect that the control room information is both qualitative and quantitative, and NRC staff verified the revised statement in DCD Revision 3. Therefore, RAI 5.2-1(a) is resolved.

In RAI 5.2-1(b), the staff asked the applicant to explain how the proposed technical specification (TS) limit and alarm limit for the unidentified leakage of 5 gallons per minute (gpm) are consistent with the 1 gpm criterion specified in Positions C.2 and C.5 of RG 1.45. In its response, GEH maintained its position for the TS limit and alarm limit being specified as 5 gpm based on its historical leakage detection/alarm limits specified for BWRs. GEH stated that Positions C.2 and C.5 specified only the "sensitivity" of the instrument rather than the TS limit or alarm limit and stated that the ESBWR instrument has the sensitivity of 1 gpm. RG 1.45 (page 1.45-2) provides guidance on the "detector sensitivity" and states that "sumps and tanks used to collect unidentified leakage and air cooler condensate should be instrumented to alarm for increases of from 0.5 to 1.0 gpm." The instrument sensitivity of 1 gpm is not reflected by an alarm setpoint, or in the TS limit, that could provide an early warning signal to alert operators to take actions. The current ESBWR alarm limit of 5 gpm is not acceptable because it is not consistent with RG 1.45 as stated above, nor does it serve the intended function of alerting operators to take actions before the TS limit is reached. Therefore, the staff finds the response to RAI 5.2-1(b) unacceptable and identifies this as **Open Item 5.2-1**.

In RAI 5.2-2, the staff asked why ESBWR TS LCO 3.4.2 specified a more relaxed limit of 5 gpm for the unidentified RCPB leakage than the limit of 1 gpm specified for the ABWR and for all other advanced reactors. The more relaxed limit could lead to higher operating RCPB leakage rates, fewer RCPB leakage controls, a potentially more humid environment inside containment, and an increased probability of material degradation from corrosion. In response to RAI 5.2-2, GEH stated that an evaluation of the effects of relative humidity including that attributable to the proposed leakage limits up to 5 gpm would be part of the equipment qualification requirements in the procurement of equipment. In addition, GEH stated that the design of the ESBWR has

been improved to reduce the likelihood of leaks resulting from SCC, and historically, good operator practice plays a role in the event of an anomaly in unidentified leakage. Typical operator practice will investigate, record, track, and evaluate trends of the leakage and take necessary measures to locate, assess, and repair the source of the leakage. The staff agreed that the material design improvement can reduce the likelihood of leaks resulting from SCC, but the improvement cannot eliminate all the possible leaks. The staff also agreed that good operator actions at low-level leakage below the TS limit are acceptable measures to address the concern of long-term leakage. To account for the good operator practice, every COL applicant should have operating procedures to manage the low-level RCS leakage, and the alarm limit should be set as low as practicable to provide an early warning signal to the operators to implement the procedures. In conference calls dated August 14, 2006, and January 16, 2007, the applicant agreed to add a COL action item in DCD, Tier 2, Revision 3, Section 5.2.6. This item states that “operators will be provided with procedures to assist in monitoring, recording, trending, determining the source of leakage, and evaluating potential corrective action.” The staff found the statement unacceptable because it did not indicate that the procedures are for low-level leakage (lower than the TS limit) and did not indicate that the COL applicant/holder is responsible for the development of the procedures. In addition, the design needs an appropriate alarm limit (resolution of Open Item 5.2-1) to provide an early warning signal to the operators to implement the procedures. Therefore, RAI 5.2-2 is not resolved. The staff identifies this as **Open Item 5.2-2**.

In RAI 5.2-3, the NRC staff asked why TS basis TS B.3.4.2, “RCS Operational Leakage,” refers to GDC 55, “Reactor Coolant Boundary Penetrating Containment,” but not to GDC 30 as the bases for the TS. GDC 55 discusses the requirements for containment isolation valves, and GDC 30 specifies the quality of the RCPB. In its response, GEH indicated that it referenced GDC 55 in the context of defining the RCS pressure boundary and referenced GDC 30 in the bases for TS 3.3.4.1, “RCPB leakage detection instrumentation.” The NRC staff reviewed the response and found that although referencing GDC 55 is acceptable in the context of ESBWR TS B.3.4.2, it is not acceptable without referencing GDC 30 in TS B.3.4.2. GDC 55 does not require any limit for operational leakage and does not provide any bases for requiring leakage limits as specified in TS 3.4.2. RG 1.45 provides the guidance for implementing the requirements of GDC 30, and RG 1.45 Position C.9 states that the TS should include the limiting conditions for identified and unidentified leakage and address the availability of various types of instruments to ensure adequate coverage at all times. This regulatory position, which implements the requirements of GDC 30, provides the bases for both TS 3.3.4.1 and TS 3.4.2. In a conference call on August 14, 2006, GEH agreed to revise TS B.3.4.2 by referencing GDC 30 in the bases for TS 3.4.2. The staff confirmed this change in Revision 3 of the DCD. Therefore, RAI 5.2-3 is resolved.

In RAI 5.2-4, as related to RG 1.45 Position C.7, the staff asked the applicant to clarify whether the procedures that will provide operator guidance on converting leakage instrument indications into a common leakage rate equivalent were generic for the ESBWR design or to be developed by COL applicants. In its response, GEH stated that COL applicants would provide the procedures to convert different sources of leakage into a common rate equivalent. This is a COL action item to be added to DCD, Tier 2, Section 5.2.6. Accordingly, GEH provided a markup page for Section 5.2.6 in the RAI response. However, when reviewing DCD Revision 2, the staff could not find the promised COL action item. In a conference call on January 16, 2007, GEH agreed to incorporate the change in Revision 3 of the DCD. In its review of Revision 3, the staff found that Section 5.2.6 stated “Operators will be provided with a

procedure to determine the identified and unidentified leakage in order to establish whether the leakage rates are within the allowable TS.” The staff finds this statement unacceptable on two counts. The statement should identify the COL applicant/holder as responsible for the development of the procedures, and the statement should better characterize the purpose of the procedures. The purpose is to convert different sources of leakage (such as sump pump activity, sump level, condensate flow rate, and radioactivity) into a common rate equivalent (gpm). Operators can use this leak rate information to monitor the leakage and to keep the leakage well below the TS limit. The purpose of the procedures is not limited to establishing whether the leakage rates are within the allowable TS, as the statement indicates. In response to the NRC concerns discussed above GEH committed to incorporating the staff’s recommendations in Revision 4 of the DCD. **Pending confirmation that the staff’s recommendations have been incorporated in Revision 4 of the DCD, RAI 5.2-4 has been identified as a confirmatory item.**

In RAI 5.2-5, as related to the capability of the leak detection instrument to maintain and perform its safety functions following an earthquake, the staff asked the applicant to clarify which leak detection instrumentation discussed in DCD, Tier 2, Section 5.2.5.2 is required to perform the containment isolation function and which is not. The leak detection instrumentation required to perform the isolation function is classified as Class 1E, seismic Category I, and therefore, meets RG 1.29. In its response, GEH revised DCD, Tier 2, Section 5.2.5 to identify all the leak detection instruments that are used for isolation functions and the instruments that are not used for isolation functions. The staff confirmed that this revision appeared in DCD Revision 3. In addition, GEH stated that, with one exception, leak detection instruments that are not required for isolation functions are not required to remain functional following an earthquake. The exception is the drywell fission product radiation monitoring system, which is seismically qualified and needs to follow the guidance of Positions C.1 and C.2 of RG 1.29. The staff finds the applicant’s response acceptable and finds that the design satisfies Position C.6 of RG 1.45 and Positions C.1 and C.2 of RG 1.29. Therefore, the design satisfies GDC 2 as it relates to the capability of the design to maintain and perform its safety function following an earthquake. RAI 5.2-5 is resolved.

DCD, Tier 2, Chapter 16, Limiting Condition for Operation (LCO), Section 3.3.4.1, “RCS Leakage Detection Instrumentation,” and LCO 3.4.2 “RCS Operational Leakage,” address Position C.9 of RG 1.45. By letter dated August 3, 2006 (ADAMS Accession No. ML062150443), the staff asked the applicant to provide additional information in response to RAIs 16.2-1 and 16.2-4. In a letter dated August 21, 2006 (ADAMS Accession No. ML062440431), GEH responded to those RAIs.

In RAI 16.2-1, the staff stated that NRC Information Notice 2005-24 indicated that the containment radiation gaseous monitors might not be able to detect RCS leakage of 1 gpm within 1 hour based on the experiences of operating reactors using fuel with improved integrity. DCD, Tier 2, Section 11.5.3.2.12 indicates that the gaseous radiation monitor is able to detect 1 gpm within 1 hour, and the gaseous radiation monitor is used as one of the two monitors for the drywell fission product monitoring system in LCO 3.3.4.1(b). In its response, GEH proposed to delete the gaseous radiation monitor from TS 3.3.4.1. The airborne particulate radiation monitor remains as the drywell fission product monitoring system. Without the gaseous radiation monitor, the ESBWR design satisfies RG 1.45 Position C.3 by providing three RCS leakage detection methods. These are the drywell floor drain HCW sump monitoring system, the drywell fission product (particulate) monitoring system, and the drywell air coolers

condensate flow monitoring system. The staff found the applicant's response acceptable and confirmed that this information was provided in DCD Tier 2, Section 5.2.5.8 and Chapter 16, Technical Specification Basis B.3.3.4.1, Revision 3.

In addition, the staff asked the applicant in RAI 16.2-1 to address the procedures to convert the monitoring parameters into a common leakage rate equivalent. This issue was discussed previously in RAI 5.2-4, which the staff has identified as a confirmatory item. Therefore, the staff also identifies **RAI 16.2-1 as a confirmatory item.**

In RAI 16.2-4, the staff found that LCO 3.4.2, "RCS Operational Leakage," did not list a limit for rate increases in unidentified leakage. This is not consistent with the BWR Standard Technical Specifications (STS). This may not satisfy 10 CFR 50.36, "Technical Specifications," which requires a TS on instrumentation designed to detect a significant abnormal degradation of the RCPB. The staff asked the applicant to justify not providing the rate-of-change leakage TS for the ESBWR. In its response, GEH explained that the BWR STS (NUREG-1434, "Standard Technical Specifications General Electric Plants, Revision 3, June 2004) LCO 3.4.5 specifies a limit for an increase in unidentified leakage; however, it is shown as bracketed in its entirety. This indicates that incorporation of this LCO requirement is a plant-specific issue. This TS requirement was prompted from GL 88-01, which applies to all BWR piping made of austenitic stainless steel that is susceptible to IGSCC. According to DCD, Tier 2, Section 5.2.3.4.1, the RCS piping is designed to avoid sensitization and susceptibility to IGSCC through the use of reduced carbon content material and process controls. During fabrication, solution heat treatment is used. During welding, heat input is controlled. The ESBWR design does not use austenitic stainless steel. Historically, good operator practice plays a role in the event of an anomaly in unidentified leakage. The operators regularly observe and record data, monitor trends in plant parameters, and detect abnormal conditions during their shift. This provides a means to alert the plant staff to a condition that warrants further scrutiny and assessment. For example, if operators observe leakage that is more than the normal expected leakage, yet less than the 5-gpm TS limit, the plant operators typically will be alerted to investigate, record, and track pertinent data, evaluate trends in the data, and assess the cause of any change that could ultimately lead to a reactor shutdown to make a drywell entry to take further action to locate, assess, and potentially repair the source of leakage.

The staff reviewed the above responses and concluded that the limit for rate increases in unidentified leakage could be deleted subject to the condition that the plant would follow "good operator practice" as discussed above. Every COL applicant should have operating procedures to implement the "good operator practice" in managing the low-level RCS leakage. The staff determined that it needed a COL item the same as the one discussed in Open Item 5.2-2. The staff identifies this as **Open Item 16.2-4**, which is the same as **Open Item 5.2-2**.

#### 5.2.5.4 Conclusions

Based on the preceding, the staff finds that the applicant has met the requirements of GDC 2 with respect to the systems' capability to maintain and perform their safety functions in the event of earthquakes by meeting Positions C-1 and C-2 of RG 1.29. Pending the resolution of above open items, the staff will determine whether the applicant has met the requirements of GDC 30.

## 5.3 Reactor Vessel

### 5.3.1 Reactor Vessel Materials

The staff reviewed DCD, Tier 2, Section 5.3.1, "Reactor Vessel Materials," in accordance with the SRP Section 5.3.1. The applicant's reactor vessel (RV) materials are acceptable if they meet codes, standards, and regulatory guidance commensurate with the safety function to be performed. This will ensure that the materials meet the relevant requirements of 10 CFR 50.55a; Appendix G and Appendix H, "Reactor Vessel Material Surveillance Program Requirements," to 10 CFR Part 50; and GDC 1, 4, 14, 30, 31, and 32. These requirements are discussed below.

- GDC 1 and 30 and 10 CFR 50.55a(a)(1) require SSCs important to safety to be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function to be performed.
- GDC 4 requires SSCs important to safety to be designed to accommodate the effects of, and to be compatible with, the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents.
- GDC 14 requires the RCPB to be designed, fabricated, erected, and tested so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture.
- GDC 31 requires the RCPB to be designed with sufficient margins to ensure that, when stressed under operation, maintenance, testing, and postulated accident conditions, it will behave in a nonbrittle manner and minimize the probability of rapidly propagating fracture.
- GDC 32 requires the RCPB components to be designed to permit an appropriate material surveillance program for the RV.
- Appendix G to 10 CFR Part 50 specifies the fracture toughness requirements for ferritic materials of the pressure-retaining components of the RCPB. The staff reviewed the RV materials as they relate to the materials testing and acceptance criteria for fracture toughness contained in Appendix G. Pursuant to Appendix G, the RV beltline materials must have Charpy upper-shelf energy (USE) values, in the transverse direction for base material and along the weld for weld material, of no less than 101.7 N-m (75 ft-lbs) initially and must maintain Charpy USE values throughout the life of the vessel of no less than 67.8 N-m (50 ft-lbs).
- Appendix H to 10 CFR Part 50 presents the requirements for a materials surveillance program to monitor the changes in the fracture toughness properties of materials in the RV beltline region resulting from exposure to neutron irradiation and the thermal environment. These requirements include conformance to ASTM E-185, "Standard Recommended Practices for Surveillance Tests for Nuclear Reactor Vessels."

Compliance with Appendix H satisfies the requirements of GDC 32 regarding the provision of an appropriate materials surveillance program for the RV. The staff reviewed the RV materials to determine whether they meet the relevant requirements of Appendix H for determining and monitoring material fracture toughness.

#### 5.3.1.1 Summary of Technical Information

##### 5.3.1.1.1 Material Specifications

The applicant indicated that the material specifications are in accordance with the ASME Code requirements. All ferritic RV materials shall comply with the fracture toughness requirements of 10 CFR 50.55a and Appendices G and H to 10 CFR Part 50.

DCD, Tier 2, Table 5.2-4, shows the materials used in the RV and appurtenances. The chemical compositions of the ferritic materials of the RV beltline are restricted to the maximum limits shown in DCD, Tier 2, Table 5.3-1. Copper, nickel, and phosphorus content is restricted to reduce sensitivity to irradiation embrittlement in service.

##### 5.3.1.1.2 Special Processes Used for Manufacturing and Fabrication

The RV is constructed primarily from low-alloy, high-strength steel plate and forgings. Plates are ordered to ASME Code SA533, Type B, Class 1, and forgings to ASME Code SA508, Grade 3, Class 1, specifications. These materials are melted to fine grain practice and are supplied in the quenched and tempered condition. Further restrictions include a requirement for vacuum degassing to lower the hydrogen level and improve the cleanliness of the low-alloy steels. The shells and vessel heads are made from formed plates or forgings, whereas flanges and nozzles are made from forgings. Welding performed to join these vessel components is in accordance with procedures qualified per ASME Code, Section III and IX, requirements. Gas tungsten arc welding (GTAW), gas metal arc welding (GMAW), shielded metal arc welding, and submerged arc welding (SAW) processes may be employed. Electroslag welding is not used except for cladding.

Post-weld heat treatment of all low-alloy welds is performed in accordance with ASME Code, Subsection NB-4620 (DCD, Tier 2, Table 5.3-1). The materials, fabrication procedures, and testing methods used in the construction of the ESBWR RV meet or exceed the requirements of ASME Code, Section III, Class 1, vessels.

The reactor vessel assembly components are classified as ASME Class 1. Complete stress reports on these components are prepared in accordance with the ASME Code requirements. NUREG-0619, "BWR Feedwater Nozzle and Control Rod Drive Return Line Nozzle Cracking," issued November 1980, is also considered for feedwater nozzle and other such RV inlet nozzle designs. The action plan item A-10, BWR Feedwater Nozzle Cracking, is considered resolved through compliance with NUREG-0619, consistent with the NRC resolution, and compliance with GL 81-11, "BWR Feedwater Nozzle and Control Rod Drive Return Line Nozzle Cracking (NUREG-0619)."

The staff's review of DCD, Tier 2, Section 5.3.1 in accordance with SRP Section 5.3.1 identified areas in which additional information was necessary to complete the review of the reactor vessel materials.

In response to RAI 5.3-1, the applicant confirmed that the carbon content is limited to not exceed 0.02 percent in all welded wrought austenitic stainless steel components in the ESBWR that are exposed to reactor water at temperatures exceeding 93 °C (200 °F). The applicant also stated that the distinction in Table 5.2-4 between 304 and 304L/316 and 316L is only strength. The applicant updated DCD Table 5.2-4 indicating that for these components the maximum allowable carbon content is 0.02 percent.

In response to RAI 5.3-2, the applicant confirmed that the current practice for welding stub tubes to the bottom head is automatic GTAW. The inclusion of manual welding in the DCD is to allow for local repair using manual GTAW or GMAW. The applicant also confirmed that all weld metal is Alloy 82 with stabilization parameter control. Use of Alloy 182 is prohibited in contact with reactor water. The applicant modified the appropriate DCD sections accordingly.

In response to RAI 5.3-3, the applicant stated the following:

- Several BWR reactor vessels have been site assembled. This includes Vermont Yankee, Monticello, Leibstadt, Clinton, and Limerick. The process for ESBWR has not been finalized at this time, but it is anticipated that the nearly completed reactor vessel will be shipped to the site in two or possibly three sections. Joining of the sections at the site may be done with the vessel axis vertical using mechanized welding equipment. Alternately, temporary rollers may be set up at the site, and the closure weld completed with mechanized SAW or GMAW.
- Local post-weld heat treatment, as allowed by ASME Code, Section III, will be performed on the circumferential weld(s). This is a relatively simple operation because the weld joins two axisymmetric cylinders of uniform thickness. The goal is to locate the welds away from discontinuities. Finite-element analysis will be used to establish the heating pattern and define temperature gradients away from the heated band. This will be followed by stress analysis to demonstrate that stresses in the adjacent material are maintained at acceptable levels. This approach has previously been successfully used to apply local post-weld heat treatment to reactor vessel nozzles where reapplication of nozzle butters was required. Likewise, this approach is routinely used to attach main steam nozzle extension forgings of low alloy steel to the steam nozzle at the ABWR construction sites. Local heat treatment of the final closing weld has been standard practice by some European manufacturers (e.g., the Cofrentes RPV) since most of their furnaces do not have the capacity to heat treat a complete RPV. The local heat treatments were performed using either heating pads or induction heating.

The applicant confirmed that the process of assembling the reactor vessel at a plant site has not been finalized yet. Thus, the staff concludes that the fabrication process and examination process will be verified using the ITAAC described in DCD, Tier 1, Table 2.1.1-2, Item 5.

#### 5.3.1.1.3 Special Methods for Nondestructive Examination

The NDE of the RV and its appurtenances is conducted in accordance with ASME Code, Section III, requirements. Volumetric examination and surface examination are performed on all pressure-retaining welds as required by ASME Code, Section III, Subsection NB-5320. In

addition, all pressure-retaining welds are given a supplemental ultrasonic preservice examination in accordance with ASME Code, Section XI. The ultrasonic examination method, including calibration, instrumentation, scanning, and coverage, is based on the requirements imposed by ASME Code, Section XI, Appendix I.

#### 5.3.1.1.4 Special Controls for Ferritic and Austenitic Stainless Steels

In DCD, Tier 2, Section 5.3.1.4 addresses issues raised in the following regulatory guides affecting the RV:

- RG 1.31 addresses controls on stainless steel welding, which are discussed in DCD, Tier 2, Section 5.2.3.4.2.
- RG 1.34 is not applicable to the ESBWR vessel, because electroslag welding is not used in structural low-alloy steel welds.
- RG 1.43 is not applicable to the ESBWR vessel because the RV is constructed from low-alloy steel forgings or plates conforming to the SA-508, Grade 3, or SA-533, Type B, specification which are produced to fine grain practice. Therefore, underclad cracking is not a concern.
- RG 1.44 addresses the control of sensitization of stainless steel by the use of service-proven low-carbon materials and by the use of appropriate design and processing steps, including solution heat treatment, control of welding heat input, control of heat treatment during fabrication, and control of stresses.
- RG 1.50 delineates preheat temperature control requirements and welding procedure qualifications supplementing those in ASME Code, Sections III and IX. The preheat temperature employed for welding of low-alloy steel meets or exceeds the recommendations of ASME Code, Section III, Appendix D. Components are either held for an extended time at preheat temperature to assure removal of hydrogen, or preheat is maintained until post-weld heat treatment. The minimum preheat and maximum interpass temperature are specified and monitored. Acceptance Criteria II.3.b(1)(a) of SRP Section 5.2.3 for control of preheat temperature require that minimum and maximum interpass temperatures be specified. The minimum preheat and maximum interpass temperatures for welding the ESBWR RV are specified. In addition, welding procedure qualification shall be performed at a temperature within the range of minimum preheat temperature and minimum preheat temperature plus 28 °C (50 °F).
- RG 1.71 addresses welder qualification for areas of limited accessibility, which is addressed in DCD, Tier 2, Section 5.2.3.4.2.
- RG 1.99, "Radiation Embrittlement of Reactor Vessel Materials," Revision 2, issued May 1988, addresses ways to predict changes in transition temperature and USE.
- RG 1.37 addresses the quality assurance requirements for cleaning of systems and components on the site during and at the completion of construction. This cleaning follows written procedures, which ensure both cleanliness and that the components are not exposed to materials or practices that may degrade their performance. For

components containing stainless steel, RG 1.37 presents the procedures. The procedures prohibit contact with low-melting-point compounds and substances that are known to cause SCC or that can release, in any manner, substances that can cause such problems. In addition, controls are placed on the use of grinding wheels and wire brushes, which ensures that they cannot introduce degrading materials either through prior usage or through their materials of construction. In this context, degradation includes SCC. Controls also limit the introduction of unnecessary dirt and require restrictions on dirt-producing processes such as welding or grinding, which include prompt cleaning.

#### 5.3.1.1.5 Fracture Toughness

Compliance with the requirements for fracture toughness testing included in ASME Code, Section III, paragraph NB-2300, and Appendix G to 10 CFR Part 50 ensures adequate fracture toughness of the ferritic materials in the RV.

#### 5.3.1.1.6 Material Surveillance

Appendix H to 10 CFR Part 50 presents the requirements for a material surveillance program for operating reactors. The purpose of the material surveillance program is to monitor changes in the fracture toughness properties of ferritic materials in the RV beltline region, which result from exposure of these materials to neutron irradiation. Material surveillance is accomplished using surveillance capsules, which are holders of archival beltline material and fast neutron (i.e., neutron with energy greater than 1.0 million electron volts) dosimeters. Assessment of the irradiated material samples yields a measure of the embrittlement, and measurement of the dosimeter activation estimates the irradiation exposure.

RG 1.190, "Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence," issued March 2001, which is based on GDC 14, 30, and 31, describes methods and practices acceptable to the staff regarding calculational techniques and statistical practices using the dosimetry measurements. In addition, the results of the dosimetry are used to benchmark and validate calculational methods for estimating vessel irradiation.

Reactor vessel material surveillance specimens are provided in accordance with requirements of ASTM E-185 and Appendix H to 10 CFR Part 50. Materials for the program are selected to represent materials used in the reactor beltline region. Specimens are manufactured from a forging actually used in the beltline region and a weld typical of those in the beltline region and thus represent base metal, weld material, and the weld heat-affected zone (HAZ) material. The base metal and weld are heat treated in a manner that simulates the actual heat treatment performed on the beltline region of the completed vessel. Each in-reactor surveillance capsule contains 36 Charpy V-notch and 6 tensile specimens. The capsule loading consists of 12 Charpy V-notch specimens each of base metal, weld metal, HAZ material, and 3 tensile specimens each from base metal and weld metal. A set of out-of-reactor beltline Charpy V-notch specimens, tensile specimens, and archive material are provided with the surveillance test specimens. Neutron dosimeters and temperature monitors are located within the capsules as required by ASTM E-185.

Four capsules are provided to monitor the 60-year design life of the vessel. This exceeds the three capsules specified in ASTM E-185 as required by Appendix H to 10 CFR Part 50, since the predicted transition temperature shift is less than 55.6 °C (100 °F) at the inside surface of the low-alloy steel vessel.

The following proposed withdrawal schedule is modified from the ASTM E-185 schedule to monitor the RV for its 60-year design life:

- first capsule: after 6 effective full-power years (EFPY)
- second capsule: after 20 EFPY
- third capsule: with an exposure not to exceed the peak end of life (EOL) fluence
- fourth capsule: schedule to be determined based on results of first three capsules per ASTM E-185, paragraph 7.6.2

In response to RAI 5.3-4, the applicant explained that achieving a lead factor exceeding 1.0 is relatively easy in the ESBWR because there are no obstructions in the annulus that restrict placement of the capsule holders. The location of the axial and circumferential flux peaks are known from fluence calculations, and the capsule holders can be placed precisely at these peak locations (there are a total of eight peak locations). Since the capsule holder is mounted somewhat inboard of the vessel wall, a lead factor greater than 1.0 is assured. The applicant modified DCD, Tier 2, Section 5.3.4 (refer to GEH letter MFN 06-152, dated June 6, 2006) and confirmed that the COL applicant/holder will identify the following information:

- specific materials in each surveillance capsule
- capsule lead factors
- withdrawal schedule for each surveillance capsule
- neutron fluence to be received by each capsule at the time of its withdrawal
- vessel EOL peak neutron fluence

In response to RAI 5.3-5, the applicant stated that like all BWRs, the ESBWR will operate at a nominal temperature of about 550 °F (288 °C). The reactor vessel wall inside surface may be slightly but not significantly lower and certainly not below 525 °F.

The applicant also modified DCD, Tier 2, Section 5.3.1.6.1 of the DCD and included a statement that the RV material will not be exposed to normal operating temperatures below 274 °C (525 °F) and that enhanced radiation embrittlement resulting from temperature is of no concern.

The applicant's schedule for removing the capsules for post-irradiation testing includes the withdrawal of four capsules, which is in accordance with ASTM E-185-82 (i.e., the 1982 edition of E-185) and Appendix H to 10 CFR Part 50.

#### 5.3.1.1.7 Reactor Vessel Fasteners

The materials for the fasteners for the RV are controlled as follows:

- Closure studs, nuts, and washers for the main closure flange are of ASME Code, SA-540, Grade B23 or Grade B24, material with a minimum yield strength level of 893 Mpa (129.5 ksi).
- Maximum measured ultimate tensile strength of the stud bolting materials shall not exceed 1172 Mpa (170 ksi).

#### 5.3.1.2 Staff Evaluation

The staff reviewed DCD, Tier 2, Section 5.3.1, "Reactor Vessel Materials," in accordance with SRP Section 5.3.1.

The NRC staff also reviewed the ESBWR RV materials to ensure that they meet the relevant requirements of GDC 1 and GDC 30 and 10 CFR 50.55a(a)(1) related to the material specifications, fabrication, and NDE. Compliance with these requirements will determine whether the RV materials are adequate to ensure a quality product commensurate with the importance of the safety function to be performed. The material specifications for the ESBWR design are in accordance with ASME Code, Section III, requirements and Appendix G to 10 CFR Part 50. In addition, the design and fabrication of the RV conforms with ASME Code, Section III, Class 1, requirements. Furthermore, the RV and its appurtenances are fabricated and installed in accordance with ASME Code, Section III, paragraph NB-4100. The NDE of the RV and its appurtenances is conducted in accordance with ASME Code, Section III, requirements. Examination of the RV and its appurtenances by NDE complies with paragraph NB-5000. The applicant stated that all plates, forgings, and bolting are 100 percent ultrasonically tested and surface examined by magnetic particle methods or liquid penetrant methods as required by ASME Code, Section III, Division 1.

The staff finds this acceptable because compliance with ASME Code, Section III, and Appendix G to 10 CFR Part 50 constitutes an adequate basis for satisfying the requirements of GDC 1 and 30 and 10 CFR 50.55a(a)(1) as they relate to the material specifications, fabrication, and NDE of RV materials.

Section 5.2.3 of this report provides the staff's evaluation of the welding of ferritic steels and austenitic stainless steels and addresses GDC 4.

In DCD, Tier 2, Table 5.3-1 provides the maximum limits for the elements in the materials of the RV beltline. Specified limits for RV materials used in the core beltline region are the following:

- Base Materials: 0.05 percent maximum copper, 0.006 percent maximum phosphorus, 1.0 percent maximum nickel (forging), and 0.73 percent maximum nickel (plate)
- Weld Materials: 0.05 percent maximum copper, 0.008 percent maximum phosphorus, 1.0 percent nickel, and 0.008 percent maximum vanadium

Also, Table 5.3-1 provides the maximum limits for the RV studs, nuts, and washers for the main closure flange.

The tests for fracture toughness of RV materials specified in the DCD are in accordance with ASME Code, Section III, paragraph NB-2300, and Appendix G to 10 CFR Part 50. The staff confirmed that the applicant's initial Charpy V-notch minimum upper-shelf fracture energy levels for the RV beltline base metal transverse direction and welds are 101.7 N-m (75 ft-lbs). DCD, Tier 2, Table 5.3-3, indicates that the EOL values for the USE are greater than 67.8 N-m (50 ft-lbs) for the beltline forgings and welds. The staff confirmed this by using the calculations of RG 1.99 for the beltline forgings and welds. The predicted EOL Charpy USE and adjusted reference temperature for the RV materials are in accordance with the requirements of Appendix G to 10 CFR Part 50. The fracture toughness tests required by the ASME Code and Appendix G provide reasonable assurance that adequate safety margins against the possibility of nonductile behavior or rapidly propagating fracture can be established for all pressure-retaining components of the RV. This methodology will provide adequate safety margins during operating, testing, maintenance, and postulated accident conditions. Compliance with the provisions of Appendix G to 10 CFR Part 50 satisfies the requirements of GDC 14 and 31 and 10 CFR 50.55a regarding the prevention of fracture of the RV. Therefore, the staff finds that the applicant has adequately met the requirements of GDC 14 and 31 and 10 CFR 50.55a for the RV.

The design of an RV must consider the potential embrittlement of RV materials as a consequence of neutron irradiation and the thermal environment. GDC 32 requires that the RCPB components shall be designed to permit an appropriate material surveillance program for the RV. Appendix H to 10 CFR Part 50 details the requirements of such a program.

The applicant explained that since there are no obstructions in the annulus that restrict placement of the capsule holders, achieving a lead factor of greater than 1.0 is relatively easy in the ESBWR. The location of the axial and circumferential flux peaks are known from fluence calculations, and the capsule holders can be placed precisely at these peak locations (there is a total of eight peak locations). Since the capsule holder is mounted somewhat inboard of the vessel wall, a lead factor greater than 1.0 is assured. The applicant also confirmed that it will perform an analysis defining the lead factors and will define the azimuth locations of the surveillance holders. This is included as a COL action item in DCD, Tier 2, Section 5.3.4.

To meet the requirements of GDC 32, the ESBWR design includes provisions for a material surveillance program to monitor changes in the fracture toughness caused by exposure of the RV beltline materials to neutron radiation. Appendix H to 10 CFR Part 50 requires that the surveillance program for the ESBWR RV meets the recommendations of ASTM E-185. ASTM E-185 applies to plants designed for a 40-year life, whereas the design life of ESBWR is 60 years. ASTM E-185 recommends a minimum of three surveillance capsules for an RV with an EOL shift of less than 38 °C (100 °F). The ESBWR surveillance capsule program includes four specimen capsules, with archive materials available for additional replacement capsules. The staff verified that the surveillance test materials will be prepared from samples taken from the materials used in fabricating the beltline of the RV. In addition, the staff verified that the base metal, weld metal, and HAZ materials included in the program will be those predicted to be most limiting in terms of setting pressure-temperature (P/T) limits for operation of the reactor to compensate for radiation effects during its lifetime. The staff finds that the materials selection, withdrawal, and testing requirements for the ESBWR design are in accordance with

those recommended in ASTM E-185-82. Compliance with the materials surveillance requirements of Appendix H to 10 CFR Part 50 and ASTM E-185 satisfies the requirements of GDC 32 for an appropriate surveillance program for the RV. Thus, the ESBWR design meets the requirements of GDC 32.

The applicant indicated that the material used to fabricate the closure studs will meet the fracture toughness requirements of Section III of the ASME Code and Appendix G to 10 CFR Part 50. NDE of the studs will be performed according to Section III of the ASME Code, Subarticle NB-2580. In addition, ISI will be performed according to Section XI of the Code, supplemented by paragraph NB-2545 or NB-2546. The integrity of the ESBWR RV closure studs is assured by conformance with the recommendations of RG 1.65, "Materials and Inspections for Reactor Vessel Closure Studs," issued October 1973, thus satisfying the quality standards requirements of GDC 1 and 30 and 10 CFR 50.55a. Compliance with the recommendations of RG 1.65 also satisfies the requirement in GDC 31 for the prevention of fracture of the RCPB and the requirements of Appendix G to 10 CFR Part 50, as detailed in the provisions of Section III of the ASME Code.

### 5.3.1.3 Conclusions

The staff concludes that the ESBWR RV material specifications, RV manufacturing and fabrication processes, NDE methods of the RV and its appurtenances, fracture toughness testing, material surveillance, and RV fasteners are acceptable and meet the material testing and monitoring requirements of Section III of the ASME Code, Appendices G and H to 10 CFR Part 50, and 10 CFR 50.55a, which provide an acceptable basis for satisfying the requirements of GDC 1, 14, 30, 31, and 32.

### 5.3.2 **Pressure-Temperature Limits**

The staff reviewed DCD, Tier 2, Section 5.3.2, "Pressure-Temperature Limits," in accordance with SRP Section 5.3.2, "Pressure-Temperature Limits and Pressurized Thermal Shock." The applicant's P/T limit curves are acceptable if they meet codes, standards, and regulatory guidance commensurate with the safety function to be performed. This will ensure that the applicant meets the relevant requirements of 10 CFR 50.55a, Appendix G to 10 CFR Part 50, and GDC 1, 14, 31, and 32. These requirements are discussed below.

- GDC 1 requires that SSCs important to safety shall be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function to be performed.
- GDC 14 requires that the RCPB shall be designed, fabricated, erected, and tested so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture.
- GDC 31 requires that the RCPB shall be designed with sufficient margin to assure that, when stressed under operation, maintenance, testing, and postulated accident conditions, it will behave in a nonbrittle manner and minimize the probability of rapidly propagating fracture.

- GDC 32 requires that the RCPB components shall be designed to permit an appropriate material surveillance program for the RV.

The NRC has established requirements in 10 CFR Part 50 to protect the integrity of the RCPB in nuclear power plants. The staff evaluates the P/T limit curves based on Appendix G to 10 CFR Part 50, RG 1.99, and SRP Section 5.3.2.

Appendix G to 10 CFR Part 50 requires that P/T limit curves for the RV be at least as conservative as those obtained by applying the methodology of Appendix G to Section XI of the ASME Code.

RG 1.99 contains methodologies for determining the increase in transition temperature and the decrease in USE resulting from neutron radiation. SRP Section 5.3.2 provides an acceptable method of determining the P/T limit curves for ferritic materials in the beltline of the RV based on the linear elastic fracture mechanics methodology of Appendix G to Section XI of the ASME Code. The basic parameter of this methodology is the stress intensity factor,  $K_I$ , which is a function of the stress state and flaw configuration. Appendix G to the ASME Code requires a safety factor of 2.0 on stress intensities resulting from reactor pressure during normal and transient operating conditions; for hydrostatic testing curves, Appendix G to the ASME Code requires a safety factor of 1.5.

The methods of Appendix G to the ASME Code postulate the existence of a sharp surface flaw in the RV that is normal to the direction of the maximum stress. This flaw is postulated to have a depth that is equal to one-quarter of the RV beltline thickness and a length equal to 1.5 times the RV beltline thickness. The critical locations in the RV beltline region for calculating heatup and cooldown P/T curves are the one-quarter thickness (1/4T) and three-quarters thickness (3/4T) locations, which correspond to the depth of the maximum postulated flaw if initiated and grown from the inside and outside surfaces of the RV, respectively.

The ASME Code, Section XI, Appendix G, methodology requires that applicants determine the limiting materials' adjusted reference temperature (ART or adjusted  $RT_{NDT}$ ). The ART is defined as the sum of the initial (unirradiated) reference temperature (initial  $RT_{NDT}$ ), the mean value of the adjustment in reference temperature caused by irradiation ( $\Delta RT_{NDT}$ ), and a margin (M) term.

The  $\Delta RT_{NDT}$  is a product of a chemistry factor (CF) and a fluence factor. The CF is dependent on the amount of copper and nickel in the material and may be determined from tables in RG 1.99 or from surveillance data. The fluence factor is dependent on the neutron fluence at the maximum postulated flaw depth. The margin term is dependent on whether the initial  $RT_{NDT}$  is a plant-specific or a generic value, and whether the CF was determined using the tables in RG 1.99 or surveillance data. The margin term is used to account for uncertainties in the values of the initial  $RT_{NDT}$ , the copper and nickel contents, the fluence and the calculational procedures. RG 1.99 describes the methodology to use in calculating the margin term.

Appendix H to 10 CFR Part 50 presents the requirements for a materials surveillance program to monitor the changes in fracture toughness properties of materials in the RV beltline region resulting from exposure to neutron irradiation and the thermal environment. These requirements include conformance with ASTM E-185-82. Compliance with Appendix H satisfies the requirements of GDC 32 regarding the provision of an appropriate materials surveillance

program for the RV. The staff reviewed the RV materials to determine whether they meet the relevant requirements of Appendix H as they relate to determining and monitoring material fracture toughness.

In addition, RG 1.190 describes attributes of vessel fluence calculational methodologies (or equivalent) that are acceptable to the staff.

#### 5.3.2.1 Summary of Technical Information

DCD, Tier 2, Section 5.3 describes material properties and the effects of irradiation on material fracture toughness and the irradiation surveillance requirements. DCD, Tier 2, Section 5.3.1.6.5, "Neutron Flux and Fluence Calculations," references DCD, Tier 2, Section 4.1.4.5, "Neutron Fluence Calculations." Reference is made to neutron dosimetry measurements for the purpose of establishing a relation between activation and reactor thermal power. DCD, Tier 2, Section 5.3.3 outlines the vessel design bases for material construction, fabrication, inspection, operating conditions, in-service surveillance, safety design, and power generation. The section continues with the description of RV internals, CRD housing, in-core neutron flux monitoring, RV insulation, and RV nozzle design and inspections. The section concludes with fabrication methods, inspection requirements, and the 10 CFR 50.55a vessel requirements.

The responses to RAIs 5.3-9 to 5.3-12 and 5.3-14 supplement this information. The additional information describes vessel dosimetry and compliance with Appendix H to 10 CFR Part 50 and ASTM-E185, eliminates the reference to RG 1.2 (withdrawn), restates Section 5.3.3, corrects a typo on vessel failure probability, and adds peak vessel fluence and its azimuthal location by expanding Table 5.3-4. Finally, the response to RAI 5.3-14 will add text to DCD Section 4.1.4.5 (Revision 4) to clarify that the application of the staff-approved vessel fluence methodology (NEDC-32983P-A, "GEH Methodology for Reactor Pressure Vessel Fast Neutron Flux Evaluations," issued August 2000) will include resonance self-shielding in the preparation of the working cross-section library.

The ESBWR DCD discussion on P/T limits indicates that the heatup and cooldown P/T limit curves are required as a means of protecting the RV during startup and shutdown to minimize the possibility of brittle fracture. The P/T limits are based on flaw sizes specified in paragraph G-2120 of ASME Code, Section III, Appendix G. The maximum throughwall temperature gradient from continuous heating or cooling at 55.6 °C (100 °F) per hour was considered. The safety factors applied were as specified in the ASME Code, Section III, Appendix G. Beltline material properties degrade with radiation exposure, and this degradation is measured in terms of the ART, which includes a reference nil ductility temperature shift, initial  $RT_{NDT}$ , and margin. The initial  $RT_{NDT}$  of the vessel materials is determined in accordance with the ASME Code, Section III, Subsection NB-2320; DCD, Tier 2, Table 5.3.1 lists the requirements.

The RV flange, RV head and flange areas, feedwater nozzles, bottom head, and the core beltline areas were evaluated, and the operating limit curves are based on the most limiting locations. The P/T limits are based on flaw sizes specified in paragraph G-2120 of ASME Code, Section III, Appendix G. The analysis considered the maximum throughwall temperature gradient from continuous heating or cooling at 55.6 °C (100 °F) per hour. The safety factors applied were as specified in ASME Code, Section III, Appendix G.

The applicant stated that the P/T curves are developed considering a radiation embrittlement of up to 54 EFPYs. This is consistent with an expected plant life of 60 years with 90 percent load factor. The maximum chemical compositions for the RV materials used in the core beltline region are as follows:

- base materials: 0.05 percent maximum copper, 0.006 percent maximum phosphorus, 1 percent maximum nickel (for forging), and 0.73 percent nickel (for plate)
- weld materials: 0.05 percent maximum copper, 0.008 percent maximum phosphorus, 1 percent maximum nickel, and 0.05 percent maximum vanadium

The following shows the results of the RV fluence analysis for the EOL:

- expected peak EOL fluence at the 1/4T location:  $<1.37 \times 10^{19} \text{ n/cm}^2$  ( $E>1.0 \text{ MeV}$ )
- expected 1/4T EOL fluence for the weld above the top of the active fuel:  $<4.14 \times 10^{17} \text{ (n/cm}^2)$  ( $E>1.0 \text{ MeV}$ )

The operating curves are developed in accordance with Appendix G to 10 CFR Part 50. The initial  $RT_{NDT}$  for all RV materials is  $-20 \text{ }^\circ\text{C}$  ( $-4 \text{ }^\circ\text{F}$ ). Thus, a minimum flange and boltup temperature of  $RT_{NDT}$  plus  $33 \text{ }^\circ\text{C}$  ( $60 \text{ }^\circ\text{F}$ ) or  $13 \text{ }^\circ\text{C}$  ( $56 \text{ }^\circ\text{F}$ ) will be used for tensioning at preload condition and during detensioning. In DCD, Tier 2, Figures 5.3-1 and 5.3-2, the applicant provided generic curves for the ESBWR RV design. These are limiting curves based on the maximum copper and nickel contents and EOL peak fluence.

The results of the material surveillance program will be used to verify the validity of  $\Delta RT_{NDT}$  used in the calculation for the development of heatup and cooldown curves. The projected fluence, copper content, and nickel content, along with the  $RT_{NDT}$  calculation, will be occasionally adjusted, if necessary, using the surveillance capsules.

The applicant also indicated that temperature limits for core operation (both critical and noncritical), inservice leak tests, and hydrotests are calculated in accordance with the ASME Code, Section XI, Appendix G.

#### 5.3.2.2 Staff Evaluation

DCD, Tier 2, Section 5.3.1.6.3, "Neutron Flux and Fluence Calculations," references DCD, Tier 2, Section 4.1.4.5, which also does not identify the proposed calculational method, but in turn, references DCD, Tier 2, Section 12.3. The material in Section 12.3 is also irrelevant to the subject. The material reviewed here is from the responses to the RAIs.

DCD, Tier 2, Section 5.3.5 lists the GEH staff-approved fluence methodology topical report NEDC-32983P-A. The staff's evaluation established that this methodology complies with the guidance in RG 1.190 and, therefore, is acceptable.

The RAI 5.3-9 response regarding DCD, Tier 2, Section 5.3.1.6.5, "Time and Number of Dosimetry Measurements," clarifies that the dosimetry will satisfy the requirements of

Appendix H to 10 CFR Part 50 and also ASTM-185, adopted by reference in Appendix H. The proposed set of dosimeters provides adequate spectral coverage. It is noteworthy that jet pumps or other obstructions will not shadow the dosimetry in the ESBWR (as is the case with current BWRs).

The response to RAI 5.3-10 proposed a revised DCD, Tier 2, Section 5.3.3 and, among other things, eliminated reference to RG 1.2, which has been withdrawn, corrected a typo regarding vessel failure probability (RAI 5.3-11), and restated DCD, Tier 2, Section 5.3.3.1. Finally, the response to RAI 5.3-12 supplemented DCD, Tier 2, Table 5.3-4 by adding peak vessel fluence and its azimuthal location for 60 calendar years of operation.

The staff reviewed the P/T limits for the ESBWR in accordance with SRP Section 5.3.2 to ensure adequate safety margins for the structural integrity of the ferritic components of the RCPB.

In response to RAI 5.3-6, the applicant stated that the P/T calculation is performed in accordance with the requirements of Appendix G to 10 CFR Part 50. For the representative curves provided, the material initial  $RT_{NDT}$  data from the RV specification is used. To calculate the adjusted reference temperature (accounting for the effects of irradiation in the vessel beltline region), the copper and nickel specification limits were used in combination with the peak fluence values and the methodology of RG 1.99. This is considered conservative since the actual  $RT_{NDT}$  values and chemical composition are normally much lower than the ones specified. Margins for the adjusted reference temperature calculation are as defined in RG 1.99.

For each individual component (e.g., main steam nozzle), a finite-element model is used to determine the stresses (pressure and thermal) for the transient events for normal and upset conditions. These stresses are then used to determine the applied  $K_I$  for each transient. The most limiting transient  $K_I$  for a given pressure and temperature is then compared to the minimum required  $K_{IC}$  (note that the minimum temperature limits of Appendix G to 10 CFR Part 50 also apply). The minimum required  $K_{IC}$  is based on the limiting  $RT_{NDT}$  of the materials for the component (determined per above) and calculated using the methodology of ASME Code, Section III, Appendix G. For the pressure test condition, a factor of 1.5 is applied to  $K_{IP}$  ( $K_I$  from primary membrane and bending stresses).

For the core not critical and core critical conditions, a factor of 2.0 is applied to  $K_{IP}$ . These safety factors are consistent with ASME Code, Section III, Appendix G. The corresponding DCD, Tier 2, Section 5.3.2.1 is modified accordingly.

The staff accepts the explanation considering the fact that these are only representative P/T limits and that plant-specific P/T limits will be provided during the COL application process (also see the response to RAI 5.3-7). The applicant also stated that the final P/T limits will be developed before plant startup.

The staff reviewed the P/T limits imposed based on the ESBWR RV materials to ensure that they meet the relevant requirements of GDC 1 and 10 CFR 50.55a(a)(1), as they relate to the selection of materials for the RV and their ability to ensure adequate safety margins for the structural integrity of the RV ferritic components. The SRP Section 5.3.2, indicates that P/T limits established for the RCPB must be consistent with the requirements of Appendix G to

10 CFR Part 50 and to ASME Code, Section III, Appendix G to ensure satisfaction of the requirements for RCPB material fracture toughness. The applicant indicated that the temperature limits for core operation (both critical and noncritical), inservice leak tests, and hydrotests are calculated in accordance with Appendix G to 10 CFR Part 50 and ASME Code, Section III, Appendix G. Thus, the probability of the RV material failure and the subsequent effects on reactor core cooling and confinement is minimized. Therefore, the staff finds that the applicant has adequately met the relevant requirements of GDC 1 and 10 CFR 50.55a(a)(1).

The staff reviewed the P/T limits imposed on the RV to ensure that the materials selected for the RV meet the relevant requirements of GDC 14, in that they possess adequate fracture toughness properties to resist rapidly propagating failure and to act in a nonbrittle manner. The applicant indicated that the P/T limit curves will be developed in accordance with the criteria of Appendix G to 10 CFR Part 50, thereby ensuring a low probability of significant degradation or gross failure of the RV that could cause a loss of reactor coolant inventory and a reduction in the capability to confine fission products.

The staff reviewed the RV materials to ensure that they meet the relevant requirements of GDC 31 as they relate to behavior in a nonbrittle manner and an extremely low probability of rapidly propagating fracture. In the DCD, the applicant indicated that RG 1.99 is used to calculate the ART. The staff finds this acceptable because RG 1.99 provides methods for predicting the effects of radiation on fracture toughness properties that are applicable to the requirements of GDC 31. In addition, the staff reviewed the P/T limits that will be imposed on the RCPB during preservice hydrostatic tests, inservice leak and hydrostatic tests, heatup and cooldown operations, and core critical operation. The staff verified that adequate safety margins against nonductile behavior of rapidly propagating failure of ferritic components will exist, as required by GDC 31.

The staff reviewed the RV materials to ensure that they meet the relevant requirements of GDC 32 as they relate to the provision of a materials surveillance program. Compliance with Appendix H to 10 CFR Part 50 satisfies the requirements of GDC 32 for the provision of an appropriate materials surveillance program for the RV. The staff reviewed the RV materials to determine whether they meet the relevant requirements of Appendix H to 10 CFR Part 50, as they relate to determining and monitoring fracture toughness. Section 5.3.2 of this report provides the staff's review of the material surveillance program.

The applicant stated that the P/T limits are in accordance with Appendix G to 10 CFR Part 50, and RG 1.99. The applicant also stated that the vessel flange, RV head and flange areas, feedwater nozzles, bottom head and the core beltline areas were evaluated, and the operating limit curves are based on the most limiting locations. The P/T limits are based on flaw sizes specified in paragraph G-2120 of ASME Code, Section III, Appendix G.

In response to RAI 5.3-7, the applicant stated that a commitment will be provided as a COL action item. This commitment will indicate the need to provide plant-specific information for the development of the P/T limit curves. The applicant revised Tier 2, Section 5.3.4 of the DCD and stated that the COL applicant will provide the P/T limit methodology in a pressure and temperature limits report for NRC review and approval with the plant-specific P/T limits and fracture toughness data.

The applicant confirmed that the fluence analysis was performed using the NRC-accepted methodology as documented in NEDC-32983P-A, Class III (Proprietary), and NEDO-32983-A, Class 1 (Nonproprietary), issued December 2001.

As stated above, the applicant provided P/T curves for the ESBWR design which are shown in DCD, Tier 2, Figures 5.3-2 and 5.3-3. The applicant's DCD indicated that these curves are generic curves for the ESBWR RV design. In addition, they are the limiting curves based on the maximum copper and nickel material composition and EOL neutron fluence values. The applicant also indicated that the COL applicant will address the use of plant-specific curves during procurement of the RV. This is included as a COL action item in DCD, Tier 2, Section 5.3.4.

In response to RAI 5.3-8, the applicant stated that the actual RV material properties will be used to refine the P/T curves before plant startup. The data from the surveillance capsules are available after plant startup in accordance with the schedule defined in DCD, Tier 2, Section 5.3.1.6.1. Appendix H to 10 CFR Part 50, which the COL applicant/holder is required to follow, defines the process to be followed if it is necessary to change the P/T curves based on the results of the surveillance program.

10 CFR 50.34(f)(2)(iii), TMI Action Item II.K.3.45, requires that vessel integrity limits not be exceeded during rapid depressurization and rapid cooldown. The applicant stated that the ESBWR ADS DPVs are sized such that the vessel depressurization and cooldown are slow enough that vessel integrity limits are not exceeded. A comprehensive thermal analysis was performed considering the effect of blowdown and the reflooding by the GDCS. Hypothetical ESBWR accidents are much slower than those of currently operating BWRs. In addition, reactor operating procedures are established so that actual transients would not be more severe than those for which the adequacy of the RV design has been demonstrated.

#### 5.3.2.3 Conclusions

DCD, Tier 2, Section 5.3.2 demonstrates that the methodology for fluence calculations adheres to the guidance in RG 1.190, and, therefore, the methodology is acceptable. Fluence calculations require code benchmarking based on plant-specific dosimetry. In this section, the DCD states that it complies with the requirements of Appendix H to 10 CFR Part 50 and ASTM-185, which govern the plant dosimetry requirements. Therefore, the section is acceptable.

The staff also concludes that the P/T limits imposed on the RCS for operating and testing conditions to ensure adequate safety margins against nonductile or rapidly propagating failure conform with the fracture toughness criteria of Appendix G to 10 CFR Part 50. A material surveillance program developed in conformance with Appendix H to 10 CFR Part 50 will determine the change in fracture toughness properties of the RV beltline materials during operation. The use of operating limits, as determined by the criteria defined in SRP Section 5.3.2, provides reasonable assurance that nonductile or rapidly propagating failure will not occur. This constitutes an acceptable basis for satisfying the requirements of 10 CFR 50.55a, Appendix A to 10 CFR Part 50, and GDC 1, 14, 31, and 32.

### 5.3.3 Reactor Vessel Integrity

The staff reviewed DCD, Tier 2, Section 5.3.3, "Reactor Vessel Integrity," in accordance with the SRP Section 5.3.3. The applicant's assessment of RV integrity is acceptable if it meets codes, standards, and regulatory guidance commensurate with the safety function to be performed. This will ensure that the assessment meets the relevant requirements of 10 CFR 50.55a, Appendices G and H to 10 CFR Part 50, and GDC 1, 4, 14, 30, 31, and 32. These requirements are discussed below.

- GDC 1, GDC 30, and 10 CFR 50.55a(a)(1) require that SSCs important to safety shall be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function to be performed.
- GDC 4 requires that SSCs important to safety shall be designed to accommodate the effects of, and to be compatible with, the environmental conditions associated with normal operation, maintenance, testing, and postulated accidents.
- GDC 14 requires that the RCPB shall be designed, fabricated, erected, and tested so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture.
- GDC 31 requires that the RCPB shall be designed with sufficient margin to assure that, when stressed under operation, maintenance, testing, and postulated accident conditions, it will behave in a nonbrittle manner and will minimize the probability of rapidly propagating fracture.
- GDC 32 requires that the RCPB components shall be designed to permit an appropriate material surveillance program for the RV.
- Appendix G to 10 CFR Part 50 specifies the fracture toughness requirements for ferritic materials of the pressure-retaining components of the RCPB. The staff reviewed the RV materials as they relate to the materials testing and acceptance criteria for fracture toughness contained in Appendix G.
- Appendix H to 10 CFR Part 50 presents the requirements for a material surveillance program to monitor the changes in fracture toughness properties of materials in the RV beltline region resulting from exposure to neutron irradiation and the thermal environment. These requirements include conformance with ASTM E-185. Compliance with Appendix H satisfies the requirements of GDC 32 regarding the provision of an appropriate materials surveillance program for the RV. The staff reviewed the RV materials to determine that they meet the relevant requirements of Appendix H as they relate to determining and monitoring fracture toughness.

#### 5.3.3.1 Summary of Technical Information

The RV is a vertical, cylindrical pressure vessel of welded low-alloy steel forging sections. The vessel is designed, fabricated, tested, inspected, and stamped in accordance with ASME Code, Section III, Class 1 requirements. The ESBWR RV dimensions are as follows:

- nominal inner diameter: 7.112 m (280 in)
- nominal wall thickness including clad: 182 mm (7.17 in)
- minimum cladding thickness : 3.2 mm (0.125 in)
- nominal height from the inside of the bottom head (elevation zero) to the inside of the top head: 27.56 m (90.4 ft)
- bottom of the active fuel location from elevation zero: 4405 mm (14.45 ft)
- top of the active fuel location from elevation zero: 7453 mm (24.45 ft)

The cylindrical shell and top and bottom heads of the RV are fabricated of low-alloy steel, the interior of which is clad with stainless steel weld overlays, except for the top head and most nozzles. The main steam and bottom head drain nozzles are clad with stainless steel weld overlay. The bottom head is clad with nickel-chromium-iron (Ni-Cr-Fe) alloy.

A variety of welding processes, such as electroslag, SAW, manual welding, and automated GTAW, are used for cladding, depending on the location and configuration of the item in the vessel. Cladding in the “as-clad” condition may be acceptable for service if deposits are made with automatic processes such as SAW, GTAW, and electroslag welding. For other processes, particularly where manual welding is employed, some grinding or machining is required. Workmanship samples are prepared for each welding process in the “as-clad” condition and for typically ground surfaces.

The welding material used for cladding in the shell area is ASME Code, SFA-5.9 or SFA-5.4, type 309L or 309MoL, for the first layer, and type 308L or 309L/MoL for subsequent layers. For the bottom head cladding, the welding material is ASME Code, SFA-5.14, type ERNiCr-3. The materials used in the RV are listed in the applicant’s DCD, Tier 2, Table 5.2-4.

The RV is designed and fabricated in accordance with the quality standards set forth in 10 CFR Part 50, GDC 1 and 30, 10 CFR 50.55a, and the requirements of Section III of the ASME Code. The design and construction of the RV enables inspection in accordance with Section XI of the ASME Code. In addition, the design documents impose additional requirements to ensure integrity and safety of the RV. Design of the RV and its support system meets seismic Category I equipment requirements.

All plates, forgings, and bolting are 100 percent ultrasonically tested and surface examined by magnetic particle methods or liquid penetrant methods as required by ASME Code, Section III, Subsection NB. Welds on the RV are examined in accordance with methods prescribed in, and meet the acceptance requirements specified by, ASME Code, Section III, Subsection NB. In addition, the pressure-retaining welds are ultrasonically examined using acceptance standards provided in ASME Code, Section XI.

ISI of the RV shall be in accordance with the requirements of Section XI of the ASME Code. The RV will be examined once before startup to satisfy the preoperational requirements of IWB-2000 of the ASME Code, Section XI. Subsequent ISI will be scheduled and performed in accordance with the requirements of 10 CFR 50.55a(g), as described in Section 5.2.4 of this report.

The material surveillance program monitors changes in the fracture toughness properties of ferritic materials in the RV beltline region resulting from exposure to neutron irradiation and thermal environment. Specimens of actual reactor beltline material will be exposed in the RV and periodically withdrawn for impact testing. Operating procedures will be modified in accordance with test results to assure brittle fracture control.

The RV support is considered a sliding support block type as defined in ASME Code, Section III, Subsection NF-3124. The vessel supports are constructed of low-alloy or carbon steel. Sliding supports are provided at a number of positions around the periphery of the vessel. The vessel support is designed to withstand the loading conditions specified in the design documents and meet the stress criteria of ASME Code, Section III, Subsection NF.

All piping connected to the reactor vessel nozzles has been designed not to exceed the allowable loads on any nozzle. Four drain nozzles are provided in the bottom head. Nozzles connecting to stainless steel piping have safe ends or extensions made of stainless steel. These safe ends or extensions are to be welded to the nozzles after the pressure vessel is heat treated to avoid furnace sensitization of the stainless steel. All nozzles, except the drain nozzles and the water-level instrumentation nozzles, are low-alloy steel forgings in accordance with ASME Code, SA-508, Grade 3, Class 1, material. The safe end materials used are compatible with the material of the mating pipes. The design of the nozzles conforms with ASME Code, Section III, Subsection NB, and meets the applicable requirements of the vessel design documents.

#### 5.3.3.2 Staff Evaluation

Although the staff reviewed most areas separately in accordance with the other SRP sections, the integrity of the vessel is of such importance that a special summary review of all factors relating to RV integrity was warranted. The staff reviewed the fracture toughness of the ferritic materials for the RV, the P/T limits for the operation of the RV, and the materials surveillance program for the RV beltline. SRP Section 5.3.3 provides the acceptance criteria and references that form the bases for this evaluation.

The staff reviewed the information in each area to ensure that inconsistencies did not exist that would reduce the certainty of vessel integrity. The following is a list of the areas reviewed and the sections of this report in which they are discussed:

- RCPB materials (Section 5.2.3)
- RCS pressure boundary ISI and testing (Section 5.2.4)
- RV materials (Section 5.3.1)
- P/T limits (Section 5.3.2)

The integrity of the RV is ensured for the following reasons:

- The RV will be designed and fabricated to the high standards of quality required by the ASME Boiler and Pressure Vessel Code and the pertinent Code Cases.
- The RV will be fabricated from material of controlled and demonstrated quality.
- The RV will be subjected to extensive PSI and testing to ensure that the RV will not fail because of material or fabrication deficiencies.
- The RV will operate under conditions, procedures, and protective devices that ensure that the vessel design conditions will not be exceeded during normal reactor operation, maintenance, testing, and anticipated transients.
- The RV will be subjected to periodic inspection to demonstrate that its high initial quality has not deteriorated significantly under service conditions.
- The RV will be subjected to surveillance to monitor for neutron irradiation damage so that the operating limitations may be adjusted.
- The fracture toughness of the RV materials will be sufficient to ensure that when stressed under operation, maintenance, testing, and postulated accident conditions, they will behave in a nonbrittle manner and will minimize the probability of rapidly propagating fracture.

The ESBWR RV support is considered sliding support block type as defined in ASME Code, Section III, Subsection NF-3124. These supports are not in the region of high neutron fluence, where neutron radiation embrittlement of the supports would be a significant concern. On the basis of the information provided, the staff considers the RV supports for the ESBWR design to be adequately designed to withstand the effects of radiation, and thus the new Generic Issue 15, "Radiation Effects on Reactor Vessel Supports," is resolved for the ESBWR design.

#### 5.3.3.3 Conclusions

The staff concludes that the structural integrity of the ESBWR RV meets the requirements of GDC 1, 4, 14, 30, 31, and 32 of Appendix A to 10 CFR Part 50; Appendices G and H to 10 CFR Part 50; and 10 CFR 50.55a. Therefore, the staff finds the structural integrity of the ESBWR RV to be acceptable. The basis for this conclusion is that the design, materials, fabrication, inspection, and quality assurance requirements of the ESBWR plants conforms to the applicable NRC regulations and regulatory guides discussed above, as well as to the rules of Section III of the ASME Code. The ESBWR meets the fracture toughness requirements of the regulations and Section III of the ASME Code, including requirements for surveillance of vessel material properties throughout its service life, in accordance with Appendix H to 10 CFR Part 50. In addition, operating limitations on temperature and pressure will be established for the plant in accordance with Appendix G, "Protection Against Nonductile Failure," of ASME Code, Section III, and Appendix G to 10 CFR Part 50.

## **5.4 Component and Subsystem Design**

**5.4.1 Reactor Coolant Pumps—Not applicable to the ESBWR**

**5.4.2 Steam Generators—Not applicable to the ESBWR**

**5.4.3 Reactor Coolant Piping—Not applicable to the ESBWR**

**5.4.4 [Reserved]**

**5.4.5 [Reserved]**

### **5.4.6 Isolation Condenser System**

#### **5.4.6.1 Regulatory Criteria**

The staff reviewed DCD, Tier 2, Section 5.4.6, “Isolation Condenser System (ICS)” using relevant portions of SRP Section 5.4.6, “Reactor Core Isolation Cooling System (RCIC),” Revision 4. Since the ICS is part of the ECCS, the staff also used SRP Section 6.3, “Emergency Core Cooling System,” Revision 3.

Acceptance criteria are based on the following:

- GDC 4 as related to dynamic effects associated with flow instabilities and loads (e.g., water hammer)
- GDC 5, “Sharing of Structures, Systems, and Components,” as it relates to SSCs important to safety not being shared among nuclear power units unless it can be demonstrated that sharing will not impair the ability of the SSCs to perform their safety function
- GDC 33, “Reactor Coolant Makeup,” as it relates to the system’s capability to provide reactor coolant makeup for protection against small breaks in the RCPB so that fuel design limits are not exceeded
- GDC 34, “Residual Heat Removal,” as it relates to the system design being capable of removing fission product decay heat and other residual heat from the reactor core to preclude fuel damage or RCPB overpressurization
- GDC 54, “Systems Penetrating Containment,” as it relates to the provision of leak detection and isolation capabilities for piping systems penetrating primary containment
- 10 CFR 50.63, “Loss of All Alternating Current Power,” as it relates to design provisions to support the plant’s ability to withstand and recover from a station blackout (SBO) of a specified duration.

Section 6.3 of this SER presents the acceptance criteria and the evaluation of the ICS as an ECCS.

#### 5.4.6.2 Summary of Technical Information

The ICS removes decay heat after any reactor isolation during power operations. Decay heat removal limits additional pressure rise in the reactor and keeps the RPV pressure below the SRV pressure setpoint. The system consists of four independent loops, each containing a vertical heat exchanger that condenses steam on the tube side and transfers heat by heating/evaporating water in the isolation condenser/passive containment cooling system (IC/PCCS) expansion pools, which are vented to the atmosphere.

To place an IC into operation, condensate return valves are opened whereupon the standing condensate drains into the reactor and the steam-water interface in the IC tube bundle moves downward below the lower headers to a point in the main condensate return line. The ICS can also be initiated manually from the MCR. Each IC has a fail-open nitrogen piston-operated condensate return bypass valve, which opens if the 250-V dc power is lost.

The IC/PCCS expansion pool is divided into subcompartments that are interconnected at their lower ends to provide full use of the water inventory for heat removal by any IC. The fuel and auxiliary pools cooling system (FAPCS) performs cooling and cleanup of IC/PCCS expansion pool water. During IC operation, IC/PCCS pool water can boil, and the steam produced is vented to the atmosphere.

ICs are capable of achieving and maintaining safe stable conditions for at least 72 hours without operator action following non-LOCA events. Operator action is credited after 72 hours to refill IC/PCCS pools or initiate shutdown cooling.

The IC/PCCS pool has an installed capacity that provides at least 72 hours of reactor decay heat removal capability. The heat rejection process can be continued indefinitely by replenishing the IC/PCCS pool inventory. A safety-related FAPCS makeup line is provided to convey emergency makeup water into the IC/PCCS expansion pool from a water supply outside of the reactor building. The flow path for this makeup can be established by manually opening the isolation valve on the FAPCS makeup line located at grade level in the yard area external to the reactor building.

The ICS passively removes sensible and core decay heat from the reactor (i.e., natural convection transfers heat from the IC tubes to the surrounding IC/PCCS expansion pool water, and no forced circulation equipment is required) when the normal heat removal system is unavailable.

The ICs are sized to remove post-reactor isolation decay heat with three of four ICs operating and to reduce reactor pressure and temperature to safe shutdown conditions (420 °F), with occasional venting of radiolytically generated noncondensable gases to the suppression pool. The ICS operation is independent of station alternating current (ac) power and function whenever normal heat removal systems are unavailable to maintain reactor pressure and temperature below required limits.

The control room operators can perform periodic surveillance testing of the ICS valves via remote manual switches that actuate the isolation valves and the condensate return valves. Status lights on the valves verify the opening and closure of the valves. The essential monitored parameters for the IC/PCCS expansion pools are pool water level and pool radiation.

IC/PCCS expansion pool water level monitoring is a function of the FAPCS. IC/PCCS expansion pool radiation monitoring is a function of the process radiation monitoring system.

#### 5.4.6.3 Staff Evaluation

The staff assessed the design and function of the ESBWR ICS as described in Revision 3 of DCD, Tier 2.

The ICS in the ESBWR is part of the ECCS and also serves as a standby source of cooling water to provide a limited decay heat removal capability whenever the main feedwater system is isolated from the reactor vessel. In addition, the ICS will provide decay heat removal necessary for coping with an SBO. The water supply for the ICS pools comes from the condensate demineralizer outlet or from the condensate storage tank.

The ICS is designed and qualified as a safety system.

The ICS removes residual and decay heat from the reactor. The system employs natural circulation as the driving head through the isolation condenser vertical tubes. The shell side of the condenser is the IC/PCCS expansion pool which boils off to remove heat transferred from the reactor. The heated IC/PCCS expansion pool vents to the outside atmosphere. This is achieved with minimal loss of coolant inventory from the reactor when the normal heat removal system is unavailable subsequent to any of the following events:

- reactor isolation
- SBO
- ATWS
- LOCA

The IC operation automatically limits the reactor pressure and reduces the probability of SRV and ADS operation.

The staff reviewed the piping and instrumentation diagram to verify that the essential ICS components are designated seismic Category I. The portions of the ICS (including isolation valves) that are located inside the containment and on the steamlines out to the IC flow restrictors are designed to ASME Code, Section III, Class 1, QG A. Other portions of the ICS are ASME Code, Section III, Class 2, QG B. The IC/PCCS expansion pools are safety-related and seismic Category I. Section 3.6.2 of this report discusses protection of the ECCS against pipe whip and discharging fluids (GDC 4). Section 3.11 of this report discusses environmental qualification of the ECCS equipment.

The ICS consists of four independent loops, and the ICS heat exchangers are sized to remove post-reactor isolation decay heat with three out of four ICs operating (101.25 MWt) and to reduce reactor pressure and temperature to safe shutdown conditions. Since the ICS design is capable of removing fission product decay heat and other residual heat from the reactor core (101.25 MWt), the system meets GDC 34.

The IC, connected by piping to the RPV, is placed at an elevation above the RPV. When the steam is condensed, the condensate is returned to the vessel via a condensate return pipe.

The steam-side connection between the RPV and the IC is usually open during normal operation. The accumulated subcooled water in the condensate return line is used for reactor coolant makeup during a LOCA.

Any of the following sets of signals generates an actuation signal for the ICS to come into operation:

- two or more MSIV valve positions at less than or equal to 92 percent open, with an MSIV valve position on another main steam line (MSL) less than or equal to 92 percent open, with reactor mode switch in "run" only (percent-open values are those used in the safety analyses)
- RPV dome gauge pressure greater than or equal to 7.447 MPa (1080 psig) for 10 seconds
- reactor water level below Level 2, with time delay
- reactor water below Level 1
- loss of feedwater (loss of power to two out of four feedwater pumps) in reactor run mode
- operator manual initiation

The condensate return line is provided with two parallel valves, a motor-operated main valve which fails as is and a nitrogen piston-operated fail-open valve. This diversity provides more reliability for the system. Two normally closed, fail-closed, solenoid-operated lower head vent valves are located in the vent line from the lower headers. They can be actuated both automatically (when RPV pressure is high and either of the condensate return valves is open) and manually by the control room operator. Two normally closed, motor-operated lower head bypass vent valves allow the operator to vent noncondensable gases in case of failure of the automatic lower head vent valves. The vent line from the upper headers is provided with two normally closed, fail-closed, solenoid-operated upper header vent valves to permit opening of the noncondensable gas flow path by the operator. All the vent valves will be located in vertical pipe run near the top of the containment. The vent lines will be sloped to the suppression pool to prevent accumulation of condensate in the piping. During ICS standby operation, discharge of potential entrained hydrogen excess or air is accomplished by a purge line that takes a small stream of gas from the top of the IC and vents it to the MSL. In RAI 5.4-32 Supplement 2, the staff asked GEH for a detailed description of the nitrogen rotary motor-operated valve and the pneumatic piston-operated valve operation, including the actuator. The staff identifies this as **Open Item 5.4-32**.

The four radiation monitors in the IC/PCCS expansion pool steam atmospheric exhaust passages for each IC loop are used to detect leakage from the IC outside the containment. Four sets of differential pressure transmitters are located in the steamline and the condensate return line to detect excessive flow as a result of a pipe break or a leak. The IC is isolated automatically when either a high radiation level in the IC pool area is detected or excess flow is detected in the steam supply line or condensate return line.

The IC/PCCS expansion pools have an installed capacity that provides at least 72 hours of reactor decay heat removal capability. The heat rejection can be continued indefinitely by replenishing the IC/PCCS expansion pool inventory. A safety-related independent FAPCS makeup line is provided to convey emergency makeup water into the IC/PCCS expansion pool from the site fire protection system .

The ICS will have controls that will shut down the system if operating conditions exceed certain limits. The ICS is equipped with a leak detection system.

The vendor testing program conducted at PANTHERS/IC test facility in Siet, Italy, included the IC performance test. The Siet test facility also performed full-scale testing on the SBWR isolation condenser. The purpose of the prototype IC test was to show the capability of the IC heat exchanger to meet its design requirements for heat rejection (component performance). Section 21.5 of this report describes the staff evaluation of this vendor test.

Periodic heat removal capability testing of the ICS will be performed. During plant outages, routine ISI is required for the IC, piping, and supports according to ASME Code requirements. The technical specifications provide periodic test and surveillance requirements for essential components of the system. Chapter 14 of this SER discusses the proposed initial test program.

The ICS is also part of the ECCS, and Section 6.3 of this SER describes the evaluation of the ECCS function of the system.

In RAI 5.4-37, the staff identified that the ICS and DPVs are connected to common stub lines from the reactor vessel. In the early stages of RCS depressurization, if the ICS is in operation, blowdown through the DPVs may draw fluid back from the cold side of the IC, as well as from the upper part of the reactor vessel. Depressurization loads will also affect the ICS, which serves as the primary boundary between the RCS and the environment, since the IC pools are outside of the containment. Because the ICS is part of the ECCS, the ICS should be physically separate from DPVs, which are also part of the ECCS. The staff requested that GEH discuss the ramifications of the common-tie between the ICS and DPVs on the stub line from the reactor vessel, explain why the design does not meet the physical separation criterion for the ECCS, and describe in detail the potential system interactions and explain why there is no negative impact from the cross-tie between the IC steamline and DPVs.

In its response, GEH supplied the following information:

The cross-tie between IC steamline and DPVs in the ESBWR produces no significant negative impact on the loads and safety margins. The key details are as follow:

1. During a LOCA event, the peak operation of ICS occurs during the early part of the depressurization and before the DPV openings.
2. At the time of first DPV opening, there is no subcooled water inside the IC drain line and in the downcomer region. The total dynamic head (DPV flow + IC steam flow) inside the stub tube is small and will not induce backflow into the IC tubes.

3. Failure of one IC drain valve or one DPV valve will not prevent the operation of the other system connecting to the common stub line.
4. Based on (1) and (3), the common-tie between the ICS and DPVs on the stub line has no significant impact on the safety margins (refer to (5) below). Therefore, the physical separation of these two systems is not necessary.
5. Parametric studies were performed with and without the function of the IC heat transfer (i.e., no IC condensation). The results indicate that the long-term containment pressure is slightly higher for the case without the function of IC heat transfer.

The following paragraphs provide additional details on the system interactions:

The nozzles for the stub line and the IC drain line connect to the RPV at elevations of 21.9 and 13.0 m, respectively (reference to the RPV bottom). The bottom of IC tubes is approximately at 6 m above the stub line elevation, or approximately 15 m above the IC drain line nozzle elevation.

In the early stages of reactor coolant system (RCS) depressurization (0 ~ 500 seconds, before the opening of DPVs), the ICS are in operation and condense significant amount of steam flow (~36 kg/s per IC, MSL break case) from the RPV. The steam flow to the ICS reduces as the RPV pressure decreases and the downcomer water level drops. The first group of ADS valves open after the downcomer level drops below the Level 1.0 setpoint (11.5 m from the RPV bottom, Table 6.3-1, DCD Rev. 2). Consequently, both the RPV pressure and the steam flow to the ICS reduce further after the first ADS valve opening. The first group of DPV valves opens at 50 seconds after the first ADS valve opening. At this time, the RPV pressure decreases to about 700 kPa (100 psia), the DPV flow is about 7.5 kg/s per DPV and the IC steam flow reduces to about 4 kg/s per IC. The total velocity inside the stub tube is in the range of 35 m/s. The dynamic head is in the range of 2.2 kPa (0.3 psia), which is small compared to the static head of two-phase mixture in the vertical portion of the IC drain line.

At the time of DPV opening, the RPV downcomer as well as the IC drain lines are filled with saturated two-phase mixture due to the fast depressurization resulting from the opening of ADS valves. As the result of additional depressurization from the DPV opening, the downcomer two-phase level could swell up a few meters from the Level 1.0 position, and get closer to or below the stub line elevation. However, there is no subcooled water inside the IC drain line, or inside the downcomer near by the nozzle elevations of the IC drain line or the stub line. In addition, there are loop seals at the lowest elevation of the IC drain lines, near by the injection nozzles. The loop seal provides extra static head, in addition to the 15 meters of static head of the two-phase mixture inside the vertical portion of the IC drain line, to prevent any flow reversal in the IC drain line and steam inlet line due to the DPV opening.

GEH indicated that the information provided in response to RAI 5.4-37 S01 is included in DCD, Tier 2, Revision 3, Sections 5.4.6.2.2 and 5.4.6.2.3. The staff determined that the information provided in DCD, Tier 2, Revision 3, Sections 5.4.6.2.2 and 5.4.6.2.3 is adequate to comply with the requirements of 10 CFR 52.47(a)(4), NUREG-0933, Task Action Plan A-17, Systems Interactions in Nuclear Power Plants. Therefore, RAI 5.4-37 is considered resolved.

Section 14.3 of this SER describes the adequacy and the acceptability of the ESBWR design description and ITAACs. Section 6.2 of this report discusses containment isolation in accordance with the requirements of GDC 54.

GDC 5 is not applicable since the ESBWR is a single-unit plant.

In its letter MFN 06-249, GEH stated that the condensate return line is sloped downward from the IC to an elevation below reactor water level to reduce the trapping and collapse of the steam in the drain piping. The staff believes that this sloping will reduce the potential for water hammer events during system startup.

The ICS is designed as a high-pressure reactor coolant makeup system that will start independent of the ac power supply. IC heat exchangers are independent of plant ac power, and they function whenever normal heat removal systems are unavailable to maintain reactor pressure and temperature below limits. Subsequent to an SBO, the system is initiated when the RPV water level 2 is reached following the feedwater pumps trip. The ICS initiates when the condensate return line valve opens using safety-related dc power.

The IC/PCCS expansion pool makeup serves as a clean water supply for replenishing the level during normal plant operation and level monitoring is provided from the FAPCS.

Because the materials selected for the IC are considered corrosion resistant, leakage across these components to the IC/PCCS pool is not expected. As a result, the prompt identification and response to leakage are important since the leakage indicates degradation of this barrier. In response to RAI 5.4-53, the applicant indicated that the alarm setpoint (in contrast to the high radiation setpoint) is selected close enough to background so that the alarm gives an early warning of a detected leak. In this response, however, the applicant did not indicate the actions to be taken in response to such an IC radiation alarm (e.g., plant shutdown, inspection of the IC tubes), nor did it address why the leak rate associated with a critical size was not used in determining when the IC should be isolated. The staff identifies this as **Open Item 5.4-53**.

In RAI 5.4-20, the staff requested that the applicant provide detailed information pertaining to the IC design. In response to RAI 5.4-20 (GEH letter MFN 06-479 dated November 20, 2006), the applicant indicated that the IC tubes would be fabricated from a modified form of Alloy 600 (ASME Code Case N-580-1). However, in other portions of its submittal, the applicant stated that Alloy 600 would be used in the fabrication of the IC tubes. As part of its response to RAI 5.4-20, the applicant also indicated that the IC tubes will be bent by induction bending. However, the applicant did not indicate what effect, if any, this would have on the material properties of the tubing nor did it indicate what testing, if any, was performed to confirm the acceptability of the material properties following bending of the piping/tubing. In supplemental RAI 5.4-20 dated January 4, 2007, the staff asked the applicant to clarify the actual type of Alloy 600 used in the IC. With regard to the applicant's discussion of induction bending of IC tubes, the staff requested that the applicant discuss how it has confirmed that the material

properties of the most limiting bent tube remain acceptable following induction bending. The staff also asked the applicant to include a discussion of the material properties tested (e.g., hardness), the results, and the acceptance criteria.

In response to RAI 5.4-20, the applicant indicated that the design of the support structures of the IC tubes was not currently available. The staff notes that depending on the design, possible crevices between the IC tube and the support could result in the accumulation of chemical contaminants that could lead to corrosion. In addition, the materials of construction of the support are important in that they could corrode and result in a loss of support for, or damage to, the IC tubes. Because material selection and specific design attributes, such as the presence of crevices, can contribute to degradation, the staff requested, in supplemental RAI 5.4-20, that the applicant provide a COL action item to submit this information. The staff identifies these issues related to the IC as **Open Item 5.4-20**.

Table 6.1-1 indicates that Alloy 600 is used for IC tubing and header fabrication. Alloy 600 has a history of being susceptible to SCC in LWR systems. In RAI 6.1-10, the staff asked the applicant to provide a basis for the use of Alloy 600 in the IC, including material condition (i.e., mill annealed or thermally treated) as it relates to susceptibility to SCC in the reactor coolant and demineralized water environment. In GEH letter MFN 06-365 (October 4, 2006), the applicant indicated that there have been no reports of Alloy 600 cracking in BWRs in the absence of a welded crevice or a crack initiated in adjacent Alloy 182. These initiating features are absent from the ESBWR design. In addition, the material used for the IC is the same alloy as used for reactor shroud support and stub tubes (see RAI response 4.5-18). This alloy (see ASME Code Case N-580-1) is a significantly modified version of Alloy 600 wherein the carbon content is limited, niobium (columbium) is added as a stabilizer, and high-temperature solution heat treatment is required instead of a mill anneal. Stress corrosion resistance is very good. The alloy is approved for use by the ASME Code (Code Case N-580-1) and has been deployed in several operating BWRs, including the Kashiwazaki-Kariwa 6/7 ABWRs. Several of these units have been operating for more than 10 years. In RAI 5.4-55, the staff requested that the applicant discuss the corrosion allowances for Alloy 600 used in the IC. The applicant responded in GEH letter MFN 06-501 (December 11, 2006) that the Alloy 600 tubing in early BWR ICs performed satisfactorily without incident related to general corrosion in this application. Although general corrosion is not a concern, the applicant did not address whether any other incidences of corrosion or other degradation have occurred in operating units. The staff identifies this issue as **Open Item 5.4-55**.

For the passive containment cooling system (PCCS), the staff asked GEH to provide the same information as requested in supplemental RAI 5.4-58. In addition, the staff requested that GEH discuss whether the cracking that occurred in earlier ICs (refer to GEH response to RAI 5.4-54) could occur in the PCCS heat exchanger. If so, the applicant should discuss the inspections needed to ensure timely detection of cracking. The staff identifies this as **Open Item 5.4-57**.

In response to RAI 5.4-58, the applicant indicated that modified Alloy 600 has been in service for a number of years, but it is not currently inspected as part of a formal ISI program. In RAI 5.2-56, the staff asked the applicant to confirm that the method/technique for inspection of IC tubes is capable of detecting general wall thinning, pit-like defects, and SCC along the entire length of the tube. In response to RAI 5.4-56, the applicant indicated that because of the size of the IC tubes (2 nominal pipe size (NPS)), the IC tubes are exempt from volumetric and surface inservice examinations by ASME Code, Section XI, IWC-1220, which exempts sizes

NPS 4 and smaller. The applicant contends that the ICs are subject to leakage (VT-2) examination under ASME Code Section XI. Given the lack of long-term service experience (with inspection results) and the limitations of accelerated corrosion testing to fully simulate the range of variables that may exist in the field (and are pertinent to corrosion), in supplemental RAI 5.4-58, the staff requested additional information concerning the inspection and acceptance criteria for the IC tubes or justification as to why inspection requirements are not needed. The staff noted that the applicant's response to RAI-5.4-56 did not address the information requested by the staff in that RAI. Supplemental RAI 5.4-58 also requested that the applicant address the original RAI 5.4-56. The staff identifies these issues as **Open Items 5.4-56 and 5.4-58**.

In response to RAI 5.4-47, GEH, in MFN letter 06-265, stated that corrective maintenance for IC tube plugging following tube leak detection can be performed during refueling. After closing the isolation valves to/from the IC and after emptying its pool, personnel operating from the refueling floor can perform subcompartment plugging/repair of the leaking tube. Maintenance will be performed from the upper and lower end, after removal of the header covers. A remotely operated tool will be used to reduce radiation exposure to personnel. If there is considerable damage to some component part of the IC, each module of the IC unit is designed to be easily removable, after cutting the feed, drain, and vent lines. Also, the pool water in a specific IC subcompartment is designed to be removable without requiring the emptying of the remaining IC/PCCS expansion pools.

In response to RAI 5.4-51, GEH, in letter MFN 06-265, stated that the ICS is designed to remove post-reactor isolation decay heat with three out of four IC heat exchangers operating and to reduce the RCS temperature to safe shutdown conditions of 400 °F in 36 hours with occasional venting to the suppression pool of radiolytically generated noncondensable gases. The ICS is capable of achieving and maintaining the safe shutdown conditions without operator action for at least 72 hours. The safety-related flow paths of the FAPCS are designed to provide makeup water past 72 hours to the ICS. The FAPCS has the ability to supply water to the ICS pools when connected to the fire protection system (FPS). Permanently installed piping is included in the FAPCS, which is connected directly with the site FPS, and this can provide makeup water from 72 hours through 7 days.

Periodic heat removal capability testing of the IC is performed during normal plant operation at 5-year intervals.

On August 10, 2006, GEH informed the staff that it was incorporating a change in the ICS drain line into the ESBWR design. The reason for this change is to improve operator flexibility and to maintain minimum chimney collapsed level during a LOCA. This change also reduces the probability of ADS trip in SBO and loss-of-feedwater events. In addition, this change resulted in the elimination of the Level 1.5 trip and simplified ADS logic with only a Level 1 setpoint. The new inline vessel (tank) is located on each ICS train condensate return line to provide the additional condensate volume for the RPV. The following information should be added to the ICS ITAAC:

1. The calculated flow resistance in TRACG between the ICS condensate return line and the reactor.

2. In ITAAC No. 20, the total volume assumed in the analysis for the IC/PCCS expansion pool.

The staff identifies this as **Open Item 14.3-146**.

In addition, the staff requested in RAI 5.4-22 Supplement 2 that GEH discuss the means it will use to make certain that the ICS drain line is full during normal operation thus ensuring that the water volume assumed in the safety analysis is available for injection on a LOCA signal. GEH provided its response in MFN 06-265 Supplement 1, dated June 21, 2007, which is currently under staff review. Therefore, the staff identifies this issue as **Open Item 5.4-22**.

The staff requested the following information, identified as **Open Item 5.4-59**:

Provide additional information regarding operation of the reactor water cleanup/shutdown cooling (RWCU/SDC) system during Modes 5 and 6 (cold shutdown and refueling).

- (A) Provide a drawing of the ESBWR vessel showing the elevations of the feedwater (FW) nozzles and the RWCU/SDC piping penetrations inside and outside the shroud.
- (B) Include a discussion in the DCD regarding vessel level for normal RWCU/SDC operation in all modes, including Modes 4, 5, and 6.
- (C) Perform a calculation demonstrating under what temperatures and levels the RWCU/SDC system can adequately remove decay heat in Modes 4, 5, and 6 (with the RPV head installed) including any minimum and maximum temperatures and levels.
- (D) Include a discussion in the DCD regarding RWCU/SDC flow and mixing within the vessel and within the shroud.
- (E) Address thermal-hydraulic uncertainty.
- (F) Address the impact on the ESBWR shutdown PRA.

Section 15.6 of this SER discusses the ESBWR design's compliance with 10 CFR 50.63.

#### 5.4.6.4 Conclusions

Section 14.3 of this report presents the evaluation of the adequacy and acceptability of the ICS design description and ITAACs.

Due to the open items that remain to be resolved for this section the staff was unable to finalize its conclusions regarding acceptability.

## 5.4.7 Residual Heat Removal

### 5.4.7.1 Regulatory Criteria

The staff reviewed DCD, Tier 2, Section 5.4.7, in accordance with the staff position given in the applicable sections of SRP Section 5.4.7, Revision 4.

Because of the functional limitations of the passive plant designs, the Commission, in a staff requirements memorandum (SRM) dated June 30, 1994, approved the position in SECY-94-084, "Policy and Technical Issues Associated with the Regulatory Treatment of Non-safety systems in Passive Plant Designs," dated March 28, 1994. This position accepts 420 °F or lower, rather than the cold shutdown specified in RG 1.139, "Guidance for Residual Heat Removal," issued for comment in May 1978, as the safe stable condition that the passive systems must be capable of achieving and maintaining following non-LOCA events.

Acceptance criteria are based on the following:

- GDC 1 as it relates to the quality standards of the SSCs important to safety
- GDC 2 with respect to the seismic design of the system
- GDC 4 as related to dynamic effects associated with flow instabilities and loads (e.g., water hammer)
- GDC 5 as it relates to SSCs important to safety not being shared among nuclear power units unless it can be demonstrated that sharing will not impair the ability of the SSCs to perform their safety function
- GDC 19, "Control Room," as it relates to the provision of a control room from which actions can be taken to operate the nuclear power plant
- GDC 34 as it relates to the system design's capability to remove fission product decay heat and other residual heat from the reactor core to preclude fuel damage or RCPB overpressurization

### 5.4.7.2 Summary of Technical Information

The shutdown cooling (SDC) mode of the RWCU system is the normal residual heat removal system for the ESBWR. The RWCU/SDC performs the following functions:

- removal of decay heat during normal plant shutdowns
- removal of the core decay heat, plus displacement of the CRD cooling flow approximately one-half hour following control rod insertion, assuming either the main condenser or ICS is available for initial cooldown
- with loss of preferred offsite ac power, bringing the plant to cold shutdown in 36 hours in conjunction with the ICS, assuming the most restrictive single-active failure

In conjunction with the heat removal capacity of either the main condenser and/or the ICS, the RWCU/SDC system can reduce the RPV pressure and temperature during cooldown operation from the rated design pressure and temperature to below boiling at atmospheric pressure in less than 1 day. The system is also designed to control the reactor temperature reduction rate. The system can be connected to non-safety-related standby ac power (diesel generators), which allows the system to fulfill its reactor cooling functions during conditions when the preferred power is unavailable.

The shutdown cooling function of the RWCU/SDC system provides decay heat removal capability at normal reactor operating pressure, as well as at lower reactor pressures. The redundant trains of the RWCU/SDC system permit shutdown cooling even if one train is out of service; however, cooldown time is extended when using only one train. If preferred power is lost, the RWCU/SDC system, in conjunction with the ICS, is capable of bringing the RPV to the cold shutdown condition in 36 hours, assuming the most limiting single-active failure, and with the ICs removing the initial heat load.

The operation of the RWCU/SDC system at high reactor pressure reduces the plant reliance on the main condenser or ICS. The entire cooldown is controlled automatically. As cooldown proceeds and reactor temperatures are reduced, pump speeds are increased and various bypass valves are opened, as described below. During the early phase of shutdown, the RWCU/SDC pumps operate at reduced speed to control the cooldown rate to less than the maximum allowed RPV cooling rate. To maintain less than the maximum allowed RPV cooling rate, both RWCU/SDC trains are placed into operation early during the cooldown, but with the pumps and system configuration aligned to provide a moderate system flow rate. The flow rate for each train is gradually increased as RPV temperature drops. To accomplish this, in each train, the bypass line around the regenerative heat exchanger and the bypass line around the demineralizer are opened to obtain the quantity of system flow required for the ending condition of the SDC mode. In addition to the reactor component cooling water system (RCCWS) inlet valve to the nonregenerative heat exchanger (NRHX) being open, at an appropriate point, the motor-operated RCCWS inlet valve opens to increase the cooling water flow to each NRHX. The automatic reactor temperature control function governs the adjustable speed drive and controls the cooldown by gradually increasing the speed of the system pumps up to the maximum pump flow. Water purification operation continues without interruption. Over the final part of the cooldown, maximum flow is developed through the RWCU/SDC pumps. Flow rate reduction becomes possible while maintaining reactor coolant temperatures within target temperature ranges. CRD system flow is maintained to provide makeup water for the reactor coolant volume contraction that occurs as the reactor is cooled down. The RWCU/SDC system discharge line is used for fine-level control of the RPV water level as needed.

During hot standby, the RWCU/SDC system may be used as required in conjunction with the main or isolation condenser to maintain a nearly constant reactor temperature by processing reactor coolant from the reactor bottom head and the mid-vessel region of the reactor vessel and transferring the decay heat to the RCCWS by operating both RWCU/SDC trains and returning the purified water to the reactor via the feedwater lines. The pumps and the instrumentation necessary to maintain hot standby conditions are connectable to the standby ac power supply during any loss of preferred power.

The RWCU/SDC system can be used to supplement the FAPCS spent fuel heat removal capacity during refueling (or at other times). The system also can provide additional cooling of the reactor well water when the RPV head is off in preparation for removing spent fuel from the core.

In conjunction with the ICs, the system has the capability of removing the core decay heat, plus drain excess makeup resulting from the CRD purge flow, 30 minutes following control rod insertion.

#### 5.4.7.3 Staff Evaluation

The staff assessed the design and function of the RWCU/SDC for the ESBWR as described in Revision 3 of the DCD, Tier 2.

The ESBWR RWCU/SDC is a non-safety-related system and is not required to operate to mitigate design-basis events. However, some of the valves of the RWCU/SDC perform the following safety-related isolation functions:

- containment isolation of RWCU/SDC lines penetrating containment using containment isolation valves according to the criteria specified in DCD, Tier 2, Section 6.2.4.
- preservation of the RCS pressure boundary integrity using pressure isolation valves according to the criteria specified in DCD, Tier 2, Section 5.4.8.

The RWCU/SDC is designed to remove both residual and sensible heat from the core and the RCS during shutdown operations, with the capability to (1) reduce the temperature of the RCS from 270 °C (518 °F) to 49 °C (120 °F) within 96 hours after shutdown in conjunction with the heat removal capacity of main condenser and/or the ICs, and (2) maintain the reactor coolant temperature at 49 °C (120 °F) for the entire plant shutdown.

In SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," dated January 12, 1990, as well as in SECY-93-087, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor (ALWR) Designs," dated April 2, 1993, the staff specified that the ALWR designs should reduce the possibility of a LOCA outside containment by designing, to the extent practical, all systems and subsystems connected to the RCS to an ultimate rupture strength at least equal to full reactor pressure. DCD, Tier 2, Section 5.4.8.1.2, discusses the ESBWR design features that address the intersystem LOCA (ISLOCA). Section 5.4.8.1.2 states that "The supply side of the RWCU/SDC system is designed for the RCPB design pressure plus 10 percent. Downstream of the pumps, the pump shutoff head at 5 percent overspeed is added to the supply side design pressure." The system is designed for operation at reactor pressure, and hence, the ISLOCA issue is resolved for the system.

In SECY-93-087, the staff specified that passive plants must have a reliable means of maintaining decay heat removal capability during all phases of shutdown activities, including refueling and maintenance. The staff's review of the ESBWR design with respect to shutdown operations is based on the applicant's systematic assessment of shutdown operation concerns identified in NUREG-1449, "Shutdown and Low-Power Operations at Commercial Nuclear Power Plants in the United States," issued September 1993. DCD, Tier 2, Section 19.4.7,

“Shutdown PRA Insights,” provides this assessment. Section 19.4 of this report discusses the staff’s evaluation of the shutdown operation issues. This section addresses the issues raised in NUREG-1449.

Both adjustable speed drive pumps are connectable to the diesel generator bus during any loss of preferred power supply. There are two redundant trains, and the SDC has the capability to bring the reactor to cold shutdown conditions.

DCD, Tier 2, Section 5.4.8.1.4 describes inspection and testing requirements for the SDC. Preoperational tests, which include valve inspection and testing, flow testing, and verification of heat removal capability, verify the proper operation of the SDC. The inspection and test requirements of the SDC valves are consistent with those identified in DCD, Tier 2, Section 5.2.4 and 6.2.6, respectively, for the valves that constitute the RCPB and the valves that isolate the line penetrating containment. In addition, DCD, Tier 2, Table 6.2-31, includes these valves, which are subject to IST. The staff finds that the applicant has set proper inspection and test requirements for the SDC valves performing the safety-related functions of containment isolation and RCPB integrity preservation.

The design classifications of the RWCU/SDC components discussed above comply with GDC 1 which specifies that SSCs important to safety shall be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety functions to be performed.

The RCPB portion and the containment isolation valves of the RWCU/SDC are designed as safety Class A. The remaining portions are designed as safety Class B. The system design meets Position C-2 of RG 1.29. This complies with GDC 2 which specifies that the SSCs important to safety shall be designed to withstand the effects of natural phenomena, such as earthquakes. Section 3.6.2 of this report discusses the protection of the RWCU/SDC system against pipe whip and against discharging fluids (GDC 4). GDC 5 is not applicable for the ESBWR design because the RWCU/SDC system is designed for a single nuclear power unit and is not designed to be shared between units. The RWCU/SDC system is operated from the MCR, and hence GDC 19 is satisfied. Because the RWCU/SDC system is not designed to provide safety-related heat removal mitigation of design-basis events, the safety-related ICS complies with the heat removal function of GDC 34. Section 5.4.6 of this SER includes discussions about achieving the safe shutdown condition.

#### 5.4.7.4 Conclusions

Section 14.3 of this report presents the evaluation of the adequacy and acceptability of the RWCU/SDC design description and ITAACs.

The NRC staff has reviewed the applicant’s information related to the RWCU/SDC system. The staff concludes that the applicant has adequately demonstrated that the RWCU/SDC system has the capability to cool the RCS following shutdown and provide decay heat removal. The staff concludes that the RWCU/SDC system meets the requirements of GDC 1, 2, 4, 5, and 19.

## 5.4.8 Reactor Water Cleanup/Shutdown Cooling System

### 5.4.8.1 Regulatory Criteria

The staff reviewed the RWCU/SDC system description in accordance with SRP Section 5.4.8, "Reactor Water Cleanup System (BWR)." Staff acceptance of the design is based on compliance with the requirements of GDC 1, 2, 14, 60, "Control of Releases of Radioactive Materials to the Environment," and 61, "Fuel Storage and Handling and Radioactivity Control." These requirements are discussed below.

- GDC 1 as it relates to the design of the reactor water cleanup system (RWCU) and components to standards commensurate with the importance of the system's safety function
- GDC 2 as it relates to the RWCU being able to withstand the effects of natural phenomena
- GDC 14 as it relates to ensuring the RCPB integrity
- GDC 60 as it relates to the capability of the RWCU to control the release of radioactive effluents to the environment
- GDC 61 as it relates to designing the RWCU with appropriate confinement

RG 1.56, "Maintenance of Water Purity in Boiling Water Reactors," Revision 1, issued July 1978, describes a method acceptable to the NRC staff for implementing the criteria for minimizing the probability of corrosion-induced failure of the RCPB in BWRs by maintaining acceptable purity levels in the reactor coolant. It also describes instrumentation acceptable to the staff for determining the condition of reactor coolant and the coolant purification system.

### 5.4.8.2 Summary of Technical Information

The two basic functions of the RWCU/SDC system are reactor water cleanup and shutdown cooling. The RWCU/SDC system performs the reactor water cleanup function during startup, normal power operation, cooldown, and shutdown. The shutdown cooling function of the RWCU/SDC system provides decay heat removal capability in conjunction with the main condenser or the ICs at normal reactor operating pressure, as well as at lower reactor pressures. There are two redundant RWCU/SDC trains. Section 5.4.7 of this report presents the review of the shutdown cooling function of the RWCU/SDC system.

The RWCU/SDC system consists of the following major components:

- demineralizers
- valves and piping
- regenerative heat exchangers
- nonregenerative heat exchangers
- pumps with adjustable-speed motor drives

The RWCU/SDC system functions are not safety related; therefore, the system has no safety-related design basis other than a containment isolation function and providing instrumentation for detection of system breaks outside the containment.

#### 5.4.8.3 Staff Evaluation

The staff reviewed the RWCU/SDC system description in accordance with SRP Section 5.4.8. Staff acceptance of the design is based on compliance with the requirements of (1) GDC 1 as related to the design meeting standards commensurate with the system's safety function, (2) GDC 2 as related to the system being able to withstand the effects of natural phenomena, (3) GDC 14 as related to assuring the integrity of the RCPB, (4) GDC 60 as related to the capability of the system to control the release of radioactive effluents to the environment, and (5) GDC 61 as related to designing the system with appropriate confinement.

The RWCU/SDC system performs the following functions:

- removes solid and dissolved impurities from the reactor coolant and measures the reactor water conductivity during all modes of operation in accordance with RG 1.56
- discharges excess reactor water during startup, shutdown, and hot standby conditions and during refueling to the main condenser or to the radwaste system
- minimizes RPV temperature gradients by enhancing circulation through the bottom head region of the RPV and reducing core thermal stratification at low power
- provides containment isolation which ensures that the major portion of the system is outside the RCPB
- provides heated primary coolant for RPV hydrostatic tests and reactor startups
- supplies redundant cleanup capacity with respect to major system components

The RWCU/SDC system is a closed-loop system consisting of two independent pumps and purification equipment. Each train consists of a regenerative heat exchanger (RHX), a nonregenerative heat exchanger (NRHX), a demineralizer, two circulating pumps, isolation valves, piping, and instrumentation. The system takes its suction from the mid-vessel area of the RPV and from the reactor bottom head and discharges back to the vessel via the feedwater lines. Water is cooled by flowing through the tube side of the RHX and the NRHX before pump suction. After the NRHX, water moves to the demineralizer to remove all impurities and returns and reheats the reactor water via the shell side of the RHX. Each train is capable of performing the functions of reactor water cleanup and shutdown cooling. The system capacity is 1 percent of the rated feedwater flow rate.

The system is classified as non-safety-related with the exception of the containment isolation valves. The two independent trains are located in the reactor building. System piping from the RPV to the outboard containment isolation valve forms part of the RCPB and is classified as QG A, ASME Section III, Class 1, and seismic Category I. In the remainder of the system,

downstream of the containment isolation valves, the piping is classified as QG C, ASME Section III, Class 3, and seismic Category I. The RWCU/SDC return line from the isolation valve, up to and including the connection to the feedwater line, is classified as QG B, ASME Section III, Class 2, and seismic Category I.

By letter dated February 1, 2006 (ML060250432), the staff asked the applicant to provide the basis for designing the return line from the isolation valve, up to and including the connection to the feedwater line, as QG B. In its response dated February 28, 2006 (ML060660175), the applicant stated that the portion of the RWCU/SDC system return line from the isolation valve to the interface with the feedwater line is designed to QG B to be consistent with the QG of the feedwater line at the interface. The staff finds the applicant's response acceptable because it is consistent with RG 1.26.

By letter dated March 30, 2006 (ML060880217), the staff asked the applicant to explain how the effects of high- and moderate-energy piping failures outside the primary containment were evaluated in the RWCU/SDC design to ensure that the other safety-related systems and equipment will not be made inoperable. In its response dated May 8, 2006 (ML061360037), the applicant stated that DCD, Tier 2, Section 3.6 (Sections 3.6.1.2 and 3.6.2.1) describes protection against dynamic effects associated with postulated rupture of piping outside the containment for high- and moderate-energy piping. The description included the identification of the high-energy piping located outside the containment, the potential damage resulting from dynamic effects, the design-basis compartment break, compartment pressurization, and equipment qualification. The staff evaluation of these DCD sections appears in Sections 3.6.1 and 3.6.2 of this SER.

In the same letter, the staff asked the applicant to demonstrate the capability of safety-related systems to withstand the effects of postulated internally generated missiles from the RWCU/SDC system both inside and outside the primary containment. In its response, the applicant stated that DCD, Tier 2, Section 3.5.1 includes the evaluation of safety-related systems' ability to withstand the effects of internally generated missiles both inside and outside containment. The staff evaluation of this DCD section is in Section 3.5.1 of this SER. In addition, the staff asked the applicant to demonstrate the capability of structures housing the RWCU/SDC, including safety-related components and instruments inside these structures, to withstand external and internal flood conditions. In its response, the applicant stated that the RWCU/SDC system components are housed in the containment and the reactor building. DCD Section 3.4 describes the internal and external flooding evaluation. As a result of responding RAI 5.4.10, GEH revised DCD, Tier 2, Sections 3.4.1.3, 3.4.1.4, and 3.4.1.4.2 to further clarify its flooding analysis. The staff found the applicant's response acceptable and confirmed the changes in DCD, Revision 2. Section 3.4.1 of this SER presents the staff's evaluation of this DCD section.

Based on this seismic and QG classification design information, the staff concludes that by following the guidelines of RGs 1.26 and 1.29, the applicant has met the requirements of GDC 1 and 2 as they relate to the RWCU/SDC design's meeting the standards commensurate with the system's safety function and the system being able to withstand the effects of natural phenomena.

The two safety-related containment isolation valves on the suction lines of the RWCU/SDC system receive isolation signals from the leak detection and isolation system. These valves will automatically isolate on the following indications:

- high RWCU/SDC flow
- low reactor water level (Level 2)
- high temperature in the MSL tunnel
- initiation of the standby liquid control system

The suction lines of each train are isolated by one automatic nitrogen-operated gate valve inside and one air-operated gate valve outside the containment. The reactor bottom suction line has a sampling line isolated by one automatic nitrogen-operated globe valve inside and one air-operated globe valve outside the containment. RWCU/SDC pumps, heat exchangers and demineralizers are located outside the containment. In addition, the applicant stated that the RWCU/SDC meets the requirements of RG 1.56. Based on this information, supplemented by the seismic and quality group classifications for the portion of the system including the containment isolation valves discussed above, the staff concludes that the system meets the requirements of GDC 14 as it relates to assuring the integrity of the RCPB.

By letter dated February 1, 2006 (ML060250432), the staff asked the applicant to describe the design features of the RWCU/SDC system that will control the release of radioactive effluents to the environment in accordance with GDC 60. In its response dated February 28, 2006 (ML060660175), the applicant stated that contaminated liquid waste will be transferred to the liquid waste management system (LWMS). In addition, flushing connections are provided to decontaminate piping and equipment such as the demineralizers and the heat exchangers. The RWCU/SDC system is provided with piping connections routed to the main condenser and the LWMS. The piping has butt-welded connections, rather than socket welds, to reduce crud traps. If high radiation is detected downstream of the demineralizer, the flow will be manually shifted to the LWMS by first opening the remote manual isolation valve to the LWMS and then closing the remote manual system isolation valve to the main condenser. The staff finds the applicant's response acceptable because the purpose of the LWMS is to control, collect, process, handle, store, and dispose of liquid radioactive waste generated as the result of normal operation, including AOOs. Based on this information, the staff concludes that the system meets the requirements of GDC 60 as it relates to the capability of the RWCU to control the release of radioactive effluents to the environment.

The demineralizers used are of the mixed bed type with nonregeneration type resin beads. A resin strainer capable of removing resin particles from the demineralizers' effluent is located at the outlet line to prevent resin beads from entering the system. Resin bed performance is monitored by the process sampling system. Sample probes are located in the inlet and outlet lines of the two demineralizers where samples are routed to the sample station for analysis. In addition, the conductivity of the demineralizer influent and effluent streams is continuously measured and transmitted to the MCR. The performance of the resin beads determines their replacement time. Since nonregeneration type resin beads are used, whenever it is necessary to replace the spent resins, the resin vessel will be isolated from the rest of the system before resin addition. By letter dated February 1, 2006 (ML060250432), the staff asked the applicant to describe the resin transfer system and indicate the provisions taken to ensure that transfers are complete and that crud traps in transfer lines are eliminated. In its response dated February 28, 2006 (ML060660175), the applicant stated that the details of the resin transfer

system will be designed in the detail design phase and that it will add the following design description in DCD, Tier 2, Section 5.4.8.1.2—"The resin transfer system will be designed to prevent resin traps in sluice lines. Consideration will be given in the design to avoid collection of resins in valves, low points and stagnant areas." The applicant committed to placing this statement in a future revision of the DCD. The staff found the applicant's response acceptable and confirmed the changes in DCD Revision 3.

Spent resins will be sluiced to a backwash-receiving tank from which they will be transferred to the radwaste system for processing and disposal. Demineralizers are located in separate concrete-shielded cubicles that are accessible through shielded hatches. Valves and piping within the cubicles are reduced to the extent that entry into the cubicles is not required during any operational phase. Most of the valves and piping are located in a shielded valve gallery adjacent to the demineralizer cubicles. The valves are remotely operable to the greatest practical extent to minimize entry requirements into this area. The backwash tank is shielded separately from the resin transfer pump.

Each demineralizer is protected from high flow, high differential pressure across the strainer and across the demineralizer and from demineralizer inlet high temperature by a bypass valve. In the event of high differential pressure or high temperature, an alarm will be activated in the MCR to alert the plant operator and will automatically isolate the demineralizer by first opening the bypass valve and then closing the demineralizer inlet valve.

By letter dated February 1, 2006 (ML060250432), the staff asked the applicant to describe the control features that will prevent inadvertent opening of the demineralizer backwash valves during normal operation. In its response dated February 28, 2006 (ML060660175), the applicant stated that interlocks are provided to prevent inadvertent opening of the resin addition and backflushing valves during normal operation. The staff finds the applicant's response acceptable because the use of interlocks will be adequate to prevent the inadvertent opening of the valves.

SRP Section 5.4.8 states that in order to prevent resin loss from the demineralizer bed, the RWCU system should include a means for automatically maintaining flow through demineralizer beds in the event of low-process flow or loss of flow. By letter dated February 1, 2006 (ML060250432), the staff asked the applicant to describe design requirements for a system controlling the ability of the demineralizer to automatically adjust flow through its resin beds in order to prevent resin loss in the event of a decrease of system flow. In its response dated March 30, 2006 (ML060940114), the applicant stated that this SRP requirement does not apply to the ESBWR demineralizers because they use nonregeneration bead type resins which do not lose resins on a reduction or loss of process flow. The staff finds the applicant's response acceptable.

Other components of the RWCU/SDC system exposed to high-radiation levels are the RHX and the NRHX. These components are also located in shielded cubicles with valves operated remotely by use of extension valve stems or from instrument panels located outside the cubicle.

The cleanup flow leaving the NRHX and going into the demineralizers should be of a specific temperature; therefore, the NRHX should be able to maintain the required temperature of the cleanup flow when its cooling capacity is reduced as a result of partially bypassing a portion of the return flow to the main condenser or the radwaste system. By letter dated February 1, 2006

(ML060250432), the staff asked the applicant to describe whether the NRHX has the capacity of maintaining the desired temperature when its return flow is reduced. In its response dated March 30, 2006 (ML060940114), the applicant stated that the NRHX performance was evaluated in the cleanup mode with a reduced RHX capacity, by assuming that 25 percent of its normal return flow is bypassed to the main condenser. Since the NRHX cools the reactor water by transferring heat to the RCCWS, increasing the water flow of the RCCWS will provide enough cooling capacity to maintain the required temperature of the cleanup flow to the demineralizer. This proved sufficient to maintain the demineralizer required inlet temperature. The staff finds the applicant's response acceptable.

Based on this information, the staff concludes that the RWCU/SDC system design meets the requirements of GDC 61 as related to designing the system with adequate confinement features.

#### 5.4.8.4 Conclusions

The RWCU/SDC system will be used to maintain the reactor water purity and to reduce the reactor water inventory as required by plant operations. The staff's review has included system schematics along with descriptive information concerning the system design and operation.

The staff concludes that the proposed design of the RWCU/SDC system is acceptable and meets the relevant requirements of GDC 1, 2, 14, 60, and 61. This conclusion is based on the following:

- The applicant has met the requirements of GDC 1 by designing, in accordance with the guidelines of RG 1.26, the portion of the RWCU/SDC extending from the reactor vessel and recirculation loops to the outermost primary containment isolation valves to QG A and by designing, in accordance with Position C.2 of RG 1.26, the remainder of the system outside the primary containment to QG C.
- The applicant has met the requirements of GDC 2 by designing, in accordance with Positions C.1, C.2, C.3, and C.4 of RG 1.29, the portion of the RWCU/SDC extending from the reactor vessel and recirculation loops to the outermost primary containment isolation valves to seismic Category I.
- The applicant has met the requirements of GDC 14 by meeting the positions of RG 1.56 in maintaining reactor water purity and material compatibility to reduce corrosion probabilities and thus reducing the probability of RCPB failure.
- The applicant has met the requirements of GDC 60 and 61 by designing a system containing radioactivity with confinement and by venting and collecting drainage from the RWCU/SDC components through closed systems.

Based on this information, the staff concludes that the RWCU/SDC design for the ESBWR is acceptable.

#### **5.4.9 Main Steamlines and Feedwater Piping**

The applicant provided information regarding main steamline and feedwater piping in DCD, Tier 2, Section 5.4.9. These systems are evaluated by the staff in Chapter 10 of this report.

#### **5.4.10 Pressurizer - Not applicable to the ESBWR**

#### **5.4.11 Pressurizer Relief Discharge System - Not applicable to the ESBWR**

#### **5.4.12 Reactor Coolant High-Point Vents**

##### 5.4.12.1 Regulatory Criteria

The staff performed its review of the ESBWR RCS high-point vent system in accordance with SRP Section 5.4.12, Revision 1.

The following requirements appear in 10 CFR 50.34(f)(2)(vi):

Provide the capability of high point venting of non-condensable gases from the RCS, and other systems that may be required to maintain adequate core cooling. Systems to achieve this capability shall be capable of being operated from the control room and their operation shall not lead to an unacceptable increase in the probability of LOCA or an unacceptable challenge to containment integrity (II.B.1).

Acceptance criteria are based on the following:

- 10 CFR Part 50.55a and GDCs 1 and 30 as they relate to the vent system components that are part of the RCPB being designed, fabricated, erected, and tested and maintained to high quality standards
- GDC 14 as it relates to the RCPB being designed, fabricated, erected, and tested to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture
- 10 CFR 50.46(b) as it relates to the long-term cooling of the core following any calculated successful initial operation of the ECCS to remove decay heat for an extended period of time
- 10 CFR 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants," with respect to environmental qualification of electrical equipment necessary to operate the reactor coolant vent system
- GDC 17, "Electric Power Systems," with respect to the provision of normal and emergency power for the vent system components
- GDC 19 with respect to the vent system controls being operable from the control room
- GDC 36 as it relates to the vent system being designed to permit periodic inspection

#### 5.4.12.2 Technical Information

The ESBWR has an RPV head vent system that handles any noncondensable gas buildup at the high point inside the RPV head by sweeping the gases through a MSL and then ultimately to the condenser. Additionally, systems that are connected to the RPV and are stagnant during normal plant operation have lines that are sloped to prevent any buildup of noncondensable gases.

During reactor operation, the noncondensable gases that may collect in the reactor head and the IC steamlines are drawn to the steamline through a vent line from the RPV head and a purge line from each of the ICs. Differential pressure between the reactor head and the downstream steamline location extracts the noncondensables. The noncondensables are swept from these lines to the condenser, where they are extracted. These vents and purge lines are not required to assure natural circulation core cooling. The vent line used to vent the reactor head noncondensables following a refueling operation is isolated with two normally closed valves during reactor power operation. The ICs also vent noncondensables to the suppression pool to maintain their performance; however, the ICs are isolable and not part of the primary system. The IC vents are discussed in Section 5.4.6 of this report.

#### 5.4.12.3 Staff Evaluation

The staff reviewed the design and function of the RPV vent system as described in Revision 3 of DCD, Tier 2.

The ESBWR meets the requirements of 10 CFR 50.34(f)(2)(vi), TMI Action Item II.B.1, regarding the capability of high-point venting of noncondensable gases from the RCS. The noncondensables are swept from the steamlines to the condenser, where they are extracted. Position indication and controls for opening and closing the valves are in the control room. These vents and purge lines are not required to assure natural circulation core cooling. DCD, Tier 2, Section 5.4.12.1 discusses the procedure for operation of the RPV head vent system.

When the RPV is in an isolated condition, the RPV head vent line and the SRVs provide redundancy for venting the RCS. The vent line used to vent the reactor head noncondensables following a refueling operation is isolated with two normally closed valves during reactor power operation. These valves are subject to an environmental qualification (10 CFR 50.49(a)) program, as described in DCD, Tier 2, Section 3.11.

GDC 17 is met by an onsite electric power system that provides normal and emergency power to permit operation of the RPV head vent line valves. GDC 19 is met by controls and indication that permit operation of the valves from the MCR. The RPV head vent system is not part of the ECCS and is not required to assure natural circulation core cooling. Therefore, GDC 36 does not apply. For RCPB isolation purposes during reactor power operation, the use of two motor-operated valves in series in the piping that vents the RPV to the equipment and floor drain sump provides redundancy. Either or both valves isolate the piping. Failure modes consist of loss of power supply, failure of the control system, and mechanical failure in the valve. If one of

the valves experiences a failure, the second valve in series performs the isolation function. Indication of open and close position and temperature downstream of the second valve are available to operators in the control room.

A connection at the RPV flange area links the internal integral head vent piping to the external head vent piping. The piping is 2 inches in diameter. The vent piping directs air and noncondensable gases from the RPV to either the equipment and floor drain sump or one of the MSLs. The vent piping permits air to be released from the RPV so that the vessel can be filled with water for hydrostatic testing, vents gases during reactor operation and reactor shutdown, and provides the upper tap for RPV level measurement during reactor shutdown. The diameter of the vent line piping is much smaller than the diameter of the MSL piping. Therefore, a break in this piping is bounded (per 10 CFR 50.46a, "Acceptance Criteria for Reactor Coolant System Venting Systems") by a MSL break, which is addressed in DCD, Tier 2, Section 6.3.

#### 5.4.12.4 Conclusions

As discussed above, the RPV vent system design for the ESBWR complies with the guidelines of SRP Section 5.4.12 and therefore is acceptable. The staff concludes that the design of the RCS high-point vents is acceptable as it meets the relevant requirements of 10 CFR 50.34(f)(2)(vi), 10 CFR 50.46a, 10 CFR 50.49, 10 CFR 50.55a, and GDC 1, 14, 17, and 19.

The staff concludes that the ESBWR design provides various means to prevent accumulation of noncondensable gases in the RCS. The staff also finds that the high-point vents will be designed in accordance with Section III of the ASME Code.

5.	REACTOR COOLANT SYSTEM AND CONNECTED SYSTEMS . . . . .	5-1
5.1	Introduction . . . . .	5-1
5.2	Integrity of Reactor Coolant Pressure Boundary . . . . .	5-2
	5.2.1 Compliance with Code and Code Cases . . . . .	5-2
	5.2.2 Overpressure Protection . . . . .	5-6
	5.2.3 Reactor Coolant Pressure Boundary Materials . . . . .	5-12
	5.2.4 RCS Pressure Boundary Inservice Inspection and Testing . . . . .	5-21
	5.2.5 Reactor Coolant Pressure Boundary Leakage Detection . . . . .	5-27
5.3	Reactor Vessel . . . . .	5-32
	5.3.1 Reactor Vessel Materials . . . . .	5-32
	5.3.2 Pressure-Temperature Limits . . . . .	5-40
	5.3.3 Reactor Vessel Integrity . . . . .	5-47
5.4	Component and Subsystem Design . . . . .	5-51
	5.4.1 Reactor Coolant Pumps—Not applicable to the ESBWR . . . . .	5-51
	5.4.2 Steam Generators—Not applicable to the ESBWR . . . . .	5-51
	5.4.3 Reactor Coolant Piping—Not applicable to the ESBWR . . . . .	5-51
	5.4.4 [Reserved] . . . . .	5-51
	5.4.5 [Reserved] . . . . .	5-51
	5.4.6 Isolation Condenser System . . . . .	5-51
	5.4.7 Residual Heat Removal . . . . .	5-61
	5.4.8 Reactor Water Cleanup/Shutdown Cooling System . . . . .	5-65
	5.4.9 Main Steamlines and Feedwater Piping . . . . .	5-71
	5.4.10 Pressurizer - Not applicable to the ESBWR . . . . .	5-71
	5.4.11 Pressurizer Relief Discharge System - Not applicable to the ESBWR . . . . .	5-71
	5.4.12 Reactor Coolant High-Point Vents . . . . .	5-71