

Originator: CONVERTED DATA

Originator Phone: 0

Originator Group: CONVERTED DATA

Operability Required: N

Supervisor Name: CONVERTED DATA

Reportability Required: N

Discovered Date: 05/22/1999 00:00

Initiated Date: 05/22/1999 00:00

Condition Description:

DURING UNDERWATER INSPECTION OF THE TORUS CONTAINMENT SHELL ONE AREA OF PITTING CORROSION EXCEEDS THE ACCEPTANCE CRITERIA OF .066 INCHES BASE DEPTH IN BAY #3 (NCR99-05)

Immediate Action Description:

Suggested Action Description:

EQUIPMENT:

Tag Name

Tag Suffix Name Component Code Process System Code

50

REFERENCE ITEMS:

Type Code

Description

CONVERTED PR

PR.99.9249

TRENDING (For Reference Purposes Only):

Trend Type

Trend Code

KEYWORDS

MAINT RULE

Entergy

ADMIN

CR-PNP-1999-09249

Initiated Date: 5/22/1999 0:00

Owner Group :Regulatory & Industry Affairs Staff

Current Contact: SCREENING TEAM

Current Significance: C - CORRECTION

Closed by: SCREENING TEAM

5/29/1999 0:00

Summary Description:

DURING UNDERWATER INSPECTION OF THE TORUS CONTAINMENT SHELL ONE AREA OF PITTING
CORROSION EXCEEDS THE ACCEPTANCE CRITERIA OF .066 INCHES BASE DEPTH IN BAY #3 (NCR99-05)

Remarks Description:

PR=EF CONTAINMENT TP99-010 NCR 99-05 MR19701280 CORROSION

Closure Description:

SEE EVALUATION RESPONSE.

Version: 1**Significance Code:** C - CORRECTION**Classification Code:** NON-SIGNIFICANT**Owner Group:** Regulatory & Industry Affairs Staff**Performed By:** Ellis,Douglas W

05/23/1999 00:00

Assignment Description:

CONDUCT A 10CFR50.73 REPORTABILITY REVIEW

CA Number: 1

Group**Name**

Assigned By: Regulatory & Industry Affairs Staff

BRENNION, S.

Assigned To: Regulatory & Industry Affairs Staff

Ellis,Douglas W

Subassigned To :

Originated By: BRENNION, S.

5/22/1999 00:00:00

Performed By: ELLIS, D.

5/25/1999 00:00:00

Subperformed By:

Approved By:

Closed By: BRENNION, S.

5/25/1999 00:00:00

Current Due Date: 05/30/1999**Initial Due Date:** 05/30/1999

CA Type: GENERAL

Plant Constraint: NONE

CA Description:

CONDUCT A 10CFR50.73 REPORTABILITY REVIEW

Response:

CONVERTED DATA

Subresponse :**Closure Comments:**

MEMO DOCUMENTING RESULTS OF REPORTABILITY REVIEW

[05/25/99; S. BRENNION]

A 10CFR50.73 Reportability Evaluation has been performed for the condition involving pitting of Torus shell described in PR99.9249.00 resulting in a determination of NOT REPORTABLE under 10CFR50.73 (a)(2)(i), (v), and (vii) as well as (a)(2)(ii)