

Originator: CONVERTED DATA

Originator Group: CONVERTED DATA

Supervisor Name: CONVERTED DATA

Discovered Date: 09/20/2001 00:00

Originator Phone: 0

Operability Required: N

Reportability Required: N

Initiated Date: 09/20/2001 00:00

Condition Description:

TOUR OPERATOR FOUND ALARM C190-D3 SBO DG FUEL TANK LEAKAGE IN ALARM. PANEL INDICATES PROBE #1 WET ALERT WATER DETECTED ALARM

Immediate Action Description:

Suggested Action Description:

EQUIPMENT:

Tag Name

Tag Suffix Name Component Code Process System Code

63

REFERENCE ITEMS:

Type Code

Description

CONVERTED PR

PR.01.4171

Entergy

ADMIN

CR-PNP-2001-04171

Initiated Date: 9/20/2001 0:00

Owner Group : Maint I&C Staff

Current Contact: MILLER, R.

Current Significance: C - CORRECTION

Closed by: MILLER, R.

9/27/2001 0:00

Summary Description:

TOUR OPERATOR FOUND ALARM C190-D3 SBO DG FUEL TANK LEAKAGE IN ALARM. PANEL INDICATES PROBE #1 WET ALERT WATER DETECTED ALARM

Remarks Description:

PR=EF

2.1.12.2 C190 SBO DG FUEL TANK LEAKAGE ALARM D. NOYES

Closure Description:

SEE CORRECTIVE ACTION RESPONSE.