

**PRIORITY ATTENTION REQUIRED MORNING REPORT - REGION I**

**Morning Report Date: MAR 19, 2007**

**Licensee/Facility:**

ENTERGY NUCLEAR GENERATION COMPANY  
Pilgrim  
Plymouth, Massachusetts  
Dockets: 050-00293  
[1] GE-3

**Notification:**

MR Number: 1-2007-0008  
Date: 03/17/2007  
Call from Licensee

**Subject:** Pilgrim Manual Reactor Shutdown.

**Discussion:**

On March 17, 2007, the Pilgrim reactor was manually shutdown due to increasing unidentified drywell leakage. Upon drywell entry, a steam leak was identified from the packing of a 6-inch reactor water cleanup valve. The valve was repacked and will be tested during plant heatup/pressurization. Startup commenced at approximately 6:00 a.m. on March 19, 2007.

**Contact:**

POWELL, RAYMOND J

**Org:**

R1

**Phone No:**

(610) 337-6967

**Email:**

RJP@nrc.gov