

JOB PERFORMANCE MEASURE APPROVAL SHEET


I. JPM Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

JPM ID Number: 2K7 NRC S.1

Revision: 0

II. Initiated:

D. Minnich
Developer



12/8/06
Date

III. Reviewed:

Martin
Technical Reviewer



1/24/7
Date

IV. Approved:

NA
Cognizant Plant Supervisor (optional)

NA

Date

P. Altman
Nuclear Training Supervisor



1/24/07
Date

JOB PERFORMANCE MEASURE APPROVAL SHEET

SUMMARY OF CHANGES

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Applicant: _____

JPM ID Number: 2K7 NRC S.1 Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

System: 004

Time Critical Task: () YES (X) NO

Validated Time (minutes): 10

Task Number(s): 344-05-036

Applicable To: SRO X RO X PEO _____

K/A Number: APE: 022 AA2.02 K/A Rating: 3.2 / 3.7
004-A4.08 3.8 / 3.4

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards: All critical steps are performed satisfactorily. All sequential steps are performed in proper procedural sequence.

Required Materials: None.

General References: EOP 3506 Rev. 009-00

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective(s) for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution were actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: 2K7 NRC S.1

Revision: 0

- Simulator Requirements:
- A. Reset to any 100% Power IC
 - B. Insert I/O [CV] 3CHS*AV8149C CLOSE OFF (FALSE)
 - C. Place simulator in "RUN"
 - D. Ensure The "B" charging pump is running. Ensure CHS*AV8149C will not close.
 - E. Insert MALF CV11B, Charging Pump "B" Overcurrent trip.
 - F. Acknowledge annunciators, then place simulator in "FREEZE"
 - G. Place simulator in "RUN" after the operator receives instructions.

Approximate Simulator setup time is 10 minutes

Initial Conditions: The plant was at 100% power with charging and letdown in a normal lineup. Moments ago the "B" Charging pump tripped and the applicable ARP's referenced.

Initiating Cues: The US has directed you to perform EOP 3506, "Loss Of All Charging Pumps," beginning with step 1.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. The students performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

Start Time:

STEP	<u> 1 </u>	<u> </u>	Performance Step:	Obtains copy of EOP 3506
GRADE	<u> </u>	<u> </u>	Standards:	Obtains a copy of EOP 3506 and refers to step 1
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 2 </u>	<u> </u>	Performance Step:	The Foldout page must be open. Note prior to step 1
GRADE	<u> </u>	<u> </u>	Standards:	Opens foldout page and reviews
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 3 </u>	<u> </u>	Performance Step:	Verify Charging Pumps – NONE RUNNING EOP 3506, step 1.
GRADE	<u> </u>	<u> </u>	Standards:	Determines that no charging pumps are running by observation of indicating lights, amps, flow etc.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 4 </u>	<u> </u>	Performance Step:	Check Reactor- NOT TRIPPED 2.
GRADE	<u> </u>	<u> </u>	Standards:	At Main Board 4 determines that the reactor trip breakers are closed observation of red indicating lights on, DRPI indication, etc.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 5 </u>	<u> </u>	Performance Step:	Check Busses 34C And 34D - BOTH ENERGIZED 3.
GRADE	<u> </u>	<u> </u>	Standards:	Determines Busses 34C And 34D are both energized by observation of the Main Board 8 emergency bus voltage

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

indicators reading about 4160 volts
OR emergency load center voltage
indicators (8) reading about 480 volts.

Grade: **SAT** **UNSAT**

STEP 6

Performance Step: Isolate Letdown
4.a. CLOSE letdown orifice isolation valves

GRADE

Standards: Depresses close pushbuttons for
CHS*AV8149C. Determines that
8149C has not closed by observation
of red indicating light on, green off,
and transitions to RNO column.

Grade: **SAT** **UNSAT**

STEP 7 X

Performance Step: CLOSE Ctmt letdown isolation valves:
4.a. RNO
 • 3CHS*CV8152
 • 3CHS*CV8160

GRADE X

Standards: Depresses close pushbuttons for
CHS*CV8152 and CV8160

GRADE

Standards: Checks position indicating lights and
determines valves have closed by red
ind. lights off, green on

Grade: **SAT** **UNSAT**

STEP 8

Performance Step: Verify excess letdown and reactor
4.b. head vent isolation valves - CLOSED

GRADE

Standards: Checks red indicating lights off / green
on for head vent and excess letdown
isolations

Grade: **SAT** **UNSAT**

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

STEP	<u>9</u>		Performance Step: 5.a.	<p>Check For Loss Of Charging Pump Suction Check previously running charging pump – ANY OF THE FOLLOWING FLUCTUATING PRIOR TO PUMP TRIP</p> <ul style="list-style-type: none"> • Charging flow <u>OR</u> • RCP seal supply flows <u>OR</u> • Charging pump discharge pressure <u>OR</u> • Charging pump amps
GRADE			Standards:	The applicant should question the US if there were any indications of cavitation prior to the pump trip.
			CUE:	Respond as the US that there were no indications of cavitation or gas binding prior to the pump trip from the control room or reports from the field.
			Grade:	SAT _____ UNSAT _____
STEP	<u>10</u>		Performance Step: 5.a. RNO	Proceed to step 5.c.
GRADE			Standards:	Proceeds to step 5.c.
			Grade:	SAT _____ UNSAT _____
STEP	<u>11</u>		Performance Step: 5.c.	Check indications of pump cavitation or gas binding - REPORTED FROM FIELD
GRADE			Standards:	The applicant may question the US if there were any indications of cavitation reported from the field.
			CUE (if required):	Respond as the US that there were no indications of cavitation or gas binding reported from the field.

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

STEP 12 _____

Performance Step: Proceed to step 5.f.
5.c. RNO

GRADE _____

Standards: Proceeds to step 5.f.

Grade: SAT _____ UNSAT _____

STEP 13 _____

Performance Step: Verify charging pump suction
5.f.

- Check VCT to charging isolation valves
(3CHS*LCV112B and 3CHS*LCV112C) – OPEN

OR

- Check at least one RWST to charging isolation valve
(3CHS*LCV112D or 3CHS*LCV112E) - OPEN

GRADE _____

Standards: Determines that both VCT to charging isolation valves (3CHS*LCV112B and 3CHS*LCV112C) are open by checking red indicating lights on / green off.

Grade: SAT _____ UNSAT _____

STEP 14 _____

Performance Step: Check RCPs For A Loss Of All Seal Cooling
6. a. Check any RCP

- Thermal barrier cooling (CCP) – LOST

OR

- Seal injection flow - LESS THAN 6 gpm

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

GRADE	<u> </u>	<u> </u>	Standards:	Determines that there is adequate Thermal barrier cooling by observing thermal barrier flow low annunciators not in alarm.
			Grade:	SAT <u> </u> UNSAT <u> </u>

GRADE	<u> </u>	<u> </u>	Standards:	Determines that there is NO seal injection flow by observation of seal injection flowrate indicators CHS-F1145A, 144A, 143A, and 142A on MB3.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 15 </u>	<u> </u>	Performance Step:	Check affected RCP(s) - 6.b. RUNNING
-------------	---------------	---------------	--------------------------	--

GRADE	<u> </u>	<u> </u>	Standards:	Determines that all RCPs are running by observation of red indicating lights on / green off, amps, flow etc.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 16 </u>	<u> X </u>	Performance Step:	Check affected RCPs #1 seal inlet temperatures – ANY GREATER THAN OR EQUAL TO 230 °F 6.c. (PPC, NSSS screen 15)
-------------	---------------	--------------	--------------------------	---

GRADE	<u> </u>	<u> X </u>	Standards:	At any PPC AYDIN terminal, calls up NSSS screen 15 and determines that all RCP #1 seal inlet temperatures are less than 230 degrees.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 17 </u>	<u> </u>	Performance Step:	Proceed to step 7. 6.c. RNO
-------------	---------------	---------------	--------------------------	--------------------------------

GRADE	<u> </u>	<u> </u>	Standards:	Proceeds to step 7.
--------------	---------------	---------------	-------------------	---------------------

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

			Grade:	SAT _____	UNSAT _____
STEP	<u> 18 </u>	_____	Performance Step:	Check If A Charging Pump Should Be Started	
			7.a.	Verify charging pump operation - NONE RUNNING	
GRADE	_____	_____	Standards:	Determines that no charging pumps are running by observation of indicating lights, amps, flow etc.	
			Grade:	SAT _____	UNSAT _____
STEP	<u> 19 </u>	_____	Performance Step:	Check RCPs – ALL RUNNING	
			7.b.		
GRADE	_____	_____	Standards:	Determines that all RCPs are running by observation of red indicating lights on / green off, amps, flow etc.	
			Grade:	SAT _____	UNSAT _____
STEP	<u> 20 </u>	<u> X </u>	Performance Step:	START one charging pump	
			7.c.		
GRADE	_____	<u> X </u>	Standards:	Rotates the control switch for the "A" charging pump to the start position.	
			Standards:	Observes for proper indications of a successful pump start; red indicating light, amps, flow, etc.	
			CUE (if required):	If the applicant questions whether to attempt a start of the "B" charging pump, respond as the US that the "A" charging pump should be started.	
			Grade:	SAT _____	UNSAT _____

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

STEP	<u> 21 </u>	<u> </u>	Performance Step:	Check procedure entered from - ES-0.1, REACTOR TRIP RESPONSE 7.d.
GRADE	<u> </u>	<u> </u>	Standards:	Initial conditions were given at 100% power, therefore the applicant should procede to step 7.d. RNO.
			CUE (if required):	If the applicant questions if the crew had transitioned from ES-0.1, reiterate that initial conditions were 100% power.

Grade: **SAT** **UNSAT**

STEP	<u> 22 </u>	<u> </u>	Performance Step:	Proceed to step 8. 7.c. RNO.
GRADE	<u> </u>	<u> </u>	Standards:	Proceeds to step 8.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 23 </u>	<u> </u>	Performance Step:	Check Charging System 8.a. Alignment Verify charging line flow control valve - OPEN
GRADE	<u> </u>	<u> </u>	Standards:	Observes that 3CHS*FK121 has output and flow indicated or observes charging flow indicated on the PPC CVCS trend display.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 24 </u>	<u> </u>	Performance Step:	Verify charging header loop isolation valves (3CHS*AV8146 or 3CHS*AV8147) - ONE OPEN 8.b.
GRADE	<u> </u>	<u> </u>	Standards:	Observes that only one charging header loop isolation valve is open by observing a red indicating light for 3CHS*AV8146 and a green indicating light for 3CHS*AV8147.

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

		Grade:	SAT _____	UNSAT _____
STEP	<u> 25 </u>	Performance Step:	Verify charging header isolation valves (3CHS*MV8106 and 3CHS*MV8105) - OPEN	
		8.c.		

GRADE	_____	Standards:	Observes that both charging header isolation valves are open by observing red indicating lights lit and green lights out for 3CHS*MV8106 and 3CHS*MV8105.	
--------------	-------	-------------------	---	--

		Grade:	SAT _____	UNSAT _____
STEP	<u> 26 </u>	Performance Step:	Verify charging pump recirculation isolation valves - OPEN	
		8.d.	3CHS*MV8111A 3CHS*MV8111B 3CHS*MV8111C 3CHS*MV8110	

GRADE	_____	Standards:	Observes that all charging pump recirculation isolation valves are open by observing red indicating lights lit and green lights out for 3CHS*MV8111A, B, C and 3CHS*MV8110.	
--------------	-------	-------------------	---	--

		Grade:	SAT _____	UNSAT _____
STEP	<u> 27 </u>	Performance Step:	Verify charging pump miniflow isolation valves to RWST (3CHS*MV8511A and 3CHS*MV8511B) - CLOSED	
		8.e.		

GRADE	_____	Standards:	Observes that both charging pump miniflow isolation valves to RWST are closed by observing green indicating lights lit and red lights out for	
--------------	-------	-------------------	---	--

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

3CHS*MV8511A and
3CHS*MV8511B.

Grade: **SAT** **UNSAT**

STEP 28

Performance Step: 8.f. Verify RCP seal supply valve
(3CHS*HCV182) - OPEN

GRADE

Standards: Observes that the seal supply valve
3CHS*HCV182 is open by observing
meter needle on CHS-HC182
indicating open (100%).

Grade: **SAT** **UNSAT**

STEP 29

Performance Step: 8.g. Verify seal injection flow to
RCPs with unisolated seals -
BETWEEN 8 and 13 gpm

GRADE

Standards: Determines seal injection flow to
All RCPs is between 8 and 13 gpm by
observing flowrates on seal injection
flowrate indicators CHS-F1145A, 144A,
143A, and 142A.

Grade: **SAT** **UNSAT**

STEP 30

Performance Step: 9.a. Verify Charging Flow
Check charging flow

- Check PZR level - STABLE OR INCREASING
- Check charging flow control valve - CAPABLE OF BEING THROTTLED

GRADE

Standards: Determines PZR level is stable or
increasing by observing PZR level

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

recorder trace or PPC CVCS trend display. Takes manual control of the charging line flow control valve and verifies throttling capability.

Grade: **SAT** **UNSAT**

STEP 30

Performance Step: Proceed to step 11.
9.b.

GRADE

Standards: Proceeds to step 11.

Grade: **SAT** **UNSAT**

STEP 31

Performance Step: Align RCS Letdown
11.a.

Check normal letdown- ISOLATED

GRADE

Standards: Observes that letdown is isolated by observing green indicating lights lit and red lights out for CHS*CV8152 and CV8160.

Grade: **SAT** **UNSAT**

STEP 32

Performance Step: Verify PZR level - GREATER THAN
11.b. 22%

GRADE

Standards: Determines PZR level is greater than 22% by observing PZR level recorder trace or PZR level meters on MB4.

Grade: **SAT** **UNSAT**

STEP 33

Performance Step: Verify normal charging path
11.c. - ESTABLISHED

GRADE

Standards: Determines a normal charging flowpath established by observing charging flow and valve lineup

PERFORMANCE INFORMATION

JPM Number: S.1

Revision: 0

Task Title: Respond To A Loss Of All Charging Pumps (Overcurrent)

Grade: SAT _____ UNSAT _____

STEP 34 _____

Performance Step: Using GA-13, Establish normal letdown
11.d.

GRADE _____

Standards: Informs the US that normal letdown needs to be established using GA-13.

CUE: Inform the Examinee that another RO will establish letdown and complete EOP 3506. Inform the Examinee the evaluation for this JPM is concluded.

Grade: SAT _____ UNSAT _____

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC S.1

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 10

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

STUDENT HANDOUT

JPM Number: S.1

Initial Conditions: The plant was at 100% power with charging and letdown in a normal lineup. Moments ago the "B" Charging pump tripped and the applicable ARP's referenced.

Initiating Cues: The US has directed you to perform EOP 3506, "Loss Of All Charging Pumps," beginning with step 1.

JOB PERFORMANCE MEASURE APPROVAL WORKSHEET

I. JPM Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA DURING ECA - 0.0

JPM ID Number: 2K7 NRC S.2

Revision: 1

II. Initiated:

Steve Jackson
Developer

6/12/02
Date

III. Reviewed:

Martin
Technical Reviewer

1/24/07
Date

IV. Approved:

Hutterman Em
Nuclear Training Manager

1/24/07
Date

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Student: _____

JPM ID Number: 2K7 NRC S.2 Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA DURING ECA - 0.0

System: AC Electrical Distribution (62) Safety Function: Electrical (6)

Time Critical Task: () YES (X) NO

Validated Time (minutes): 5

Alternate Path? Yes

Task Number(s): 000-05-097

Applicable To: SRO X RO _____ PEO _____

K/A Number: 062.A2.05 K/A Rating: 2.9 / 3.3

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards: Respond to a Loss of All AC Power

Required Materials: ECA-0.0, Loss of All AC Power, Rev. 020-01
EOP 35 General Attachment, GA-3; Energizing 4.16 KV Bus From Offsite Power, Rev. 001

General References: None

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objectives for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: S.2

Revision: 1

- Simulator Requirements:
1. Reset to IC- 21, 100% power, EOL.
 2. Enter MALF **EG07B**, EDG B Trip & **EG08A**; 0%, EDG A Load Limiter Failure
 3. Enter I/O (EG) 1A-3ENSACB-A, CLOSE - FALSE, to prevent EDG A Output breaker from closing manually
 4. Place the Simulator in Run
 5. Enter MALF ED01, Loss of Offsite Power, run for 5 minutes, perform E-0, steps 1-3, and ECA-0.0, steps 1-4.
 6. Remove MALF ED01
 7. Place the Simulator in Freeze. Go to run when the examinee is ready to begin

Initial Conditions: The plant has experienced a Loss of Offsite Power. The A EDG started but did not load. The B EDG started and catastrophically failed. The crew responded using E-0 and ECA-0.0 and has completed ECA-0.0 through step 4. CONVEX has restored offsite power, which is available and reliable.

Initiating Cues: The Unit Supervisor directs you to restore power to any AC emergency bus starting at ECA-0.0, step 5.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. The students performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: S.2

Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA DURING ECA - 0.0

Start Time:

STEP	<u> 1 </u>	<u> </u>	Performance Step: Try To Restore Power To Any AC Emergency Bus: START at least one EDG (MB8)	
			Standards: Observes A EDG running. Observes that the EDG has NOT automatically close onto bus 34C. Candidate MAY observe degraded frequency	
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 2 </u>	<u> </u>	Performance Step: Verify EDG output breaker - CLOSED (Step 5.b) Alternate Path	
GRADE	<u> </u>	<u> </u>	Standards: Observes that Bus 34C and 34D are both de-energized. The candidate may try to close the A EDG Output Breaker since it is an automatic action which did not occur. Candidate transitions to RNO column.	
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 3 </u>	<u> X </u>	Performance Step: CLOSE breaker (MB8) (Step 5.b RNO)	
GRADE	<u> </u>	<u> X </u>	Standards: Candidate attempts to close the A EDG output breaker. When it will not close transitions to step 5.c	
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 4 </u>	<u> </u>	Performance Step: Verify at least one AC emergency bus - ENERGIZED	
GRADE	<u> </u>	<u> </u>	Standards: Observes that Bus 34C and 34D are both still de-energized.	

PERFORMANCE INFORMATION

JPM Number: S.2

Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA DURING ECA - 0.0

		Grade:	SAT _____	UNSAT _____
STEP	<u> 5 </u>	Performance Step:	Proceed to step 5.e (Step 5.c RNO)	
GRADE	_____	Standards:	Candidate Proceeds to step 5.e.	
		Grade:	SAT _____	UNSAT _____
STEP	<u> 6 </u>	Performance Step:	Check offsite power - AVAILABLE (Step 5.e)	
GRADE	_____	Standards:	At MB8 observes any of the following: <ul style="list-style-type: none"> • Grid frequency meter (upright) • Grid voltage meter (upright) • RSST "available" white lights (apron) 	
		Comment:	This information also given in initial conditions. Candidate may choose not to verify.	
		Grade:	SAT _____	UNSAT _____
STEP	<u> 7 </u>	Performance Step:	Using GA-3, energize emergency bus 34C or 34D through the RSST or the NSST	
GRADE	_____	Standards:	Candidate locates and opens GA binder to GA-3.	
GRADE	_____	Standards:	The applicant should question the US which emergency bus is desired to be energized and from which offsite source.	
		CUE:	Respond as the US to restore power to Bus 34C with the RSST.	
		Grade:	SAT _____	UNSAT _____

PERFORMANCE INFORMATION

JPM Number: S.2

Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA
DURING ECA - 0.0

STEP 8 _____ **Performance Step:** Check Energizing Bus 34C - DESIRED
(step 1 of GA-3)

GRADE _____ _____ **Standards:** Candidate Proceeds to step 2 based
on previous cue.

Grade: **SAT** _____ **UNSAT** _____

STEP 9 X **Performance Step:** Energize Bus 34C.
(step 2.a) Place the following control switches in
PULL-TO-LOCK

- One Train A Service Water Pump
- RPCCW Pump A
- RPCCW Pump C (Train A)
- Quench Spray Pump A
- Recirc Spray Pump A
- Recirc Spray Pump C
- SI Pump A
- RHR Pump A
- Control Building Chiller A
- Aux Building Filter A
- Charging Pump A
- Charging Pump C (Train A)
- MD AFW Pump A

GRADE _____ X **Standards:** Locates the control switches for the
following components and places the
switch in stop and then in PULL-TO-
LOCK.

- One Train A Service Water Pump
- RPCCW Pump A
- RPCCW Pump C (Train A)
- Quench Spray Pump A
- Recirc Spray Pump A
- Recirc Spray Pump C
- SI Pump A
- RHR Pump A
- Control Building Chiller A
- Aux Building Filter A
- Charging Pump A

PERFORMANCE INFORMATION

JPM Number: S.2

Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA DURING ECA - 0.0

- Charging Pump C (Train A)
- MD AFW Pump A

			Grade:	SAT _____	UNSAT _____
STEP	<u> 10 </u>	_____	Performance Step:	Verify annunciator, "Bus 34C UNDERVOLTAGE" (MB8A 3-12) - <u>NOT</u> LIT	
GRADE	_____	_____	Standards:	Observes annunciator MB8A 3-12, "Bus 34C UNDERVOLTAGE" <u>not</u> lit on MB8A.	
			Grade:	SAT _____	UNSAT _____
STEP	<u> 11 </u>	<u> X </u>	Performance Step:	Press "BYPASS" for 34C undervoltage block pushbutton. (MB8R)	
GRADE	_____	<u> X </u>	Standards:	Locates pushbutton on MB8R, pushes button and observes white light go <u>off</u> .	
			Grade:	SAT _____	UNSAT _____
STEP	<u> 12 </u>	_____	Performance Step:	Check undervoltage block white light - <u>NOT</u> LIT.	
GRADE	_____	_____	Standards:	Observes white light <u>NOT</u> LIT on pushbutton on MB8R	
			Grade:	SAT _____	UNSAT _____
STEP	<u> 13 </u>	_____	Performance Step:	Check energizing Bus 34C from Bus 34A - DESIRED	
GRADE	_____	_____	Standards:	Candidate Proceeds to step 2.e.RNO based on previous cue.	
			CUE (if required):	Respond as the US to restore power to Bus 34C with the RSST.	

PERFORMANCE INFORMATION

JPM Number: S.2

Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA DURING ECA - 0.0

		Grade:	SAT	UNSAT
STEP	14	X	_____	_____
		Performance Step:	Energize Bus 34C from RSSA:	
		(Step 2.e.1 RNO)	Place RSSA sync selector switch in ON.	
GRADE	_____	X	Standards:	Places or checks sync selector handle in synchronizing selector for RSSA to bus 34C and turns to ON position. Observes INCOMING voltage meter register voltage at about 125 v.
			Grade:	SAT _____ UNSAT _____
STEP	15	X	Performance Step:	CLOSE RSSA supply breaker (RSSA*34C-2).
			(Step 2.e.2 RNO)	
GRADE	_____	X	Standard:	Locates and turns RSSA*34C-2, RSSA supply breaker to the close position and releases.
			Standards:	Observes breaker green light go OFF and red light go ON. Observes voltage on bus 34C at about 4000 v. Also may observe synchroscope RUNNING voltage go to about 125 v.
			Note:	Lights come on in the Control Room
			Grade:	SAT _____ UNSAT _____
STEP	16	_____	Performance Step:	Place RSSA sync selector switch in OFF.
			(Step 2.e.3 RNO)	
GRADE	_____	_____	Standards:	Rotates sync selector handle in synchronizing selector for RSSA to bus 34C to the OFF position. Observes INCOMING and RUNNING voltage meters go to zero.
			Grade:	SAT _____ UNSAT _____

PERFORMANCE INFORMATION

JPM Number: S.2

Revision: 1

Task Title: ENERGIZE THE AC EMERGENCY BUS THROUGH THE RSSA
DURING ECA - 0.0

STEP 17 _____

Performance Step: Proceed to step 2.g.
(Step 2.e.4 RNO)

Comments: When candidate reads step 2.e.4 RNO
go to terminating cue and end the
JPM.

Terminating Cue: The evaluation for this JPM is concluded.

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: S.2

Revision: 1

Date Performed:

Student:

Evaluator:

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES NO X

Validated Time (minutes): 5

Actual Time to Complete (minutes):

Result of JPM: ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions:

Number of Correct Responses:

Score:

Areas for Improvement:

STUDENT HANDOUT

JPM Number:

S.2

Initial Conditions:

The plant has experienced a Loss of Offsite Power. The A EDG started but did not load. The B EDG started and catastrophically failed. The crew responded using E-0 and ECA-0.0 and has completed ECA-0.0 through step 4. CONVEX has restored offsite power, which is available and reliable.

Initiating Cues:

The Unit Supervisor directs you to restore power to any AC emergency bus starting at ECA-0.0, step 5.

JOB PERFORMANCE MEASURE APPROVAL SHEET

I. JPM Title: Respond to Main Steam Pressure Transmitter MSS-PT20D Failure to 100%, Causing SG Atmospheric Relief Valve MSS-PV20 to Open (OP3353.MB5C 5-7)

JPM ID Number: 2K7 NRC S.3

Revision: 0 chg 1

II. Initiated:

Barry Pinkowitz
Developer

13 Sept 2004
Date

III. Reviewed:

Paul Malzahn
Technical Reviewer

03/13/04
Date

IV. Approved:

NA
Cognizant Plant Supervisor (optional)

Date

Trad Horner
Nuclear Training Supervisor

09/14/04
Date

JOB PERFORMANCE MEASURE APPROVAL SHEET

SUMMARY OF CHANGES

12/27/06	Revised JPM to correspond to the standard NTP format. DLM	Rev 0 change 1

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Applicant: _____

JPM ID Number: 2K7 NRC S.3 Revision: 0 chg 1

Task Title: Respond to Main Steam Pressure Transmitter MSS-PT20D Failure to 100%, Causing SG Atmospheric Relief Valve MSS-PV20 to Open

System: 039

Time Critical Task: () YES (X) NO

Validated Time (minutes): 10 for RO / 15 for SRO

Task Number(s): _____

Applicable To: SRO X RO X PEO _____

K/A Number: 039 A4.07 K/A Rating: 2.8 / 2.9
041 A4.06 3.1 / 2.9

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards:

- Applicant closes isolation valve 3MSS*MOV18D
- Applicant recognizes both instrument failure and component failure.

Required Materials: None.

General References: OP 3353.MB5C 5-7, MAIN STEAM RELIEF VV NOT CLOSED, rev 003-07

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective(s) for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution were actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: 2K7 NRC S.3

Revision: 0

- Simulator Requirements:
- A. Reset to IC 18 or any other 100% Power IC.
 - C. Place simulator in "RUN"
 - D. Ensure plant is stable and computer point alarms enabled.
 - F. Acknowledge annunciators, then place simulator in "FREEZE"
 - G. Place simulator in "RUN" after the operator receives instructions.

Approximate Simulator setup time is 5 minutes

Simulator Instruction:

T = 0 seconds: Candidate takes the shift.

At T = 45 seconds, insert malfunction MS11D, Severity = 100%. (MS PRESSURE TRANS FAIL MSS-PT20D)

At T = 50 seconds, insert malfunction MS09D, Severity = 100% (PRESS RLF VV PV20D FAIL)

Initial Conditions:

The plant is steady state at 100% power with no equipment out of service. You are to respond to the simulator just as you would respond to the actual plant.

Do you have any questions?

Are you ready to begin?

Initiating Cues:

You have the shift.

****** NOTES TO EVALUATOR ******

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. The student's performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: S.3

Revision: 0 chg 1

Task Title: Respond to Main Steam Pressure Transmitter MSS-PT20D Failure

Start Time:

Comment: It is expected that the applicant take manual control of MSS-PIC20D ("D" SG Atmospheric Relief Valve Controller) and attempt to close the "D" atmospheric relief valve. Once determined that the atmospheric relief valve will not close, it is expected that the applicant will recommend isolating the relief valve by closing 3MSS*MOV18D. It is satisfactory to reference OP 3353.MB5C 5-7 (applicable ARP) after the relief valve is isolated.

STEP	<u> 1 </u>	<u> </u>	Performance Step:	CHECK the following steam generator pressures for proper operation of main steam pressure relief valve (MB5):
			MB5C 5-7 step 1	<ul style="list-style-type: none"> • 3MSS-PIC20A • 3MSS-PIC20B • 3MSS-PIC20C • 3MSS-PIC20D

GRADE	<u> </u>	<u> </u>	Standards:	Applicant checks SG pressures for proper operation of SG Atmospheric Relief Valve. Observes that the process input (3MSS-PT20D) to 3MSS-PIC20D is pegged high as indicated by the controller red pointer.
--------------	-------------------	-------------------	-------------------	---

Grade: **SAT** **UNSAT**

STEP	<u> 2 </u>	<u> </u>	Performance Step:	IF pressure controller has failed, PLACE controller in "MAN" and CLOSE the valve.
			MB5C 5-7 step 2	

GRADE	<u> </u>	<u> </u>	Standards:	Applicant depresses the manual pushbutton on 3MSS-PIC20D and lowers controller output in an attempt to manually close 3MSS-PV20D.
--------------	-------------------	-------------------	-------------------	---

Grade: **SAT** **UNSAT**

PERFORMANCE INFORMATION

JPM Number: S.3

Revision: 0 chg 1

Task Title: Respond to Main Steam Pressure Transmitter MSS-PT20D Failure

STEP	<u> 3 </u>	<u> X </u>	Performance Step: MB5C 5-7 step 3	IF relief valve does not close, CLOSE the following isolation valves (MB5): <ul style="list-style-type: none"> • 3MSS*MOV18D, "ATMOSPHERIC RELIEF ISOL" "SG 4"
-------------	--------------	--------------	---	---

GRADE	<u> </u>	<u> </u>	Standards:	Applicant recommends to the US that the failed open relief valve be isolated by closing 3MSS*MOV18D.
--------------	---------------	---------------	-------------------	--

CUE:	Respond as the US and direct the closing of 3MSS*MOV18D.
-------------	--

GRADE	<u> </u>	<u> X </u>	Standards:	Applicant depresses close pushbutton for 3MSS*MOV18D.
--------------	---------------	--------------	-------------------	---

NOTE:	3MSS*MOV18D is a throttle valve. Applicant must hold the CLOSE pushbutton until the valve is fully shut.
--------------	--

GRADE	<u> </u>	<u> </u>	Standards:	Checks position indicating lights and determines valve has closed by green indicating light on, red off.
--------------	---------------	---------------	-------------------	--

Grade:	SAT <u> </u>	UNSAT <u> </u>
---------------	--------------------------	----------------------------

Examiner Cue for RO Applicants ONLY:	The Unit Supervisor is referring to Technical Specifications. The evaluation for this JPM is complete.
---	--

NOTE:	SRO Applicants continue.
--------------	--------------------------

STEP	<u> 4 </u>	<u> X </u>	Performance Step: MB5C 5-7 step 4	Refer To Technical Specification 3.7.1.6 and DETERMINE Limiting Condition for Operation.
-------------	--------------	--------------	---	--

GRADE	<u> </u>	<u> X </u>	Standards:	SRO Applicant refers to Technical Specifications and enters LCO Action 3.7.1.6.a. (7 day allowed outage time).
			NOTE TO EXAMINER:	SRO applicant should state or otherwise indicate recognition of LCO

PERFORMANCE INFORMATION

JPM Number: S.3

Revision: 0 chg 1

Task Title: Respond to Main Steam Pressure Transmitter MSS-PT20D Failure

requirement.

Grade: SAT UNSAT

STEP 5

Performance Step: If failure is due to an instrument
MB5C 5-7 step 4 problem, Go To AOP 3571.

GRADE

Standards: SRO applicant obtains AOP 3571.

GRADE

Standards: SRO applicant recognizes that all
actions as specified in AOP 3571 for a
failure of 3MSS-PT20D are complete
with the exception of notifying I & C
Department.

Grade: SAT UNSAT

STEP 6

Performance Step: Request I&C Department perform
AOP 3571, Att. I corrective maintenance on failed
Step 3. instrument.

GRADE

Standards: SRO Applicant should state or
otherwise demonstrate request for I&C
action on failed instrument 3MSS-
PT20D.

Grade: SAT UNSAT

Examiner Cue: The evaluation for this JPM is
complete.

Stop Time:

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC S.3

Revision: 0 chg 1

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 10 for RO / 15 for SRO

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

STUDENT HANDOUT

JPM Number: S.3

Initial Conditions: The plant is steady state at 100% power with no equipment out of service. You are to respond to the simulator just as you would respond to the actual plant.

Do you have any questions?

Are you ready to begin?

Initiating Cues: You have the shift.

JOB PERFORMANCE MEASURE WORKSHEET

I. JPM Title: CONTROL ROD OUT OF ALIGNMENT

ID Number: 2K7 NRC S.4

Revision: 1 ch 3

[Change 2, 09/24/2003, J. Deveau]
[Change 3, R.J. Acquaro, 5/30/06]

II. Initiated:

R.L. Lueneburg
Developer

5/15/97
Date

III. Reviewed:

R. Royce
Technical Reviewer

6/13/97
Date

R. Carr
Instructional Reviewer

6/13/97
Date

IV. Approved:

Barry Pinkowitz
Operations Manager

06/13/97
Date

Dave Lazarony
Nuclear Training Supervisor

06/13/97
Date

JOB PERFORMANCE MEASURE WORKSHEET

Change 1	Update to procedure rev 4. Barry Pinkowitz	08/04/2003
Change 2	Update to procedure rev 5 01. John Deveau	09/24/2003
Change 3	Update to procedure rev 007-00 and other minor enhancements. R.J. Acquaro	05/30/2006

JOB PERFORMANCE MEASURE WORKSHEET

JPM Tracking Number: 2K7 NRC S.4
minutes

Validation Time: _____

Task Title: CONTROL ROD OUT OF ALIGNMENT

Time Critical Task: () YES (X) NO

Task Number: 344*05*030 and 344*05*041

System: 001, Control Rod Drive System

K/A Number: 001-A2.03

K/A Rating: 3.5 / 4.2

Applicable Methods of Testing:

Simulate Performance _____ Actual Performance X

Classroom _____ Simulator X Plant _____

Task Standards: Satisfactorily recover from a misaligned control rod using AOP 3552 Attachment A

Required Materials: Shutdown margin calculation

General References: AOP 3552, Rev. 007-00

READ TO THE EXAMINEE

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objectives for this JPM will be satisfied. You may use any approved reference materials normally available in the Control Room, including logs. Make all written reports, oral reports and log entries as if the evolution was actually being performed.

Initial Conditions: **A problem in the EHC circuit caused a momentary runback of the turbine/generator. During the subsequent insertion of the reactor control rods, rod D4 in Control Bank D was observed to be misaligned. The control room team entered AOP 3552, *Malfunction of the Rod Drive System*, and has decided that Attachment A to that procedure is to be used to recover from the misaligned rod.**

The lift coil fuse for rod D4 was blown, and has been replaced.

Rod D4 has been misaligned for less than one hour.

Initiating Cues: **The US has directed you to complete Attachment A of AOP 3552 step 1 through step 7.f.**

JOB PERFORMANCE MEASURE WORKSHEET

SIMULATOR REQUIREMENTS:

1. **Reset to IC# 18.**
2. Enter malfunction **RD0457** Control Band "D" stuck rod "D4"
3. Place the master silence switch in the "Master Silence" position and place the simulator in "RUN".
4. Reduce turbine load by about 20 MWe using the Load Limit potentiometer to cause Control Bank D to insert.
5. Allow rod D4 to misalign by greater than 12 steps, then place Rod Bank SEL switch to MAN.
6. Allow the simulator time to stabilize prior to performing the next step.
7. Remove malfunction **RD0457** to allow recovery of the rod.

Approximate simulator setup time is 12 minutes.

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

Start Time: _____

STEP 1 _____

Performance Step: Obtains copy of AOP 3552

GRADE _____

Standards: Obtains a copy of AOP 3506 and refers to Attachment A, step 1.

STEP 2 _____

Performance Step: Improper rod alignment can cause fuel damage either directly or in conjunction with plant transients.
(Cautions prior to step 1)

Resetting ROD CONTROL URGENT FAILURE (MB4C 4-8) alarm without correcting the cause may result in dropping a group of control rods.

GRADE _____

Standards: Candidate reviews cautions.

Grade: SAT _____ UNSAT _____

STEP 3 _____

Performance Step: A ROD CONTROL URGENT FAILURE (MB4C 4-8) alarm will inhibit both manual and automatic motion for all rods controlled from the affected power cabinet.
(Note prior to step 1)

GRADE _____

Standards: Candidate reviews note.

Grade: SAT _____ UNSAT _____

STEP 4 _____

Performance Step: Check Plant Conditions
(Step 1.a)

Verify operational mode - MODE 1

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

(Step 1.a)

GRADE	<u> </u> <u> </u>	Standards:	Verifies that the plant is in Mode 1 based on current power level.
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 5 </u> <u> </u>	Performance Step:	Identify misaligned rod(s) using:
		(Step 1.b)	
			<ul style="list-style-type: none"> • DRPI display • Rod Supervision on plant process computer

GRADE	<u> </u> <u> </u>	Standards:	Checks the DRPI display and calls up PPC "Rod Supervision" display (NSSS, page forward, F6, F2) and identifies rod D4 as the only affected rod.
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 6 </u> <u> </u>	Performance Step:	Check ROD CONTROL URGENT FAILURE (MB4C 4-8) annunciator - LIT
		(Step 1.c)	

GRADE	<u> </u> <u> </u>	Standards:	Checks Main Board annunciator MB4C 4-8 NOT LIT . Takes RNO action.
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 7 </u> <u> </u>	Performance Step:	Proceed to step 1.o
		(Step 1.c RNO)	

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

GRADE	<u> </u> <u> </u>	Standards:	Proceeds to step 1.o
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 8 </u> <u> </u>	Performance Step:	Request I&C verify affected rod lift coil fuse - NOT BLOWN
		(Step 1.o)	

GRADE	<u> </u> <u> </u>	Standards:	Recognizes from Initial Conditions that the lift coil fuse for rod D4 was blown and has been replaced by I&C.
--------------	-------------------------	-------------------	---

Cue: (If Required)	Inform the candidate that the lift coil fuse for rod D4 was blown and has been replaced by I&C.
---------------------------	---

Grade:	SAT <u> </u> UNSAT <u> </u>
---------------	---

STEP	<u> 9 </u> <u> </u>	Performance Step:	Verify Reactivity Control Systems Limits
		(Step 2.a)	

Using TRM, Appendix 8.1, COLR,
Check all shutdown rods -
WITHDRAWN TO GREATER THAN
OR EQUAL TO THE SHUTDOWN
INSERTION LIMIT

GRADE	<u> </u> <u> </u>	Standards:	Refers to the TRM and verifies that the shutdown rods are greater than the listed insertion limit of 220 steps.
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 10 </u> <u> </u>	Performance Step:	Checks rods - AT LEAST ONE ROD
-------------	-------------------------	--------------------------	--------------------------------

PERFORMANCE INFORMATION

Facility: Millstone Unit 3 System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

		(Step 2.b)	MISALIGNED BY MORE THAN ± 12 STEPS FROM ITS GROUP STEP COUNTER.
GRADE	_____	Standards:	Checks DRPI and/or the PPC "Rod Supervision" display and verifies that rod D4 is out of alignment by more than 12 steps.
		Grade:	SAT _____ UNSAT _____

STEP	<u>11</u>		Performance Step: Checks rods - A MAXIMUM OF ONE ROD MISALIGNED BY MORE THAN ± 12 STEPS FROM ITS GROUP STEP COUNTER. (Step 2.c)
-------------	-----------	--	---

GRADE		Standards:	Checks DRPI and/or the PPC "Rod Supervision" display, and verifies that ONLY rod D4 is out of alignment by more than 12 steps.
		Grade:	SAT _____ UNSAT _____

STEP	<u>12</u>		Performance Step: Notify Reactor Engineering. (Step 2.d)
-------------	-----------	--	--

GRADE		Standards:	Informs the US that D4 is misaligned more than 12 steps from its group and to notify Reactor Engineering. Candidate may call RE directly which is acceptable.
		Grade:	SAT _____ UNSAT _____

STEP	<u>13</u>		Performance Step: Within 1 hour, using OP 3209B, Shutdown Margin, Determine (Step 2.e)
-------------	-----------	--	--

PERFORMANCE INFORMATION

Facility: Millstone Unit 3 System: 001
 JPM Number: 2K7 NRC S.4
 Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"
 NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

Shutdown Margin in Modes 1 and 2
with an inoperable rod.

GRADE **Standards:** Informs the US that Shutdown Margin
in Modes 1 and 2 with an inoperable
rod must be determined within 1 hour.

Cue: As US, inform Candidate that
Shutdown Margin has been
determined to be adequate for present
plant conditions.

Grade: **SAT** **UNSAT**

STEP 14 **Performance Step:** **Verify Power Distribution Limits**
(Step 3.a) Verify reactor power - GREATER
THAN 50%.

GRADE **Standards:** Checks the power range meters on
MB4 and determines that reactor
power is greater than 50%.

Grade: **SAT** **UNSAT**

STEP 15 **Performance Step:** Determine QPTR using:
(Step 3.b)

- Plant computer - Tilting Factors
OR
- SP 31012, Quadrant Power Tilt
Ratio

GRADE **Standards:** Calls up PPC "Tilting Factors" display
(NSSS, page forward, F9, F2) and
determines QPTR.

Grade: **SAT** **UNSAT**

PERFORMANCE INFORMATION

Facility: Millstone Unit 3 System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

STEP	<u>16</u>	<u> </u>	Performance Step:	Check QPTR - LESS THAN OR EQUAL TO 1.09 (Step 3.c)
GRADE	<u> </u>	<u> </u>	Standards:	Recognizes that QPTR < 1.09, and proceeds to next step.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u>17</u>	<u> </u>	Performance Step:	Check QPTR - LESS THAN OR EQUAL TO 1.02 (Step 3.d)
GRADE	<u> </u>	<u> </u>	Standards:	Recognizes that QPTR provided indicates < 1.02, and proceeds to next step.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u>18</u>	<u> </u>	Performance Step:	Using TRM, Appendix 8.1, COLR, Check AFD – WITHIN LIMITS (Step 3.e)
			Cue:	Inform the candidate that AFD is within the limits specified in the TRM.

GRADE	<u> </u>	<u> </u>	Standards:	AFD within limits, candidate proceeds to next step.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u>19</u>	<u> </u>	Performance Step:	Check If Power Should Be Reduced (Step 4.a) If necessary, Request Reactor Engineering determine time rod has been misaligned.
-------------	-----------	-------------	--------------------------	--

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

GRADE	<u> </u> <u> </u>	Standards:	Questions the US how long the rod has been misaligned. The candidate may contact RE directly to determine time rod has been misaligned.
		Cue:	Inform the examinee that the rod has been misaligned for 25 minutes.
		Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>20</u> <u> </u>	Performance Step:	Check rod misaligned - GREATER THAN 1 hour
GRADE	<u> </u> <u> </u>	Standards:	Candidate proceeds to step 4.b. RNO.
		Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>21</u> <u> </u>	Performance Step:	Perform the applicable action: (Step 4.b RNO)
			<ul style="list-style-type: none"> • <u>IF</u> performing rod alignment within 1 hour is desired (T/S 3.1.3.1 ACTION b.1 or T/S 3.1.3.5 ACTION a), <u>THEN</u> Proceed to NOTE prior to step 5
GRADE	<u> </u> <u> </u>	Standards:	Examinee proceeds to step 5.
		Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>22</u> <u> </u>	Performance Step:	A ROD CONTROL URGENT FAILURE (MB4C 4-8) alarm will occur during recovery unless the affected rod is in Shutdown Bank C, D, or E.

PERFORMANCE INFORMATION

Facility: Millstone Unit 3 System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"
 NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

If the affected rod is in a Control Bank, a ROD CONTROL BANKS LIMIT LO (MB4C 3-9) alarm and ROD CONTROL BANKS LIMIT LO LO (MB4C 4-9) alarm may occur during recovery and remain in alarm until the P/A converter is reset. Therefore, response to these alarms is not appropriate during this period.

GRADE **Standards:** Candidate review notes.
Grade: **SAT** **UNSAT**

STEP 23 **Performance Step:** **Establish Conditions For Rod Alignment**
 (Step 5.a)
 Verify cause of the misaligned rod - CORRECTED.

GRADE **Standards:** Recognizes that cause has been corrected from information provided in the Initial Conditions. If questioned as the US provide the following Cue:

Cue (if required): Inform the candidate that the lift coil fuse for rod D4 was blown, and has been replaced.

Grade: **SAT** **UNSAT**

STEP 24 X **Performance Step:** Record affected group step counter position.
 (Step 5.b)

GRADE X **Standards:** Notes the position of the control bank D group 1 step counter and records that number in Step 5.b.

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

			Grade:	SAT	UNSAT
STEP	<u>25</u>	_____	Performance Step:		
			(Step 5.c.1)		
					Align control rod disconnect switches: Unlock and Open control rod disconnect switch box (BOX 3RDS-HDSBOX1, CAT 60, Key #18 in CO key locker)
			Cue:		Inform examinee that the rod control disconnect box is unlocked.
GRADE	_____	_____	Standards:		
					Locates and opens control rod disconnect switch box.
			Grade:	SAT	UNSAT
				_____	_____
STEP	<u>26</u>	<u>X</u>	Performance Step:		
			(Step 5.c.2)		
					Place each rod disconnect switch for the affected bank, <i>except the misaligned rod</i> , to the ROD DISCONNECTED position.
GRADE	_____	<u>X</u>	Standards:		
					Positions all of the disconnect switches for the control bank D rods with the exception of rod D4 "up" to the ROD DISCONNECT position.
			Grade:	SAT	UNSAT
				_____	_____
STEP	<u>27</u>	<u>X</u>	Performance Step:		
			(Step 5.d)		
					Place control rod bank SEL switch to affected bank position.
GRADE	_____	<u>X</u>	Standards:		
					Places the control bank SEL switch to the CBD position.

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

			Grade:	SAT _____	UNSAT _____
STEP	<u>28</u>	_____	Performance Step:	Align Rod	
			(Step 6.a)	Using DRPI display, Check misaligned rod - HIGHER THAN ASSOCIATED BANK.	
GRADE	_____	_____	Standards:	Checks the DRPI display and verifies that rod D4 is higher than the remaining rods in control bank D.	
			Grade:	SAT _____	UNSAT _____
STEP	<u>29</u>	<u>X</u>	Performance Step:	Insert misaligned rod until next lower position DRPI LED just changes state.	
			(Step 6.b)		
GRADE	_____	<u>X</u>	Standards:	Takes the In-Hold-Out switch to the "IN" position until the next lower position LED for rod D4 comes on, then releases the switch.	
			Comment:	This action will cause main board annunciator MB4C 4-8 to alarm. The examinee should silence and acknowledge the alarm. This is not required to satisfy the critical nature of the step.	
			Grade:	SAT _____	UNSAT _____
STEP	<u>30</u>	<u>X</u>	Performance Step:	Reset affected group step counter to a value of 2 steps higher than affected rod's indicated DRPI position.	
			(Step 6.c)		
GRADE	_____	<u>X</u>	Standards:	Resets the control bank D group 1 step counter to a position that	

PERFORMANCE INFORMATION

Facility: Millstone Unit 3 System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"
 NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

corresponds to 2 steps higher than the
 DRPI indication for rod D4.

		Grade:	SAT	UNSAT
STEP	<u>31</u>			
		Performance Step:	Proceed to step 6.g. (Step 6.d)	
GRADE		Standards:	Proceeds to step 6.g.	
		Grade:	SAT	UNSAT
STEP	<u>32</u>			
		Performance Step:	Verify rod misaligned - LESS THAN 16 hours.	
GRADE		Standards:	Use information provided in the Initial Conditions.	
		Grade:	SAT	UNSAT
STEP	<u>33</u>	<u>X</u>		
		Performance Step:	Move misaligned rod until affected group step counter indicates value recorded in step 5.b.	
GRADE		<u>X</u>		
		Standards:	Takes the In-Hold-Out switch to the "IN" position until the control bank D group 1 step counter is at the number that was previously recorded and than releases the switch.	
		Grade:	SAT	UNSAT
STEP	<u>34</u>	<u>X</u>		
		Performance Step:	Restore Rod Control System (Step 7.a)	
			Place all lift coil disconnect switches	

PERFORMANCE INFORMATION

Facility: Millstone Unit 3 System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

for affected bank to ROD
CONNECTED position.

GRADE	<u> </u>	<u> X </u>	Standards:	Returns all lift coil disconnect switches to the "Connected" position.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 35 </u>	<u> </u>	Performance Step:	Check ROD CONTROL URGENT FAILURE (MB4C 4-8) annunciator – LIT
-------------	---------------	-------------	--------------------------	---

GRADE	<u> </u>	<u> </u>	Standards:	Observes that annunciator MB4C 4-8 IS LIT.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 36 </u>	<u> X </u>	Performance Step:	Press ROD DRIVE RESET (Step 7.c)
-------------	---------------	--------------	--------------------------	----------------------------------

GRADE	<u> </u>	<u> X </u>	Standards:	Presses the ROD DRIVE RESET pushbutton on MB4.
			Comments:	This action will cause annunciator MB4C 4-8 to clear. The candidate should reset this alarm. This is not required to complete the critical task of the step.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 37 </u>	<u> </u>	Performance Step:	Place control rod bank SEL switch in MAN
-------------	---------------	-------------	--------------------------	--

GRADE	<u> </u>	<u> </u>	Standards:	Rotates the control bank SEL switch to the MAN position.
--------------	-------------	-------------	-------------------	--

PERFORMANCE INFORMATION

Facility: Millstone Unit 3

System: 001

JPM Number: 2K7 NRC S.4

Task Title: CONTROL ROD OUT OF ALIGNMENT

Denote Critical Steps with an "X"

NOTE Critical Steps must be completed correctly to achieve a satisfactory grade

			Grade:	SAT _____	UNSAT _____
STEP	<u>38</u>	_____	Performance Step:	Check affected rod in a – CONTROL BANK	
			(Step 7.e)		
GRADE	_____	_____	Standards:	Examinee determines that rod D4 is in a control bank.	
			Grade:	SAT _____	UNSAT _____
STEP	<u>39</u>	_____	Performance Step:	Check affected rod in GROUP 1	
			(Step 7.f)		
GRADE	_____	_____	Standards:	Examinee determines that D4 is a Group 1 rod.	
			Grade:	SAT _____	UNSAT _____
			Terminating Cue:	The evaluation for this JPM is concluded.	

Stop Time: _____

VERIFICATION OF COMPLETION

JPM Number: 2K7 NRC S.4

Revision: 1 chg 3

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 9

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

EXAMINEE HANDOUT

INITIAL CONDITIONS AND INITIATING CUES

JPM Tracking Number: 2K7 NRC S.4

Initial Conditions: A problem in the EHC circuit caused a momentary runback of the turbine/generator. During the subsequent insertion of the reactor control rods, rod D4 in Control Bank D was observed to be misaligned. The control room team entered AOP 3552, *Malfunction of the Rod Drive System*, and has decided that Attachment A to that procedure is to be used to recover from the misaligned rod.

The lift coil fuse for rod D4 was blown and has been replaced.

Rod D4 has been misaligned for less than one hour.

Initiating Cues: The US has directed you to complete Attachment A of AOP 3552 step 1 through step 7.f.

JOB PERFORMANCE MEASURE APPROVAL SHEET


I. JPM Title: PERFORMANCE OF THE IMMEDIATE ACTIONS IN E-0

JPM ID Number: 2K7 NRC S.5

Revision: 0

II. Initiated:


Dave Minnich
Developer



12/21/06
Date

III. Reviewed:

Technical Reviewer



1/24/07
Date


IV. Approved:

Cognizant Plant Supervisor (optional)

NA

Date

Nuclear Training Supervisor



1/24/07
Date

JOB PERFORMANCE MEASURE APPROVAL SHEET

SUMMARY OF CHANGES

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Student: _____

JPM ID Number: 2K7 NRC S.5 Revision: 0

Task Title: PERFORMANCE OF THE IMMEDIATE ACTIONS IN E-0

System: 012

Time Critical Task: () YES (X) NO

Validated Time (minutes): 5

Task Number(s): 000*05*084

Applicable To: SRO _____ RO _____ PEO _____

K/A Number:	012-A4.01	K/A Rating:	4.5 / 4.5
	013-A4.03		4.5 / 4.7
	<u>EPE: 007-EA2.02</u>		<u>4.3 / 4.6</u>

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards: Satisfactorily complete the first 4 steps in E-0 from memory including any applicable RNO actions.

Required Materials: None.

General References: EOP 35, E-0, Rev. 022

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective(s) for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution were actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: 2K7 NRC S.5

Revision: 0

- Simulator Requirements:
1. Reset to IC-18 or any other 100% power certified IC. Ensure the turbine is on the Load Limit.
 2. Enter malfunctions TC03 (turbine fails to trip), RP07A ("A" train of SI fails to auto actuate) and RC09B to cause the "B" RCP to trip.
 3. Place the simulator in run. Place the master silence switch in the "silence" position.
 4. After the reactor has tripped, place the simulator in "freeze".
 5. Place the simulator in "run" after the examinee has read and understands the Initial conditions and initiating cues.

Approximate simulator setup time is 5-7 minutes.

Initial Conditions: Just seconds ago, while the plant was operating at 100% power, the "B" RCP tripped. The US has placed the master silence switch in the "silence" position. The evaluator will acknowledge all communications to the US.

Initiating Cues: You are directed to carry out the first four (4) steps of E-0 from memory. The simulator will be placed in run when you are ready to begin.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. The student's performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.5

Revision: 0

Task Title: PERFORMANCE OF THE IMMEDIATE ACTIONS IN E-0

Start Time: _____

STEP 1 _____

Performance Step: Verify Reactor Trip.
1.

- Check reactor trip and bypass breakers - OPEN.
- Check rod bottom lights - LIT.
- Check neutron flux - DECREASING.

GRADE _____

Standards:

Observes that the reactor trip breakers are open, all the rod bottom lights are lit and that reactor power is decreasing. Reports that the reactor is tripped.

Grade:

SAT _____ UNSAT _____

STEP 2 _____

Performance Step: Verify Turbine Trip.
2.a.

- a. Check all turbine stop valves - CLOSED.

GRADE _____

Standards:

Looks at the stop valve meter indications on the EHC insert on MB7 and observes that all of the turbine stop valves are open. Shifts to the actions in the RNO column.

Grade:

SAT _____ UNSAT _____

STEP 3 X

Performance Step: TRIP the turbine.
2.a.RNO

GRADE _____ X

Standards:

Pushes the turbine trip push-button on the EHC insert. Looks at the stop valve meter indications on the EHC insert on MB7 and observes that all of

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.5

Revision: 0

Task Title: PERFORMANCE OF THE IMMEDIATE ACTIONS IN E-0

the turbine stop valves are still open.

Grade: **SAT** _____ **UNSAT** _____

STEP 4 X **Performance Step:** IF the turbine will NOT trip, THEN
2.a.RNO Runback the turbine to close the control valves. IF the turbine can NOT be runback THEN CLOSE the MSIVs and MSIV bypass valves.

GRADE _____ X **Standards:** Rapidly rotates the load limiting control knob in the lower direction all the way to the zero position. Observes that the control valves are closing and when the control valves are fully closed declares that the turbine is tripped. Shifts to actions in the ACTION column.

Grade: **SAT** _____ **UNSAT** _____

Evaluator NOTE: The applicant may decide the control valves are not closing fast enough or the control valves are not fully closed. In that case he will go to 'CLOSE' on the MSIV switches and verify the MSIV Bypass valves closed. This is acceptable.

STEP 5 _____ **Performance Step:** Verify Power to AC Emergency
3.a. Busses.

a. Check AC emergency busses 34C and 34D - BOTH ENERGIZED

GRADE _____ _____ **Standards:** Determines Busses 34C And 34D are both energized by observation of the Main Board 8 emergency bus voltage indicators reading about 4160 volts OR emergency load center voltage indicators (8) reading about 480 volts.

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.5

Revision: 0

Task Title: PERFORMANCE OF THE IMMEDIATE ACTIONS IN E-0

Grade: SAT _____ UNSAT _____

Note: An SI will have actuated due to the turbine not tripping.

STEP 6 _____

Performance Step: Check if SI is Actuated.
4.a.

a. Verify SAFETY INJECTION ACTUATION annunciator (MB4D 1-6 or MB2B 5-9) - LIT

GRADE _____ _____

Standards: AT MB4 or MB2, observes that the Safety Injection Actuation annunciator is lit.

Grade: SAT _____ UNSAT _____

STEP 7 _____

Performance Step: By observation of ESF Group 2 Status Panel lights, Verify both trains of SI - ACTUATED
4.b.

GRADE _____ _____

Standards: At MB2, observes ESF Group 2 Status Panel and determines only one train of SI has actuated. Shifts to the actions in the RNO column.

Grade: SAT _____ UNSAT _____

STEP 8 X

Performance Step: Manually Initiate SI.
4.b.RNO

GRADE _____ X

Standards: At MB2 or MB4, manually actuates SI by rotating the SI actuation switch to

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.5

Revision: 0

Task Title: PERFORMANCE OF THE IMMEDIATE ACTIONS IN E-0

Standards: the actuate position.
By observation of ESF Group 2 Status Panel determines that both trains of SI have actuated.

Grade: SAT _____ UNSAT _____

STEP 9 _____

Performance Step: Check reactor trip and bypass breakers - OPEN
4.c.

GRADE _____

Standards: At MB4, observes that the reactor trip and bypass breakers are open.

Grade: SAT _____ UNSAT _____

STEP 10 _____

Performance Step: Reports that the first four steps of E-0 have been completed.

GRADE _____

Standards: Informs the examiner that he has completed the first four (4) steps of E-0 and that a safety injection has occurred.

Grade: SAT _____ UNSAT _____

Terminating Cue: The evaluation for this JPM is concluded.

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC S.5

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 5

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

Candidate HANDOUT

JPM Number:

2K7 NRC S.5

Initial Conditions:

Just seconds ago, while the plant was operating at 100% power, the "B" RCP tripped. The US has placed the master silence switch in the "silence" position. The evaluator will acknowledge all communications to the US.

Initiating Cues:

You are directed to carry out the first four (4) steps of E-0 from memory. The simulator will be placed in "run" when you are ready to begin.

JOB PERFORMANCE MEASURE APPROVAL SHEET

I. JPM Title: Check if RCP(s) Should Be Stopped

JPM ID Number: 2K7 NRC S.6

Revision: 0

II. Initiated:

P. Malzahn
Developer

6/20/05
Date

III. Reviewed:

R. McDonald
Technical Reviewer

6/30/05
Date

IV. Approved:

J. Grogan
Cognizant Plant Supervisor (optional)

6/30/05
Date

T. Kulterman
Nuclear Training Supervisor

7/1/05
Date

JOB PERFORMANCE MEASURE APPROVAL SHEET

SUMMARY OF CHANGES

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Student: _____

JPM ID Number: 2K7 NRC S.6 Revision: 0

Task Title: Check If RCP(s) Should Be Stopped

System: 002

Time Critical Task: () YES (X) NO

Validated Time (minutes): 5

Task Number(s): 344-05-033

Applicable To: SRO X RO X PEO _____

K/A Number: 002-A2.04 K/A Rating: 4.3 / 4.6

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards: All critical steps are performed satisfactorily. All sequential steps are performed in proper procedural sequence.

Required Materials: None.

General References: EOP 3505 Rev. 010-02

READ TO THE STUDENT

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective(s) for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution were actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: S.6

Revision: 0

Simulator Requirements:

- A. Reset to IC 29 or equivalent (Mode 5, 170° - 180°F, steam bubble in PZR, 2 RHR trains in service)
- B. Insert Malfunctions RH01A, RH01B (RHR P1A and B trip)
- C. Place the "A" RHR pp control switch in P-T-L and place a yellow caution tag on the switch.
- D. Place simulator in "RUN" and verify "A" & "B" RCPs running and RHR pumps off/tripped.
- E. Adjust Charging flow if necessary to maintain RCS pressure between 310 and 375 psia.
- E. Place simulator in "FREEZE".
- F. Place simulator in "RUN" after candidate receives instructions.

Approximate Simulator setup time is 10 minutes

Initial Conditions:

The plant is in Mode 5 with a steam bubble in the PZR and "A" & "B" RCPs in service. The "A" RHR pump is out of service due to a breaker problem. Several minutes ago the "B" RHR pump tripped and the crew entered EOP 3505, Loss Of Shutdown Cooling And/Or RCS Inventory. Attachment "B," Loss of Shutdown Cooling And/Or RCS Inventory During Mode 5, has been completed through step 8 and all S/G's have been verified available.

Initiating Cues:

The US has directed you to perform step 9 of EOP 3505 Att. "B," Check if RCP(s) Should Be Stopped.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. The student's performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: S.6

Revision: 0

Task Title: Check if RCP(s) Should Be Stopped

Start Time:

STEP	<u> 1 </u>	<u> </u>	Performance Step:	Obtains copy of EOP 3505.
GRADE	<u> </u>	<u> </u>	Standards:	Obtains a copy of EOP 3505, refers to Attachment "B" Step 9.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 2 </u>	<u> </u>	Performance Step:	Check RCP status – AT LEAST ONE RUNNING
			Att. "B" step 9.a.	
GRADE	<u> </u>	<u> </u>	Standards:	Checks RCP breaker indications, flow, amps etc. and determines "A" & "B" RCPs are running
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 3 </u>	<u> </u>	Performance Step:	Verify only one RCP - RUNNING
			Att. "B" step 9.b.	
GRADE	<u> </u>	<u> </u>	Standards:	Checks RCP breaker indications, flow, amps etc. and determines "A" & "B" RCPs are running. Moves to RNO column.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 4 </u>	<u> X </u>	Performance Step:	PERFORM the applicable action:
			Att. "B" step 9.b. RNO	<ul style="list-style-type: none"> • <u>IF</u> PZR steam bubble is established, <u>THEN</u> STOP all but RCP 2 • <u>IF</u> PZR is solid, <u>THEN</u> STOP all but one RCP
GRADE	<u> </u>	<u> </u>	Standards:	Determines from initiating cue and/or PZR liquid/vapor space temperatures that PZR steam bubble established

PERFORMANCE INFORMATION

JPM Number: S.6

Revision: 0

Task Title: Check if RCP(s) Should Be Stopped

	Grade:	SAT _____	UNSAT _____
GRADE _____	Standards:	STOPS "A" RCP	

Comment: Examinee may elect to place the spray valve controller for "A" RCP in Manual and close the valve

	Grade:	SAT _____	UNSAT _____
--	---------------	------------------	--------------------

STEP <u> 5 </u> _____	Performance Step:	Check the following for the running RCP Att. "B" step 9.c. <ul style="list-style-type: none"> • No. 1 Seal differential pressure – GREATER THAN 210 psid • No. 1 Seal leakoff flow – GREATER THAN OR EQUAL TO 0.2 gpm
--------------------------------	--------------------------	--

GRADE _____	Standards:	Determines seal parameters are satisfied by observing CHS-PI152A, CHS-FR156 and/or CHS-FR160 indications at MB3.
--------------------	-------------------	--

	Grade:	SAT _____	UNSAT _____
--	---------------	------------------	--------------------

STEP <u> 6 </u> _____	Performance Step:	Maintain RCS pressure BETWEEN 310 psia and 375 psia Att. "B" step 9.d.
--------------------------------	--------------------------	---

GRADE _____	Standards:	Determines RCS pressure is within required band by observing RCS-PR403, RCS-PI405A, or a PPC pressure trend if established.
--------------------	-------------------	---

	Grade:	SAT _____	UNSAT _____
--	---------------	------------------	--------------------

STEP <u> 7 </u> _____	Performance Step:	Reports to US that step 9 of EOP 3505 Att. "B" has been completed and the "B" RCP is running, "A" RCP has been stopped.
--------------------------------	--------------------------	---

GRADE _____	Standards:	Reports completion to US
--------------------	-------------------	--------------------------

PERFORMANCE INFORMATION

JPM Number: S.6

Revision: 0

Task Title: Check if RCP(s) Should Be Stopped

Grade: **SAT** _____ **UNSAT** _____

Terminating Cue: The evaluation for this JPM is concluded.

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC S.6

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 5

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

STUDENT HANDOUT

JPM Number:

S.6

Initial Conditions:

The plant is in Mode 5 with a steam bubble in the PZR and "A" & "B" RCPs in service. The "A" RHR pump is out of service due to a breaker problem. Several minutes ago the "B" RHR pump tripped and the crew entered EOP 3505, Loss Of Shutdown Cooling And/Or RCS Inventory. Attachment "B," Loss of Shutdown Cooling And/Or RCS Inventory During Mode 5, has been completed through step 8 and all S/G's have been verified available.

Initiating Cues:

The US has directed you to perform step 9 of EOP 3505 Att. "B," Check if RCP(s) Should Be Stopped.

JOB PERFORMANCE MEASURE APPROVAL WORKSHEET


I. JPM Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

JPM ID Number: 2K7 NRC S.7

Revision: 0

II. Initiated:

D. Minnich
Developer



12/27/06
Date

III. Reviewed:

Technical Reviewer



1/24/07
Date

IV. Approved:

Cognizant Plant Supervisor (optional)

Date

Nuclear Training Supervisor



1/24/07
Date

JOB PERFORMANCE MEASURE APPROVAL WORKSHEET

SUMMARY OF CHANGES

Change	Description	Date

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Candidate: _____

JPM ID Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

System: 010

Time Critical Task: () YES (X) NO

Validated Time (minutes): 5

Task Number(s): 000-05-050

Applicable To: SRO X RO X PEO _____

K/A Number: 010-A2.03 K/A Rating: 4.1 / 4.2
009-EA1.15 3.9 / 4.1

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards: Depressurize the RCS to refill the PZR as specified in ES-1.2, steps 10 and 11.

Required Materials: None

General References: ES-1.2, Post LOCA Cooldown and Depressurization, Rev. 015-00

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objectives for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: 2K7 NRC S.7

Revision: 0

- Simulator Requirements:
- 1 Reset to IC-79, trip from 100% power, Post-LOCA cooldown conditions.
 - 2 Insert the following I/Os:
 - 3 (RC) 3RCS*PCV455A OPEN TO FALSE
 - 4 (RC) 3RCS*PCV455A RED TO FALSE
 - 5 (RC) 3RCS*PCV455A GREEN TO FALSE
 - 6 (RC) 3RCS*PCV456 OPEN TO FALSE
 - 7 (RC) 3RCS*MV8000 RED TO FALSE
 - 8 (RC) 3RCS*MV8000 GREEN TO FALSE
 - 9 Roll the following recorders forward:
 - Pressurizer level.
 - RCS wide range pressure.
 - 10 Place the simulator in "RUN" and perform the following manual actions:
 - Acknowledge/clear all alarms.
 - Throttle AFW flow to 100 gpm for each S/G.
- NOTE: Move through this setup expeditiously to avoid pressurizer refill above 25% before the candidate gets to the depressurization step.
- Acknowledge/clear associated alarms.
 - Place the simulator in "FREEZE."
 - Ensure key for 3RCS*AV8145 inserted for valve operation
 - Hang a yellow tag on 3RCS*MV8000
- 11 After the examinee has received the initial conditions and initiating cues, place the simulator in "RUN."
- Approximate simulator setup time is 5 minutes.

Initial Conditions:

Following a loss of coolant accident which resulted in a safety injection, the Control Room Team has worked through the EOPs and is currently carrying out the actions in ES-1.2, Post LOCA Cooldown and Depressurization. The "A" PORV is out of service due to an electrical short in the control circuitry.

Initiating Cues:

The US has directed you to depressurize the RCS to refill the PZR using ES-1.2, steps 10 and 11.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, ALL critical steps must be completed correctly.

JOB PERFORMANCE MEASURE GUIDE (Continued)

The students performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.

2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

Start Time: _____

STEP	<u>1</u>	Performance Step:	Obtains copy of ES-1.2
GRADE	_____	Standards:	Obtains a copy of ES-1.2 and refers to step 10.
		Grade:	SAT _____ UNSAT _____
		Comment:	The heater control switches in the first JPM step may be operated in any order.
STEP	<u>2</u>	Performance Step:	Place All PZR Heater Switches To OFF position. (ES-1.2 step 10)
GRADE	<u>X</u>	Standards:	Rotates the "D" PZR B/U heaters control switch to "OFF." Observes the amber light goes OFF.
GRADE	<u>X</u>	Standards:	Rotates the "E" PZR B/U heaters control switch to "OFF." Observes the amber light goes OFF.
GRADE	<u>X</u>	Standards:	Rotates the "C" PZR Control Heaters control switch to "OFF." Observes the amber light goes OFF and the flag shifts to "green."
		Comments:	MB4A 6-4 annunciator "PZR HEATER CONTROL GROUP AUTO TRIP" will clear. The candidate should silence and clear this alarm. This action is not required to complete the critical nature of this step.
GRADE	<u>X</u>	Standards:	Rotates the "A" PZR B/U heaters control switch to "OFF." Observes the amber light goes OFF.

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

GRADE X **Standards:** Rotates the "B" PZR B/U heaters control switch to "OFF." Observes the amber light goes OFF.

Grade: **SAT** **UNSAT**

Comments: When the last PZR B/U heaters control switch is taken to "OFF", MB4A 6-3 annunciator "PZR HEATER BACKUP GROUP AUTO TRIP" will clear. The examinee should acknowledge and clear this alarm. This action is not required to complete the critical nature of this step.

Comment: Prior to completing the depressurization, the examinee should check containment temperature and radiation levels to ensure that adverse CTMT conditions do not exist. Since CTMT conditions are not adverse, this action is not critical to the successful completion of the JPM.

STEP 3 **Performance Step:** Depressurize RCS to refill PZR.

(Step 11.a) Check normal PZR spray - AVAILABLE

GRADE **Standards:** Observes that no RCPs are running and therefore normal PZR spray is not available. Shifts to the Response Not Obtained column.

Grade: **SAT** **UNSAT**

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

STEP	<u>4</u>	<u>X</u>	Performance Step:	Perform the applicable action: (step 11.a RNO)
				<ul style="list-style-type: none"> • <u>IF</u> a PZR PORV is available, <u>THEN</u> Depressurize RCS using one PZR PORV and Proceed to step 11.d. • <u>IF</u> a PZR PORV is <u>NOT</u> available, <u>THEN</u> Proceed to step 11.c.
			Comments:	The candidate should determine that the "A" PORV is out of service.
GRADE		<u>X</u>	Standards:	Candidate takes the control switch for the "B" PORV to the OPEN position.
GRADE		<u>X</u>	Standards:	Candidate determines that the "B" PORV will not open and proceeds to step 11.c.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>5</u>		Performance Step:	Use auxiliary spray: (step 11.c.1)
				Verify at least one SIH pump - RUNNING
GRADE			Standards:	Determines that both SI pumps are running by observation of red indicating lights on / green off, amps, flow etc.
			Grade:	SAT <u> </u> UNSAT <u> </u>

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

STEP	<u>6</u>	<u> </u>	Performance Step: (Step 11.c.2)	Verify at least one charging pump - RUNNING
GRADE	<u> </u>	<u> </u>	Standards:	Determines that both charging pumps are running by observation of red indicating lights on / green off, amps, flow etc.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>7</u>	<u> </u>	Performance Step: (Step 11.c.3)	CLOSE charging header loop isolation valves • 3CHS*AV8146 • 3CHS*AV8147
GRADE	<u> </u>	<u> </u>	Standards:	Determines that both charging header loop isolation valves are closed by observation of green indicating lights on / red off.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>8</u>	<u>X</u>	Performance Step: (Step 11.c.4)	Fully Open charging line flow control valve.
GRADE	<u> </u>	<u>X</u>	Standards:	Candidate takes manual control of and fully opens 3CHS*FCV121 by depressing the open pushbutton on 3CHS*FK121 until output is at maximum.
			Grade:	SAT <u> </u> UNSAT <u> </u>

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

STEP	<u>9</u>	<u>X</u>	Performance Step: (Step 11.c.5)	OPEN charging header isolation valves <ul style="list-style-type: none"> • 3CHS*MV8106 • 3CHS*MV8105
GRADE	_____	<u>X</u>	Standards:	Depresses open pushbuttons for 3CHS*MV8106 and 3CHS*MV8105.
GRADE	_____	_____	Standards:	Checks position indicating lights and determines valves have opened by red indicating lights on, green off.
			Grade:	SAT _____ UNSAT _____
STEP	<u>10</u>	<u>X</u>	Performance Step: (Step 11.c.6)	Unlock and OPEN auxiliary spray valve (3RCS*AV8145)
GRADE	_____	<u>X</u>	Standards:	Obtains and inserts key into the 3RCS*AV8145 control switch and rotates clockwise to the open position.
GRADE	_____	_____	Standards:	Checks position indicating lights and determines valve has opened by red indicating light on, green off.
			Grade:	SAT _____ UNSAT _____
STEP	<u>11</u>	_____	Performance Step: (Step 11.c.7)	CLOSE both charging pump cold leg injection valves <ul style="list-style-type: none"> • 3SIH*MV8801A • 3SIH*MV8801B
GRADE	_____	<u>X</u>	Standards:	Depresses close pushbuttons for 3SIH*MV8801A and 3SIH*MV8801B.

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

GRADE **Standards:** Checks position indicating lights and determines valves have closed by green indicating lights on, red off.

GRADE **Standards:** Observes RCS pressure decreasing on Wide Range Loop pressure instruments: RCS-PI405, PI49, PI403 and PI50.

Grade: **SAT** **UNSAT**

STEP 12 **Performance Step:** Verify PZR level - GREATER THAN (Step 11.d) 25% (50% ADVERSE CTMT)

GRADE **Standards:** Monitors PZR level increase by observing instruments RCS-LI459A, 460A and 461. Initial observation will indicate level is less than 25%. Shifts to the RNO column.

Grade: **SAT** **UNSAT**

STEP 13 **Performance Step:** Proceed to CAUTION prior to step 12. and, WHEN Level is GREATER THAN 25% (50% ADVERSE CTMT), THEN Perform step 11.e.

GRADE **Standards:** Candidate Proceeds to the caution prior to step 12.

GRADE **Standards:** The examinee should continue to monitor pressurizer level to determine when the depressurization should be stopped.

Grade: **SAT** **UNSAT**

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7

Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

Cue: The US is going to wait until the depressurization is complete before starting an RCP.

Observes pressurizer level is greater than 25% (Annunciator MB4A:5-1 "PZR LVL LO HTR OFF and LT DOWN SECURE" clears.)

GRADE

Standards:

Performance Step: Check normal PZR spray valve - OPEN FOR DEPRESSURIZATION (Step 11.e)

STEP 14

Standards:

Observes indications associated with spray valves and determines spray valves are closed. Proceeds to step 11.e RNO

GRADE

Standards:

Grade: SAT UNSAT

Performance Step: Perform the applicable action:

STEP 15

Standards:

IF auxiliary spray valve open, THEN, OPEN both charging pump cold leg injection valves.

GRADE

Standards:

Depresses open pushbuttons for 3SIH*MV8801A and 3SIH*MV8801B. Checks position indicating lights and determines valves have opened by red

GRADE

Standards:

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

indicating lights on, green off.

Grade: **SAT** _____ **UNSAT** _____

STEP 16 _____ **Performance Step:** CLOSE auxiliary spray valve
(Step 11.e.2) (3RCS*AV8145).

GRADE _____ X **Standards:** Rotates key in the 3RCS*AV8145
control switch counter- clockwise to
the closed position.

GRADE _____ _____ **Standards:** Checks position indicating lights and
determines valve has closed by green
indicating light on, red off.

Grade: **SAT** _____ **UNSAT** _____

STEP 17 _____ **Performance Step:** CLOSE charging header isolation
(Step 11.e.3) valves.

GRADE _____ X **Standards:** Depresses close pushbuttons for
3CHS*MV8106 and 3CHS*MV8105.

GRADE _____ _____ **Standards:** Checks position indicating lights and
determines valves have closed by
green indicating lights on, red off.

Grade: **SAT** _____ **UNSAT** _____

STEP 18 _____ **Performance Step:** Proceed to CAUTION prior to step 12.
(Step 11.e.4)

GRADE _____ _____ **Standards:** Candidate proceeds to CAUTION prior
to step 12.

Grade: **SAT** _____ **UNSAT** _____

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC S.7 Revision: 0

Task Title: DEPRESSURIZE THE RCS TO REFILL THE PZR

STEP 19 _____

Performance Step: Inform the US that the RCS has been depressurized and the pressurizer refilled in accordance with ES-1.2.

GRADE _____

Standards: Reports to the US that Steps 10 and 11 of ES-1.2 have been completed. Pressurizer level is greater than 25% and the depressurization has been stopped.

Grade: SAT UNSAT

Terminating Cue: The evaluation for this JPM is concluded.

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC S.7

Revision: 0

Date Performed: _____

Candidate: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): XX

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

Candidate HANDOUT

JPM Number: S.7

Initial Conditions: Following a loss of coolant accident which resulted in a safety injection, the Control Room Team has worked through the EOPs and is currently carrying out the actions in ES-1.2, Post LOCA Cooldown and Depressurization. The "A" PORV is out of service due to an electrical short in the control circuitry.

Initiating Cue: The US has directed you to depressurize the RCS to refill the PZR using ES-1.2, steps 10 and 11.

JOB PERFORMANCE MEASURE APPROVAL SHEET


I. JPM Title: Respond To Containment Sump Blockage

JPM ID Number: 2K7 NRC S.8

Revision: 0

II. Initiated:

D. Minnich
Developer



12/13/06
Date

III. Reviewed:

Technical Reviewer



1/24/07
Date

IV. Approved:

Cognizant Plant Supervisor (optional)

Date

Nuclear Training Supervisor



1/24/07
Date

JOB PERFORMANCE MEASURE APPROVAL SHEET

SUMMARY OF CHANGES

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Applicant: _____

JPM ID Number: 2K7 NRC S.8 Revision: 0

Task Title: Respond To Containment Sump Blockage

System: 026

Time Critical Task: () YES (X) NO

Validated Time (minutes): X

Task Number(s): 000-05-130

Applicable To: SRO X RO X PEO _____

K/A Number: EPE: E11 EA1.1 K/A Rating: 3.9 / 4.0
026-A2.07 3.9 / 3.6
2.1.25 2.8 / 3.1

Method of Testing: Simulated Performance: _____ Actual Performance: X

Location: Classroom: _____ Simulator: X In-Plant: _____

Task Standards: All critical steps are performed satisfactorily. All sequential steps are performed in proper procedural sequence.

Required Materials: None.

General References: ECA-1.1, Loss of Emergency Coolant Recirculation, Rev 015-00

READ TO THE STUDENT

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective(s) for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution were actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: 2K7 NRC S.8

Revision: 0

Simulator Requirements:

- A. Reset to IC-18, MOL, 100% power.
- B. Insert Malfunction RC02C at 100%
- C. Allow Sim to run until "RWST LO LO LEVEL RHR PUMPS OFF" annunciator lights. RWST level should be around 520,000 gal.
- D. Complete Cold Leg Recirculation alignment per ES-1.3
- E. IO (CV) 3CHS*LCV112D "Green" to "OFF"
- F. IO (CV) 3CHS*LCV112E "Green" to "OFF"
- G. Turn on all power lockout switches on MB2R
- H. Ensure Containment Pressure less than 23 psia
- I. Insert malfunction CH08 at 80% severity
- J. When RSS pump cavitation is evident, reset SI, then LOP and CDA then stop all ECCS and RSS pumps.
- K. Acknowledge all annunciators and go to freeze
- L. Remove malfunction CH08.
- M. Place simulator in "RUN" after the operator receives instructions.

Approximate Simulator setup time is 30 minutes

Initial Conditions:

Following a large break loss of coolant accident (LBLOCA), the plant has established cold leg recirculation per ES-1.3, up to and including Step 4. Shortly thereafter, symptoms of significant CTMT sump clogging appeared. All ECCS and RSS pumps were stopped. The crew is transitioning to ECA-1.1, *Loss of Emergency Coolant Recirculation*.

Initiating Cues:

You are to complete the steps of ECA-1.1, starting with step 1.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. The students performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

Start Time:

STEP	<u> 1 </u>	<u> </u>	Performance Step:	Obtains copy of ECA-1.1
GRADE	<u> </u>	<u> </u>	Standards:	Obtains a copy of ECA-1.1 and refers to the CAUTION and NOTE prior to step 1
			Grade:	SAT
STEP	<u> 2 </u>	<u> </u>	Performance Step:	If the suction source is lost to any ECCS or containment spray pump, the pump must be stopped.
GRADE	<u> </u>	<u> </u>	Standards:	Applicant reads CAUTION.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 3 </u>	<u> </u>	Performance Step:	If emergency coolant recirculation capability is restored during this procedure, further recovery actions should continue by going to the procedure and step in effect.
GRADE	<u> </u>	<u> </u>	Standards:	Applicant reads NOTE.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 4 </u>	<u> </u>	Performance Step:	Continue Attempts To Restore Emergency Coolant Recirculation Equipment
GRADE	<u> </u>	<u> </u>	Standards:	Applicant reads the step and proceeds to step 2.
			CUE: (if required)	Respond as the US that continuing with ECA-1.1 will effectively continue attempts to Restore Emergency

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

Coolant Recirculation

Grade: **SAT** **UNSAT**

STEP 5 _____

Performance Step: 2. If offsite power is lost after SI reset, manual actions to restart safeguards equipment may be required.

GRADE _____ _____

Standards: Applicant reads the CAUTION

Grade: **SAT** **UNSAT**

STEP 6 _____

Performance Step: 2. RESET ESF Actuation Signals If Required

- SI
- CDA
- LOP

GRADE _____ _____

Standards: Applicant resets those signals requiring reset.

NOTE: SI, CDA and LOP have already been reset as part of simulator setup. The applicant may reset all signals regardless of status – this is not an error.

CUE: (If required) Respond as the US that SI, CDA and LOP have already been reset.

Grade: **SAT** **UNSAT**

STEP 7 _____

Performance Step: 3.a. Add Makeup To RWST

Using GA-10, Fill the RWST as required while continuing with this procedure WHEN RWST level has increased to greater than 100,000 gal THEN Consult ADTS to determine what flow path should be established for injection

GRADE _____ _____

Standards: Applicant reads step and informs the

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

US that GA-10 must be carried out to fill the RWST.

CUE: Respond as the US that another RO will carry out the actions of GA-10.

Grade: **SAT** _____ **UNSAT** _____

STEP 8 _____

Performance Step: Check Quench Spray Pump Requirements
4.a.

a. Verify Ctmt high range radiation monitors (3RMS*RE04A and 3RMS*RE05A) - NOT IN ALERT OR ALARM

GRADE _____ _____

Standards: Determines that the CTMT high range radiation monitors are not in alert or alarm by observation of 3RMS*RE04A and *RE05A amber and red trip lights are not lit.

NOTE: Due to OPERABILITY concerns with respect to 3RMS*RE04A and *RE05A, the applicant may use diverse indications to determine the radiation reading inside CTMT.

STEP 9 _____

Performance Step: Check Ctmt spray - INITIATED
4.b.

GRADE _____ _____

Standards: Determines that both Quench Spray pumps are running by observation of red indicating lights on / green off, amps, flow etc.

Grade: **SAT** _____ **UNSAT** _____

STEP 10 _____

Performance Step: Check Ctmt pressure - LESS THAN 17.5 psia.
4.c.

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

GRADE	<u> </u>	<u> </u>	Standards:	Determines by observation that CTMT pressure is less than 17.5 psia.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 11 </u>	<u> X </u>	Performance Step:	STOP both quench spray pumps and place in AUTO
			4.d.	
GRADE	<u> </u>	<u> X </u>	Standards:	Stops the "A" and "B" quench spray pumps by rotating each control switch to the stop position.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 12 </u>	<u> </u>	Performance Step:	CLOSE quench spray pump(s) discharge valves
			4.e.	<ul style="list-style-type: none"> • For pump A - 3QSS*MOV34A • For pump B - 3QSS*MOV34B
GRADE	<u> </u>	<u> </u>	Standards:	Depresses the 3QSS*MOV34A "CLOSE" pushbutton. Verifies indicating lights shift to green ON, red OFF
GRADE	<u> </u>	<u> </u>	Standards:	Depresses the 3QSS*MOV34B "CLOSE" pushbutton. Verifies indicating lights shift to green ON, red OFF
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 13 </u>	<u> </u>	Performance Step:	Check Ctmt pressure - GREATER THAN 23 psia.
			4.f.	
GRADE	<u> </u>	<u> </u>	Standards:	Determines by observation that CTMT pressure is less than 23 psia.

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

		Grade:	SAT _____	UNSAT _____
STEP	<u> 14 </u>	Performance Step:	Proceed to step 5. and, IF Ctmt pressure increases to 23 psia, THEN Realign quench spray system to establish only one quench spray pump running	
		4.f. RNO		
GRADE	_____	Standards:	Proceeds to step 5.	
		Grade:	SAT _____	UNSAT _____
STEP	<u> 15 </u>	Performance Step:	Verify CAR Fan Status	
		5.a.	a. Check Ctmt WR sump level (RSS*LI22A or RSS*LI22B) - LESS THAN 4 ft	
GRADE	_____	Standards:	Determines that Ctmt WR sump level is greater than 4 ft by direct observation of RSS*LI22A and RSS*LI22B.	
		Grade:	SAT _____	UNSAT _____
STEP	<u> 16 </u>	Performance Step:	STOP running CAR fans and Proceed to step 6.	
		5.a.RNO		
GRADE	_____	Standards:	At VP1 determines that CAR fans A and B are NOT running by observation of green indicating lights on / red off. Proceeds to step 6.	
		Grade:	SAT _____	UNSAT _____

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

STEP	<u> 17 </u> _____	Performance Step:	Monitor Containment Recirculation Sump- INDICATION OF BLOCKAGE <ul style="list-style-type: none"> • RSS pumps stopped due to indications of cavitation • Sump level indications NOT consistent with plant conditions
-------------	---------------------	--------------------------	--

GRADE	_____	Standards:	Determines that RSS pumps were stopped due to indications of cavitation.
		NOTE:	As given in the CUE, RSS pumps were stopped due to sump blockage indications.
		CUE (if required):	If the applicant questions whether RSS pumps were stopped due to indications of cavitation, respond as the US that they were.
		Grade:	SAT _____ UNSAT _____

STEP	<u> 18 </u> _____	Performance Step:	The charging and SI pumps should be stopped on alternate ECCS trains when possible.
-------------	---------------------	--------------------------	---

GRADE	_____	Standards:	Applicant reads NOTE.
		Grade:	SAT _____ UNSAT _____

STEP	<u> 19 </u> _____	Performance Step:	Establish One Train Of ECCS Flow <p style="margin-left: 20px;">a. Check ECCS pumps – TWO TRAINS RUNNING</p>
-------------	---------------------	--------------------------	---

GRADE	_____	Standards:	Determines that all ECCS pumps are off by observation of green indicating lights on / red off. Proceeds to step 7.a. RNO.
		Grade:	SAT _____ UNSAT _____

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

STEP	<u> 20 </u>	<u> </u>	Performance Step:	Go To step 8. 7.a.RNO
GRADE	<u> </u>	<u> </u>	Standards:	Proceeds to step 8.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 21 </u>	<u> </u>	Performance Step:	Any pump receiving suction from an affected Containment Recirculation Pump should be stopped before stopping the Containment Recirculation Pump. If any Charging Pump or Safety Injection Pump loses suction or shows indications of cavitation, the pump must be stopped.
GRADE	<u> </u>	<u> </u>	Standards:	Applicant reads CAUTIONS.
			Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 22 </u>	<u> </u>	Performance Step:	CSF status trees should be monitored for information only. Every effort should be made to address the FRGs without compromising the containment sump. Indications of cavitation should be monitored following any change of recirculation flow.
GRADE	<u> </u>	<u> </u>	Standards:	Applicant reads NOTES.
			Grade:	SAT <u> </u> UNSAT <u> </u>

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

STEP	<u> 23 </u>	<u> </u>	Performance Step:	Establish Recirculation Spray Pump Recirculation Flow
			8.a.	
				a. Verify Ctmt sump level - GREATER THAN 1.5 feet
GRADE	<u> </u>	<u> </u>	Standards:	Determines by observation that CTMT sump level is greater than 1.5 feet.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 24 </u>	<u> </u>	Performance Step:	3RSS*P1A or 3RSS*P1B are the preferred pumps due to the automatic recirculation capability.
			Step 8.b NOTE.	
GRADE	<u> </u>	<u> </u>	Standards:	Applicant reads NOTE.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 25 </u>	<u> </u>	Performance Step:	Recirculation Spray Pump
			8.b.	-ONLY ONE PUMP RUNNING
GRADE	<u> </u>	<u> </u>	Standards:	Determines by observation that NO Recirculation Spray Pumps are running.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u> 26 </u>	<u> X </u>	Performance Step:	Start or stop recirculation spray pumps to obtain one running.
			8.b.RNO	
GRADE	<u> </u>	<u> X </u>	Standards:	Rotates the control switch for either the "A" or "B" RSS pump to the start position.
			Standards:	Observes for proper indications of a successful pump start; red indicating

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

light, amps, flow, etc. Also observes for signs of sump blockage.

Grade: **SAT** **UNSAT**

STEP 27

Performance Step: 8.c. Verify RSS pump has been in operation - AT LEAST TWO MINUTES

GRADE

Standards: Applicant starts a timer to track length of time the RSS pump has been running.

CUE: The RSS pump has been running for two minutes:

Grade: **SAT** **UNSAT**

STEP 28

Performance Step: 9.a. Establish ECCS Flow from Sump.

Check charging and SI pump-
SUCTION ALIGNED TO RUNNING
RSS PUMP

GRADE

Standards: Determines by observation that a flowpath exists from the discharge of the running RSS pump to the suction of the charging and SI pumps.

Grade: **SAT** **UNSAT**

STEP 29

Performance Step: 9.b. Check Charging OR SI pump - ONLY ONE RUNNING

GRADE

Standards: Determines by observation that NO Charging OR SI pumps are running.

Grade: **SAT** **UNSAT**

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

STEP	<u>30</u>	<u>X</u>	Performance Step:	START or STOP charging and SI pumps to establish only one running.
			9.b.RNO	
GRADE	<u> </u>	<u>X</u>	Standards:	Rotates the control switch to the start position for one of the following: <ul style="list-style-type: none">• "A" Charging Pump• "B" Charging Pump• "A" SI Pump• "B" SI Pump
			Standards:	Observes for proper indications of a successful pump start; red indicating light, amps, flow, etc. Also observes for signs of sump blockage.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>31</u>	<u>X</u>	Performance Step:	Using Attachment A, Check minimum ECCS flow to remove decay heat- MINIMUM FLOW INDICATED
			9.c.	
GRADE	<u> </u>	<u>X</u>	Standards:	References Attachment A to ECA-1.1 and determines minimum ECCS flow to remove decay heat, based on the time from inception of the LOCA. Determines actual ECCS flow by observation of the pump flow meter and determines actual flow is sufficient to remove decay heat.
			CUE:	It has been 70 minutes from the start of the LOCA.
			Grade:	SAT <u> </u> UNSAT <u> </u>
STEP	<u>32</u>	<u> </u>	Performance Step:	Check Charging OR SI pump(s) - RUNNING IN RECIRCULATION ALIGNMENT
			9.d.	

PERFORMANCE INFORMATION

JPM Number: S.8

Revision: 0

Task Title: Respond To Containment Sump Blockage

GRADE	<u> </u> <u> </u>	Standards:	Determines by observation that a flowpath exists from the discharge of the running RSS pump to the suction of the running charging or SI pump, and that ECCS flow exists.
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 33 </u> <u> X </u>	Performance Step:	CLOSE recirculation spray header isolation valve for running pump- <ul style="list-style-type: none"> • 3RSS*MOV20A • 3RSS*MOV20B • 3RSS*MOV20C • 3RSS*MOV20D
-------------	----------------------------	--------------------------	---

GRADE	<u> </u> <u> X </u>	Standards:	Depresses open pushbutton for the recirculation spray header isolation valve for running pump. Determines that the valve has closed by observation of green ind. light on, red off.
		Grade:	SAT <u> </u> UNSAT <u> </u>

STEP	<u> 34 </u> <u> </u>	Performance Step:	Go to step 12.
-------------	-----------------------------	--------------------------	----------------

GRADE	<u> </u> <u> </u>	Standards:	Applicant moves ahead to step 12.
		Grade:	SAT <u> </u> UNSAT <u> </u>

CUE:	Inform the Examinee that another RO will complete ECA-1.1. Inform the Examinee the evaluation for this JPM is concluded.
-------------	--

Grade:	SAT <u> </u>	UNSAT <u> </u>
---------------	--------------------------	----------------------------

Stop Time:

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC S.8

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 15

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

STUDENT HANDOUT

JPM Number: S.8

Initial Conditions: Following a large break loss of coolant accident (LBLOCA), the plant has established cold leg recirculation per ES-1.3, up to and including Step 4. Shortly thereafter, symptoms of significant CTMT sump clogging appeared. All ECCS and RSS pumps were stopped. The crew is transitioning to ECA-1.1, *Loss of Emergency Coolant Recirculation*.

Initiating Cues: The US has directed you to perform ECA-1.1, starting with step 1.

Job Performance Measure Approval Sheet

I. JPM Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

JPM ID Number: 2K7 NRC P.1

Rev: 0

II. Initiated:

P. Maizahn
Developer

6/19/06
Date

III. Reviewed:

Dave Minnich
Technical Reviewer

06/19/06
Date

IV. Approved:

N/A
Cognizant Plant Supervisor (optional)

Date

Tim Kulterman
Nuclear Training Supervisor

06/20/06
Date

Job Performance Measure Approval Sheet

SUMMARY OF CHANGES

Change	Description	Date

Job Performance Measure Guide

Facility: Millstone Unit 3 Student: _____

JPM ID Number: 2K7 NRC P.1 Revision: 0

Task Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

System: 062

Time Critical Task: () YES (X) NO

Validated Time (minutes): 20

Task Number(s): 000-05-171

Applicable To: SRO X RO X PEO X

K/A Number:	062-A4.04	K/A Rating:	2.6 / 2.7
	APE-068-AA1.14		4.2 / 4.4
	APE-068-AA1.10		3.7 / 3.9

Method of Testing: Simulated Performance: X Actual Performance: _____

Location: Classroom: _____ Simulator: _____ In-Plant: X

Task Standards: Satisfactorily complete primary side PEO actions on a control room evacuation IAW 3509.1 Att. A, steps 6 - 11

Required Materials: None

General References: EOP 3509.1, Attachment A, rev. 011-02

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objectives for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution was actually being performed.

Job Performance Measure Guide

JPM Number: P.1

Revision: 0

Initial Conditions:

A fire event has occurred requiring shut down outside the control room. The control room team is carrying out actions of EOP 3509.1, *Control Room, Cable Spreading Area, or Instrument Rack Room Fire*.

Initiating Cues:

The US directs you to perform primary side PEO actions on a control room evacuation IAW EOP 3509.1, Attachment A, steps 6 through 11 only, after referring to the "Appendix "R" Lighting Illuminated Path" maps at the end of the attachment. Another operator is performing steps 1 through 5. You have the locked valve key.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, ALL critical steps must be completed correctly. The student's performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue."
3. If necessary, question the student for details of simulated actions/observations (i.e., "What are you looking at?" or "What are you observing?").

Performance Information

JPM Number: P.1

Revision: 0

Task Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

Start Time:

Comments:

Direction to refer to maps is step 1 of Attachment A and was included as part of initiating cue. Examinee may elect to review all steps prior to step 6

STEP 1

Performance Step: Refer to "Appendix R" Lighting Illuminated Path" maps at end of attachment prior to performing local actions.
(Step 1)

GRADE

Standards: Locates maps at end of attachment and reviews.

Cue: When examinee reviews maps provide the following cue, "Adequate emergency lighting is in operation to allow the use of normal access/egress paths".

Grade: **SAT** **UNSAT**

STEP 2 X

Performance Step: **Verify Reactor Tripped**
(Step 6)

a. Check Reactor Trip and Bypass Breakers - OPEN

GRADE X

Standards: Locates reactor trip breakers, 3RPS*SWGR-1 & -2] [West MCC*SWGR, Aux Bldg 46']

GRADE X

Standards: Locates OPEN / CLOSED position indicating flags for each breaker and determines TRIP breakers indicate CLOSED. Proceeds to RNO column.

(Step 6.a. RNO) TRIP the reactor trip and bypass breakers.

Performance Information

JPM Number: P.1

Revision: 0

Task Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

GRADE X **Standards:** Locates red TRIP push button (PB) and simulates pushing TRIP PB. [RNO direction]

GRADE **Standards:** Locates breaker flag indication; both trip breakers are OPEN

Grade: **SAT** **UNSAT**

Cue:	Upon arrival at the TRIP & BYPASS breakers, TRIP breaker flags indicate CLOSED; BYPASS breakers indicate OPEN
-------------	---

Cue:	Breaker TRIP/OPEN flag appears AFTER candidate simulates pushing TRIP PBs on breaker front panel
-------------	--

Comments: RNO must be performed

STEP 3 X **Performance Step:** **Block Open Auxiliary Building North Doors to Outside on EI. 24'-6"**
(Step 7)

Door A-24-1
Door A-24-2

GRADE X **Standards:** Locates North doors A-24-2 [inner] & A-24-1 [outer] and simulates propping BOTH doors open - applicant explains method and component(s) used to achieve blocking OPEN

Grade: **SAT** **UNSAT**

Cue:	Provide the following cue for each door as simulation performed: Door is blocked OPEN
-------------	--

STEP 4 X **Performance Step:** **De-energize TD AFW Pump Steam Supply Isolation Valves**
(Step 8)

Performance Information

JPM Number: P.1

Revision: 0

Task Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

- For 3MSS*MOV17A, Place breaker 32-4U-R5H to OFF
- For 3MSS*MOV17B, Place breaker 32-4T-R6E to OFF
- For 3MSS*MOV17D, Place breaker 32-4T-R6H to OFF

GRADE	<u> </u>	<u> X </u>	Standards:	Locates breaker R5H on MCC 4U (ESF Bldg 36') and simulates placing the breaker in the OFF position [3MSS*MOV17A]
--------------	-------------	--------------	-------------------	--

GRADE	<u> </u>	<u> X </u>	Standards:	Locates breaker R6E on MCC 4T (ESF Bldg 36') and simulates placing the breaker the OFF position [3MSS*MOV17B]
--------------	-------------	--------------	-------------------	---

GRADE	<u> </u>	<u> X </u>	Standards:	Locates breaker R6H on MCC 4T (ESF Bldg 36') and simulates placing the breaker in the OFF position [3MSS*MOV17D]
--------------	-------------	--------------	-------------------	--

Grade: **SAT** **UNSAT**

Cue: As each breaker is located, provide the following cue:

 Breaker as-found is ON/CLOSED

Cue: As each breaker is simulated operated, provide the following cue:

 Breaker is in the OFF position

STEP	<u> 5 </u>	<u> X </u>	Performance Step:	Block Open the TD AFW pump Cubicle Doors Door SF-24-1 Door SF-24-2
-------------	--------------	--------------	--------------------------	---

Performance Information

JPM Number: P.1

Revision: 0

Task Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

Grade: SAT _____ UNSAT _____

STEP 8 _____

Performance Step: Checks SG D TD AFW Pump Non-Return valve 3MSS*MOV17D OPEN.
(Step 10)

GRADE _____ _____

Standards: Locates valve 3MSS*MOV17D and checks the position indicator (rod).
OR
Manually checks valve position by engaging the manual handwheel.

Cue: Stem position rod is as you see it.
---THIS STEP IS COMPLETE---
OR
Cue: The MOV clutch is disengaged.

GRADE _____ _____

Standards: Rotates the handwheel in the clockwise direction to confirm the valve is open.

Cue: Valve handwheel rotates in the clockwise direction.

GRADE _____ _____

Standards: Rotates the handwheel in the counterclockwise direction until the valve is fully open.

Cue: Valve handwheel rotates in the counterclockwise direction, eventually some resistance is met and the valve comes to a hard stop.

Grade: SAT _____ UNSAT _____

STEP 9 _____

Performance Step: Perform the Following:
(Step 11)

- a. Establish communication with the ASP operator

Performance Information

JPM Number: P.1

Revision: 0

Task Title: Primary Side PEO Actions on a Control Room Evacuation (Part 2)

- b. Report Attachment A complete
- c. Provide support as required

GRADE

Standards:

Locates phone or walkie-talkie and simulates establishing communication with ASP operator

GRADE

Standards:

Simulates communicating Attachment A steps 6 through 11 are complete

Grade:

SAT

UNSAT

Terminating Cue: The evaluation for this JPM is concluded

Stop Time:

Verification of JPM Completion

JPM Number: P.1

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 20

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

Student Hand Out

JPM Number: P.1

Initial Conditions: A fire event has occurred requiring shut down outside the control room. The control room team is carrying out actions of EOP 3509.1, *Control Room, Cable Spreading Area, or Instrument Rack Room Fire*.

Initiating Cues: The US directs you to perform primary side PEO actions on a control room evacuation IAW EOP 3509.1, Attachment A, steps 6 through 11 only, after referring to the "Appendix "R" Lighting Illuminated Path" maps at the end of the attachment. Another operator is performing steps 1 through 5. You have the locked valve key.

JOB PERFORMANCE MEASURE APPROVAL WORKSHEET

I. JPM Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

JPM ID Number: 2K7 NRC P.2

Revision: 0/Ch1
ch 1 R. McDonald

II. Initiated:

J. William Cote
Developer

2/10/00
Date

III. Reviewed:

Rich Carr
Technical Reviewer

12/18/01
Date

IV. Approved:

W. Hoffner
Cognizant Plant Supervisor (optional)

12/20/01
Date

Tim Kulterman
Nuclear Training Supervisor

12/19/01
Date

JOB PERFORMANCE MEASURE APPROVAL WORKSHEET

SUMMARY OF CHANGES

Change Description	Date of Change
1. Revised task description and updated to new procedure revision. rjm	9/3/04

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Student: _____

JPM ID Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

System: 0

Time Critical Task: () YES (X) NO

Validated Time (minutes): 12

Task Number(s): 344-05-017

Applicable To: SRO X RO X PEO X

K/A Number: 065-AA1.04 K/A Rating: 3.5/3.4

Method of Testing: Simulated Performance: X Actual Performance: _____

Location: Classroom: _____ Simulator: _____ In-Plant: X

Task Standards: Satisfactorily perform the local actions on a loss of instrument air as specified in AOP 3562, *Loss of Instrument Air*, Attachment A and OP 3332A, *Instrument Air System*.

Required Materials: None

General References: AOP 3562 (Rev 005), Loss of Instrument Air, & OP3332A Rev (015)

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objectives for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution was actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: P.2

Revision: 0

Simulator Requirements: None: In-plant JPM

Initial Conditions: A loss of instrument air has occurred and the Control Room Team is carrying out the actions of AOP 3562, *Loss of Instrument Air*. Steps 1 and 2.a are complete, but instrument air pressure continues to decrease. Actions in accordance with the "Response Not Obtained" column are required.

Initiating Cues: The US has directed you to locally start air compressors and perform filter and dryer checks using Attachment A of AOP 3562, *Loss of Instrument Air*.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, ALL critical steps must be completed correctly. The student's performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

Start Time: _____

STEP 1 _____

Performance Step: Place both instrument air compressor control switches to CS (continuous service).
Att. A Step 1.a

Comments: AOP 3562 step 2a RNO has an operator locally place both instrument air compressor control switches to CS (continuous service).

GRADE _____

Standards: Locates the control switch for 3IAS-C1A (Turbine Building 14' elev. SW corner on top of panels) and checks the switch position.

Cue:	The control switch is already in the CS position.
-------------	---

GRADE _____

Standards: Locates the control switch for 3IAS-C1B (Turbine Building 14' elev. SW corner on top of panels) and checks the switch position.

Cue:	The control switch is already in the CS position.
-------------	---

Comments: The instrument air compressor switches addressed in this step may be operated in any order.

Grade: SAT _____ UNSAT _____

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

STEP 4 X

Performance Step: OPEN service air to instrument air cross-connect valve (3IAS-AOV14).
Att. A Step 1.d

GRADE _____

Standards: Locates valve 3IAS-AOV14 control switch (on IAS Panel) and checks valve position indicating lights.

Cue: The green light is illuminated and the red light is dark.

GRADE _____ X

Standards: Opens valve by positioning switch to the "OPEN" position.

Cue: The green light goes dark and the red light illuminates.

Grade: SAT _____ UNSAT _____

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

STEP 5 _____ **Performance Step:** Verify the following Instrument Air Dryer Annunciators - NOT LIT

Att. A Step 2

- AIR DRYER REACTIVATION BLOWER (IS 3-2)
- AIR DRYER HEATER TEMP HI (IS 3-3)
- AIR DRYER DISCHARGE MOIST HI (IS 3-4)
- ALARM BLOWER FAILURE (Dryer Skid, 3IAS-PNLCP1)

Comments: The examinee may verify the alarm status in any order.

GRADE _____ _____ **Standards:** Locates panel IS (Turbine Building 14' elev. SW corner facing west wall) and verifies the alarms are not lit (alarm windows dark).

Cue: Alarm windows 3-2, 3-3 and 3-4 are not lit.

Comments: The examinee may elect to perform an alarm panel lamp test, if so provide the following cue:

Cue: The lamp test is satisfactory, all lamps illuminated as expected.

GRADE _____ _____ **Standards:** Locates panel CP1 (behind air dryer) and verifies the alarms are not lit (alarm windows dark).

Cue: Alarm widow "ALARM BLOWER FAILURE" is not lit.

Grade: **SAT** _____ **UNSAT** _____

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

STEP	<u>9</u>	<u>X</u>	Performance Step:	Throttle open 3IAS-V18, filter 2B inlet isolation. OP 3332 4.6.2.a
GRADE	_____	_____	Standards:	Locates 3IAS-V18 and slowly throttles open on 3IAS-V18 until air equalizes.
			Cue:	Slight air noise is heard and slowly fades away
			Grade:	SAT _____ UNSAT _____
STEP	<u>10</u>	<u>X</u>	Performance Step:	<u>WHEN</u> filter pressure equalizes with the instrument air header pressure, fully <u>OPEN</u> 3IAS-V18, filter 2B inlet isolation. OP 3332 4.6.2.b
GRADE	_____	_____	Standards:	Rotates 3IAS-V18 in the counterclockwise direction until fully open.
			Cue:	Valve hand wheel rotates freely until some resistance is met. Valve hand wheel comes to a hard stop.
GRADE	_____	_____	Standards:	Rotates the handwheel in the clockwise direction 1/4 of 1 turn
			Cue:	Handwheel has been rotated 1/4 turn in the clockwise direction.
			Grade:	SAT _____ UNSAT _____
STEP	<u>11</u>	<u>X</u>	Performance Step:	Open 3IAS-V19, filter 2B outlet isolation. OP 3332 4.6.2.c

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

GRADE _____ _____ **Standards:** Locates and rotates 3IAS-V19 in the counterclockwise direction until fully open.

Cue: Valve hand wheel rotates freely until some resistance is met. Valve hand wheel comes to a hard stop.

GRADE _____ _____ **Standards:** Rotates the handwheel in the clockwise direction 1/4 of 1 turn.

Cue: Handwheel has been rotated 1/4 turn in the clockwise direction.

Grade: **SAT** _____ **UNSAT** _____

STEP 12 X **Performance Step:** Close 3IAS-V21, filter 2A outlet isolation.

GRADE _____ _____ **Standards:** Locates and rotates 3IAS-V21 in the clockwise direction until fully closed.

Cue: Valve hand wheel rotates freely until some resistance is met. Valve hand wheel comes to a hard stop.

Grade: **SAT** _____ **UNSAT** _____

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

STEP	<u>13</u>	<u>X</u>	Performance Step:	Close 3IAS-V20, filter 2A inlet isolation. OP 3332 4.6.2.e								
GRADE	_____	_____	Standards:	Locates and rotates 3IAS-V-20 in the clockwise direction until fully closed.								
			Cue:	Valve hand wheel rotates freely until some resistance is met. Valve hand wheel comes to a hard stop.								
			Grade:	<table border="0" style="width: 100%;"> <tr> <td style="width: 50%;">SAT</td> <td style="width: 50%;">UNSAT</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> </table>	SAT	UNSAT	_____	_____	_____	_____	_____	_____
SAT	UNSAT											
_____	_____											
_____	_____											
_____	_____											

STEP	<u>14</u>	_____	Performance Step:	Verify Instrument Air Filter Differential Pressure - LESS THAN 4 psid. Att. A Step 3								
GRADE	_____	_____	Standards:	Locates air filter differential pressure gauge (3IAS-PDIS16) (East of air dryer) and verifies differential pressure reading.								
			Cue:	Filter DP reads 0.25 psid								
			Grade:	<table border="0" style="width: 100%;"> <tr> <td style="width: 50%;">SAT</td> <td style="width: 50%;">UNSAT</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> <tr> <td>_____</td> <td>_____</td> </tr> </table>	SAT	UNSAT	_____	_____	_____	_____	_____	_____
SAT	UNSAT											
_____	_____											
_____	_____											
_____	_____											

STEP	<u>15</u>	_____	Performance Step:	Notify the Control Room that Attachment A of AOP 3562 is complete.
-------------	-----------	-------	--------------------------	--

PERFORMANCE INFORMATION

JPM Number: 2K7 NRC P.2 Revision: 0

Task Title: LOCAL ACTIONS ON LOSS OF INSTRUMENT AIR

GRADE _____

Standards:

Examinee reports to the US that instrument and service air compressor are running and supplying the instrument air header and that the filter and dryer checks are complete as specified in AOP 3562, Attachment A. The 2A filter had a high DP and filter 2B was placed in service.

Grade:

SAT _____

UNSAT _____

Terminating Cue:

The evaluation for this JPM is concluded.

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: 2K7 NRC P.2

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): _____

Actual Time to Complete (minutes): 12

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

STUDENT HANDOUT

JPM Number:

P.2

Initial Conditions:

A loss of instrument air has occurred and the Control Room Team is carrying out the actions of AOP 3562, *Loss of Instrument Air*. Steps 1 and 2.a are complete, but instrument air pressure continues to decrease. Actions in accordance with the "Response Not Obtained" column are required.

Initiating Cues:

The US has directed you to locally start air compressors and perform filter and dryer checks using Attachment A of AOP 3562, *Loss of Instrument Air*.

JOB PERFORMANCE MEASURE APPROVAL SHEET


I. JPM Title: Cross-Connect Service Water to East Switchgear Ventilation

JPM ID Number: 2K7 NRC P.3

Revision: 0

II. Initiated:

D. Minnich
Developer



12/8/06
Date

III. Reviewed:

Technical Reviewer



1/24/07
Date

IV. Approved:

Cognizant Plant Supervisor (optional)

Date


T. Kulterman

Nuclear Training Supervisor

1/24/07
Date

JOB PERFORMANCE MEASURE APPROVAL SHEET

SUMMARY OF CHANGES

JOB PERFORMANCE MEASURE GUIDE

Facility: Millstone Unit 3 Student: _____

JPM ID Number: 2K7 NRC P.3 Revision: 0

Task Title: Cross-Connect Service Water to East Switchgear Ventilation

System: 076

Time Critical Task: () YES (X) NO

Validated Time (minutes): 12

Task Number(s): 000-05-171

Applicable To: SRO X RO X PEO X

K/A Number: 076 K1.19 K/A Rating: 3.6 / 3.7
APE; 068 A1.21 3.9 / 4.1

Method of Testing: Simulated Performance: X Actual Performance: _____

Location: Classroom: _____ Simulator: _____ In-Plant: X

Task Standards: All critical steps are performed satisfactorily. All sequential steps are performed in proper procedural sequence.

Required Materials: PA 8235 Keys and a Locked Valve Key

General References: EOP 3509.1, Rev. 11-02

*****READ TO THE STUDENT*****

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective(s) for this JPM will be satisfied. You may use any approved reference material normally available in the Control Room, including logs. Make all written reports, oral reports, alarm acknowledgements, and log entries as if the evolution were actually being performed.

JOB PERFORMANCE MEASURE GUIDE (Continued)

JPM Number: 2K7 NRC P.3

Revision: 0

Initial Conditions: A fire occurred in the MP3 Control Room requiring evacuation. The crew is controlling the plant from the Auxiliary Shutdown Panel in accordance with EOP 3509.1.

Initiating Cues: The US has directed you to perform local actions to align ventilation for the East Switchgear Room by performing Steps 42.a and b of EOP 3509.1. You have two PA 8235 keys and a locked valve key.

**** NOTES TO EVALUATOR ****

1. Critical steps for this JPM are indicated by an "X" after the step number. For the student to achieve a satisfactory grade, ALL critical steps must be completed correctly. The student's performance is graded by an "S" for satisfactory or a "U" for unsatisfactory on each step.
2. When the student states what his/her simulated action/observation would be, read the appropriate "Cue".
3. If necessary, question the student for details of simulated actions/observations (i.e. "What are you looking at?" or "What are you observing?").

PERFORMANCE INFORMATION

JPM Number: P.3

Revision: 0

Task Title: Cross-Connect Service Water to East Switchgear Ventilation

Start Time: _____

Comment: If examinee asks for current ACU indicating light status, provide the following; cubicle 3J, green light lit, cubicle 3M, red light lit. Steps 1 and 2 of this JPM are bulleted procedure steps and can be performed in either order.

STEP 1 X

Performance Step: At MCC 32-2T, using PA 8235 keys, START east switchgear ACUs

- East Switchgear air conditioning unit (3HVC*ACU3A) at cubicle 3J
- East Switchgear air conditioning unit (3HVC*ACU4A) at cubicle 3M

GRADE _____ X

Standards: Locates 32-2T (3J) in E. Switchgear Room 4'-6" elev and simulates inserting PA 8235 key into key lock and turning clockwise to START, verifies green indicating light OFF, red light ON.

Cue: Breaker is closed and 3HVC*ACU3A is running.

GRADE _____ _____

Standards: Locates 32-2T (3M) in E. Switchgear Room 4'-6" elev, and simulates inserting PA 8235 key into key lock and turning clockwise to START, verifies green indicating light OFF, red light ON.

Cue: Breaker is closed and 3HVC*ACU4A is running. (Initial condition is that this ACU is running, as key switch is turned from Remote position thru Stop position, ACU will stop (green light ON, red light OFF) and restart when keyswitch is placed in Start.)

PERFORMANCE INFORMATION

JPM Number: P.3

Revision: 0

Task Title: Cross-Connect Service Water to East Switchgear Ventilation

Grade: **SAT** **UNSAT**

Note: The following step de-energizes the Train A HVK isolation valves to/from East Switchgear Room to ensure they are closed. (Train B valves were de-energized in an earlier procedure step which de-energized 34D.)

STEP 2 X

Performance Step: Cross-connect service water to the switchgear room ACUs
(EOP 3509.1, Step 42.b.1)

1) At 3SCV*PNLR1(O) (Control Building 4'-6") Place breakers 19 and 22 to OFF

GRADE X

Standards: Locates 3SCV*PNLR1(O) in E. Switchgear Room, opens panel door, simulates sliding breakers 19 and 22 to the OFF position.

Cue: Breakers are in the OFF position

Grade: **SAT** **UNSAT**

STEP 3 X

Performance Step: 2) Locally Open service water cross-connect valves (Control Building 4'-6")
(EOP 3509.1, Step 42.b.2)

3SWP*V745
3SWP*V747
3SWP*V744
3SWP*V746

GRADE X

Standards: Locates each valve and using locked valve key unlocks and removes chain. Rotates valve handwheel (or handle) in counter clockwise direction until valve comes to a hard stop.

Comment: Valve should be positioned ¼ turn closed from the full open position in accordance with Ops guidance for keeping manual valves off the

PERFORMANCE INFORMATION

JPM Number: P.3

Revision: 0

Task Title: Cross-Connect Service Water to East Switchgear Ventilation

backseat. Positioning valve off of the backseat is not a critical task.

Cue:

For each valve, as examinee simulates rotating valve handwheel in the counterclockwise direction, provide cue that increased resistance is felt and handwheel comes to a hard stop, valve is OPEN. For the two valves with position indication, provide cue that pointers are aligned vertically.

Grade:

SAT _____

UNSAT _____

Terminating Cue: The evaluation for this JPM is concluded.

Stop Time: _____

VERIFICATION OF JPM COMPLETION

JPM Number: P.3

Revision: 0

Date Performed: _____

Student: _____

Evaluator: _____

For the student to achieve a satisfactory grade, **ALL** critical steps must be completed correctly. If task is Time Critical, it **MUST** be completed within the specified time to achieve a satisfactory grade.

Time Critical Task? YES _____ NO X

Validated Time (minutes): 12

Actual Time to Complete (minutes): _____

Result of JPM: _____ ("S" for satisfactory, "U" for unsatisfactory)

Result of oral questions (if applicable):

Number of Questions: _____

Number of Correct Responses: _____

Score: _____

Areas for Improvement:

STUDENT HANDOUT

JPM Number: P.3

Initial Conditions: A fire occurred in the MP3 Control Room requiring evacuation. The crew is controlling the plant from the Auxiliary Shutdown Panel in accordance with EOP 3509.1.

Initiating Cues: The US has directed you to perform local actions to align ventilation for the East Switchgear Room by performing Steps 42.a and b of EOP 3509.1. You have two PA 8235 keys and a locked valve key.