



U.S. NUCLEAR REGULATORY COMMISSION
STANDARD REVIEW PLAN

**15.6.1 INADVERTENT OPENING OF A PWR PRESSURIZER PRESSURE RELIEF VALVE
 OR A BWR PRESSURE RELIEF VALVE**

REVIEW RESPONSIBILITIES

Primary - Organization responsible for review of transient and accident analyses for PWRs/BWRs

Secondary - None

I. AREAS OF REVIEW

An accidental depressurization of the reactor coolant system (RCS) could be caused by the inadvertent opening of a pressure relief valve, which in turn could be caused by a spurious electrical signal or by an operator error. As this event can occur one or more times during the plant's lifetime, it is an anticipated operational occurrence (AOO), as defined in 10 CFR Part 50, Appendix A.

The inadvertent opening of a pressure relief valve results in a decrease in reactor coolant inventory and RCS pressure. A pressure relief valve, as defined in American National Standards Institute (ANSI) B95.1-1972, is a device designed to reclose and prevent further fluid flow after normal conditions are restored. The effect of the decreased pressure is a decreased neutron flux (via moderator density feedback). In a pressurized-water reactor (PWR), a reactor trip occurs with low RCS pressure or low thermal margin. In a boiling water reactor (BWR), the pressure relief valve discharges into the suppression pool and normally there is no reactor trip. The pressure regulator senses the RCS pressure decrease and partially closes the turbine control valves to stabilize the reactor at a lower pressure. The reactor power settles out at nearly the initial power level. The coolant inventory is maintained by the feedwater control system with water from the condensate storage tank via the condenser hotwell. The specific areas of review are as follow:

Revision 2 - March 2007

USNRC STANDARD REVIEW PLAN

This Standard Review Plan, NUREG-0800, has been prepared to establish criteria that the U.S. Nuclear Regulatory Commission staff responsible for the review of applications to construct and operate nuclear power plants intends to use in evaluating whether an applicant/licensee meets the NRC's regulations. The Standard Review Plan is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide an acceptable method of complying with the NRC regulations.

The standard review plan sections are numbered in accordance with corresponding sections in Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)." Not all sections of Regulatory Guide 1.70 have a corresponding review plan section. The SRP sections applicable to a combined license application for a new light-water reactor (LWR) are based on Regulatory Guide 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)."

These documents are made available to the public as part of the NRC's policy to inform the nuclear industry and the general public of regulatory procedures and policies. Individual sections of NUREG-0800 will be revised periodically, as appropriate, to accommodate comments and to reflect new information and experience. Comments may be submitted electronically by email to NRR_SRP@nrc.gov.

Requests for single copies of SRP sections (which may be reproduced) should be made to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Reproduction and Distribution Services Section, or by fax to (301) 415-2289; or by email to DISTRIBUTION@nrc.gov. Electronic copies of this section are available through the NRC's public Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>, or in the NRC's Agencywide Documents Access and Management System (ADAMS), at <http://www.nrc.gov/reading-rm/adams.html>, under Accession # ML070520094.

1. The review of these transients should consider the sequence of events, the analytical model, the values of parameters in the analytical model, and the predicted consequences of the transient.
 - A. The sequence of events described in the applicant's safety analysis report (SAR) is reviewed by the organization responsible for review of reactor systems. The reviewer focuses on the need for the reactor protection system, the engineered safety systems, and operator action to secure and maintain the reactor in a safe condition.
 - B. The analytical methods are reviewed for whether the mathematical modeling and computer codes have been previously reviewed and accepted by the staff. If a referenced method has not been reviewed, the reviewer initiates a generic evaluation. The values of all parameters in the new analytical model, including the initial conditions of the core and system, are reviewed. The predicted results of the transient are reviewed for whether the consequences meet the acceptance criteria of SRP section 15.0 and subsection II of this SRP section. The analysis results are reviewed for whether pertinent system parameter values are within ranges expected for the type and class of reactor under review.
 - C. Reactor protection system functions (e.g., automatic reactor trips) that are identified as available protection for this event, other than the credited function, are evaluated to ascertain whether the specified functions would be effective (i.e., setpoints and response times would lead to timely action, to satisfy the acceptance criteria). For example, the credited protection function might be the low pressurizer pressure reactor trips, and an available protection function might be the overtemperature delta-T trip. The reviewer would verify that the overtemperature delta-T trip would be executed in time to meet the relevant acceptance criteria (e.g., prevention of departure from nucleate boiling (DNB)).
 - D. The reviewer verifies whether the applicant's core physics data are appropriate.
2. COL Action Items and Certification Requirements and Restrictions. For a DC application, the review will also address COL action items and requirements and restrictions (e.g., interface requirements and site parameters).

For a COL application referencing a DC, a COL applicant must address COL action items (referred to as COL license information in certain DCs) included in the referenced DC. Additionally, a COL applicant must address requirements and restrictions (e.g., interface requirements and site parameters) included in the referenced DC.

Review Interfaces

Other SRP sections interface with this section as follows:

- General information on transient and accident analyses is provided in SRP Section 15.0.
- Design basis radiological consequence analyses associated with design basis accidents are reviewed under SRP Section 15.0.3.

- Verification of the safety analysis sequence described by the applicant for automatic actuation, remote sensing, indication, control, interlocks with auxiliary or shared systems, potential bypass modes, and the possibility of manual control by the operator is performed under SRP Chapter 7.
- Verification of whether the equipment necessary to mitigate the event is qualified for the transient and post-transient environments and identification, if requested, of equipment that the failure of which as a result of the initiating event could have adverse consequences performed under applicable SRP sections.
- On request, the organization responsible for review of electrical engineering verifies whether the control systems power sources needed to mitigate the event are available as required by the applicant's description of the event under SRP Chapter 8.
- Plant operating procedures are reviewed to verify they include appropriate actions as to a reactor coolant pump trip after the inadvertent opening of a PWR pressure relief valve as described in Generic Letters 85-12, 86-05, and 86-06 under SRP Chapter 18.

The specific acceptance criteria and review procedures are contained in the referenced SRP sections.

II. ACCEPTANCE CRITERIA

Requirements

Acceptance criteria are based on meeting the relevant requirements of the following Commission regulations:

1. General Design Criterion (GDC) 10, as it relates to designing the RCS with appropriate margin to assure that specified acceptable fuel design limits are not exceeded during normal operations, including AOOs.
2. GDC 13, as it relates to providing instrumentation to monitor variables and systems over their anticipated ranges for normal operation to assure adequate safety, and to providing appropriate controls to maintain these variables and systems within prescribed operating ranges.
3. GDC 15, as it relates to designing the RCS and associated auxiliary systems with sufficient margin to assure that the design conditions of the reactor coolant pressure boundary are not exceeded during normal operations, including AOOs.
4. GDC 26, as it relates to providing a reactivity control system capable of reliably controlling reactivity changes during manual operations and AOOs so the specified fuel design limits are not exceeded.

5. 10 CFR 52.47(a) and 52.79(a), as they relate to demonstrating compliance with any technically relevant portions of the Three Mile Island (TMI)-related requirements set forth in 10 CFR 50.34(f)(1)(vi) and 10 CFR 50.34(f)(1)(iii), for DC and COL reviews, respectively.¹

SRP Acceptance Criteria

Specific SRP acceptance criteria acceptable to meet the relevant requirements of the NRC's regulations identified above are as follows for the review described in this SRP section. The SRP is not a substitute for the NRC's regulations, and compliance with it is not required. However, an applicant is required to identify differences between the design features, analytical techniques, and procedural measures proposed for its facility and the SRP acceptance criteria and evaluate how the proposed alternatives to the SRP acceptance criteria provide acceptable methods of compliance with the NRC regulations.

1. Pressure in the reactor coolant and main steam systems should be maintained below 110 percent of the design values.
2. Fuel cladding integrity is maintained if the minimum departure from nucleate boiling ratio (DNBR) remains above the 95/95 DNBR limit for PWRs and the critical power ratio (CPR) above the minimum critical power ratio safety limit for BWRs based on acceptable correlations (see SRP Section 4.4).
3. An AOO should not develop into a more serious plant condition without other faults occurring independently. Satisfaction of this criterion precludes the possibility of a more serious event during the lifetime of the plant.

To meet the requirements of GDCs 10, 13, 15, and 26, the positions of Regulatory Guide (RG) 1.105, "Instrument Setpoints for Safety-Related Systems," are useful as to their impact on the plant response to the type of transient addressed in this SRP section.

The most limiting plant system single failure, as defined in the "Definitions and Explanations" of 10 CFR Part 50, Appendix A, should be assumed in the analysis and should satisfy the positions of RG 1.53.

The applicant's analysis of this transient should use an acceptable analytical model. If the applicant proposes to use analytical methods not previously reviewed and approved by the staff, the staff evaluates them for acceptability. For new generic methods, the reviewer initiates an evaluation of the new analytical model.

The values of the parameters in the analytical model should be suitably conservative. The following values are acceptable.

¹ For 10 CFR Part 50 applicants not listed in 10 CFR 50.34(f), the portions of 10 CFR 50.34(f) will be made a requirement during the licensing process.

- A. The initial power level is taken as the licensed core thermal power for the number of loops initially assumed to operate plus an allowance of 2 percent to account for power measurement uncertainties unless the applicant can justify a lower power level. The number of loops operating at the initiation of the event should correspond to the operating condition that maximizes the consequences of the event.
- B. Conservative scram characteristics are assumed (*i.e.*, for a PWR maximum time delay with the most reactive rod held out of the core and for a BWR a design conservatism factor of 0.8 times the calculated negative reactivity insertion rate).
- C. The core burn-up is selected to yield the most limiting combination of moderator temperature coefficient, void coefficient, Doppler coefficient, axial power profile, and radial power distribution.
- D. Mitigating systems should be assumed to be actuated in the analyses at setpoints with allowance for instrument inaccuracy in accordance with RG 1.105.

Technical Rationale

The technical rationale for application of these acceptance criteria to the areas of review addressed by this SRP section is discussed in the following paragraphs:

1. GDC 10 requires design of the reactor core and its coolant, control, and protection systems with appropriate margin so specified acceptable fuel design limits are not exceeded during any conditions of normal operation, including the effects of AOOs.

GDC 10 applies to this section because the reviewer evaluates the consequences of an inadvertent opening of a PWR pressurizer pressure relief valve or a BWR pressure relief valve. These AOOs could exceed allowable thermal design criteria for fuel cladding integrity. RG 1.53 provides guidance for applying the single-failure criterion to the design and analysis of nuclear power plant protection systems. RG 1.105 provides guidance for ensuring that instrument setpoints remain within the technical specification limits.

GDC 10 requirements provide assurance that specified acceptable fuel design limits are not exceeded in the inadvertent opening of a PWR pressurizer pressure relief valve or a BWR pressure relief valve.

2. GDC 13 requires the provision of instrumentation that is capable of monitoring variables and systems over their anticipated ranges to assure adequate safety, and of controls that can maintain these variables and systems within prescribed operating ranges.

GDC 13 applies to this section because the reviewer evaluates the sequence of events, including automatic actuations of protection systems, and manual actions, and determines whether the sequence of events is justified, based upon the expected values of the relevant monitored parameters and instrument indications.

3. GDC 15 requires design of the RCS and its auxiliary, control, and protection systems with sufficient margin so reactor coolant pressure boundary design conditions are not exceeded during any condition of normal operation, including AOOs.

GDC 15 applies to this section because the reviewer evaluates the consequences of the inadvertent opening of a PWR pressurizer pressure relief valve or a BWR pressure relief valve (*i.e.*, AOOs).

As part of the reactor coolant pressure boundary, the pressurizer relief and safety valves must be able to reseal properly after actuation. As an AOO, the inadvertent opening of a pressurizer relief valve should not prevent the plant from returning to power a short time after shutdown.

4. GDC 26 requires that reactivity control systems at nuclear power plants include control rods that can control reactivity changes so specified acceptable fuel design limits are not exceeded under conditions of normal operation, including AOOs. This system design must have an appropriate margin to accommodate malfunctions (*e.g.*, stuck rods).

GDC 26 applies to this section because the transient analyzed by the reviewer may require the responsive movement of control rods. In such instances, rod misalignment, including stuck rods, can result in more severe thermal-hydraulic conditions. GDC 26 requires that the thermal margin be sufficient to accommodate these conditions. SRP Section 15.6.1 examines this margin for whether thermal criteria are satisfied. Compliance with GDC 26 is best demonstrated by showing that adequate thermal margin is maintained, during the event, as the result of automatic protective action (*e.g.*, a reactor trip) actuated by the monitoring of parameters related directly to thermal margin (*e.g.*, the OTΔT trip, the low thermal margin trip, or low DNBR trip). The review should encompass claims that automatic reactor protection is available from specified trip signals in addition to the trip signal credited in the licensing basis analysis. The review should verify whether such signals can provide adequate, timely protection.

GDC 26 requirements provide assurance of appropriate margins to accommodate malfunctions of the reactivity control system, including stuck rods, minimizing the possibility that specified acceptable fuel design limits would be exceeded.

5. 10 CFR 50.34(f), "Additional TMI-Related Requirements," applies to this section because the TMI incident involved a stuck open power-operated relief valve. For plants licensed under 10 CFR Part 52, the requirements of 10 CFR 50.34 are incorporated under 10 CFR 52.47 and 10 CFR 52.79.

III. REVIEW PROCEDURES

The reviewer will select material from the procedures described below, as may be appropriate for a particular case.

These review procedures are based on the identified SRP acceptance criteria. For deviations from these acceptance criteria, the staff should review the applicant's evaluation of how the proposed alternatives provide an acceptable method of complying with the relevant NRC requirements identified in Subsection II.

The procedures are used during both the construction permit (CP) and operating license (OL) reviews. During the CP review, the values of system parameters and setpoints in the analysis are preliminary and subject to change. At the OL review, final values should be in the analysis, and the reviewer should compare these to the limiting safety system settings in the proposed technical specifications.

The applicant's description of the inadvertent pressure relief valve opening transient is reviewed for the occurrences leading to the initiating event. The sequence of events from initiation until stabilization is reviewed to ascertain:

1. The extent to which normally operating plant instrumentation and controls are assumed to function.
2. The extent to which plant and reactor protection systems are required to function.
3. The credit taken for the functioning of normally operating plant systems.
4. The extent to which the operation of engineered safety systems is required.
5. The extent to which operator actions are required.
6. The following TMI Action Plan items are reviewed for compliance with the acceptance criteria:
 - A. II.K.3.16 (10 CFR 50.34(f)(1)(vi)): For BWR designs, the reviewer confirms whether the results of the applicant's feasibility study and, if required, system modifications to reduce the numbers of challenges to and failures of relief valves are included properly in the evaluation of the event.
 - B. II.K.3.25 (10 CFR 50.34(f)(1)(iii)) and II.K.3.40: If containment isolation is indicated as a result of the transient or of loss of alternating current power, the reactor coolant pump component cooling water may be lost. The reviewer evaluates the applicant's submission for whether the reactor coolant pump seal integrity is lost. If seal integrity cannot be ensured, the reviewer verifies whether the evaluation of this event correctly accounts for seal failure.
7. If the SAR states that the inadvertent pressure relief valve opening transient is not as limiting as some other similar transient, the reviewer evaluates the applicant's justification. If the SAR presents a quantitative analysis of the transient, the timing of the initiation of those protection, engineered safety, and other systems needed to limit transient consequence to acceptable levels is reviewed. The reviewer compares the predicted variation of system parameters to various trip and system initiation setpoints.

To the extent deemed necessary, the reviewer evaluates the effects of system and component single, active failures which may alter the course of the transient. In this phase of the review the system reviews are as described in the SRP sections for SAR Chapters 5, 6, 7, and 8. The reviewer considers possible single failures in systems that replenish or maintain the reactor coolant inventory.

The applicant's mathematical models to evaluate core performance and to predict system pressure in the RCS and main steam line are reviewed for whether they have been reviewed and found acceptable by the staff. If not, the reviewer initiates a generic review of the applicant's proposed model.

The values of system parameters and initial core and system conditions as input to the model also are reviewed. Of particular importance are the reactivity coefficients and control rod worths in the applicant's analysis and the variation of moderator temperature, void, and Doppler coefficients of reactivity with core life. The applicant's justification showing that the selected core burn-up yields the minimum margins is evaluated.

The results of the analysis are reviewed and compared to the acceptance criteria of subsection II for the maximum pressure in the reactor coolant and main steam systems. The following transient parameters are reviewed:

- reactor power;
- heat fluxes (average and maximum);
- RCS pressure;
- pressurizer water volume (PWR);
- minimum DNBR (PWR) or CPR (BWR);
- core and recirculation loop coolant flow rates (BWR);
- coolant conditions (inlet temperature, core average temperature (PWR), core average steam volume fraction (BWR), average exit and hot channel exit temperatures, and steam fractions);
- steamline pressure;
- containment pressure;
- pressure relief valve flow rate; and
- flow rate from the RCS to the containment system (if applicable).

Values of the more important of these parameters for the transient caused by the inadvertent pressure relief valve opening are compared to those predicted for other similar plants for whether they are within the expected range.

Upon request from the reviewer, other responsible organizations provide input for the areas of review stated in subsection I of this SRP section. The reviewer uses the input requested as required to complete the review procedure.

7. For review of a DC application, the reviewer should follow the above procedures to verify that the design, including requirements and restrictions (e.g., interface requirements and site parameters), set forth in the final safety analysis report (FSAR) meets the acceptance criteria. DCs have referred to the FSAR as the design control document (DCD). The reviewer should also consider the appropriateness of identified COL action items. The reviewer may identify additional COL action items; however, to ensure these COL action items are addressed during a COL application, they should be added to the DC FSAR.

For review of a COL application, the scope of the review is dependent on whether the COL applicant references a DC, an early site permit (ESP) or other NRC approvals (e.g., manufacturing license, site suitability report or topical report).

IV. EVALUATION FINDINGS

The reviewer verifies that the applicant has provided sufficient information and that the review and calculations (if applicable) support conclusions of the following type to be included in the staff's safety evaluation report. The reviewer also states the bases for those conclusions.

“The applicant evaluated this transient using a mathematical model previously reviewed and found acceptable by the staff. The input parameters for this model were reviewed and found suitably conservative. The results showed specified acceptable fuel design limits maintained by a minimum DNBR² not below ____ and a maximum pressure within the reactor coolant and main steam systems not in excess of 110 percent of the design pressures.

The staff concludes that the analysis or evaluation of this AOO is acceptable and meets the relevant requirements of GDCs 10, 13, 15, and 26 and the applicable paragraphs of 10 CFR 50.34(f)(1). This conclusion is based on the following findings:

1. The applicant meets the requirements of GDCs 10 and 26 by demonstrating that resultant fuel integrity is maintained because the specified acceptable fuel design limits were not exceeded for the event.
2. The applicant meets GDC 13 requirements by demonstrating that all credited instrumentation was available, and that actuations of protection systems, automatic and manual, occurred at values of monitored parameters that were within the instruments' prescribed operating ranges.
3. The applicant meets GDC 15 requirements by demonstrating that the reactor coolant pressure boundary limits were not exceeded by the event and that resultant leakage is within acceptable limits. This requirement is met because the maximum pressure within the reactor coolant and main steam systems did not exceed 110 percent of the design pressure.

²Minimum CPR for a BWR.

4. The applicant meets GDC 26 requirements for the capability of the reactivity control system to control reactivity adequately during the event with appropriate margin for stuck rods because the specified acceptable fuel design limits were not exceeded.
5. The staff has determined that, in meeting GDCs 10, 13, 15, and 26, the analysis used a mathematical model previously reviewed and accepted by the staff. The input parameters for this model were reviewed and found suitably conservative. In addition, we have determined further that the positions of RG 1.53 on single failure criterion and RG 1.105 for instrument setpoints also are satisfied.
6. The applicant has shown that this AOO would not develop into a postulated accident without other faults occurring independently.
7. The applicant has met 10 CFR 50.34(f)(1)(vi) and (iii) by [describe means used by the applicant to implement the action plan item].”
8. For DC and COL reviews, the findings will also summarize the staff’s evaluation of requirements and restrictions (e.g., interface requirements and site parameters) and COL action items relevant to this SRP section.

V. IMPLEMENTATION

The staff will use this SRP section in performing safety evaluations of DC applications and license applications submitted by applicants pursuant to 10 CFR Part 50 or 10 CFR Part 52. Except when the applicant proposes an acceptable alternative method for complying with specified portions of the Commission’s regulations, the staff will use the method described herein to evaluate conformance with Commission regulations.

The provisions of this SRP section apply to reviews of applications submitted six months or more after the date of issuance of this SRP section, unless superseded by a later revision.

VI. REFERENCES

1. 10 CFR Part 50, Appendix A
2. NUREG-0718, "Licensing Requirements for Pending Applications for Construction Permits and Manufacturing Licenses."
3. NUREG-0737, "Clarification of TMI Action Plan Requirements."
4. NRC Generic Letter 85-12, "Implementation of TMI Action Item II.K.3.5, 'Automatic Trip of Reactor Coolant Pumps,' for Westinghouse-Designed Nuclear Steam Supply Systems."
5. NRC Generic Letter 86-05, "Implementation of TMI Action Item II.K.3.5, 'Automatic Trip of Reactor Coolant Pumps,' for Babcock and Wilcox-Designed Nuclear Steam Supply Systems."

6. NRC Generic Letter 86-06, "Implementation of TMI Action Item II.K.3.5, 'Automatic Trip of Reactor Coolant Pumps,' for Combustion Engineering-Designed Nuclear Steam Supply Systems."
7. ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," Article NB-7000, "Protection Against Overpressure," American Society of Mechanical Engineers.
8. RG 1.105, "Instrument Setpoints for Safety-Related Systems."
9. RG 1.53, "Application of the Single Failure Criterion to Nuclear Power Plant Protection Systems."

PAPERWORK REDUCTION ACT STATEMENT

The information collections contained in the Standard Review Plan are covered by the requirements of 10 CFR Part 50 and 10 CFR Part 52, and were approved by the Office of Management and Budget, approval number 3150-0011 and 3150-0151.

PUBLIC PROTECTION NOTIFICATION

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid OMB control number.
