From: Richard Raione
To: "Allen Fetter" <AHF@nrc.gov>,"Mark Notich" <mdn@nrc.gov>
Date: 3/22/2007 3:30:16 PM
Subject: Vogtle Incident 1990

As information:

No water related issue relating to 1988 - they had a loss of offsite power (shutdown risk) on March 20, 1990. With one plant operating and the other in a RFO, a truck in the switchyard struck a pole and caused a loss of offsite power event. Unit 1 experienced major complications because of ongoing maintenance activities. Unit 2 automatically tripped and stabilized in hot shutdown.

Taken from Richard Laura's presentation "Four Major Historical Events and Recent lessons learned"

Richard Raione, PG, CPG, CGWP
Hydrologist
301-415-1018
RPR4@nrc.gov

Hearing Identifier: Vogtle_Non_Public
Email Number: 1804

Mail Envelope Properties (4607CD24.HQGWDO01.TWGWPO04.200.2000014.1.9605A.1)

Subject: Vogtle Incident 1990
Creation Date: 3/22/2007 3:30:16 PM
From: Richard Raione

Created By: RPR4@nrc.gov

Recipients
"Allen Fetter" <AHF@nrc.gov>
"Mark Notich" <mdn@nrc.gov>

Post Office	Route
TWGWPO04.HQGWDO01	nrc.gov

Files	Size	Date & Time
MESSAGE	581	3/22/2007 3:30:16 PM

Options
Priority: Standard
Reply Requested: No
Return Notification: None
None

Concealed Subject: No
Security: Standard