

PRIORITY Normal

DISPOSITION OF THE ORIGINAL DOCUMENT WILL BE TO THE TRANSMITTAL SIGNATURE UNLESS RECIPIENT IS OTHERWISE IDENTIFIED BELOW

- 1) 02532 MCG NRC INSP MG-ADMIN MAIL RM
- 2) 02546 WC LIBRARY - MG01WC
- 3) 03044 MCG DOC CNTRL MISC MAN MGO5DM
- 4) 03379 D E CALDWELL MG01MM
- 5) 03447 HARRY J SLOAN MG01RP
- 6) 03614 MCG OPS PROCEDURE GP MG01OP
- 7) 03744 OPS TRNG MGR. MG03OT
- 8) 03759 U S NUC REG ROCKVLE, MD
- 9) 04809 MCG PLANT ENG. LIBR. MG05SE
- 10) 05162 MCG SHIFT WORK MGRS MG01OP
- 11) 09460 W C SPENCER MG01RP
- 12) 09665 JAMES SHEA, PM, USNRC

**Duke Energy  
DOCUMENT TRANSMITTAL FORM**

**REFERENCE**  
MCGUIRE NUCLEAR STATION  
RECORD RETENTION # 005893  
-  
SELECTED LICENSEE  
COMMITMENTS MANUAL (SLC)

Date: 03/21/07

Document Transmittal #: DUK070800007

QA CONDITION  Yes  No

OTHER ACKNOWLEDGEMENT REQUIRED  Yes

IF QA OR OTHER ACKNOWLEDGEMENT REQUIRED, PLEASE ACKNOWLEDGE RECEIPT BY RETURNING THIS FORM TO:

Duke Energy  
McGuire  
DCRM MG01S2  
13225 Hagers Ferry Road  
Huntersville, N.C. 28078

Rec'd By \_\_\_\_\_

Date \_\_\_\_\_

| DOCUMENT NO            | QA COND | REV #/ DATE  | DISTR CODE | 1  | 2  | 3 | 4  | 5  | 6  | 7  | 8  | 9  | 10 | 11 | 12 | 13 | 14 | 15 | TOTAL |
|------------------------|---------|--------------|------------|----|----|---|----|----|----|----|----|----|----|----|----|----|----|----|-------|
| SLC - INSTRUCTION MEMO | NA      | 075 03/14/07 | MADM-03A   | V1 | V1 | X | V1 | V1 | V1 | V2 | V8 | V2 | V1 | V1 | V1 |    |    |    | 37    |

REMARKS: PLEASE UPDATE ACCORDINGLY

RECIPIENT # 00422 PREVIOUSLY COMPLETED

G R PETERSON  
VICE PRESIDENT  
MCGUIRE NUCLEAR STATION

BY:  
B C BEAVER MG01RC BCB/CMK

A053

March 14, 2007

MEMORANDUM

To: All McGuire Nuclear Station Selected Licensee Commitments (SLC) Manual Holders

Subject: McGuire SLC Manual Update

Please revise your copy of the manual as follows:

REMOVE

INSERT

List of Effective Sections (Rev 74)

List of Effective Sections (Rev 75)

SLC 16.2 (entire section) (Rev 62)

SLC 16.2 (entire section) (Rev 90)

**Revisions may skip numbers due to Regulatory Compliance Filing System.**

Please call me if you have questions.

*Bonnie Beaver*

Bonnie Beaver  
Regulatory Compliance

SELECTED LICENSEE COMMITMENTS (SLC)

LOES

SLCs ARE REVISED PER SECTION

| SECTION | REVISION NUMBER | DATE     |
|---------|-----------------|----------|
| 16.1    | REVISION 32     | 12/2/02  |
| 16.2    | REVISION 90     | 3/13/07  |
| 16.3    | REVISION 48     | 7/31/03  |
| 16.4    | Not Issued      |          |
| 16.5.1  | REVISION 82     | 6/12/06  |
| 16.5.2  | REVISION 0      | 12/14/99 |
| 16.5.3  | REVISION 0      | 12/14/99 |
| 16.5.4  | REVISION 55     | 3/23/04  |
| 16.5.5  | REVISION 0      | 12/14/99 |
| 16.5.6  | REVISION 0      | 12/14/99 |
| 16.5.7  | REVISION 53     | 1/13/04  |
| 16.5.8  | REVISION 0      | 12/14/99 |
| 16.5.9  | REVISION 0      | 12/14/99 |
| 16.5.10 | REVISION 38     | 4/9/03   |
| 16.6.1  | REVISION 0      | 12/14/99 |
| 16.6.2  | DELETED         | 6/11/03  |
| 16.6.3  | REVISION 61     | 04/07/05 |
| 16.6.4  | REVISION 27     | 06/12/02 |
| 16.7.1  | REVISION 0      | 12/14/99 |
| 16.7.2  | REVISION 80     | 10/1/05  |
| 16.7.3  | REVISION 0      | 12/14/99 |
| 16.7.4  | REVISION 1      | 4/11/00  |
| 16.7.5  | REVISION 0      | 12/14/99 |
| 16.7.6  | REVISION 0      | 12/14/99 |
| 16.7.7  | REVISION 0      | 12/14/99 |
| 16.7.8  | REVISION 77     | 10/12/05 |
| 16.7.9  | REVISION 0      | 12/14/99 |
| 16.7.10 | REVISION 0      | 12/14/99 |
| 16.7.11 | REVISION 71     | 05/25/05 |
| 16.8.1  | REVISION 85     | 10/12/06 |
| 16.8.2  | REVISION 0      | 12/14/99 |
| 16.8.3  | REVISION 65     | 12/21/04 |
| 16.9.1  | REVISION 53     | 1/13/04  |
| 16.9.2  | REVISION 81     | 6/15/06  |
| 16.9.3  | REVISION 81     | 16.15.06 |
| 16.9.4  | REVISION 83     | 7/12/06  |
| 16.9.5  | REVISION 81     | 6/15/06  |
| 16.9.6  | REVISION 81     | 6/15/06  |
| 16.9.7  | REVISION 72     | 6/02/05  |
| 16.9.8  | REVISION 76     | 7/25/05  |
| 16.9.9  | REVISION 34     | 2/26/03  |
| 16.9.10 | REVISION 13     | 2/26/01  |
| 16.9.11 | REVISION 22     | 2/25/02  |
| 16.9.12 | REVISION 34     | 2/26/03  |

SELECTED LICENSEE COMMITMENTS (SLC)

LOES

*SLCs ARE REVISED PER SECTION*

| SECTION  | REVISION NUMBER   | DATE     |
|----------|-------------------|----------|
| 16.9.13  | Not Used - Rev 13 | 2/26/01  |
| 16.9.14  | REVISION 22       | 2/25/02  |
| 16.9.15  | REVISION 68       | 2/28/05  |
| 16.9.16  | REVISION 65       | 12/21/04 |
| 16.9.17  | REVISION 86       | 1/17/07  |
| 16.9.18  | REVISION 0        | 12/14/99 |
| 16.9.19  | REVISION 48       | 7/31/03  |
| 16.9.20  | REVISION 8        | 11/30/00 |
| 16.9.21  | REVISION 0        | 12/14/99 |
| 16.9.22  | REVISION 29       | 7/10/02  |
| 16.9.23  | REVISION 88       | 1/17/07  |
| 16.9.24  | Not Used – Rev 74 | 6/20/05  |
| 16.9.25  | REVISION 87       | 1/17/07  |
| 16.10.1  | REVISION 56       | 4/6/04   |
| 16.11.1  | REVISION 9        | 2/1/01   |
| 16.11.2  | REVISION 84       | 7/19/06  |
| 16.11.3  | REVISION 0        | 12/14/99 |
| 16.11.4  | REVISION 0        | 12/14/99 |
| 16.11.5  | REVISION 0        | 12/14/99 |
| 16.11.6  | REVISION 59       | 6/1/04   |
| 16.11.7  | REVISION 84       | 7/19/06  |
| 16.11.8  | REVISION 0        | 12/14/99 |
| 16.11.9  | REVISION 0        | 12/14/99 |
| 16.11.10 | REVISION 0        | 12/14/99 |
| 16.11.11 | REVISION 41       | 8/21/03  |
| 16.11.12 | REVISION 67       | 2/28/05  |
| 16.11.13 | REVISION 0        | 12/14/99 |
| 16.11.14 | REVISION 21       | 1/17/02  |
| 16.11.15 | REVISION 21       | 1/17/02  |
| 16.11.16 | REVISION 1        | 4/11/00  |
| 16.11.17 | REVISION 1        | 4/11/00  |
| 16.11.18 | REVISION 0        | 12/14/99 |
| 16.11.19 | REVISION 0        | 12/14/99 |
| 16.11.20 | REVISION 0        | 12/14/99 |
| 16.12.1  | REVISION 0        | 12/14/99 |
| 16.12.2  | REVISION 0        | 12/14/99 |
| 16.13.1  | REVISION 51       | 10/1/03  |
| 16.13.2  | Not Used – Rev 75 | 8/05     |
| 16.13.3  | Not Used – Rev 75 | 8/05     |
| 16.13.4  | REVISION 58       | 5/11/04  |
| 16.14.1  | REVISION 0        | 12/14/99 |

## 16.2 APPLICABILITY

---

This section provides the general requirements applicable to each of the COMMITMENTS and Testing Requirements within UFSAR Section 16.0, Selected Licensee Commitments.

- 16.2.1 COMMITMENTS shall be met during the MODES or other specified conditions in the Applicability.
- 16.2.2 Upon discovery of a failure to meet a COMMITMENT, the associated REMEDIAL ACTION(S) shall be met, except as provided in SLC 16.2.11. If the COMMITMENT is met or is no longer applicable prior to expiration of the specified time interval, completion of the REMEDIAL ACTION(S) is not required, unless otherwise stated.
- 16.2.3 When a COMMITMENT is not met, except as provided in the associated REMEDIAL ACTIONS, the Station Manager and/or the Responsible Group Superintendent will determine any further actions.
- 16.2.4 When a COMMITMENT is not met, entry into an OPERATIONAL MODE or other specified condition in the Applicability shall not be made except when the associated REMEDIAL ACTIONS to be entered permit continued operation in the MODE or other specified condition in the Applicability for an unlimited period of time. This COMMITMENT shall not prevent changes in OPERATIONAL MODES or other specified conditions in the Applicability that are required to comply with REMEDIAL ACTIONS. Exceptions to this COMMITMENT are stated in the individual COMMITMENTS.
- 16.2.5 COMMITMENTS including the associated REMEDIAL ACTIONS shall apply to each unit individually unless otherwise indicated as follows:
- a. Whenever the COMMITMENT refers to systems or components which are shared by both units, the REMEDIAL ACTIONS will apply to both units simultaneously. This will be indicated in the REMEDIAL ACTIONS;
  - b. Whenever the COMMITMENT applies to only one unit, this will be identified in the Applicability section of the COMMITMENT; and
  - c. Whenever certain portions of a COMMITMENT contain operating parameters, setpoints etc., which are different for each unit, this will be identified in parentheses or footnotes, for example, "...flow rate of 54,000 cfm (Unit 1) or 43,000 cfm (Unit 2)..."

---

16.2 APPLICABILITY (continued)

---

16.2.6 Testing Requirements shall be met during the OPERATIONAL MODES or other specified conditions in the Applicability for individual COMMITMENTS unless otherwise stated in an individual Testing Requirement or Reference. Failure to meet a Testing Requirement, whether such failure is experienced during the performance of the Testing Requirement or between performances of the Testing Requirement, shall be failure to meet the COMMITMENT. Failure to perform a Testing Requirement within the specified Frequency shall be failure to meet the COMMITMENT except as provided in COMMITMENT 16.2.8. Exceptions to these requirements are stated in the individual commitments or may be approved by the Station Manager and/or the Responsible Group Superintendent. Testing Requirements do not have to be performed on inoperable equipment or variables outside specified limits.

16.2.7 The specified Frequency for each Testing Requirement is met if the Test is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

If a Completion Time requires periodic performance on a "once per..." basis, the above Frequency extension applies to each performance after the initial performance.

Exceptions to this SLC are stated in the individual SLCs.

16.2.8 If it is discovered that a Testing Requirement was not performed within its specified Frequency, then compliance with the requirement to declare the COMMITMENT not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is greater. This delay period is permitted to allow performance of the Testing Requirement. A risk evaluation shall be performed for any Testing Requirement delayed greater than 24 hours, and the risk impact shall be managed.

If the Testing Requirement is not performed within the delay period, the COMMITMENT must immediately be declared not met, and the applicable REMEDIAL ACTIONS must be entered.

When the Testing Requirement is performed within the delay period and the Testing Requirement is not met, the COMMITMENT must immediately be declared not met, and the applicable REMEDIAL ACTIONS must be entered.

The clarifications provided by the McGuire Nuclear Station Technical Specification Bases for SR 3.0.3 are similarly applicable to SLC 16.2.8 and Testing Requirements.

---

**16.2 APPLICABILITY (continued)**

---

- 16.2.9 Entry into an OPERATIONAL MODE or other specified condition in the Applicability of a COMMITMENT shall not be made unless the COMMITMENT'S Testing Requirement(s) have been met within the specified frequency or as approved by the Station Manager and/or Responsible Group Superintendent. This provision shall not prevent entry into OPERATIONAL MODES or other specified conditions in the Applicability that are required to comply with REMEDIAL ACTIONS.
- 16.2.10 Testing Requirements shall apply to each unit individually unless otherwise indicated as stated in Specification 16.2.5 for individual commitments or whenever certain portions of a specification contain testing parameters different for each unit, which will be identified in parentheses or footnotes.
- 16.2.11 Equipment removed from service or declared inoperable to comply with REMEDIAL ACTIONS may be returned to service under administrative control solely to perform testing required to demonstrate its OPERABILITY or the OPERABILITY of other equipment. This is an exception to SLC 16.2.2 for the system returned to service under administrative control to perform the required testing to demonstrate OPERABILITY.