


# Explanation of Color Codes Used in Flag and Rainbow Reports

- Determine mode for Susceptibility (S) score; for multi-modal case, higher value of S is chosen for the mode
- Determine average for S and Knowledge (K) scores
- Value of S: higher of the average and the mode
- Color chosen according to the value of S and K
  - If S is equal to 1 or 2 (i.e., at a color box interface):
    - Upper color is chosen if at least one score exists that is higher than the value of S, otherwise lower color is chosen
    - An asterisk next to the color indicates the existence of one or more scores higher than the value of S
  - If S is <1 or <2 & >1 (i.e., inside a color box):
    - An "X" next to the color indicates the existence of one or more scores higher than this color box upper interface
  - If K is equal to 2, the left column colors are chosen
- A **BOLD** number in flag table for S indicates the mode
- Degradation mechanism in "BLACK" lettering for low K (left column colors) and in "WHITE" lettering for high K (right column colors) scores



\* Susceptibility at interface between colors with one or more scores higher than this interface.  
 X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**1 Reactor Coolant System**

**Reactor Pressure Vessel Closure Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 1.1	Pressure Vessel Head Flanges and Nozzles SA 508 Cl.2 Forging Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
<b>FR</b>	1.00	0	8	0	0	2.75	0	2	6	2.38	0	5	3
<b>SCC</b>	1.38	0	5	3	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 1.2	Pressure Vessel Plate SA-533 Gr.B Rolled Plate Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	0.50	4	4	0	0	3.00	0	0	8	3.00	0	0	8
<b>FAT-HWC</b> *	0.75	3	4	1	0	2.88	0	1	7	2.75	0	2	6
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b>	1.13	0	7	1	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 1.3	RPV Cladding 309 SS 7/32" thick .08%C max. Reactor Coolant Steam, 547°F, 1020 psia												
<b>DEBOND</b>	0.88	1	7	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.00	0	8	0	0	2.75	0	2	6	2.00	0	8	0
<b>SCC</b>	1.25	0	6	2	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
Subgroup 1.4	Closure Studs, Nuts and Washers SA 540 Carbon Steel Containment Air, < 547°F												
<b>EC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	0.88	1	7	0	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**1 Reactor Coolant System**

**Reactor Pressure Vessel Closure Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 1.5	SA508 Nozzle to SA 533 Plate Welds LAS SFA5.5:15-308 Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b> *	1.00	1	6	1	0	2.75	0	2	6	2.25	0	6	2
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 1.6	A533B Plate to Plate Welds LAS SFA5.5:15-308 Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
<b>FR</b>	1.13	0	7	1	0	2.63	0	3	5	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	3.00	0	0	8	2.88	0	1	7
Subgroup 1.7	A508 Nozzle to 304 SS Flange Weld 182 Weld Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	0.88	1	7	0	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.13	1	5	2	0	2.63	0	3	5	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	2.75	0	2	6	2.75	0	2	6
Subgroup 1.8	304 SS Flange HAZ Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	0.88	1	7	0	0	3.00	0	0	8	3.00	0	0	8
<b>FR</b>	1.25	0	6	2	0	2.75	0	2	6	2.13	0	7	1
<b>SCC</b> *	2.00	0	1	6	1	2.88	0	1	7	2.88	0	1	7
Subgroup 1.9	Nozzle Flanges A508 Cl.1 Reactor Coolant Steam, 547°F, 1020 psia												
<b>FR</b>	0.88	1	7	0	0	2.75	0	2	6	2.25	0	6	2
<b>SCC</b>	1.25	0	6	2	0	3.00	0	0	8	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**1 Reactor Coolant System**

**Reactor Pressure Vessel Closure Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 1.10	Dryer Hold Down Bracket 304 Stainless Steel Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	1.38	0	5	3	0	2.75	0	2	6	2.63	0	3	5
<b>SCC</b>	1.63	0	3	5	0	3.00	0	0	8	2.88	0	1	7
Subgroup 1.11	Dryer Hold Down Bracket A533 Gr. B LAS Reactor Coolant Steam, 547°F, 1020 psia												
<b>FR</b>	0.88	1	7	0	0	2.88	0	1	7	2.38	0	5	3
<b>SCC</b>	1.13	0	7	1	0	3.00	0	0	8	2.88	0	1	7
Subgroup 1.12	Dryer Hold Down Bracket Weld 182 Weld Reactor Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	2.75	0	2	6	2.63	1	1	6
Subgroup 1.13	Lifting Lug Welds LAS SFA5.5:15-308 Containment Air												
<b>FR</b>	0.88	1	7	0	0	2.50	0	4	4	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.1	Pressure Vessel Flanges and Nozzles SA 508 Cl.2 Forging Reactor Coolant Steam/Water, 547°F, 1020 psia												
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.00	0	8	0	0	2.75	0	2	6	2.38	0	5	3
<b>SCC</b>	1.38	0	5	3	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 2.2	Pressure Vessel Plate SA-533 Gr.B Rolled Plate Reactor Water, 533-547°F, 1020 psia Low Neutron dose												
<b>FAT</b>	0.75	2	6	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b> *	0.75	3	4	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.13	0	7	1	0	2.63	0	3	5	2.38	0	5	3
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
Subgroup 2.3	SA508 Nozzle/Flange to SA 533 Plate Welds Reactor Water, 533-547°F, 1020 psia LAS SFA5.5:15-308												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.4	SA508Nozzle to SA 533 Plate Welds Reactor Water, 533-547°F, 1020 psia LAS SFA5.5:15-308												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 2.5	SA 533 to SA 533 Plate Welds Reactor Water, 533-547°F, 1020 psia LAS SFA5.5:15-308												
<b>FAT</b>	0.88	1	7	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b> *	0.88	2	5	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b>	1.25	0	6	2	0	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
Subgroup 2.6	SA533 to SA 533 Plate Welds Reactor Water, 533-547°F, 1020 psia, Beltline Higher Neutron Dose LAS SFA5.5:15-308												
<b>FAT</b>	0.88	1	7	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b> *	0.88	2	5	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.50	0	4	4	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b>	1.38	0	5	3	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.7	SA 533Gr. B Plate Reactor Water, 533-547°F, 1020 psia Beltline, Higher Neutron Dose LAS SFA5.5:15-308												
<b>FAT</b>	0.88	1	7	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b> *	0.88	2	5	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.38	0	5	3	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b>	1.38	0	5	3	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
Subgroup 2.8	Feedwater Safeend Inconel 600 Reactor Water, 427°F, 1045 psia												
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.25	0	6	2	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.14	1	4	2	0	2.29	0	5	2	2.14	0	6	1
<b>SCC</b>	2.13	0	0	7	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.75	0	2	6	0	2.88	0	1	7	2.88	0	1	7
Subgroup 2.9	Feedwater Thermal Sleeve Inconel 600 Reactor Water, 427°F, 1045 psia												
<b>FAT</b>	1.38	0	5	3	0	3.00	0	0	8	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.50	0	4	4
<b>SCC</b>	2.13	0	0	7	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.63	0	3	5	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.10	Feedwater Thermal Sleeve/A508 Nozzle Weld Dissimilar 182 Weld Reactor Water, 427°F, 1045 psia												
<b>CREV</b> *	0.88	2	5	1	0	2.75	0	2	6	2.75	0	2	6
<b>FAT</b>	1.25	0	6	2	0	3.00	0	0	8	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.50	0	4	4	0	2.75	0	2	6	2.75	0	2	6
Subgroup 2.11	Nozzle Safeends and Thermal Sleeves SS 316 including HAZ Reactor Water, 427°F, 1045 psia												
<b>FAT</b>	1.38	0	5	3	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.50	0	4	4	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.50	0	4	4	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.13	0	0	7	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.50	0	4	4	0	2.88	0	1	7	2.75	0	2	6
Subgroup 2.12	Dissimilar 82/182 Weld Between Carbon Steel Extension and Alloy 600 Safe end Reactor Water, 427°F, 1045 psia												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.63	0	3	5
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.50	0	4	4	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.13	82/182 Weld Pad Between Clad A508 Nozzle and Alloy 600 Safe End Reactor Water, 533°F, 1059 psia												
<b>CREV</b> *	0.88	2	5	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.50	0	4	4
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.25	0	6	2
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.25	0	0	6	2	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.50	0	4	4	0	2.75	0	2	6	2.63	0	3	5
Subgroup 2.14	Safe end Extension Carbon Steel (Unclad) Reactor Water, <533°F, 1059 psia												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	0.88	1	7	0	0	2.75	0	2	6	2.38	0	5	3
<b>PIT</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 2.15	RPV Cladding, 309 SS Reactor Water or Coolant Steam 533°F, 1059 psia												
<b>DEBOND</b>	0.88	1	7	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.00	0	8	0	0	2.50	0	4	4	2.00	0	8	0
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.16	Main Steam Outlet Nozzle and Safe End A 508, Carbon Steel Reactor Coolant Steam, 533°F, 1059 psia												
<b>EC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6
<b>FR</b>	1.00	0	8	0	0	2.75	0	2	6	2.13	0	7	1
<b>PIT</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.38	0	5	3	0	2.88	0	1	7	2.75	0	2	6
Subgroup 2.17	Attachment Pads Alloy 182 on Top of SS Cladding or on RPV 575°F, Reactor Water or Coolant Steam, 1020 psia												
<b>DEBOND</b>	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.50	0	4	4	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	2.75	0	2	6	2.75	0	2	6
<b>SCC-HWC</b>	1.50	0	4	4	0	2.63	0	3	5	2.63	0	3	5
Subgroup 2.18	Brackets for Steam Dryer, Guide Rods CF8M Reactor Water or Coolant Steam, 547°F, 1020 psia												
<b>FAT</b>	1.38	0	5	3	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.25	0	6	2	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.63	0	3	5	0	2.63	0	3	5	2.38	0	5	3
<b>SCC</b>	1.50	0	4	4	0	2.00	1	6	1	1.88	2	5	1
<b>SCC-HWC</b>	1.25	0	6	2	0	2.00	1	6	1	1.88	2	5	1

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**2 Reactor Coolant System**

**Reactor Pressure Vessel Shell**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 2.19	Jet Pump Riser Bracket 304 SS HAZ Reactor Water, 533°F, 1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
Subgroup 2.20	CRD Return Nozzle Cap Weld LAS SFA5.5:15-308, Not Stress Relieved Reactor Water, 533°F, 1059 psia (Stagnant)												
<b>FAT</b> *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
<b>FR</b> *	1.00	1	5	1	0	2.71	0	2	5	2.29	0	5	2
<b>SCC</b>	1.38	1	3	4	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	1	5	2	0	2.88	0	1	7	2.75	0	2	6
Subgroup 2.21	Stabilizer Lug Welds LAS SFA5.5:15-308 Containment Air												
<b>FR</b>	0.88	1	7	0	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**3 Reactor Coolant System**

**Reactor Pressure Vessel Bottom Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 3.1	Pressure Vessel Head Nozzles SA 508 Cl.2 Forging Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.13	0	<b>7</b>	1	0	2.63	0	3	5	2.25	0	6	2
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 3.2	Pressure Vessel Plate SA-533 Gr.B Rolled Plate Reactor Coolant 533-547°F, 1020-1059 psia												
<b>FAT</b>	0.75	2	<b>6</b>	0	0	2.88	0	1	7	3.00	0	0	8
<b>FAT-HWC</b> *	0.75	3	<b>4</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b>	1.25	0	<b>6</b>	2	0	2.63	0	3	5	2.25	0	6	2
<b>SCC</b>	1.00	0	<b>8</b>	0	0	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.88	0	1	7	2.88	0	1	7
Subgroup 3.3	SA508 Nozzle to SA 533 Plate Welds LAS SFA5.5:15-308 Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.13	0	<b>7</b>	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**3 Reactor Coolant System**

**Reactor Pressure Vessel Bottom Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 3.4	Dissimilar Metal Weld 182/82 508 Nozzle to 316L Safe End Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.50	0	4	4
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.25	0	6	2
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.50	0	4	4	0	2.88	0	1	7	2.88	0	1	7
Subgroup 3.5	Dissimilar Metal Weld 182/82 J-weld Incore and CRD Penetrations Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.63	0	3	5
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.50	0	4	4	0	2.88	0	1	7	2.88	0	1	7
Subgroup 3.6	Safe End and Thermal Sleeve 316NG or 316L SS HAZ Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.63	0	3	5
<b>FAT-HWC</b>	1.25	0	6	2	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> *	2.00	0	1	6	1	3.00	0	0	8	2.75	0	2	6
<b>SCC-HWC</b> *	1.00	2	4	2	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**3 Reactor Coolant System**

**Reactor Pressure Vessel Bottom Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 3.7	Safe End 304 SS HAZ Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
Subgroup 3.8	308 Weldments Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.75	0	2	6	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	1.00	0	8	0	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 3.9	82/182 Weld Pad Between Thermal Sleeve and Nozzle Reactor Water, 533-547°F, 1020-1059 psia												
<b>CREV</b> *	0.88	2	5	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.50	0	4	4
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.63	0	3	5	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**3 Reactor Coolant System**

**Reactor Pressure Vessel Bottom Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 3.10	CRD Stubtube Alloy 600 HAZ Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.13	0	1	5	2	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.38	0	5	3	0	2.75	0	2	6	2.63	0	3	5
Subgroup 3.11	Dissimilar 82/182 Welds A533B to Inconel Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.63	0	3	5	0	2.88	0	1	7	2.75	0	2	6
Subgroup 3.12	Alloy 600 (e.g., Shroud Support Leg, Gussets) Alloy 600 HAZ Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	1	4	3	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.38	0	5	3	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**3 Reactor Coolant System**

**Reactor Pressure Vessel Bottom Head**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 3.13	182 Weldments of Inconel to Inconel Reactor Water, 533-547°F, 1020-1059 psia												
<b>FAT</b> X	1.25	0	7	0	1	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.63	0	0	3	5	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.50	0	4	4	0	2.88	0	1	7	2.75	0	2	6
Subgroup 3.14	Support Skirt SA533B to A508 Forgings Containment Air, 533°F												
<b>FAT</b>	0.88	1	7	0	0	2.75	0	2	6	2.88	0	1	7
<b>FR</b> X	0.63	4	3	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 3.15	Vessel Cladding 309 SS, 0.08%C max Reactor Water, 533-547°F, 1020-1059 psia												
<b>DEBOND</b>	0.88	1	7	0	0	2.50	1	2	5	2.50	1	2	5
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.00	0	7	0	0	2.71	0	2	5	2.71	0	2	5
<b>FR</b>	1.00	0	8	0	0	2.63	0	3	5	2.13	0	7	1
<b>SCC</b>	1.25	0	6	2	0	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.17	0	5	1	0	2.83	0	1	5	2.83	0	1	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.1	Various Ring - Ring Segment Weld Metal - Vertical Type 308/308L Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4
Subgroup 4.2	Various Ring - Ring Segment Welds - Vertical HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5
Subgroup 4.3	Various Ring - Shell Circumferential Weld Metal Type 308/308L weld metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.4	Various Ring - Shell Circumferential Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5
Subgroup 4.5	Various Shell Plate Vertical Weld Metal Type 308/308L Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4
Subgroup 4.6	Various Shell Plate Vertical Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.50	0	0	4	4	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.7	Various Plate Vertical & Circumferential Weld Metal Type 308/308L weld metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, moderate fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
Subgroup 4.8	Various Plate Vertical & Circumferential Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, moderate fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.75	0	2	6	2.75	0	2	6
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.50	0	0	4	4	2.88	0	1	7	2.63	0	3	5
<b>SCC-HWC</b> *	1.75	0	3	4	1	2.75	0	2	6	2.50	0	4	4
Subgroup 4.9	Shell -Shroud Support Ring (H7) Weld Metal Alloy 182 weld metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.25	1	4	3	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.50	0	4	4	2.00	0	8	0
<b>SCC</b>	2.25	0	0	6	2	2.88	0	1	7	2.63	0	3	5
<b>SCC-HWC</b>	1.38	1	3	4	0	2.75	0	2	6	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.10	Shell -Shroud Support Ring (H7) Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> X	1.50	0	5	2	1	2.75	0	2	6	2.63	0	3	5
Subgroup 4.11	Ring material (segments often forged) Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	0.88	1	7	0	0	2.75	0	2	6	2.63	0	3	5
Subgroup 4.12	Shell material (segments) Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> X	1.50	0	5	2	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.13	Shell material (segments) - beltline region Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, moderate fluence												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	<b>7</b>	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	<b>7</b>	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> X	1.63	0	<b>4</b>	3	1	2.88	0	1	7	2.63	0	3	5
<b>SCC-HWC</b>	1.25	1	<b>4</b>	3	0	2.63	0	3	5	2.50	0	4	4
Subgroup 4.14	Miscellaneous brackets, pads, etc. on shroud Type 304 SS (some/all probably with 308L welds) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	0.88	1	<b>7</b>	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	<b>6</b>	2	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.13	0	0	<b>7</b>	1	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.50	0	4	4
Subgroup 4.15	Entire top guide structure - interlocked (wedged) Type 304 SS Reactor Water (<0.15 mS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi, moderate to high fluence												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	<b>7</b>	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	<b>6</b>	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.50	0	0	4	<b>4</b>	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b> X	1.63	0	<b>5</b>	1	2	2.63	0	3	5	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.16	Top guide wedge Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> X	1.50	0	5	2	1	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.50	0	4	4
Subgroup 4.17	Entire core plate structure Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> *	1.75	0	3	4	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 4.18	Core plate bolt assembly Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b> X	1.63	0	4	3	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**4 Reactor Coolant System**

**Core Shroud**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 4.19		Core plate bypass flow plug Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi											
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.00	0	8	0	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b> *	1.00	1	6	1	0	2.75	0	2	6	2.25	0	6	2
<b>SCC</b> X	1.50	0	5	2	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 4.20		Core plate bypass flow plug X750 Spring Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi											
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.63	0	3	5	0	2.75	0	2	6	2.25	0	6	2
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> *	1.88	0	2	5	1	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**5 Reactor Coolant System**

**Core Controls**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 5.1	Fuel Support Structure Wrought or Cast SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	<b>7</b>	0	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.50	0	4	<b>4</b>	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b> X	1.50	0	<b>5</b>	2	1	2.75	0	2	6	2.50	1	2	5
<b>SCC-HWC</b>	1.25	1	<b>4</b>	3	0	2.63	0	3	5	2.25	1	4	3
Subgroup 5.2	Control Rod Blade 304/316 Stainless Steel, often chemistry controls Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, 4-6 dpa												
<b>FAT</b>	1.00	1	<b>7</b>	0	0	2.71	0	2	5	2.71	0	2	5
<b>FAT-HWC</b>	0.86	2	<b>6</b>	0	0	2.71	0	2	5	2.57	0	3	4
<b>FR</b>	1.29	1	<b>5</b>	2	0	2.57	0	3	4	2.14	0	6	1
<b>SCC</b>	2.29	1	0	<b>5</b>	2	2.86	0	1	6	2.71	0	2	5
<b>SCC-HWC</b> X	1.43	2	<b>3</b>	2	1	2.57	0	3	4	2.29	0	5	2
Subgroup 5.3	Control Rod Guide Tube & Housing CF3 A351 Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low to moderate fluence												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.63	0	3	<b>5</b>	0	2.25	0	6	2	2.00	0	8	0
<b>SCC</b>	1.63	0	3	<b>5</b>	0	2.38	0	5	3	2.13	1	5	2
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.50	0	4	4	2.38	1	3	4
<b>WEAR</b>	1.14	1	<b>6</b>	1	0	2.57	0	3	4	2.29	0	5	2

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**5 Reactor Coolant System**

**Core Controls**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 5.4	Fuel Bundle Alignment Pin Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b> X	1.50	0	5	2	1	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4
Subgroup 5.5	Control Rod Drive Housing Flange Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b> X	1.38	0	6	1	1	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 5.6	Control Rod Drive Housing Flange Weld Metal Type 308/L or 309 Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 105°F, 1059 psi (CRD drive water)												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.13	1	5	2	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b>	1.25	1	4	3	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**5 Reactor Coolant System**

**Core Controls**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 5.7	Control Rod Drive Housing Flange Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 105°F, 1059 psi (CRD drive water)												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.13	1	5	2	0	2.50	0	4	4	2.38	0	5	3
<b>FR</b>	1.25	1	4	3	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4
Subgroup 5.8	RPV Stub Tube - CRD Housing - upper weld metal Alloy 182 Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.25	1	4	3	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b>	1.50	0	4	4	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.75	0	2	6
<b>SCC-HWC</b>	1.25	1	4	3	0	2.75	0	2	6	2.50	0	4	4
Subgroup 5.9	RPV Stub Tube - CRD Housing - upper weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**5 Reactor Coolant System**

**Core Controls**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 5.10	RPV Stub Tube - CRD Housing - upper weld HAZ Alloy 600 HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.13	0	1	5	2	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.63	0	3	5
Subgroup 5.11	Misc. CRD & Neutron Monitoring - out of core Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	0.88	1	7	0	0	2.75	0	2	6	2.63	0	3	5
Subgroup 5.12	In-core Guide Tube Ass. (no delta P across tube) Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525-550°F, 1059 psi, high fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.13	0	0	7	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.25	1	4	3	0	2.63	0	3	5	2.50	1	2	5
<b>WEAR</b>	1.29	1	5	2	0	2.43	0	4	3	2.29	0	5	2

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**5 Reactor Coolant System**

**Core Controls**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 5.13	Misc CRD Support Structures - outside vessel ASTM A36 & A235 Dry <135°F, Containment Atmosphere												
<b>FAT</b>	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	0.63	3	5	0	0	2.88	0	1	7	2.88	0	1	7
<b>SCC</b>	0.38	5	3	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 5.14	Misc DP & Liquid Control Structures - in-vessel Type 304 SS base metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.86	1	6	0	0	2.71	0	2	5	2.71	0	2	5
<b>SCC</b> X	1.38	0	6	1	1	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	5	1	0	2.86	0	1	6	2.71	0	2	5
Subgroup 5.15	Misc DP & Liquid Control Structures - in-vessel 308/L SS Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.13	1	5	2	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	1.25	0	6	2	0	2.63	0	3	5	2.63	0	3	5
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.50	0	4	4
Subgroup 5.16	Misc DP & Liquid Control Structures - in-vessel 182 Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	1.25	1	4	3	0	2.50	0	4	4	2.50	0	4	4
<b>FR</b>	1.50	0	4	4	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	2.75	0	2	6	2.50	0	4	4
<b>SCC-HWC</b>	1.25	1	4	3	0	2.75	0	2	6	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**5 Reactor Coolant System**

**Core Controls**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 5.17		Misc DP & Liquid Control Structures - in-vessel Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi											
<b>FAT</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.25	1	<b>4</b>	3	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.38	0	<b>5</b>	3	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.25	0	0	<b>6</b>	2	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	1	<b>5</b>	2	0	2.75	0	2	6	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**6 Reactor Coolant System**

**Jet Pump Assembly**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 6.1	Misc. Pipes & Elbows & JP Mixer/Diffuser 304SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 6.2	SS-to-SS Welds in above Pipes & Elbows 308/L SS Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.63	0	3	5
Subgroup 6.3	SS-to-SS Welds in above Pipes & Elbows (HAZ) 304SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.75	0	2	6
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**6 Reactor Coolant System**

**Jet Pump Assembly**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 6.4	Restrainer Bracket Support XM-19 (Nitronic 50) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.63	0	3	5	2.38	0	5	3
<b>SCC</b> X	1.50	0	5	2	1	2.75	0	2	6	2.75	0	2	6
<b>SCC-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.50	0	4	4
Subgroup 6.5	Jet Pump Holddown Beam X750 (mostly HTH) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.25	1	4	3	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.50	0	4	4	0	2.50	0	4	4	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	2.13	0	1	5	2	2.88	0	1	7	2.75	0	2	6
Subgroup 6.6	Access Hole Cover (Ledge in Group 4) Alloy 600 (some covers are SS) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.38	0	5	3
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b> *	1.88	0	2	5	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**6 Reactor Coolant System**

**Jet Pump Assembly**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 6.7	Alloy 182Welds for Access Hole Cover Alloy 182 Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.25	1	4	3	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.50	0	4	4	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.50	0	4	4
<b>SCC-HWC</b>	1.38	1	3	4	0	2.75	0	2	6	2.50	0	4	4
Subgroup 6.8	Slip Fit on Jet Pump Mixer to Diffuser 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi												
<b>FAT</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.38	1	3	4	0	2.50	0	4	4	2.50	0	4	4
<b>WEAR</b>	1.63	0	3	5	0	2.63	0	3	5	2.50	0	4	4
Subgroup 6.9	Riser brace or bracket weld to riser 308L weld metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**6 Reactor Coolant System**

**Jet Pump Assembly**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 6.10	Riser brace or bracket weld to riser - HAZ 304SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.00	0	8	0
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.75	0	2	6
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5
Subgroup 6.11	Jet Pump Adapter to Ledge SS Adapter HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.38	0	5	3	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5
Subgroup 6.12	Alloy 182 Welds for Jet Pump Adapter to Ledge Alloy 182 Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.25	1	4	3	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.50	0	4	4	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.63	0	3	5
<b>SCC-HWC</b>	1.50	0	4	4	0	2.75	0	2	6	2.50	0	4	4

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**6 Reactor Coolant System**

**Jet Pump Assembly**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 6.13	Jet Pump Adapter to JP Diffuser SS HAZ on Adapter and Diffuser Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.38	0	<b>5</b>	3	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b>	2.38	0	0	<b>5</b>	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.38	0	<b>6</b>	1	1	2.75	0	2	6	2.63	0	3	5
Subgroup 6.14	Jet Pump Adapter to JP Diffuser Weld Metal 308/L SS Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 525°F, 1059 psi, low fluence												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	<b>7</b>	1	0	2.38	0	5	3	2.13	0	7	1
<b>SCC</b> X	1.25	0	<b>7</b>	0	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**7 Reactor Coolant System**

**ECCS Connections**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 7.1	Feedwater Pipe & Header to T-Box Weld Metal Type 308/L SS Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 427°F, 1045 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 7.2	Feedwater Pipe & Header to T-Box Welds HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 427°F, 1045 psi												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.38	0	5	3	0	2.75	0	2	6	2.63	0	3	5
Subgroup 7.3	Feedwater Sparger Components Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 427°F, 1045 psi												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.00	0	8	0	0	2.75	0	2	6	2.50	0	4	4
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**7 Reactor Coolant System**

**ECCS Connections**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 7.4	Feedwater Sparger Nozzle Weld Metal Type 308/L Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 427°F, 1045 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.00	0	8	0	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 7.5	Feedwater Sparger Nozzle Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 427°F, 1045 psi												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.25	0	0	6	2	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.38	0	5	3	0	2.75	0	2	6	2.63	0	3	5
Subgroup 7.6	Core Spray Components Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	0.75	2	6	0	0	2.75	0	2	6	2.50	0	4	4
<b>SCC</b> X	1.50	0	5	2	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**7 Reactor Coolant System**

**ECCS Connections**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 7.7	Core Spray Component Type 308/L SS Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.00	0	8	0	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 7.8	Core Spray Component Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b> X	1.50	0	5	2	1	2.75	0	2	6	2.63	0	3	5
Subgroup 7.9	LPCI Components Type 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b>	0.88	1	7	0	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	0.75	2	6	0	0	2.75	0	2	6	2.50	0	4	4
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	1.29	0	5	2	0	2.71	0	2	5	2.71	0	2	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**7 Reactor Coolant System**

**ECCS Connections**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 7.10	LPCI Component Weld Metal Type 308/L Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	<b>7</b>	1	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	<b>6</b>	1	0	2.75	0	2	6	2.63	0	3	5
Subgroup 7.11	LPCI Component Weld HAZ Type 304 SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 533°F, 1059 psi												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	<b>7</b>	1	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.38	0	0	<b>5</b>	3	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> X	1.50	0	<b>5</b>	2	1	2.75	0	2	6	2.63	0	3	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**8 Reactor Coolant System**

**Steam Separator & Dryer**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 8.1	Steam Separator and Dryer Assembly 304SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 550°F, 1045 psi, wet steam												
<b>FAT</b> *	1.88	0	2	5	1	2.75	0	2	6	2.25	1	4	3
<b>SCC</b> X	1.63	0	4	3	1	3.00	0	0	8	2.88	0	1	7
Subgroup 8.2	Steam Separator and Dryer Assembly Welds Type 308/L Weld Metal Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 550°F, 1045 psi, wet steam												
<b>FAT</b> *	1.88	0	2	5	1	2.75	0	2	6	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.25	0	6	2	2.13	0	7	1
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	3.00	0	0	8
Subgroup 8.3	Steam Separator & Dryer Assembly Weld HAZ 304SS HAZ Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 550°F, 1045 psi, wet steam												
<b>FAT</b> *	2.00	0	2	4	2	2.75	0	2	6	2.38	0	5	3
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
Subgroup 8.4	Steam Separator and Dryer Assembly ASTM A193, Gr. B8 Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 550°F, 1045 psi, wet steam												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.50	0	4	4
<b>FR</b>	1.13	0	7	1	0	2.38	0	5	3	2.25	0	6	2
<b>SCC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.63	0	3	5
Subgroup 8.5	Steam Separator Guide Pin 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 550°F, 1045 psi, wet steam												
<b>FAT</b>	1.38	0	5	3	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.00	0	8	0	0	2.50	0	4	4	2.38	0	5	3
<b>SCC</b> X	1.50	0	5	2	1	3.00	0	0	8	3.00	0	0	8

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**8 Reactor Coolant System**

**Steam Separator & Dryer**

		Susceptibility				Confidence				Knowledge				
		Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup	8.6	RCIC Head Spray Nozzle 304 SS Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) 550°F, 1045 psi, wet steam												
	<b>FAT</b>	1.25	0	<b>6</b>	2	0	2.63	0	3	5	2.63	0	3	5
	<b>FR</b>	1.00	0	<b>8</b>	0	0	2.50	0	4	4	2.38	0	5	3
	<b>SCC</b> <b>X</b>	1.38	0	<b>6</b>	1	1	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
 X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**9 Reactor Coolant System**

**Reactor Recirculation System**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 9.1	All Stainless Steel Components External Surfaces When at <150°C Normally Dry When at Low Temp												
<b>PIT</b>	0.88	1	7	0	0	2.88	0	1	7	2.75	0	2	6
<b>SCC</b>	0.88	1	7	0	0	3.00	0	0	8	2.88	0	1	7
Subgroup 9.2	LAS, SA-508 Cl.2 (Forged Ring) 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) CUF 0.48 w env effect												
<b>CREV</b> *	0.88	2	5	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.50	0	4	4	0	2.75	0	2	6	2.63	0	3	5
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.00	0	8	0	0	2.63	0	3	5	2.38	0	5	3
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 9.3	LAS, SA-508 Cl.2 HAZ 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) CUF 0.48 w env effect												
<b>CREV</b> *	0.75	3	4	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.50	0	4	4	0	2.75	0	2	6	2.63	0	3	5
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.00	0	8	0	0	2.50	0	4	4	2.38	0	5	3
<b>SCC</b> X	1.63	0	4	3	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	0.86	1	6	0	0	2.86	0	1	6	2.86	0	1	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**9 Reactor Coolant System**

**Reactor Recirculation System**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 9.4	Dissimilar metal welds LAS to SS 308 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl) CUF 0.48 w env effect												
<b>FAT</b>	1.50	0	4	4	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b>	1.25	1	4	3	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.38	0	5	3
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 9.5	Safe-end, SS 316NG 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b> X	1.25	0	7	0	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> *	0.88	2	5	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.6	316 HAZ 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.63	0	3	5
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.50	0	4	4	2.13	0	7	1
<b>SCC</b>	2.38	0	0	5	3	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.38	0	5	3	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**9 Reactor Coolant System**

**Reactor Recirculation System**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 9.7	Welds SS 308 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.00	0	8	0	0	2.50	0	4	4	2.25	0	6	2
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.8	Straight pipe SS Type 316 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b> X	1.25	0	7	0	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.9	HAZ 304 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>FR</b>	1.33	0	4	2	0	2.50	0	3	3	2.17	0	5	1
<b>SCC</b>	2.50	0	0	4	4	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> X	1.38	0	6	1	1	2.75	0	2	6	2.75	0	2	6
Subgroup 9.10	Straight pipe SS Type 304 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b> X	1.25	0	7	0	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**9 Reactor Coolant System**

**Reactor Recirculation System**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 9.11	Elbows SS Type 304 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.12	Tee SS Type 304 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT-HWC</b> *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b> X	1.38	0	6	1	1	3.00	0	0	8	3.00	0	0	8
<b>SCC-HWC</b>	1.13	1	5	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.13	Socket Welds SS 308 on 304 and 316 550°F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>CREV</b> *	1.00	1	6	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	2.50	0	0	4	4	2.88	0	1	7	2.50	0	4	4
<b>FAT-HWC</b>	2.25	0	0	6	2	2.75	0	2	6	2.50	0	4	4
<b>SCC</b>	2.13	0	0	7	1	3.00	0	0	8	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.14	Flange SA 182, GR F316 550 F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
<b>CREV</b>	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT-HWC</b>	1.13	1	5	2	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b> X	1.25	0	7	0	1	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**9 Reactor Coolant System**

**Reactor Recirculation System**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 9.15	Cast SS CF-8 and CF-8M 550 F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
FAT	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
FAT-HWC	1.13	1	5	2	0	2.63	0	3	5	2.63	0	3	5
FR	1.25	0	6	2	0	2.63	0	3	5	2.25	0	6	2
SCC	1.25	0	6	2	0	2.75	0	2	6	2.38	1	3	4
SCC-HWC	1.13	1	5	2	0	2.63	0	3	5	2.50	1	2	5
Subgroup 9.16	Reducing Branch SS 304 550 F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
FAT	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
FAT-HWC *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
SCC X	1.25	0	7	0	1	3.00	0	0	8	3.00	0	0	8
SCC-HWC *	1.00	1	6	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.17	Cap SS 304, 308/L Weld, and HAZ 550 F, 1265 psia (design) Reactor Water (<0.15 uS/cm, <5 ppb SO4/Cl)												
FAT	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
FAT-HWC *	1.00	1	6	1	0	2.63	0	3	5	2.63	0	3	5
FR	1.25	0	6	2	0	2.63	0	3	5	2.25	0	6	2
SCC	1.75	0	2	6	0	2.88	0	1	7	2.88	0	1	7
SCC-HWC	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 9.18	Pump Casing Bolting SA 193 GR B7 External Drywell Containment												
CREV	0.88	1	7	0	0	2.63	0	3	5	2.63	0	3	5
FAT	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
SCC	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**10 Emergency Core Cooling System**

**Low Pressure Core Spray**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 10.1	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA105,106,216,234 - Carbon Steel Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 10.2	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA105,106,216,234 - Carbon Steel Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.88	0	1	7	2.75	0	2	6
Subgroup 10.3	Weldolets and Sockolets SA105,106,234 - Carbon Steel & Weld Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.75	0	2	6
<b>GC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**10 Emergency Core Cooling System**

**Low Pressure Core Spray**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 10.4	Valves SA105,106,216,234 - Carbon Steel Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 10.5	Flange & Bolts at strainer Carbon Steel (including higher strength bolts) in galvanic contact with SS Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	2.13	0	0	7	1	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b> X	1.50	0	5	2	1	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
Subgroup 10.6	Strainer & Flange Parts Type 304 SS Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.75	0	2	6	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	2.00	0	0	8	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**10 Emergency Core Cooling System**

**Low Pressure Core Spray**

	Susceptibility					Confidence				Knowledge			
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 10.7	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA106,234 - Carbon Steel 100-550°F stagnant reactor water												
<b>CREV</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>MIC</b>	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 10.8	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA106,234 - Carbon Steel 100-550°F stagnant reactor water												
<b>CREV</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>MIC</b>	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 10.9	Valves SA105,106,216,234 - Carbon Steel 100-200°F stagnant reactor water HWC unimportant here (low temp)												
<b>CREV</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>MIC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.75	0	2	6	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**10 Emergency Core Cooling System**

**Low Pressure Core Spray**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 10.10	LPCS Pump Parts A106,A516 Carbon & Low Alloy Steels Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.88	0	1	7	3.00	0	0	8
<b>GC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
 X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**11 Emergency Core Cooling System**

**High Pressure Core Spray - SP Water**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 11.1	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA105,106,216,234 - Carbon Steel Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 11.2	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA105,106,216,234 - Carbon Steel Weld Metal Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
Subgroup 11.3	Weldolets and Sockolets SA105,106,234 - Carbon Steel Base & Weld Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**11 Emergency Core Cooling System**

**High Pressure Core Spray - SP Water**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 11.4	Valves SA105,106,216,234 - Carbon Steel Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
Subgroup 11.5	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA106,234 - Carbon Steel 100-550°F stagnant reactor water												
<b>CREV</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>MIC</b>	1.38	0	5	3	0	2.50	0	4	4	2.63	0	3	5
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 11.6	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA106,234 - Carbon Steel 100-550°F stagnant reactor water												
<b>CREV</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>MIC</b>	1.38	0	5	3	0	2.50	0	4	4	2.63	0	3	5
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**11 Emergency Core Cooling System**

**High Pressure Core Spray - SP Water**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 11.7	HPCS Pump Parts A106,A516 Carbon & Low Alloy Steels Suppression pool water for cooling, typically <100°F												
<b>CREV</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**11A Emergency Core Cooling System**

**HPCS - CST Water (OTHER PLANT)**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 11A.1	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA105,106,216,234 - Carbon Steel Condensate storage water for cooling, typ. <100°F												
<b>CREV</b> *	2.00	0	1	5	1	2.71	0	2	5	2.71	0	2	5
<b>FAT</b>	1.00	0	7	0	0	2.86	0	1	6	3.00	0	0	7
<b>GC</b> X	1.57	0	4	2	1	2.71	0	2	5	2.71	0	2	5
<b>MIC</b> *	1.86	0	2	4	1	2.71	0	2	5	2.71	0	2	5
<b>PIT</b> *	2.00	0	1	5	1	2.86	0	1	6	2.71	0	2	5
<b>SCC</b>	1.29	0	5	2	0	2.86	0	1	6	2.71	0	2	5
Subgroup 11A.2	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA105,106,216,234 - Carbon Steel Weld Metal Condensate storage water for cooling, typ. <100°F												
<b>CREV</b> *	2.00	0	1	5	1	2.71	0	2	5	2.71	0	2	5
<b>FAT</b>	1.00	0	7	0	0	3.00	0	0	7	3.00	0	0	7
<b>GC</b> X	1.57	0	4	2	1	2.71	0	2	5	2.71	0	2	5
<b>MIC</b> *	1.86	0	2	4	1	2.71	0	2	5	2.71	0	2	5
<b>PIT</b> *	2.00	0	1	5	1	2.86	0	1	6	2.71	0	2	5
<b>SCC</b> X	1.43	0	5	1	1	2.86	0	1	6	2.71	0	2	5
Subgroup 11A.3	Weldolets and Sockolets SA105,106,234 - Carbon Steel Base & Weld Condensate storage water for cooling, typ. <100°F												
<b>CREV</b>	1.86	0	1	6	0	2.71	0	2	5	2.71	0	2	5
<b>FAT</b>	1.00	0	7	0	0	2.86	0	1	6	3.00	0	0	7
<b>GC</b>	1.43	0	4	3	0	2.71	0	2	5	2.71	0	2	5
<b>MIC</b>	1.71	0	2	5	0	2.71	0	2	5	2.71	0	2	5
<b>PIT</b>	1.86	0	1	6	0	2.86	0	1	6	2.71	0	2	5
<b>SCC</b>	1.29	0	5	2	0	2.86	0	1	6	2.71	0	2	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**11A Emergency Core Cooling System**

**HPCS - CST Water (OTHER PLANT)**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 11A.4	Valves SA105,106,216,234 - Carbon Steel Condensate storage water for cooling, typ. <100°F												
<b>CREV</b> *	2.00	0	1	5	1	2.71	0	2	5	2.71	0	2	5
<b>FAT</b>	1.00	0	7	0	0	3.00	0	0	7	3.00	0	0	7
<b>GC</b>	1.43	0	4	3	0	2.71	0	2	5	2.71	0	2	5
<b>MIC</b>	1.71	0	2	5	0	2.71	0	2	5	2.71	0	2	5
<b>PIT</b>	1.86	0	1	6	0	2.86	0	1	6	2.71	0	2	5
<b>SCC</b>	1.29	0	5	2	0	2.86	0	1	6	2.71	0	2	5
Subgroup 11A.5	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA106,234 - Carbon Steel 100-550°F stagnant reactor water												
<b>CREV</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.14	0	6	1	0	2.71	0	2	5	2.86	0	1	6
<b>FAT-HWC</b>	1.14	0	6	1	0	2.71	0	2	5	2.71	0	2	5
<b>MIC</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
<b>PIT</b>	1.71	0	2	5	0	2.86	0	1	6	2.86	0	1	6
<b>SCC</b>	1.29	0	5	2	0	2.86	0	1	6	2.71	0	2	5
<b>SCC-HWC</b>	1.14	0	6	1	0	2.71	0	2	5	2.71	0	2	5
Subgroup 11A.6	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA106,234 - Carbon Steel 100-550°F stagnant reactor water												
<b>CREV</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.14	0	6	1	0	2.71	0	2	5	2.86	0	1	6
<b>FAT-HWC</b>	1.14	0	6	1	0	2.71	0	2	5	2.71	0	2	5
<b>MIC</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
<b>PIT</b>	1.71	0	2	5	0	2.86	0	1	6	2.86	0	1	6
<b>SCC</b>	1.29	0	5	2	0	2.86	0	1	6	2.71	0	2	5
<b>SCC-HWC</b>	1.14	0	6	1	0	2.71	0	2	5	2.71	0	2	5

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**11A Emergency Core Cooling System**

**HPCS - CST Water (OTHER PLANT)**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 11A.7	HPCS Pump Parts A106,A516 Carbon & Low Alloy Steels Condensate storage water for cooling, typ. <100°F												
<b>CREV</b> *	2.00	0	1	5	1	2.71	0	2	5	2.71	0	2	5
<b>FAT</b>	1.00	0	7	0	0	2.86	0	1	6	3.00	0	0	7
<b>GC</b> X	1.57	0	4	2	1	2.71	0	2	5	2.71	0	2	5
<b>MIC</b> *	1.71	0	3	3	1	2.71	0	2	5	2.71	0	2	5
<b>PIT</b> *	1.86	0	2	4	1	2.71	0	2	5	2.71	0	2	5
<b>SCC</b>	1.29	0	5	2	0	2.86	0	1	6	2.71	0	2	5
Subgroup 11A.8	Various elbows, flanges, & pipe (base metal) Primary & secondary containment Type 304 SS Base Metal Condensate storage water for cooling, typ. <100°F												
<b>FAT</b>	1.00	0	7	0	0	2.86	0	1	6	3.00	0	0	7
<b>MIC</b>	1.43	0	4	3	0	2.71	0	2	5	2.71	0	2	5
<b>SCC</b>	1.14	0	6	1	0	3.00	0	0	7	2.86	0	1	6
Subgroup 11A.9	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment Type 304 SS Weld Metal & HAZ Condensate storage water for cooling, typ. <100°F												
<b>FAT</b>	1.00	0	7	0	0	3.00	0	0	7	3.00	0	0	7
<b>MIC</b>	1.29	0	5	2	0	2.71	0	2	5	2.71	0	2	5
<b>SCC</b>	1.29	0	5	2	0	3.00	0	0	7	2.86	0	1	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**12 Auxiliary System**

**Reactor Core Isolation Cooling**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 12.1	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA105,106,234 - Carbon Steel 547°F, 1020 psia												
<b>FAT</b>	1.75	0	2	<b>6</b>	0	2.88	0	1	7	2.00	0	8	0
<b>GC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.25	0	<b>6</b>	2	0	2.13	0	<b>7</b>	1	2.13	0	<b>7</b>	1
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 12.2	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA105,106,234 - Carbon Steel Weld Metal 547°F, 1020 psia												
<b>FAT</b>	1.63	0	3	<b>5</b>	0	3.00	0	0	8	2.13	0	7	1
<b>GC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.25	0	<b>6</b>	2	0	2.13	0	<b>7</b>	1	2.13	0	<b>7</b>	1
<b>SCC</b>	1.50	0	4	<b>4</b>	0	2.63	0	3	5	2.88	0	1	7
Subgroup 12.3	Weldolets and Sockolets SA105 - Carbon Steel Base & Weld Stagnant Wet Steam - HWC not beneficial 547°F, 1020 psia												
<b>FAT</b> *	2.00	0	1	<b>6</b>	1	2.88	0	1	7	2.25	0	6	2
<b>GC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.25	0	<b>6</b>	2	0	2.13	0	<b>7</b>	1	2.13	0	<b>7</b>	1
<b>SCC</b>	1.50	0	4	<b>4</b>	0	2.75	0	2	6	2.88	0	1	7
Subgroup 12.4	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA105,106,216,234 - Carbon Steel 547°F, 1020 psia												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	3.00	0	0	8	2.13	0	7	1
<b>GC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.25	0	<b>6</b>	2	0	2.63	0	3	5	2.75	0	2	6
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.63	0	3	5	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**12 Auxiliary System**

**Reactor Core Isolation Cooling**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 12.5	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA105,106,216,234 - Carbon Steel Weld Metal 547°F, 1020 psia												
<b>CREV</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	3.00	0	0	8	2.13	0	7	1
<b>GC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
Subgroup 12.6	Valves SA216 - Carbon Steel Stagnant Steam Condensate - HWC not beneficial 250- 547°F, 1020 psia												
<b>CREV</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	2.00	0	8	0
<b>GC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 12.7	Various elbows, flanges, & pipe (base metal) Primary & secondary containment SA105,106,216,234 - Carbon Steel Stag. condensate water, typ. <100°F, 20-40 psia												
<b>CREV</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
<b>GC</b>	1.75	0	2	6	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.13	0	7	1	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**12 Auxiliary System**

**Reactor Core Isolation Cooling**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 12.8	Welds and HAZ in various elbows, flanges, & pipe Primary & secondary containment SA105,106,216,234 - Carbon Steel Weld metal Stag. condensate water, typ. <100°F, 20-40 psia												
<b>CREV</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
<b>GC</b>	1.88	0	1	7	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.13	0	7	1	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.25	0	6	2	2.88	0	1	7
Subgroup 12.9	Weldolets, Socklets and Tees SA105,106,234 - Carbon Steel Base & Weld Stagnant condensate storage water, typically <100°F, 20-40 psia												
<b>FAT</b>	1.50	0	4	4	0	2.25	1	4	3	2.00	0	8	0
<b>GC</b>	1.75	0	2	6	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.13	0	7	1	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.13	0	7	1	2.88	0	1	7
Subgroup 12.10	Valves SA216 - Carbon Steel Stagnant condensate storage water, typically <100°F, 20-40 psia												
<b>CREV</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>GC</b>	1.75	0	2	6	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.13	0	7	1	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**12 Auxiliary System**

**Reactor Core Isolation Cooling**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 12.11	Low alloy steel pump casing A516 Gr 70 Stagnant condensate storage water, typically <100°F, 20-40 psia												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	3.00	0	0	8	3.00	0	0	8
<b>GC</b>	1.75	0	2	<b>6</b>	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.13	0	<b>7</b>	1	0	2.13	0	<b>7</b>	1	2.13	0	<b>7</b>	1
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 12.12	Various elbows, flanges, & pipe (base metal) in primary & secondary containment SA105,106,216,234 - Carbon Steel Suppression pool water for cooling, typically <100°F and atmospheric pressure												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	3.00	0	0	8	3.00	0	0	8
<b>GC</b>	1.88	0	1	<b>7</b>	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	2.00	0	0	<b>8</b>	0	2.13	0	<b>7</b>	1	2.13	0	<b>7</b>	1
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.88	0	1	7	2.75	0	2	6
Subgroup 12.13	Welds and HAZ in various elbows, flanges, & pipe in primary & secondary containment SA105,106,216,234 - Carbon Steel Weld metal Suppression pool water for cooling, typically <100°F and atmospheric pressure												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	3.00	0	0	8	3.00	0	0	8
<b>GC</b>	1.88	0	1	<b>7</b>	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	2.00	0	0	<b>8</b>	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.13	0	<b>7</b>	1	2.13	0	<b>7</b>	1
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.13	0	<b>7</b>	1	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**12 Auxiliary System**

**Reactor Core Isolation Cooling**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 12.14	Weldolets and Sockolets SA105,106,234 - Carbon Steel Base & Weld Suppression pool water for cooling, typically <100°F and atmospheric pressure												
<b>FAT</b>	1.13	0	7	1	0	2.38	0	5	3	2.25	0	6	2
<b>GC</b>	1.88	0	1	7	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.88	0	1	7	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	1.88	0	1	7	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.25	0	6	2	0	2.13	0	7	1	2.75	0	2	6
Subgroup 12.15	Valves SA216 - Carbon Steel Suppression pool water for cooling, typically <100°F and atmospheric pressure												
<b>CREV</b> *	2.00	0	1	6	1	2.25	0	6	2	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8
<b>GC</b>	1.88	0	1	7	0	2.88	0	1	7	2.88	0	1	7
<b>MIC</b>	1.88	0	1	7	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	2.00	0	0	8	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	2.13	0	7	1	2.75	0	2	6
Subgroup 12.16	RCIC Strainer Flange & misc. components 304 SS Suppression pool water for cooling, typically <100°F and atmospheric pressure												
<b>CREV</b>	1.88	0	1	7	0	2.13	0	7	1	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8
<b>GC</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8
<b>MIC</b>	2.00	0	0	8	0	2.88	0	1	7	2.88	0	1	7
<b>PIT</b>	2.00	0	0	8	0	2.13	0	7	1	2.13	0	7	1
<b>SCC</b>	1.13	0	7	1	0	3.00	0	0	8	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**13 Engineered Safety Feature System**

**RHR Suction Line Piping to RHR Pumps**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 13.1	All Stainless Steel Components External Surfaces When at <150°C Normally less than 90 °F. Possible as high as 300 °F												
<b>MIC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.25	0	6	2	0	3.00	0	0	8	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	3.00	0	0	8	2.88	0	1	7
Subgroup 13.2	Straight pipes, Elbows, Tee, Valves 304 SS - Weld and Base Metal Reactor Water normally stagnant 549°F, pressure 1035 psia												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.50	0	4	4	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.63	0	3	5	2.50	0	4	4
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	3.00	0	0	8
<b>SCC-HWC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
Subgroup 13.3	Weld HAZ 304 SS HAZ Reactor Water normally stagnant 549°F, 1035 psia												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.50	0	4	4	2.63	0	3	5
<b>FR</b>	1.38	0	5	3	0	2.63	0	3	5	2.50	0	4	4
<b>SCC</b>	2.13	0	0	7	1	2.88	0	1	7	3.00	0	0	8
<b>SCC-HWC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7
Subgroup 13.4	Straight pipes, Elbows, Tee, Valves 304 SS Reactor Water normally stagnant 100-350°F, 300 psia. No HWC effect												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**13 Engineered Safety Feature System**

**RHR Suction Line Piping to RHR Pumps**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 13.5	Welds SS 308 Reactor Water normally stagnant 100-350°F, 300 psia. No HWC effect												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	2.88	0	1	7
Subgroup 13.6	Socket welds Reactor Water normally stagnant 100-350°F, 300 psia. No HWC effect												
<b>FAT</b>	1.63	0	3	5	0	2.50	0	4	4	2.50	0	4	4
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
Subgroup 13.7	All Carbon Steel Components External Surfaces When at <150°C Normally less than 90 °F. Possible as high as 300 °F												
<b>MIC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 13.8	Carbon Steel Welds & HAZ Suppression pool water 120-170°F, 20 psia flow rate 7450 gpm NWC water during operation												
<b>CREV</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.75	0	2	6	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	2.00	0	0	8	0	2.50	0	4	4	2.50	0	4	4
<b>SCC</b>	1.38	0	5	3	0	2.63	0	3	5	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**13 Engineered Safety Feature System**

**RHR Suction Line Piping to RHR Pumps**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 13.9	CS Straight pipes, Elbows, Tee, Valves SA234 Gr. WPB Suppression pool water 120-170°F, 20 psia flow rate 7450 gpm												
<b>CREV</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.75	0	2	6	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	2.00	0	0	8	0	2.50	0	4	4	2.50	0	4	4
<b>SCC</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**14 Engineered Safety Feature System**

**RHR Pump Discharge Piping to RHR HX**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 14.1	All Carbon Steel Components External Surfaces When at <150°C Normally less than 90 °F. Possible as high as 300 °F												
<b>MIC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 14.2	Pipes, Elbows, Tees, Flanges, Valves Various Carbon Steels 100°F suppression pool water, stagnant. Reactor water flow rate 7450 gpm 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6
Subgroup 14.3	Carbon Steel Weld and HAZ 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**14 Engineered Safety Feature System**

**RHR Pump Discharge Piping to RHR HX**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 14.4	Weldolet/Sockolet SA234 Gr. WPB 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.38	0	5	3	0	2.63	0	3	5	2.63	0	3	5
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
Subgroup 14.5	HX Weld in SS, or CS with 1/8" Clad/overlay 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	3.00	0	0	8
<b>GC</b>	1.50	0	4	4	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.75	0	2	6	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
Subgroup 14.6	Heat exchanger tubes and tubesheet - outside tubes CS w/outside clad of SS 100°F suppression pool water, stagnant. Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>MIC</b>	1.75	0	2	6	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**14 Engineered Safety Feature System**

**RHR Pump Discharge Piping to RHR HX**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 14.7	Heat exchanger tubes and tubesheet - inside tubes Carbon Steel Service water (treated) - 100°F												
<b>CREV</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.38	0	5	3	0	2.63	0	3	5	2.63	0	3	5
<b>MIC</b>	1.25	0	6	2	0	2.63	0	3	5	2.63	0	3	5
<b>PIT</b>	1.38	0	5	3	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 14.8	HX Fittings Carbon Steel Suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	6	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b> *	2.00	0	1	6	1	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 14.9	External heat exchanger support structure Carbon steel Secondary containment atmosphere												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**15 Engineered Safety Feature System**

**RHR Normal Shutdown Cooling Piping**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 15.1	All Carbon Steel Components External Surfaces When at <150°C Normally less than 90 °F. Possible as high as 300 °F												
<b>MIC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 15.2	Pipes, Elbows, Tees, Flanges, Valves Various Carbon Steels 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 120-170°F 275/1140 psia												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6
Subgroup 15.3	Carbon Steel Welds and HAZ 100°F suppression pool water, stagnant. Reactor water flow rate 7450 gpm, 120-170°F 275/1140 psia												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6
Subgroup 15.4	Carbon Steel - Base Metal, Welds and HAZ Reactor water, stagnant, 550°F, 1140 psia												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**15 Engineered Safety Feature System**

**RHR Normal Shutdown Cooling Piping**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 15.5	Weldolet/ Sockolet CS SA234 Gr. WPB (etc) 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 120-170°F 275/1140 psia												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.38	0	<b>5</b>	3	0	2.63	0	3	5	2.63	0	3	5
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
 X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**16 Engineered Safety Feature System**

**RHR Spray Piping**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 16.1	All Carbon Steel Components External Surfaces When at <150°C Normally less than 90 °F. Possible as high as 300 °F												
<b>MIC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 16.2	Pipes, Elbows, Tees, Flanges, Valves Various Carbon Steels - Base Metal and Weld 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6
Subgroup 16.3	Carbon Steel Weld HAZ 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**16 Engineered Safety Feature System**

**RHR Spray Piping**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 16.4	Weldolet/ Sockolet CS SA234 Gr. WPB (etc) 100°F suppression pool water, stagnant Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.38	0	5	3	0	2.75	0	2	6	2.75	0	2	6
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	2.88	0	1	7
Subgroup 16.5	Elbows, Valves Various Carbon Steels Reactor water, stagnant, 550°F												
<b>CREV</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.75	0	2	6
<b>GC</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>MIC</b>	0.50	4	4	0	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
Subgroup 16.6	Welds and HAZ associated with elbows and valves Various Carbon Steels Reactor water, stagnant, 550°F												
<b>FAT</b>	1.14	0	6	1	0	2.57	0	3	4	2.71	0	2	5
<b>SCC</b>	1.43	0	4	3	0	2.71	0	2	5	2.86	0	1	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**16 Engineered Safety Feature System**

**RHR Spray Piping**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 16.7	Spray header in containment, Tee, Reducer and Welds, Various Carbon Steels 100°F suppression pool water, stagnant. Reactor water flow rate 7450 gpm, 125-334°F, 275 psi operating once a cycle												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.75	0	2	6
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.38	0	<b>5</b>	3	0	2.75	0	2	6	2.75	0	2	6
Subgroup 16.8	Spray header in drywell Tee, Reducer and Welds Carbon Steel SA234 Gr. WPB N2 (when plant is operating) 100°F suppression pool water in operating mode												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.75	0	2	6
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 16.9	Sockolet in spray header in drywell Carbon Steel SA234 Gr. WPB N2 (when plant is operating) 100°F suppression pool water in operating mode												
<b>CREV</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.50	0	4	<b>4</b>	0	2.63	0	3	5	2.63	0	3	5
<b>GC</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	<b>7</b>	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**16 Engineered Safety Feature System**

**RHR Spray Piping**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 16.10	Socket in spray header in drywell Carbon Steel - Brass joint N2 (when plant is operating) 100°F suppression pool water in operating mode												
<b>CREV</b>	2.13	0	0	7	1	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.50	0	4	4	0	2.63	0	3	5	2.63	0	3	5
<b>GALV</b>	2.50	0	1	2	5	2.75	0	2	6	2.88	0	1	7
<b>GC</b>	1.75	0	2	6	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
Subgroup 16.11	Spray header in drywell Brass Nozzle N2 (when plant is operating) 100°F suppression pool water in operating mode												
<b>CREV</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.38	1	3	4	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 16.12	Spray header above the suppression pool Pipes, Elbows, Tees, Welds Various Carbon Steels 100°F suppression pool water												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**16 Engineered Safety Feature System**

**RHR Spray Piping**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 16.13	Sokolet spray header above the suppression pool Carbon Steel SA234 Gr. WPB N2 (when plant is operating) 100°F suppression pool water in operating mode												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.38	0	5	3	0	2.63	0	3	5	2.63	0	3	5
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
Subgroup 16.14	Sokolet spray header above the suppression pool Carbon Steel - Brass joint (drywell) N2 (when plant is operating) 100F suppression pool water when spraying												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.38	0	5	3	0	2.63	0	3	5	2.63	0	3	5
<b>GALV</b>	2.50	0	1	2	5	2.75	0	2	6	2.88	0	1	7
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
Subgroup 16.15	Spray header above the suppression pool Nozzle Drywell N2 (when plant is operating) 100°F suppression pool water in operating mode												
<b>CREV</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>GC</b>	1.63	0	3	5	0	2.75	0	2	6	2.75	0	2	6
<b>MIC</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>PIT</b>	1.88	0	1	7	0	2.75	0	2	6	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**17 Steam and Power Conversion System**

**Main Steam**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 17.1	All carbon and low-alloy steel components External surfaces (normally dry) <547°F No effect of HWC here												
<b>FAT</b>	1.75	0	2	<b>6</b>	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	0.88	1	<b>7</b>	0	0	2.88	0	1	7	3.00	0	0	8
<b>SCC</b>	0.25	<b>6</b>	2	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 17.2	Main steam carbon steel seam or seamless pipes, forgings, castings, fittings and weldments A106B, A234, A105, A216, A672B70 High flow rate saturated steam (<0.25% moisture) 547°F, 1020 psia												
<b>EC</b>	1.86	0	1	<b>6</b>	0	2.86	0	1	6	3.00	0	0	7
<b>FAC</b>	1.88	0	1	<b>7</b>	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.88	0	1	7	2.88	0	1	7
Subgroup 17.3	SRV and discharge lines, seamless carbon steel pipes, forgings, fittings, flanges A234, A106, A105 No effect of HWC here												
<b>FAT</b> *	1.00	1	<b>6</b>	1	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 17.4	Weldolet pipe/weld/flange A234, A106, A105 Saturated steam (<0.25% moisture) in dead leg 547°F, 1020 psia No effect of HWC here												
<b>FAT</b>	2.00	0	0	<b>8</b>	0	2.13	0	7	1	2.00	0	8	0
<b>SCC</b>	1.88	0	1	<b>7</b>	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**17 Steam and Power Conversion System**

**Main Steam**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 17.5	Low alloy steel bolts for tee quencher/sparger, A540 B21 (Hatch 2) Immersed in suppression pool water possibly with Zn primer Normally <90°F No effect of HWC here												
<b>CREV</b> X	1.38	0	6	1	1	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.13	0	7	1	2.13	0	7	1
<b>PIT</b>	2.13	0	0	7	1	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	2.75	0	0	2	6	2.75	0	2	6	2.00	0	8	0
Subgroup 17.6	SRV discharge line in suppression pool and tee quencher/sparger Austenitic stainless steel plus bimetallic joint above water level When SRVs open, steam is 547°F, 1020 psia												
<b>CREV</b>	1.75	0	2	6	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	0.88	1	7	0	0	2.13	0	7	1	2.13	0	7	1
<b>PIT</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b> *	1.00	1	6	1	0	2.88	0	1	7	2.88	0	1	7
Subgroup 17.7	CASS, A351 Type 304, Venturi flow restrictor in steam line to limit flow to 200% if failure High flow rate saturated steam (<0.25% moisture) at 100% power 547°F, 1020 psia												
<b>EC</b>	1.00	0	8	0	0	2.75	0	2	6	2.75	0	2	6
<b>FAT</b>	1.13	1	5	2	0	2.00	0	8	0	2.00	0	8	0
<b>FR</b>	1.88	0	1	7	0	2.63	0	3	5	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**18 Engineered Safety Feature System**

**Cycled Condensate Storage Tank**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 18.1	Various plates, pipes, angles, shells, flanges, nozzles, vents, columns, gussets 6061-T6 & other Al alloys 100°F demineralized water, aerated												
<b>CREV</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.00	0	8	0	0	2.88	0	1	7	3.00	0	0	8
Subgroup 18.2	Various plates, pipes, angles, shells, flanges, nozzles, vents, columns, gussets Stainless steel (OTHER PLANT) 100°F demineralized water, aerated												
<b>CREV</b> *	1.00	1	5	1	0	2.86	0	1	6	2.86	0	1	6
<b>FAT</b>	1.00	0	7	0	0	3.00	0	0	7	3.00	0	0	7
<b>PIT</b>	0.86	1	6	0	0	2.86	0	1	6	2.86	0	1	6
<b>SCC</b>	0.86	1	6	0	0	3.00	0	0	7	3.00	0	0	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**19 Steam and Power Conversion System**

**Feedwater**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 19.1	Various plates, heads, pipes, baffles, manway, tube sheet, supports SA105,A106,SA216,A234,A672 - Carbon steels - Base, Weld and HAZ 368-427F BWR water + >30 ppb O2 for FAC												
<b>FAC</b>	1.14	0	6	1	0	2.86	0	1	6	3.00	0	0	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
Subgroup 19.2	Valves Carbon Steel - Base, Weld and HAZ 368-427F BWR water + >30 ppb O2 for FAC HWC not relevant to most feedwater												
<b>FAC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	3.00	0	0	8
<b>PIT</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	3.00	0	0	8
Subgroup 19.3	Weldolet Carbon Steel - base, weld and HAZ 368-427F BWR water + >30 ppb O2 for FAC HWC not relevant to most feedwater												
<b>FAC</b>	1.13	0	7	1	0	2.88	0	1	7	2.88	0	1	7
<b>FAT</b>	1.50	0	4	4	0	2.63	0	3	5	2.63	0	3	5
<b>PIT</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	3.00	0	0	8
Subgroup 19.4	Heater Pipes and Flow Elements 304 SS 368-427F BWR water + >30 ppb O2 for FAC HWC not relevant to most feedwater												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**20 Auxiliary System**

**Control Rod Drive**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 20.1	All Stainless Steel Components External Surfaces When at <150°C Normally Dry When at Low Temp HWC not relevant to CRD drive water												
<b>PIT</b>	1.00	0	8	0	0	3.00	0	0	8	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	2.88	0	1	7
Subgroup 20.2	Pipes, Elbows, Tees and Wyes SS Type 304 Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8
Subgroup 20.3	308 SS Welds and HAZ Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.13	0	7	1	0	3.00	0	0	8	3.00	0	0	8
Subgroup 20.4	Valves Cast SS CF8 Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	0.88	1	7	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.63	0	3	5
Subgroup 20.5	Flange SS Type 316 Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	0.88	1	7	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**20 Auxiliary System**

**Control Rod Drive**

	Susceptibility					Confidence				Knowledge			
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 20.6	Pump outlet Filter Shells CS A 515, etc, unclad Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	0.88	1	7	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 20.7	Welds Carbon Steel Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 20.8	Valves Cast SS CF8 Deoxygenated Reactor Water stagnant 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	0.88	1	7	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	0.88	1	7	0	0	2.88	0	1	7	2.75	0	2	6
Subgroup 20.9	Welds SS 308 Deoxygenated Reactor Water stagnant 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	0.88	1	7	0	0	2.88	0	1	7	2.75	0	2	6
Subgroup 20.10	Tee SS Type 304 Deoxygenated Reactor Water stagnant 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.00	0	8	0	0	3.00	0	0	8	3.00	0	0	8

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**20 Auxiliary System**

**Control Rod Drive**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 20.11	Nozzles Cast CS Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b> *	1.00	1	6	1	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	0.88	1	7	0	0	3.00	0	0	8	2.88	0	1	7
Subgroup 20.12	Pump Casing Cast CS Deoxygenated Reactor Water 107°F, 1275 psia HWC not relevant to CRD drive water												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.88	0	1	7	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**21 Steam and Power Conversion System**

**Main Condenser**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 21.1	Various plates, heads, pipes, baffles, manway, tube sheet, supports, shell Carbon Steel - Base, Weld and HAZ 100-165°F BWR water HWC not relevant to condensate												
<b>FAC</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 21.2	Drainpipes Carbon Steel - Base, Weld and HAZ 330-475°F BWR water HWC not relevant to condensate												
<b>FAC</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>GC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>PIT</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
Subgroup 21.3	Condenser Tubes (40,462 tubes), 1" OD and Baffle Plates Stainless Steel, outside of tube 330-475°F BWR water on outside HWC not relevant to condensate												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 21.4	Condenser Tubes (40,462 tubes), 1" OD Stainless Steel, inside of tube Circulating water (treated or sea/lake/pond) HWC not relevant to condensate												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**21 Steam and Power Conversion System**

**Main Condenser**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 21.5		Condenser Tubes (other plants with Ti)											
		Titanium tubes, inside of tube (tubesheet other than Ti)											
		Sea water cooling											
<b>EC</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
<b>GALV</b>	1.63	0	3	5	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	0.88	1	7	0	0	2.88	0	1	7	3.00	0	0	8
Subgroup 21.6		Condenser Tubes (other plants with Ti)											
		Titanium tubes, outside of tube											
		Wet steam											
<b>EC</b> *	1.88	0	2	5	1	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
 X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**22 Steam and Power Conversion System**

**Main Condenser Discharge Piping**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 22.1	Various pipes, elbows, reducers, tees, flanges, nozzles, etc. SA105,A106,SA106,A234,A672,SA216 - Carbon steels - base, weld and HAZ 121°F BWR water, >>30 ppb O2 HWC not relevant here												
<b>FAC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 22.2	Weldolet A234 Carbon Steel - Base, Weld and HAZ 121°F BWR water, >>30 ppb O2 HWC not relevant here												
<b>FAC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.75	0	2	6	0	2.63	0	3	5	2.63	0	3	5
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 22.3	Valves A105,A216 Carbon Steel - Base, Weld and HAZ 121°F BWR water, >>30 ppb O2 HWC not relevant here												
<b>FAC</b> *	1.00	1	6	1	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 22.4	Pump Carbon Steel - Base, Weld and HAZ 121°F BWR water, >>30 ppb O2 HWC not relevant here												
<b>FAC</b>	1.13	1	5	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.63	0	3	5	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**22 Steam and Power Conversion System**

**Main Condenser Discharge Piping**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 22.5	Ejector Body & Nozzle Carbon Steel - Base, Weld and HAZ 121°F BWR water, >>30 ppb O2 HWC not relevant here												
<b>FAC</b>	1.13	1	<b>5</b>	2	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.63	0	3	<b>5</b>	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 22.6	Flow Restrictor Stainless Steel 121°F BWR water, >>30 ppb O2 HWC not relevant here												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**23 Steam and Power Conversion System**

**Condensate Piping to Booster Pump**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 23.1	Various pipes, elbows, reducers, tees, flanges, nozzles, etc. SA105,A106,SA216,A234,A672 - Carbon steels - Base, Weld and HAZ 124°F BWR water (probably low O2) HWC not relevant here												
<b>FAC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 23.2	Socket SA106,SA216,A234,A672 carbon steel - base, weld and HAZ 124°F BWR water (probably low O2) HWC not relevant here												
<b>FAC</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.50	0	4	4	0	2.63	0	3	5	2.75	0	2	6
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 23.3	Valves SA105,SA216,A672 carbon steel - base, weld and HAZ 124°F BWR water (probably low O2) HWC not relevant here												
<b>FAC</b>	1.38	0	5	3	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	3.00	0	0	8
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**24 Steam and Power Conversion System**

**Condensate Piping to FW Pump**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 24.1	Various pipes, elbows, reducers, tees, flanges, nozzles, wye, etc. SA105,A106,SA216,A234,A672 - Carbon steels - base, weld and HAZ 124°F BWR water (probably low O2)												
<b>FAC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 24.2	Various pipes, elbows, reducers, tees, flanges, nozzles, wye, etc. SA105,A106,SA216,A234,A672 - Carbon steels - base, weld and HAZ 124-370°F BWR water (probably low O2) HWC not relevant here												
<b>FAC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 24.3	Sockolet SA106,SA216,A234,A672 carbon steel - base, weld and HAZ 365°F BWR water (probably low O2) HWC not relevant here												
<b>FAC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.88	0	1	7	0	2.63	0	3	5	2.63	0	3	5
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 24.4	Valves SA105,SA216,A672 carbon steel - base, weld and HAZ 124-370°F BWR water (probably low O2) HWC not relevant here												
<b>FAC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**24 Steam and Power Conversion System**

**Condensate Piping to FW Pump**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 24.5		Pump Carbon Steel - Base, Weld and HAZ 365°F BWR water (probably low O2) HWC not relevant here											
<b>FAC</b>	1.50	0	4	4	0	2.75	0	2	6	2.88	0	1	7
<b>FAT</b>	1.25	0	6	2	0	2.75	0	2	6	3.00	0	0	8
<b>PIT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 24.6		Heater Tubes 304 SS 124-370°F BWR water (probably low O2) HWC not relevant here											
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	3.00	0	0	8	3.00	0	0	8

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**25 Support System**

**Reactor Water Cleanup Piping to Pumps**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 25.1	Various elbows, reducers and pipe (base metal) SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.50	0	4	4	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 25.2	Welds and HAZ in various elbows, reducers and pipe SA105,106,216,234 - Carbon Steel Weld & HAZ 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.50	0	4	4	2.75	0	2	6
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 25.3	Various elbows, reducers and pipe (base metal) 304 Stainless Steel 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 25.4	Various elbows, reducers and pipe (weld metal) 304 Stainless Steel - Weld Metal 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
<b>FR</b>	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**25 Support System**

**Reactor Water Cleanup Piping to Pumps**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 25.5	Various elbows, reducers and pipe (HAZ) 304 Stainless Steel - HAZ 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.50	0	4	4	0	2.50	0	4	4	2.63	0	3	5
<b>FR</b>	1.25	0	6	2	0	2.38	1	3	4	2.25	1	4	3
<b>SCC</b>	2.25	0	0	6	2	2.75	0	2	6	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 25.6	Weldolets and Sockolets SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	2.00	0	0	8	0	2.50	0	4	4	2.50	0	4	4
<b>FAT-HWC</b>	1.63	0	3	5	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 25.7	Weldolets and Sockolets 304 Stainless Steel - Base, Weld & HAZ 535°F BWR water												
<b>FAT</b>	2.00	0	0	8	0	2.63	0	3	5	2.63	0	3	5
<b>FAT-HWC</b>	1.75	0	2	6	0	2.75	0	2	6	2.63	0	3	5
<b>FR</b>	1.13	0	7	1	0	2.38	1	3	4	2.25	1	4	3
<b>SCC</b>	2.38	0	0	5	3	2.88	0	1	7	2.88	0	1	7
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 25.8	Valves SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b> X	1.38	0	6	1	1	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**25 Support System**

**Reactor Water Cleanup Piping to Pumps**

	Susceptibility				Confidence				Knowledge				
	Average	0	1	2	3	Average	1	2	3	Average	1	2	3
Subgroup 25.9	HPCS Pump Parts A106,A516 Carbon & Low Alloy Steels 535°F BWR water												
<b>FAT</b>	1.25	0	<b>6</b>	2	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	<b>6</b>	2	0	2.50	0	4	4	2.75	0	2	6
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
 X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**26 Support System**

**Reactor Water Cleanup Piping to R/NR HXs**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 26.1	Various elbows, flanges and pipe (base metal) SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.50	0	4	4	2.75	0	2	6
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.2	Welds and HAZ in various elbows, flanges and pipe SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.13	0	7	1	0	2.50	0	4	4	2.75	0	2	6
<b>SCC</b>	1.38	0	5	3	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.3	Socket - base, weld and HAZ SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	2.00	0	0	8	0	2.63	0	3	5	2.63	0	3	5
<b>FAT-HWC</b>	1.50	0	4	4	0	2.63	0	3	5	2.63	0	3	5
<b>SCC</b> X	1.38	0	6	1	1	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.4	Valves SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b> X	1.38	0	6	1	1	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**26 Support System**

**Reactor Water Cleanup Piping to R/NR HXs**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 26.5	HX Nozzle SA105,106,216,234 - Carbon Steel 435-535°F BWR water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.50	0	4	4	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b> X	1.50	0	5	2	1	2.75	0	2	6	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.6	HX Nozzle 304 Stainless Steel (assume welds annealed) 535°F BWR water												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
<b>FR</b>	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
<b>SCC</b> X	1.38	0	6	1	1	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.7	Regenerative heat exchanger head and shell 304 stainless steel (assume welds annealed) 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
<b>FR</b>	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.8	Regenerative heat exchanger tubesheet 304 Stainless Steel (assume welds annealed) 535°F BWR water												
<b>FAT</b>	1.25	0	6	2	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.38	0	5	3	0	2.50	0	4	4	2.63	0	3	5
<b>FR</b>	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
<b>SCC</b>	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
<b>SCC-HWC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**26 Support System**

**Reactor Water Cleanup Piping to R/NR HXs**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 26.9	Regenerative heat exchanger tubes 304 Stainless Steel (assume welds annealed) 535°F BWR water												
FAT	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
FAT-HWC	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
FR	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
SCC	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
SCC-HWC	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.10	Regenerative heat exchanger baffles 304 Stainless Steel 535°F BWR water												
FAT	1.25	0	6	2	0	2.63	0	3	5	2.88	0	1	7
FAT-HWC	1.38	0	5	3	0	2.50	0	4	4	2.63	0	3	5
FR	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
SCC	1.13	0	7	1	0	2.88	0	1	7	2.75	0	2	6
SCC-HWC	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.11	Non-regenerative heat exchanger baffles and fittings SA105,106,216,234 - Carbon Steel 535°F BWR water												
FAT	1.25	0	6	2	0	2.63	0	3	5	2.75	0	2	6
FAT-HWC	1.38	0	5	3	0	2.63	0	3	5	2.88	0	1	7
SCC X	1.38	0	6	1	1	2.75	0	2	6	2.75	0	2	6
SCC-HWC	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.12	Regenerative heat exchanger internal piping 304 Stainless Steel (assume welds annealed) 535°F BWR water												
FAT	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
FAT-HWC	1.25	0	6	2	0	2.50	0	4	4	2.63	0	3	5
FR	1.00	0	8	0	0	2.50	1	2	5	2.38	1	3	4
SCC	1.25	0	6	2	0	2.88	0	1	7	2.75	0	2	6
SCC-HWC	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**26 Support System**

**Reactor Water Cleanup Piping to R/NR HXs**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 26.13	Non-regenerative heat exchanger internal piping SA105,106,216,234 - Carbon Steel 535°F BWR water												
<b>FAT</b>	1.13	0	7	1	0	2.63	0	3	5	2.88	0	1	7
<b>FAT-HWC</b>	1.25	0	6	2	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
<b>SCC-HWC</b>	1.25	0	6	2	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.14	Various components in lower temp water SA105,106,216,234 - Carbon Steel 120-235°F BWR water. No HWC benefit here.												
<b>FAT</b>	1.13	0	7	1	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 26.15	Various components in lower temp water 304 Stainless Steel (welds assume annealed) 235°F BWR water. No HWC benefit here.												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.13	0	7	1	0	2.88	0	1	7	3.00	0	0	8

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**27 Support System**

**Reactor Water Cleanup Piping to/from Filters**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 27.1	Nozzle 304 Stainless Steel and Weld Metal 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 27.2	Nozzle 304 Stainless Steel HAZ 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>FR</b>	1.00	0	8	0	0	2.63	1	1	6	2.00	1	6	1
<b>SCC</b>	1.00	0	8	0	0	2.88	0	1	7	2.88	0	1	7
Subgroup 27.3	Pipe, elbow, tee, etc. SA106,216,234 - Carbon Steel Base, Weld, HAZ 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.00	0	8	0	0	2.63	0	3	5	2.88	0	1	7
<b>SCC</b>	1.00	0	8	0	0	2.75	0	2	6	2.88	0	1	7
Subgroup 27.4	Valves SA216 - Carbon Steel 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.00	0	8	0	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.13	0	7	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 27.5	Socketlet 304 Stainless Steel - Base, Weld and HAZ 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.50	0	4	4	0	2.75	0	2	6	2.75	0	2	6
<b>FR</b>	1.00	0	8	0	0	2.63	1	1	6	2.38	1	3	4
<b>SCC</b>	1.50	0	4	4	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.

**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**27 Support System**

**Reactor Water Cleanup Piping to/from Filters**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 27.6	Filter nozzles - inlet and outlet 304 Stainless Steel - Base, Weld and HAZ 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>FR</b>	1.00	0	<b>8</b>	0	0	2.63	1	1	6	2.38	1	3	4
<b>SCC</b>	1.50	0	4	<b>4</b>	0	2.88	0	1	7	2.88	0	1	7
Subgroup 27.7	Filter nozzles - inlet and outlet SA106 - Carbon Steel 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
Subgroup 27.8	Filter demin shell, nozzle, fittings.... Stainless Steel - Base, Weld and HAZ 120°F BWR water. HWC not relevant.												
<b>FAT</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	3.00	0	0	8
<b>FR</b>	1.00	0	<b>8</b>	0	0	2.63	1	1	6	2.38	1	3	4
<b>SCC</b>	1.13	0	<b>7</b>	1	0	2.88	0	1	7	2.88	0	1	7

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.



**PMDA FOR BOILING WATER REACTOR COMPONENTS**

**28 Support System**

**Reactor Water Cleanup Piping to Feedwater**

	Average	Susceptibility				Average	Confidence			Average	Knowledge		
		0	1	2	3		1	2	3		1	2	3
Subgroup 28.1	Nozzle SA105 - Carbon Steel 435°F BWR water												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 28.2	Piping, elbows, reducing tee, flange... SA106,216,234 - Carbon Steel 435°F BWR water												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 28.3	Valves SA216 - Carbon Steel 435°F BWR water												
<b>FAT</b>	1.00	0	<b>8</b>	0	0	2.75	0	2	6	3.00	0	0	8
<b>FAT-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.88	0	1	7
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.75	0	2	6
Subgroup 28.4	Weldolet SA234 - Carbon Steel 435°F BWR water												
<b>FAT</b>	1.63	0	3	<b>5</b>	0	2.63	0	3	5	2.63	0	3	5
<b>FAT-HWC</b>	1.75	0	2	<b>6</b>	0	2.88	0	1	7	2.75	0	2	6
<b>SCC</b>	1.25	0	<b>6</b>	2	0	2.75	0	2	6	2.63	0	3	5
<b>SCC-HWC</b>	1.13	0	<b>7</b>	1	0	2.75	0	2	6	2.75	0	2	6

\* Susceptibility at interface between colors with one or more scores higher than this interface.  
X Susceptibility inside color box with one or more scores higher than this color box upper interface.