

March 27, 2007  
L-07-052

Department of Environmental Protection  
Bureau of Water Quality Management  
Attention: DMR Clerk  
400 Waterfront Drive  
Pittsburgh, PA 15222

**Beaver Valley Power Station Discharge Monitoring Report (NPDES) Permit No. PA0025615**

To Whom It May Concern:

Enclosed is the February 2007 NPDES Discharge Monitoring Report (DMR) for FirstEnergy Nuclear Operating Company (FENOC), Beaver Valley Power Station, in accordance with the requirements of the Permit. Attachment 1 to this letter is supplemental monitoring data for Outfall 001 (dissolved oxygen). Review of the data indicates one Permit parameter was exceeded during the month on two (2) separate occasions.

The first occurred on February 7, 2007, when total residual chlorine at the Unit 1 Sewage Treatment Plant (STP) - Internal Monitoring Point 203 was determined to be 4.1 mg/L thus exceeding the Permit limit of 3.3 mg/L instantaneous maximum. The second occurred on February 12, 2007 when the total residual chlorine was determined to be 61.5 mg/L thus exceeding the Permit limit again. Because the plant was taken out of service due to freezing, there was no opportunity to recover, thus, the monthly average limit was also exceeded. Attachment 2 to this letter provides the description of the occurrence and corrective action taken.

Included with the report this month are two Supplemental Laboratory Accreditation Forms for analyses performed to support permit requirements as required by 25 Pa. Code § 252.

Should you have any questions regarding the attached and enclosed documents, please direct them to Mr. Michael Banko, at 724-682-4117.

Sincerely,



Peter P. Sena  
Director, Site Operations

Attachments (2)  
Enclosures (2)

cc: Document Control Desk US NRC (NOTE: No new US NRC commitments are contained in this letter.)  
US Environmental Protection Agency  
Central File: **Keyword- DMR**

TE25

**ATTACHMENT 1**

**Weekly Dissolved Oxygen Monitoring Results at Outfall 001**

The following supplemental dissolved oxygen monitoring data for Outfall 001 is provided as agreed.

<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>VALUE</b>	<b>UNITS</b>
01/30/07	1010	8.31	mg/L
02/05/07	1010	8.43	mg/L
02/12/07	1020	8.53	mg/L
02/19/07	1000	8.74	mg/L
02/27/07	0835	9.01	mg/L

Attachment 1 END

## ATTACHMENT 2

### Total Residual Chlorine Exceedance at Internal Monitoring Point 203

On February 7, 2007, the Unit 1 Sewage Treatment Plant (STP) effluent was sampled and analyzed for compliance with the effluent monitoring requirements for NPDES Internal Monitoring Point 203. The total residual chlorine (TRC) result obtained was determined to be 4.10 mg/L. The plant was not in-service at this time due to freezing. It is estimated that a total of 25 gallons was discharged at this concentration. This concentration exceeded the NPDES instantaneous maximum effluent limit of 3.3 mg/L. On February 12, 2007 the effluent was again sampled and the TRC result was determined to be 61.5 mg/L. Approximately 6 gallons was discharged at this concentration (determined to be due to thawing after restoration of heat-trace). Because the plant was not restored before the end of the month, the Monthly Average limit of 1.4 mg/L was, therefore, exceeded as well.

The condition is investigated and documented under the FENOC Problem Identification and Resolution program under Condition Report CR-07-14148. The first high result obtained on February 7, 2007 was caused by hypochlorite tablets dissolving upon restoration of the heat trace. Because the plant was shutdown, there was no flow through the plant. The hypochlorite tablets normally consumed by normal flow (approximately 10,000 gpd) were dissolved in a much smaller volume of water, essentially the volume of the chlorine contact tank, aided by heat from the restored heat trace. The second high result obtained on February 12, 2007 occurred due to the same reason. Discharge flow was initiated from ice in the system melting. Upon discovery, the effluent pathway was isolated to prevent anymore discharge from the plant.

Some contributing factors included:

- Hypochlorite tablets being added to the plant with no process flow.
- The heat trace was found non-operational because the readiness plan was less than adequate to ensure proper verification and monitoring of the STP to ensure components were operating as designed.
- Hypochlorite tablets were added to a non-operational plant because work direction, specifically pre-job briefing, was less than adequate. The current chemistry EPA pre-job brief card specifically addresses the amount of chlorine to be added to the STP and is not adequately utilized during weekends.

Corrective actions will include a review of the NPDES winter readiness plan and review of the weekend pre job briefing practices. Based on that review, the procedures will be modified/revised as necessary. These actions will be implemented prior to the next winter season.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

001A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
UNITS 1&2 COOLG. TOWER BLWDN  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.22	N/A	8.54	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO/AVG	Req. Mon. DAILY/MX.	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	**
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO/AVG	0 DAILY/MX.	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	22.2	31.4	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO/AVG	Req. Mon. DAILY/MX.	Mgal/d	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02***	<0.02***	mg/L	0	10 / 28	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 AVERAGE	1.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.001	0.02	mg/L	0	CONT****	RCRD
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO/AVG	0 DAILY/MX.	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
TYPED OR PRINTED			724	682-7773	07	03	27
			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here) *\* Not in wet layup this period.*  
HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX.

\*\* No clamicide this period. \*\*\*0.02 mg/L is minimum detectable level. \*\*\*\* No Chlorination on 2/5 and 2/6 due to frozen chlorination lines. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

002A
<b>DISCHARGE NUMBER</b>

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
INTAKE SCREEN BACKWASH  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.006	0.046	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req: Mon. MO AVG	Req: Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>		<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>
	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>					

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 30

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

003A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
003  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.042	0.092	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

004A  
**DISCHARGE NUMBER**


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT ONE COOLG TOWER OVERFLOW  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX		*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

006A  
**DISCHARGE NUMBER**


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
AUX. INTAKE SCREEN BACKWASH  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX		*****	*****	*****			Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

007A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
AUX. INTAKE SYSTEM  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****			Weekly	GRAB
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available 50064 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	.2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

008A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
UNIT 1 COOLING TOWER PUMPHOUSE  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.70	N/A	7.94	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	19.1	21.0	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	30 MO:AVG	100 DAILY:MX	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5*	<5*	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO:AVG	20 DAILY:MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon MO:AVG	Req. Mon DAILY:MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
TYPED OR PRINTED			724	682-7773	07	03	27
COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)			AREA Code	NUMBER	YEAR	MO	DAY

\* <5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

010A
<b>DISCHARGE NUMBER</b>


**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 2 COOLING WATER  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.85	N/A	7.65	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER 04251 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	3.11	4.03	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	N/A	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02 **	<0.02 **	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	.5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available 50064 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02 **	<0.02 **	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	.2 AVERAGE	.5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			724	682-7773	07	03	27
			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

\* No clamicide this period. \*\*0.02 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 36

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

011A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
DIESEL GEN & TURBINE DRAINS  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 37

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

012A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
BLOWDOWN FROM THE HVAC UNIT  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.75	N/A	7.97	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Once Per Month	GRAB
Copper, total (as Cu) 01042 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.085	0.135	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn) 01092 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.230	0.408	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	1:5 MO AVG	1:5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 28	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved 70295 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	486	508	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

013A  
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
OUTFALL 013  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.99	N/A	7.36	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Cyanide, total (as CN) 00720 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01*	<0.01*	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu) 01042 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.017	0.025	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	.05 MO AVG	1 DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene 34301 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005**	<0.005**	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.009	0.011	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
TYPED OR PRINTED			724 682-7773	07	03	27	
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.  
\* 0.01 mg/L is minimum detectable level. \*\* 0.005 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

101A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
101 CHEMICAL WASTE TREATMENT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.55	N/A	8.07	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	1.0	6.8	mg/L	0	7 / 28	2 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO:AVG	100 DAILY:MX	mg/L		Weekly	COMP-2
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	7 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO:AVG	20 DAILY:MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N) 00610 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO:AVG	Req. Mon. DAILY:MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.011	0.013	MGD	N/A	N/A	N/A	N/A	0	DAILY	CONT
	PERMIT REQUIREMENT	Req. Mon. MO:AVG	Req. Mon. DAILY:MX	Mgal/d	*****	*****	*****	N/A		DAILY	CONTIN
Hydrazine 81313 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO:AVG	Req. Mon. DAILY:MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER. \*5 mg/L is minimum detectable level. \*\* Not in wet layup this period. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

102A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
**MAJOR (SUBR05)**  
102 INTAKE SCREEN HOUSE  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.60	N/A	7.69	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	5.0	5.5	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>			<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

\*5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

103A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
**MAJOR (SUBR05)**  
SLUDGE SETTLING BASIN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.24	N/A	7.50	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4*	<4*	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO/AVG	100 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
	PERMIT REQUIREMENT	Reg Mon. MO/AVG	Reg Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
 SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.  
 \*4 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

111A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
111 DIESEL GENERATOR BLDG  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	FROM	07	02	28
			TO			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.95	N/A	7.60	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

113A
<b>DISCHARGE NUMBER</b>


**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 2 SEWAGE TMT PLANT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.19	N/A	8.00	pH	0	4 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	10.5	11.6	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO.AVG	60 DAILY.MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.006	0.008	MGD	N/A	N/A	N/A	N/A	-	10 / 28	MEAS
	PERMIT REQUIREMENT	.043 MO.AVG	Req. Mon DAILY/MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.56	0.72	mg/L	0	9 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.4 MO.AVG	3.3 INST.MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general 74055 1 1 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	5	N/A	#/100mL	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	2000 MO.GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	7.5	9	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	25 MO.AVG	50 DAILY.MX	mg/L		Twice Per Month	COMP-8

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

203A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
MAIN SEWAGE TMT PLANT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.50	N/A	7.60	pH	0	3 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	22.9	23.0	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.0010	0.0018	MGD	N/A	N/A	N/A	N/A	-	6 * / 28	MEAS
	PERMIT REQUIREMENT	023 MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	11.37**	61.5**	mg/L	3	6 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	1/4 MO AVG	3/3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general 74055 1 1 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	25	N/A	#/100mL	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	2000 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	8.8	11.0	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

\* Plant was inoperable from 2/5/07 through 2/20/07 due to extreme low temperatures. \*\* See Attachment two for description of this event. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 45

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

211A
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
**MAJOR (SUBR05)**  
211 TURBINE BLDG  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.82	N/A	7.48	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO.AVG	100 DAILY.MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO.AVG	20 DAILY.MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO.AVG	Req. Mon. DAILY.MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>			<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

213A
<b>DISCHARGE NUMBER</b>

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 COOL TOWER PUMPHOUSE  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	.5 MO AVG	125 INST MAX	mg/L		Twice Per Month	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

301A  
DISCHARGE NUMBER


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 AUX BOILER BLOWDOWN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 28	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 28	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

303A
<b>DISCHARGE NUMBER</b>

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 1 OIL WATER SEPARATOR  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.57	N/A	7.36	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	10.1	23.0	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	1.7	8.3	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.019	0.056	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27	
<b>TYPED OR PRINTED</b>		<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>		<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE OIL WATER SEPARATOR PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

313A
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
313 TURBINE BLDG DRAIN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.75	N/A	7.22	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	12.3	27.0	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO/AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO/AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO/AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27	
<b>TYPED OR PRINTED</b>		<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>		<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #21 PRIOR TO MIXING WITH ANY OTHER WATER.  
\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 50

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

401A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
CHEM.FEED AREA OF AUX BOILERS  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	FROM	07	02	28
			TO			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.21	N/A	8.54	pH	0	2 / 28	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	Req. Mon. MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 28	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 28	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

403A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N) 00610 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER 04251 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			724	682-7773	07	03	27
			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

403A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	FROM	07	02	28
			TO			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 10 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO:AVG	0 DAILY:MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724 682-7773		07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

413A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
BULK FUEL STORAGE DRAIN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.05	N/A	7.09	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	27.4	49.0	mg/L	0	3 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

\* 5 mg/L is minimum detectable level. Discharge occurred weeks of 2/18/07 & 2/25/07. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

501A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 1 GENRTR BLWDWN FILT BW  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	FROM	07	02	28
			TO			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.

**DISCHARGE MONITORING REPORT SUPPLEMENTAL SEWAGE SLUDGE REPORT**

**Instructions:**

1. Complete monthly and submit with each DMR. Attach additional sheets and comments as needed for completeness and clarity.
2. Sludge production information will be used to evaluate plant performance. Report only sludge which has been removed from digesters and other solids which have been permanently removed from the treatment process. Do not include sludge from other plants which is processed at your facility.
3. In the disposal site section, report all sludge leaving your facility for disposal. If another plant processes and disposes of your sludge, just provide the name of that plant. If you dispose of sludge from other plants, include their tonnage in the disposal site section and provide their names and individual dry tonnage on the back of this form.
4. If no sludge was removed, note on form.

Month: February  
 Year: 2007  
 Permittee: FENOC  
 Plant: Beaver Valley Power Station  
 NPDES: PA0025615  
 Municipality: Shippingport Borough  
 County: Beaver

**Unit 1**

For sludge that is incinerated:  
 Pre-incineration weight = \_\_\_\_\_ dry tons  
 Post-incineration weight = \_\_\_\_\_ dry tons

**SLUDGE PRODUCTION INFORMATION (prior to incineration)**

HAULED AS LIQUID SLUDGE				HAULED AS DEWATERED SLUDGE											
(Gallons)	X	(% Solids)	X	(Conversion Factor)	=	Dry Tons	(Tons of Dewater Sludge)	X	(% Solids)	X	(.01)	=	Dry Tons		
6000		2.0		.0000417		0.50					.01				
TOTAL						=	0.50	TOTAL						=	

**DISPOSAL SITE INFORMATION:** List all sites, even if not used this month.

	Site 1	Site 2	Site 3	Site 4
Name:	Borough of Monaca Sewage Treatment Plant	Hopewell Township		
Permit No.	PA0020125	PA0026328		
Dry Tons Disposed:				
Type: (check one)				
Landfill				
Agr. Utilization				
Other (specify)				
County:	Beaver	Beaver		

(SSR-1 3/21/91)      Donald J. Salera      Chemistry Manager      3-2707      (724) 682-4141  
 Signature      Title      Date      Telephone

**DISHARGE MONITORING REPORT SUPPLEMENTAL SEWAGE SLUDGE REPORT**

**Instructions:**

1. Complete monthly and submit with each DMR. Attach additional sheets and comments as needed for completeness and clarity.
2. Sludge production information will be used to evaluate plant performance. Report only sludge which has been removed from digesters and other solids which have been permanently removed from the treatment process. Do not include sludge from other plants which is processed at your facility.
3. In the disposal site section, report all sludge leaving your facility for disposal. If another plant processes and disposes of your sludge, just provide the name of that plant. If you dispose of sludge from other plants, include their tonnage in the disposal site section and provide their names and individual dry tonnage on the back of this form.
4. If no sludge was removed, note on form.

Month: February  
 Year: 2007  
 Permittee: FENOC  
 Plant: Beaver Valley Power Station  
 NPDES: PA0025615  
 Municipality: Shippingport Borough  
 County: Beaver

**Unit 2**

For sludge that is incinerated:  
 Pre-incineration weight = \_\_\_\_\_ dry tons  
 Post-incineration weight = \_\_\_\_\_ dry tons

**SLUDGE PRODUCTION INFORMATION (prior to incineration)**

HAULED AS LIQUID SLUDGE				HAULED AS DEWATERED SLUDGE											
(Gallons)	X	(% Solids)	X	(Conversion Factor)	=	Dry Tons	(Tons of Dewater Sludge)	X	(% Solids)	X	(.01)	=	Dry Tons		
14000		2.0		.0000417	=	1.17					.01	=			
TOTAL						=	1.17	TOTAL						=	

**DISPOSAL SITE INFORMATION:** List all sites, even if not used this month.

	Site 1	Site 2	Site 3	Site 4
Name:	Borough of Monaca Sewage Treatment Plant	Hopewell Township		
Permit No.	PA0020125	PA0026328		
Dry Tons Disposed:				
Type: (check one)				
Landfill				
Agr. Utilization				
Other (specify)				
County:	Beaver	Beaver		

(SSR-1 3/21/91) Donald J. Tolera Chemistry Manager 3-27-07 (724) 682-4141  
 Signature Title Date Telephone



## SUPPLEMENTAL LABORATORY ACCREDITATION FORM<sup>1</sup>

**Permittee Name:** FirstEnergy Nuclear Operating Company

**Address:** P.O. Box 4  
Shippingport, PA 15077  
Beaver Valley Power Station

PERMIT NUMBER	MONITORING PERIOD Year/Month/Day						
PA0025615	2007	02	01	TO	2007	02	28

PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER <sup>2</sup>
Zinc	EPA 200.7	FirstEnergy Corp-Beta Lab	68-01120
Copper	EPA 200.7	FirstEnergy Corp-Beta Lab	68-01120
Iron	EPA 200.7	FirstEnergy Corp-Beta Lab	68-01120
Chromium	EPA 200.7	FirstEnergy Corp-Beta Lab	68-01120
Ammonia	EPA 350.3	FirstEnergy Corp-Beta Lab	68-01120
CBOD-5 Day	SM5210 B	Firstechnology, Inc.	68-00434
Cyanide	EPA 335.2	Firstechnology, Inc.	68-00434
Chlorobenzene	EPA 624	Firstechnology, Inc.	68-00434

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibly of fine and imprisonment for knowing violations.

**Name/Title Principal Executive Officer**      **Phone:** 724-682-7773      **Signature of Principal Executive Officer or Authorized Agent**  
Peter P. Sena, Director Site Operations      **Date:** 3/27/17

<sup>1</sup> Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.  
<sup>2</sup> For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

## SUPPLEMENTAL LABORATORY ACCREDITATION FORM<sup>1</sup>

Permittee Name: <u>FirstEnergy Nuclear Operating Company</u>										
Address: <u>P.O. Box 4</u>										
<u>Shippingport, PA 15077</u>										
<u>Beaver Valley Power Station</u>										
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day						
PA0025615				2007	02	01	TO	2007	02	28
PARAMETER		ANALYSIS METHOD		LAB NAME		LAB ID NUMBER <sup>2</sup>				
Powerline 3627 (Clamtrol)		Photometric Determination		Beaver Valley Power Station		04-2742				
Bentonite Detoxicant (Betz DT-1)		Estimated using feed rate and discharge flow rate per NPDES Permit PA0025645		Beaver Valley Power Station		04-2742				
Total Residual Chlorine		EPA 330.5		Beaver Valley Power Station		04-2742				
Free Available Chlorine		EPA 330.5		Beaver Valley Power Station		04-2742				
pH		EPA 150.1		Beaver Valley Power Station		04-2742				
Temperature		EPA 170.1		Beaver Valley Power Station		04-2742				
Flow		NA		Beaver Valley Power Station		04-2742				
Total Suspended Solids		EPA 160.2		Beaver Valley Power Station		04-2742				
Hydrazine		ASTM D1385-01		Beaver Valley Power Station		04-2742				
Fecal Coliform		Standard Method 9222D		Beaver Valley Power Station		04-2742				
Oil and Grease		EPA 1664 Rev A		FirstEnergy Corp-Beta Lab		68-01120				
Total Dissolved Solids		EPA 160.1		FirstEnergy Corp-Beta Lab		68-01120				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 724-682-7773Signature of Principal Executive Officer or  
Authorized AgentPeter P. Sena, Director, Site OperationsDate: 3/27/07

<sup>1</sup> Submit this form with each Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes.

<sup>2</sup> For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 28

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

001A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
UNITS 1&2 COOLG. TOWER BLWDN  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.22	N/A	8.54	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Nitrogen, ammonia total (as N) 00610 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER 04251 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	**
	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	22.2	31.4	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02***	<0.02***	mg/L	0	10 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	.5 AVERAGE	1.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available 50064 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.001	0.02	mg/L	0	CONT****	RCRD
	PERMIT REQUIREMENT	*****	*****	N/A	*****	.2 AVERAGE	.5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine 81313 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here) *\* Not in wet layup this period.*  
 HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX.  
*\*\* No clamicide this period. \*\*\*0.02 mg/L is minimum detectable level. \*\*\*\* No Chlorination on 2/5 and 2/6 due to frozen chlorination lines. JPC 3-7-07*

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 29

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

002A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
INTAKE SCREEN BACKWASH  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 30

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

003A
<b>DISCHARGE NUMBER</b>

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
003  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.042	0.092	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req. Mon. MO.AVG	Req. Mon. DAILY.MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

004A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT ONE COOLG TOWER OVERFLOW  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX		*****	*****	*****			Weekly	MEASRD
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available 50064 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

006A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
AUX. INTAKE SCREEN BACKWASH  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>										
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req. Mon MO AVG	Req. Mon DAILY MX		*****	*****	*****			Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 33

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

007A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
AUX. INTAKE SYSTEM  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon. MO/AVG	Req. Mon. DAILY/MX	Mgal/d	*****	*****	*****			Weekly	GRAB
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	5 MO/AVG	1.25 INST. MAX	mg/L		Weekly	GRAB
Chlorine, free available 50064 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 34

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

008A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 1 COOLING TOWER PUMPHOUSE  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.70	N/A	7.94	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	19.1	21.0	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5*	<5*	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

\* <5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 35

NAME: FIRST ENERGY NUCLEAR OPERATING  
ADDRESS: PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
FACILITY: BEAVER VALLEY POWER STATION  
LOCATION: PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

010A  
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004  
MAJOR (SUBR05)  
UNIT 2 COOLING WATER  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.85	N/A	7.65	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	*	*	mg/L	*	*	*
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	3.11	4.03	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	N/A	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02 **	<0.02 **	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02 **	<0.02 **	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

\* No clamicide this period. \*\*0.02 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 36

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

011A
<b>DISCHARGE NUMBER</b>

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
DIESEL GEN & TURBINE DRAINS  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	<b>SAMPLE MEASUREMENT</b>	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	<b>PERMIT REQUIREMENT</b>	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>			<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 37

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

012A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
BLOWDOWN FROM THE HVAC UNIT  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.75	N/A	7.97	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Once Per Month	GRAB
Copper, total (as Cu) 01042 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.085	0.135	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon. MO. AVG.	Req. Mon. DAILY. MX.	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn) 01092 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.230	0.408	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	1:5 MO. AVG.	1:5 DAILY. MX.	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 28	EST
	PERMIT REQUIREMENT	Req. Mon. MO. AVG.	Req. Mon. DAILY. MX.	Mgal/d	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved 70295 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	486	508	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO. AVG.	Req. Mon. DAILY. MX.	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			724	682-7773	07	03	27
			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

013A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
OUTFALL 013  
External Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.99	N/A	7.36	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Cyanide, total (as CN) 00720 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01*	<0.01*	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu) 01042 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.017	0.025	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	05 MO AVG	1 DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene 34301 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005**	<0.005**	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.009	0.011	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		724	682-7773	07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.  
\* 0.01 mg/L is minimum detectable level. \*\* 0.005 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

101A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
101 CHEMICAL WASTE TREATMENT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
07	02	01	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.55	N/A	8.07	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	1.0	6.8	mg/L	0	7 / 28	2 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	COMP-2
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	7 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N) 00610 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.011	0.013	MGD	N/A	N/A	N/A	N/A	0	DAILY	CONT
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		DAILY	CONTIN
Hydrazine 81313 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	**	**	mg/L	**	**	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724 682-7773	07 03 27			
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER. \*5 mg/L is minimum detectable level. \*\* Not in wet layup this period. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

102A
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
102 INTAKE SCREEN HOUSE  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.60	N/A	7.69	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	5.0	5.5	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
	PERMIT REQUIREMENT	Reg Mon MO AVG	Reg Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

\*5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 41

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

103A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)

SLUDGE SETTLING BASIN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.24	N/A	7.50	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4*	<4*	mg/L	0	2 / 28	24 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.022	0.034	MGD	N/A	N/A	N/A	N/A	-	2 / 28	EST
	PERMIT REQUIREMENT	Req Mon: MO AVG	Req Mon: DAILY MX	Mgal/d	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Peter P. Sena, DIRECTOR OF SITE OPERATIONS	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 42

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

111A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
111 DIESEL GENERATOR BLDG  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.95	N/A	7.60	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO/AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

113A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 2 SEWAGE TMT PLANT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.19	N/A	8.00	pH	0	4 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	10.5	11.6	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.006	0.008	MGD	N/A	N/A	N/A	N/A	-	10 / 28	MEAS
	PERMIT REQUIREMENT	043 MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.56	0.72	mg/L	0	9 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general 74055 1 1 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	5	N/A	#/100mL	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	2000 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	7.5	9	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Peter P. Sena, DIRECTOR OF SITE OPERATIONS	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE		
			724	682-7773	07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 44

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

203A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
**MAJOR (SUBR05)**  
MAIN SEWAGE TMT PLANT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.50	N/A	7.60	pH	0	3 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	22.9	23.0	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.0010	0.0018	MGD	N/A	N/A	N/A	N/A	-	6 * / 28	MEAS
	PERMIT REQUIREMENT	0.023 MO AVG	Req/Mon DAILY/MX	Mgal/d	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	11.37**	61.5**	mg/L	3	6 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general 74055 1 1 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	25	N/A	#/100mL	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	2000 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C 80082 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	8.8	11.0	mg/L	0	2 / 28	8 HR COMP
	PERMIT REQUIREMENT	*****	*****	N/A	*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Peter P. Sena, DIRECTOR OF SITE OPERATIONS	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE		
			724	682-7773	07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

\* Plant was inoperable from 2/5/07 through 2/20/07 due to extreme low temperatures. \*\* See Attachment two for description of this event. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 45

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

211A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
211 TURBINE BLDG  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.82	N/A	7.48	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
TYPED OR PRINTED			AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 46

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

213A
<b>DISCHARGE NUMBER</b>


**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
UNIT 2 COOL TOWER PUMPHOUSE  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	30 MO.AVG	100 DAILY MX.	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	15 MO.AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon. MO.AVG	Req. Mon. DAILY.MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	5 MO.AVG	1.25 INST. MAX	mg/L		Twice Per Month	GRAB

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>	<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 47

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

301A
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 2 AUX BOILER BLOWDOWN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	FROM	07	02	28
			TO			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 28	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO.AVG	100 DAILY.MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 28	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO.AVG	20 DAILY.MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO.AVG	Req. Mon. DAILY.MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>			<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>
<b>COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)</b>		<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>					

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615
<b>PERMIT NUMBER</b>

303A
<b>DISCHARGE NUMBER</b>

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 1 OIL WATER SEPARATOR  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	FROM	07	02	28
			TO			

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.57	N/A	7.36	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	10.1	23.0	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO:AVG	100 DAILY:MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	1.7	8.3	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO:AVG	20 DAILY:MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.019	0.056	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO:AVG	Req. Mon. DAILY:MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	<b>TELEPHONE</b>		<b>DATE</b>			
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27	
<b>TYPED OR PRINTED</b>		<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>		<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE OIL WATER SEPARATOR PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 49

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

313A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
313 TURBINE BLDG DRAIN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.75	N/A	7.22	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	12.3	27.0	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req Mon. MO AVG	Req Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #21 PRIOR TO MIXING WITH ANY OTHER WATER.  
\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

401A  
**DISCHARGE NUMBER**

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
CHEM.FEED AREA OF AUX BOILERS  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.21	N/A	8.54	pH	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	Req. Mon. MAXIMUM	pH		Twice Per Month	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4 *	<4 *	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 **	<5 **	mg/L	0	2 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>			<b>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</b>	<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER.

\*4 mg/L is minimum detectable level. \*\* 5 mg/L is minimum detectable level. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
**PERMIT NUMBER**

403A  
**DISCHARGE NUMBER**


**DMR MAILING ZIP CODE:** 150770004  
**MAJOR (SUBR05)**  
CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N) 00610 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	Req Mon MO AVG	Req Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER 04251 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  Peter P. Sena, DIRECTOR OF SITE OPERATIONS  TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE		
			724	682-7773	07	03	27
	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

403A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR  
(SUBR05)  
CONDENSATE BLOWDOWN & RIVR WAT  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724 682-7773		07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

413A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
BULK FUEL STORAGE DRAIN  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.05	N/A	7.09	pH	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	pH		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	27.4	49.0	mg/L	0	3 / 28	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease 00556 1 0 Effluent Gross	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5 *	<5 *	mg/L	0	1 / 7	GRAB
	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	Mgal/d	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS		724	682-7773	07	03	27
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

\* 5 mg/L is minimum detectable level. Discharge occurred weeks of 2/18/07 & 2/25/07. JPC 3-7-07

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

Form Approved  
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 54

**NAME:** FIRST ENERGY NUCLEAR OPERATING  
**ADDRESS:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004  
**FACILITY:** BEAVER VALLEY POWER STATION  
**LOCATION:** PA ROUTE 168  
SHIPPINGPORT, PA 150770004

PA0025615  
PERMIT NUMBER

501A  
DISCHARGE NUMBER

**DMR MAILING ZIP CODE:** 150770004  
MAJOR (SUBR05)  
UNIT 1 GENRTR BLWDWN FILT BW  
Internal Outfall

ATTN: ELIZABETH THOMAS/MGR ENV&CHEM

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
07	02	01	TO	07	02	28

No Data Indicator

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	*****		*****	30 MO:AVG	100 DAILY:MX	mg/L		Weekly	GRAB
Flow, In conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	Req. Mon. MO:AVG	Req. Mon. DAILY:MX	Mgal/d	*****	*****	*****			Weekly	ESTIMA

<b>NAME/TITLE PRINCIPAL EXECUTIVE OFFICER</b>	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		<b>TELEPHONE</b>		<b>DATE</b>		
Peter P. Sena, DIRECTOR OF SITE OPERATIONS			724	682-7773	07	03	27
<b>TYPED OR PRINTED</b>			<b>AREA Code</b>	<b>NUMBER</b>	<b>YEAR</b>	<b>MO</b>	<b>DAY</b>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)  
SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.