

April 30, 2007

Mrs. Mary G. Korsnick
Vice President R.E. Ginna Nuclear Power Plant
R.E. Ginna Nuclear Power Plant, LLC
1503 Lake Road
Ontario, NY 14519

SUBJECT: NRC RECEIPT OF R.E. GINNA NUCLEAR POWER PLANT RESPONSE TO
GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC
AND MT FIRE BARRIER CONFIGURATIONS" (TAC NO. MD1583)

Dear Mrs. Korsnick:

The Nuclear Regulatory Commission (NRC) acknowledges the receipt of your June 9, 2006, response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Under oath or affirmation, your response states that your nuclear power plant relies on either the Hemyc or MT fire barrier system, and that you have submitted documentation that you plan to disposition any nonconforming conditions in accordance with Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.48(c) process. Also, compensatory measures have been in place since April 6, 2005; your response states that additional compensatory measures, or changes to the current measures, may be considered based on NRC Information Notice 97-48, NRC Regulatory Issue Summary 2005-07, and future industry guidance. Based on your response, the acceptability of these barriers will be reviewed by the NRC during Ginna's transition to 10 CFR 50.48(c). Therefore, no further action is requested of you.

If you have any questions regarding this response, please contact me at (301) 415-1364.

Sincerely,

/RA/

Douglas V. Pickett, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-244

cc: See next page

April 30, 2007

Mrs. Mary G. Korsnick
Vice President R.E. Ginna Nuclear Power Plant
R.E. Ginna Nuclear Power Plant, LLC
1503 Lake Road
Ontario, NY 14519

SUBJECT: NRC RECEIPT OF R.E. GINNA NUCLEAR POWER PLANT RESPONSE TO
GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC
AND MT FIRE BARRIER CONFIGURATIONS" (TAC NO. MD1583)

Dear Mrs. Korsnick:

The Nuclear Regulatory Commission (NRC) acknowledges the receipt of your June 9, 2006, response to Generic Letter 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Under oath or affirmation, your response states that your nuclear power plant relies on either the Hemyc or MT fire barrier system, and that you have submitted documentation that you plan to disposition any nonconforming conditions in accordance with Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.48(c) process. Also, compensatory measures have been in place since April 6, 2005; your response states that additional compensatory measures, or changes to the current measures, may be considered based on NRC Information Notice 97-48, NRC Regulatory Issues Summary 2005-07, and future industry guidance. Based on your response, the acceptability of these barriers will be reviewed by the NRC during Ginna's transition to 10 CFR 50.48(c). Therefore, no further action is requested of you.

If you have any questions regarding this response, please contact me at (301) 415-1364.

Sincerely,
/RA/
Douglas V. Pickett, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-244

cc: See next page

DISTRIBUTION:

PUBLIC RidsNrrPMDPickett RidsNrrLASLittle
LPLI-1 R/F RidsNrrDorLpl1-1 RidsNrrDraAfpb
RidsOgcRp RidsNrrDprPgcb RidsNrrAcrcAcnwMailCenter
MDavid

Accession Number: ML070940337

NRR-106

OFFICE	LPL1-1/PE	LPL1-1/PM	LPL1-1/LA	AFPB/BC	LPL1-1/BC
NAME	MDavid	DPickett	SLittle	SWeerakkody	MKowal
DATE	4 /16 /07	4/27/07	4 / 16 /07	4 / 27 /07	4/30/07

OFFICIAL RECORD COPY

R.E. Ginna Nuclear Power Plant

cc:

Mr. Michael J. Wallace
President
R.E. Ginna Nuclear Power Plant, LLC
c/o Constellation Energy
750 East Pratt Street
Baltimore, MD 21202

Mr. John M. Heffley
Senior Vice President and
Chief Nuclear Officer
Constellation Generation Group
1997 Annapolis Exchange Parkway
Suite 500
Annapolis, MD 21401

Kenneth Kolaczyk, Sr. Resident Inspector
R.E. Ginna Nuclear Power Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, NY 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Peter R. Smith, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Carey W. Fleming, Esquire
Senior Counsel - Nuclear Generation
Constellation Generation Group, LLC
750 East Pratt Street, 17th Floor
Baltimore, MD 21202

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Ms. Thelma Wideman, Director
Wayne County Emergency Management
Office
Wayne County Emergency Operations
Center
7336 Route 31
Lyons, NY 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
1190 Scottsville Road, Suite 200
Rochester, NY 14624

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223