

Shimizu Engineering Report

Project	General Electric Company ESBWR Project	Shimizu Document No.	SER-ESB-038
Title	Modified RBFB Truncated FE Model Analysis Data	Rev.	1
		Issued Date	9/22/06
		Revised Date	9/28/06

NOTE:

This document provides the data for the truncated Reactor/Fuel Buildings Finite Element (FE) model analysis in response to NRC's request in the DCD audit for RAI 3.8 held on July, 2006.

The requested data was originally issued by SER-ESB-027. NRC reviewed it and requested some simplification and clarification. This document provides the data modified in accordance with NRC's request.

It should be noted that this revision adds information of the modified model used for the analyses to the previous revision. The last information, i.e. analysis results, will be added in the next revision in accordance with the schedule indicated by GE.

1	9/28/06	Additional of modified truncated model	Y.O.	T.T.	T.T.
0	9/22/06	Initial Issue	Y.O.	T.T.	T.T.
Rev.	Date	Note	Approve	Review	Prepare
 Shimizu Corporation		Prepared by	T. Toyota		9/22/06
		Reviewed by	T. Takahashi		9/22/06
		Approved by	Y. Orito		9/22/06

Table of Contents

1.	Scope	4
2.	Reference.....	4
3.	Load Condition.....	4
3.1	Dead Load	5
3.2	Seismic Load.....	5
3.2.1	Shear Force.....	5
3.2.2	Overturning Moment.....	5
3.2.3	Vertical Force	5
3.3	Pressure Load	5
3.4	Hydrostatic Load	5
4.	Modified Truncated Model	6
4.1	Spent Fuel Pool slab	6
4.2	Cylindrical Wall	6
4.3	Radial Wall.....	6
4.4	NASTRAN Analysis Input Data	6
5.	Results of Analysis for Truncated model	6
	Appendix A Figures of Analysis Model	A-1
	Appendix B Definition of Shell Element Property in NASTRAN User Manual	B-1

Lists of Tables

Table 3-1 Summary of Dead Load.....	7
Table 3-2 Summary of Seismic Shear Force and Overturning Moment	8
Table 3-3 Summary of Seismic Vertical Force.....	9
Table 3-4 Summary of Pressure Load	10
Table 3-5 Summary of Hydrostatic Pressure Load.....	10
Table 3-6 Evaluation of Dead Load for the RBFB	11
Table 3-7 Evaluation of Dead Load for the RCCV	12
Table 3-8 Evaluation of Dead Load for the RPV Pedestal	12
Table 3-9 Evaluation of the Seismic Shear Force for the RBFB.....	13
Table 3-10 Evaluation of the Seismic Shear Force for the RCCV	13
Table 3-11 Evaluation of the Seismic Shear Force for the RPV Pedestal	13
Table 3-12 Moment of the Top of Truncated Model.....	14
Table 3-13 Evaluation of the Seismic Moment for the RBFB.....	15
Table 3-14 Evaluation of the Seismic Moment for the RCCV	16
Table 3-15 Evaluation of the Seismic Moment for the RPV Pedestal.....	16
Table 3-16 Evaluation of the Seismic Vertical Force for the RBFB	17
Table 3-17 Evaluation of the Seismic Vertical Force for the RCCV	18
Table 3-18 Evaluation of the Seismic Vertical Force for the RPV Pedestal	18
Table 3-19 Evaluation of the Pressure Load for the RCCV	18
Table 3-20 Evaluation of the Pressure Load for the RPV Pedestal	18
Table 3-21 Evaluation of the Hydrostatic Pressure Load for the Spent Fuel Pool.....	19
Table 4-1 NASTRAN Control Data Files.....	19
Table 4-2 NASTRAN Model Data Files	19
Table 4-3 NASTRAN Load Data Files.....	20

Lists of Figures

Figure 3-1 Pressure Load Applied to the RCCV Wall and the Basemat at 72 hr. after LOCA...	21
Figure 3-2 Hydrostatic Load Applied to the Spent Fuel Pool Walls and the Basemat.....	22
Figure 3-3 Wall Information of Truncated Model.....	23
Figure 4-1 Modification in Truncated Model	24
Figure 4-2 Modified Truncated Model	25

1. Scope

At NRC's audit on the ESBWR DCD RAI 3.8, NRC requested GE to provide the data needed to perform their verification analyses using a truncated Reactor Building and Fuel Building (RB/FB) Finite Element (FE) model. Per NRC's request, the data of the original truncated model analysis were provided by Reference 1. However, after reviewing of the original data, NRC requested to simplify and clarify the analysis data.

This report provides the load conditions and analysis model modified in accordance with NRC's request. NASTRAN analysis results for the modified load conditions are also included in this report.

Major modifications on the analysis data are as follows.

- a. Load conditions: Loads applied to the model are simplified.
- b. Analysis model: The model is modified for the following portions.

- Increase of Spent Fuel Pool slab (Basemat) thickness
- Increase of cylindrical wall thickness at the half north side under the Suppression Pool
- Addition of radial walls under the Suppression Pool

2. Reference

1. SER-ESB-027 "Reactor Building/Fuel Buildings Truncated FE Model Analysis Data," Rev. 1

3. Load Condition

Analyses are performed for the following loads.

- Dead Load
- Pressure Load (at 72 hr. after LOCA)
- Seismic Load
- Hydrostatic Load

The load conditions are summarized in Tables 3-1 through 3-5 and Figures 3-1 and 3-2. Figure 3-3 shows the names and locations of the walls in the truncated FE model.

The evaluation methods of the applied loads are described in the following sections.

It should be noted that the applied loads described in this report mean those applied to the top boundary nodes of the truncated model, i.e. boundary loads, unless noted otherwise.

In addition, loads are not applied to the cylindrical walls and radial walls under the Suppression Pool, since these walls are not connected to the RCCV wall nor RPV pedestal wall through normal rigid slabs. The walls are modeled to consider their constraint effects to the basemat.

3.1 Dead Load

Dead loads applied to the model are evaluated based on the weight of the seismic stick model. Weights of the RBFB, RCCV, and RPV pedestal in the seismic model are converted to the uniform line loads as shown in Tables 3-6 through 3-8. For the RBFB walls, the weights are distributed to each wall in proportion to its sectional area.

3.2 Seismic Load

3.2.1 Shear Force

Seismic shear forces are evaluated using the design seismic loads at the base of the buildings. As shown in Table 3-9, the loads for the RBFB are applied to the box walls which are parallel to the direction of the applied shear force. For the RCCV and RPV pedestal, loads are applied to the half areas of the walls as described in Tables 3-10 and 3-11.

3.2.2 Overturning Moment

Seismic overturning moments are evaluated based on the design seismic loads. Since the design overturning moment is defined at each floor level, the values at the top of the truncated model are calculated by the equation shown in Table 3-12.

Overturning moments are applied as vertical coupling forces to the walls perpendicular to the earthquake direction. Evaluation methods of the applied loads are shown in Tables 3-13 through 3-15.

3.2.3 Vertical Force

Applied loads for the vertical earthquake are determined using the maximum axial forces obtained from seismic analyses. The loads are distributed to the wall in the same manner as the dead load. Tables 3-16 through 3-18 summarize the calculation results of the vertical seismic load.

3.3 Pressure Load

Analysis is performed for the pressure load at the LOCA after 72 hr (45 psig = 0.31 MPa). The loads are applied to the inside surface of the RPV pedestal and the top surface of the Basemat as a uniform pressure load as shown Figure 3-1.

As the boundary loads at the top of model, the loads in the radial and vertical directions, which are evaluated from the results of the global FE model analysis, are applied together with pressure loads. The loads are summarized in Table 3-19 and 3-20. The loads in the hoop direction are not considered since they are negligibly small.

3.4 Hydrostatic Load

Hydrostatic load applied to the inside surfaces of Spent Fuel Pool walls and slab are shown in Figure 3-2. The boundary loads are calculated as shown in Table 3-21.

4. Modified Truncated Model

The following modifications were made for the truncated model. They are summarized in Figure 4-1.

- Increase of Spent Fuel Pool slab (Basemat) thickness
- Increase of cylindrical wall thickness at the half north side under the Suppression Pool
- Addition of radial walls under the Suppression Pool

4.1 Spent Fuel Pool slab

The region of the Spent Fuel Pool slab is shown as the dot pattern in Figure 4-1. The thickness of slab elements is increased from 4.0 m to 5.5 m as shown in Figure 4-2.

4.2 Cylindrical Wall

The cylindrical wall at the north side, i.e. from 90° to 270° , under the Suppression Pool is indicated as the diagonal line pattern in Figure 4-1. Its thickness increased from 0.6 m to 1.4 m as shown in Figure 4-2.

4.3 Radial Wall

The radial walls shown as cross diagonal line pattern in Figure 4-1 are added to the modified truncated model. Their thicknesses are shown in Figure 4-1. The radial walls in the modified truncated model are shown in Figure 4-2.

The configurations of modified truncated model are shown in Appendix A. In the figures, node ID and element ID are indicated.

These elements are modeled as shell elements which have membrane, bending, and transverse shear stiffnesses. The modeling method of the shell element in the NASTRAN analysis is excerpted from the NASTRAN manual and attached in Appendix B for reference.

4.4 NASTRAN Analysis Input Data

Contents of NASTRAN input data provided are summarized in Tables 4-1 through 4-3.

5. Results of Analysis for Truncated model

<Later>

Table 3-1 Summary of Dead Load

Components	Wall Name	Load Value (MN/m)	Direction
Axial	RA	-2.681	Vertical (+:Upward)
	RG	-2.681	
	R1	-2.681	
	R7	-2.681	
	F3-1	-4.825	
	F3-2	-2.681	
	Iw-R1	-1.340	
	Iw-R2	-1.340	
	Iw-R3	-1.340	
	Iw-R4	-1.340	
	Iw-F1	-2.346	
	Iw-F2	-2.010	
	Iw-F3	-2.010	
	Iw-F4	-2.010	
	Iw-F5	-1.340	
	Iw-F6	-0.804	
	Iw-F7	-2.547	
	Iw-F8	-2.681	
	Iw-F9	-1.340	
	Iw-F10	-1.340	
	Iw-F11	-1.340	
	Iw-F12	-1.541	
	Iw-F13	-1.340	
	RCCV	-5.329	
	Pedestal	-4.245	

Note1: These loads are applied to top of the wall shown in the table

Note2: For the locations of walls, see Figure 3-3.

Table 3-2 Summary of Seismic Shear Force and Overturning Moment

Components	Wall Name	Load Value (MN/m)	Direction
Shear (N to S)	RA	6.693	Horizontal (+:X)
	RG	6.693	
	RCCV_ns	4.226	
	Pedestal_ns	4.719	
Shear (W to E)	R1	6.687	Horizontal (+:Y)
	R7	6.687	
	F3-1	12.036	
	F3-2	6.687	
	RCCV_ew	5.096	
	Pedestal_ew	5.688	
Moment (N to S)	R1	10.369	Vertical (+:Upward)
	R7	-1.550	
	F3-1	-12.377	
	F3-2	-6.876	
	RCCV_ew	9.933	
	Pedestal_ew	9.847	
Moment (W to E)	RA	-10.201	Vertical (+:Upward)
	RG	10.201	
	RCCV_ns	13.142	
	Pedestal_ns	12.460	

Note1: These loads are applied to top of the wall shown in the table

Note2: For the locations of walls, see Figure 3-3.

Table 3-3 Summary of Seismic Vertical Force

Components	Wall Name	Load Value (MN/m)	Direction
Vertical (Axial)	RA	1.248	Vertical (+:Upward)
	RG	1.248	
	R1	1.248	
	R7	1.248	
	F3-1	2.247	
	F3-2	1.248	
	Iw-R1	0.624	
	Iw-R2	0.624	
	Iw-R3	0.624	
	Iw-R4	0.624	
	Iw-F1	1.092	
	Iw-F2	0.936	
	Iw-F3	0.936	
	Iw-F4	0.936	
	Iw-F5	0.624	
	Iw-F6	0.375	
	Iw-F7	1.186	
	Iw-F8	1.248	
	Iw-F9	0.624	
	Iw-F10	0.624	
	Iw-F11	0.624	
	Iw-F12	0.718	
	Iw-F13	0.624	
	RCCV	3.102	
	Pedestal	2.428	

Note1: These loads are applied to top of the wall shown in the table

Note2: For the locations of walls, see Figure 3-3.

Table 3-4 Summary of Pressure Load

Components	Wall Name	Load Value (MN/m)	Direction
Radial & Vertical	RCCV	0.309	Radial (Outward: +)
		0.816	Vertical (+:Upward)
	Pedestal	0.909	Radial (Outward: +)
		-1.608	Vertical (+:Upward)

Note1: These loads are applied to top of the wall shown in the table.

Note2: Pressure loads applied to elements directly are shown in Figure 3-1.

Table 3-5 Summary of Hydrostatic Pressure Load

Components	Wall Name	Load Value (MN/m)	Direction
Horizontal	RA	0.835	+Y
	F3-1	0.835	+X
	Iw-F2	-0.835	+Y
	Iw-F3	-0.835	+Y
	Iw-F7	-0.835	+X

Note1: These loads are applied to top of the wall shown in the table.

Note2: Hydrostatic pressure loads applied to elements directly are shown in Figure 3-2.

Table 3-6 Evaluation of Dead Load for the RBFB

Load ^{*1} (MN)	Portion	Direction	Thickness ^{*2} (t: m)	Length ^{*2} (l: m)	Area (A: m ²)	Unit Load 1 ^{*3} (MN/m ²)	Unit Load 2 ^{*4} (MN/m)
-1030.315	RA	X	2.00	68.0	136.000		-2.681
	RG	X	2.00	68.0	136.000		-2.681
	R1	Y	2.00	47.0	94.000		-2.681
	R7	Y	2.00	47.0	94.000		-2.681
	F3-1	Y	3.60	16.6	59.760		-4.825
	F3-2	Y	2.00	30.4	60.800		-2.681
	Iw-R1	X	1.00	12.0	12.000		-1.340
	Iw-R2	X	1.00	12.0	12.000		-1.340
	Iw-R3	Y	1.00	12.0	12.000		-1.340
	Iw-R4	Y	1.00	12.0	12.000		-1.340
	Iw-F1	X	1.75	4.2	7.350		-2.346
	Iw-F2	X	1.50	2.1	3.150		-2.010
	Iw-F3	X	1.50	12.9	19.350		-2.010
	Iw-F4	X	1.50	8.1	12.150		-2.010
	Iw-F5	X	1.00	12.9	12.900		-1.340
	Iw-F6	X	0.60	16.8	10.080		-0.804
	Iw-F7	Y	1.90	16.6	31.540		-2.547
	Iw-F8	Y	2.00	4.1	8.200		-2.681
	Iw-F9	Y	1.00	8.4	8.400		-1.340
	Iw-F10	Y	1.00	5.5	5.500		-1.340
	Iw-F11	Y	1.00	6.8	6.800		-1.340
	Iw-F12	Y	1.15	5.5	6.325		-1.541
	Iw-F13	Y	1.00	8.4	8.400		-1.340
	Total	-	-	-	768.705	-1.340	-

*1: Load is the same value as the stick model weight.

*2: Thickness and length are dimensions in the FE Model

*3: "Unit Load 1" is the load per unit area. Unit Load 1 = Load / Total A

*4: "Unit Load 2" is the load per unit length. Unit Load 2 = Unit Load 1 * t

Table 3-7 Evaluation of Dead Load for the RCCV

Load ^{*1} (MN)	Portion	Direction	Thickness (t: m)	Length ^{*2} (l: m)	Unit Load ^{*3} (MN/m)
-636.12	RCCV	-	2.00	119.4	-5.329

*1: Load is the same value as the stick model weight.

*2: Length = 19.0 (Radius of the modeled RCCV wall) * 2 * π

*3: "Unit Load" is the load per unit length. Unit Load = Load / l

Table 3-8 Evaluation of Dead Load for the RPV Pedestal

Load ^{*1} (MN)	Portion	Direction	Thickness (t: m)	Length ^{*2} (l: m)	Unit Load ^{*3} (MN/m)
-181.358	Pedestal	-	2.40	42.7	-4.245

*1: Load is the same value as the stick model weight.

*2: Length = 6.8 (Radius of the modeled RPV pedestal) * 2 * π

*3: "Unit Load" is the load per unit length. Unit Load = Load / l

Table 3-9 Evaluation of the Seismic Shear Force for the RBFB

Seismic Direction	Load ^{*1} (MN)	Portion	Direction ^{*2}	Thickness ^{*3} (t: m)	Length ^{*3} (l: m)	Area (A: m ²)	Unit Load 1 ^{*4} (MN/m ²)	Unit Load 2 ^{*5} (MN/m)
N to S	910.26	RA	X	2.00	68.0	136.000		6.693
		RG	X	2.00	68.0	136.000		6.693
		Total	-	-	-	272.000	3.347	-
W to E	1031.66	R1	Y	2.00	47.0	94.000		6.687
		R7	Y	2.00	47.0	94.000		6.687
		F3-1	Y	3.60	16.6	59.760		12.036
		F3-2	Y	2.00	30.4	60.800		6.687
		Total	-	-	-	308.560	3.343	-

*1: Load is the design seismic shear force at the bottom of the RBFB Walls.

*2: Walls in the same direction as seismic direction are considered.

*3: Thickness and length are dimensions on the FE Model

*4: "Unit Load 1" is the load per unit area. Unit Load 1 = Load / Total A

*5: "Unit Load 2" is the load per unit length. Unit Load 2 = Unit Load 1 * t

Table 3-10 Evaluation of the Seismic Shear Force for the RCCV

Seismic Direction	Load ^{*1} (MN)	Portion ^{*2}	Direction	Thickness	Length ^{*3} (l: m)	Unit Load ^{*4} (MN/m)
N to S	252.230	RCCV_ns	X	2.00	59.7	4.226
W to E	304.200	RCCV_ew	Y	2.00	59.7	5.096

*1: Load is the design seismic shear force at the bottom of RBFB Wall.

*2: For the portion where the load is applied, see Figure 3-3.

*3: Length is evaluated as effective length. Length = 19.0 (Radius on the FE Model) * 2 * π /2

*4: "Unit Load" is the load per unit length. Unit Load = Load / l

Table 3-11 Evaluation of the Seismic Shear Force for the RPV Pedestal

Seismic Direction	Load ^{*1} (MN)	Portion ^{*2}	Direction	Thickness	Length ^{*3} (l: m)	Unit Load ^{*4} (MN/m)
N to S	100.810	Pedestal_ns	X	2.40	21.4	4.719
W to E	121.510	Pedestal_ew	Y	2.40	21.4	5.688

*1: Load is the design seismic shear force at the bottom of RBFB Wall.

*2: For the portion where the load is applied, see Figure 3-3.

*3: Length is evaluated as effective length. Length = 6.8 (Radius on the FE Model) * 2 * π /2

*4: "Unit Load" is the load per unit length. Unit Load = Load / l

Table 3-12 Moment of the Top of Truncated Model

	Level (m)	Stick Model		Moment* (MNm)		
		EID	NID	#	Direction of Earthquake	
					NS	EW
RBFB	-6.4	1101	101	<i>Mi</i>	29730	30230
	-8.7			<u><i>M</i></u>	<u>31611</u>	<u>32602</u>
	-11.5			<i>Mj</i>	33900	35490
RCCV	-6.4	1201	201	<i>Mi</i>	9560	12720
	-8.7			<u><i>M</i></u>	<u>10142</u>	<u>13419</u>
	-11.5			<i>Mj</i>	10850	14270
RPV Pedestal	-6.4	1301	301	<i>Mi</i>	1056	1350
	-8.7			<u><i>M</i></u>	<u>1288</u>	<u>1630</u>
	-11.5			<i>Mj</i>	1570	1970

Note1: Mi, Mj: design overturning moment

Note2: Moments (M) at EL-8.7m are applied as boundary loads.

The moment (M) is calculated from the following equation.




Table 3-13 Evaluation of the Seismic Moment for the RBFB

Seismic Dir.	Load ^{*1} (MN·m)	Portion	Thickness ^{*3} (t: m)	Length ^{*3} (l: m)	Area (A: m ²)	Distance (d0: m) R1 ~ ea. Wall C.	C. of Stiff. from R1 (m) ^{*4}	Distance (d: m) C.ofStiff.~Wall C.	Moment of Inertia (I: m ⁴) ^{*5}	Unit Load1 ^{*6} (MN/m ² /m)	Unit Load2 ^{*7} (MN/m)
N to S	31611	R1	2.00	47.0	94.000	0.00		40.887	157144		10.369
		R7	2.00	47.0	94.000	47.00		-6.113	3513		-1.550
		F3-1	3.60	16.6	59.760	68.00		-27.113	43931		-12.377
		F3-2	2.00	30.4	60.800	68.00		-27.113	44695		-6.876
		Total	-	-	308.560		40.887		249282	0.127	
W to E	32602	RA	2.00	68.0	136.000	47.00		-23.500	75106		-10.201
		RG	2.00	68.0	136.000	0.00		23.500	75106		10.201
		Total	-	-	272.000		23.500		150212	0.217	

*1: Refer to Table 3-12.

*2: Orthogonal direction walls to seismic direction are considered.

*3: Thickness and length are dimensions on the FE Model.

*4: Center of Stiffness = $\Sigma(A*d0)/\text{Total A}$

*5: Moment Inertia = $A * d^2$

*6: Unit Load1 = Load / Total I


*7: Unit Load2 = Unit Load1 * t * d

Table 3-14 Evaluation of the Seismic Moment for the RCCV

Seismic Direction	Load ^{*1} (MN·m)	Portion	Direction	Model Radius (r: m)	Unit Load ^{*2} (q: MN/m)
N to S	10142	RCCV_ew	Y	19.00	9.933
W to E	13419	RCCV_ns	X	19.00	13.142

*1: Refer to Table 3-12.

*2: Unit Load = Load / (2 * 20.5 * r²) (Refer to following the figure.)

**Table 3-15 Evaluation of the Seismic Moment for the RPV Pedestal**

Seismic Direction	Load ^{*1} (MN·m)	Portion	Direction	Model Radius (r: m)	Unit Load ^{*2} (q: MN/m)
N to S	1288	Pedestal_ew	Y	6.80	9.847
W to E	1630	Pedestal_ns	X	6.80	12.460

*1: Refer to Table 3-12.

*2: Unit Load = Load / (2 * 20.5 * r²) (Refer to the figure in Table 3-14.)

Table 3-16 Evaluation of the Seismic Vertical Force for the RBFB

Load ^{*1} (MN)	Portion	Direction	Thickness ^{*2} (t: m)	Length ^{*2} (l: m)	Area (A: m ²)	Unit Load 1 ^{*3} (MN/m ²)	Unit Load 2 ^{*4} (MN/m)
479.840	RA	X	2.00	68.0	136.000		1.248
	RG	X	2.00	68.0	136.000		1.248
	R1	Y	2.00	47.0	94.000		1.248
	R7	Y	2.00	47.0	94.000		1.248
	F3-1	Y	3.60	16.6	59.760		2.247
	F3-2	Y	2.00	30.4	60.800		1.248
	Iw-R1	X	1.00	12.0	12.000		0.624
	Iw-R2	X	1.00	12.0	12.000		0.624
	Iw-R3	Y	1.00	12.0	12.000		0.624
	Iw-R4	Y	1.00	12.0	12.000		0.624
	Iw-F1	X	1.75	4.2	7.350		1.092
	Iw-F2	X	1.50	2.1	3.150		0.936
	Iw-F3	X	1.50	12.9	19.350		0.936
	Iw-F4	X	1.50	8.1	12.150		0.936
	Iw-F5	X	1.00	12.9	12.900		0.624
	Iw-F6	X	0.60	16.8	10.080		0.375
	Iw-F7	Y	1.90	16.6	31.540		1.186
	Iw-F8	Y	2.00	4.1	8.200		1.248
	Iw-F9	Y	1.00	8.4	8.400		0.624
	Iw-F10	Y	1.00	5.5	5.500		0.624
	Iw-F11	Y	1.00	6.8	6.800		0.624
	Iw-F12	Y	1.15	5.5	6.325		0.718
	Iw-F13	Y	1.00	8.4	8.400		0.624
	Total	-	-	-	768.705	0.624	-

*1: Load is the maximum axial force of dynamic analysis by the stick model.

*2: Thickness and length are dimensions on the FE Model

*3: "Unit Load 1" is the load per unit area. Unit Load 1 = Load / Total A

*4: "Unit Load 2" is the load per unit length. Unit Load 2 = Unit Load 1 * t.

Table 3-17 Evaluation of the Seismic Vertical Force for the RCCV

Load ^{*1} (MN)	Portion	Direction	Thickness (t: m)	Length ^{*2} (l: m)	Unit Load ^{*3} (MN/m)
370.300	RCCV	-	2.00	119.4	3.102

*1: Load is the maximum axial force obtained from the stick model seismic analysis.

*2: Length = 19.0 (Radius on the FE Model) * 2 * π

*3: "Unit Load" is the load per unit length. Unit Load = Load / l

Table 3-18 Evaluation of the Seismic Vertical Force for the RPV Pedestal

Load ^{*1} (MN)	Portion	Direction	Thickness (t: m)	Length ^{*2} (l: m)	Unit Load ^{*3} (MN/m)
103.750	Pedestal	-	2.40	42.7	2.428

*1: Load is the maximum axial force obtained from the stick model seismic analysis.

*2: Length = 6.8 (Radius on the FE Model) * 2 * π

*3: "Unit Load" is the load per unit length. Unit Load = Load / l

Table 3-19 Evaluation of the Pressure Load for the RCCV

Average Force (MN/node)		Nodal Tributary Length (L: m)	Unit Load (MN/m)	
Radial	Vertical		Radial	Vertical
0.768	2.031	2.487	0.309	0.816

Note1: Average Forces are calculated from nodal force at EL -8.7m of the global FE model analysis

Note2: L = 19.0(Radius of the modeled RCCV wall) * 2 * π / 48(nodes)

Note3: Unit Load = [Average Force] / L

Table 3-20 Evaluation of the Pressure Load for the RPV Pedestal

Average Force (MN/node)		Nodal Tributary Length (L: m)	Unit Load (MN/m)	
Radial	Vertical		Radial	Vertical
0.809	-1.432	0.890	0.909	-1.608

Note1: Average Forces are calculated from nodal force at EL -8.7m of the global FE model analysis

Note2: L = 6.8(Radius of the modeled RPV pedestal) * 2 * π / 48(nodes)

Note3: Unit Load = [Average Force] / L

Table 3-21 Evaluation of the Hydrostatic Pressure Load for the Spent Fuel Pool

Spent Fuel Pool			Truncated Model		
Top (EL. m)	Bottom (EL. m)	Depth (m)	Model Top (EL. m)	Depth above Model d (m)	Boundary Load [*] L (MN/m)
4.35	-10.00	14.35	-8.7	13.05	0.835

*: Boundary Load is calculated following equation. (Refer to Figure 3-2.)

$$L = 1.0(t/m^3) * d / 9.807 * d / 2$$

Table 4-1 NASTRAN Control Data Files


Load	Control Data File	Note
Dead Load	DL.dat	
Seismic Load	EQNS.dat	Shear (N to S)
	EQEW.dat	Shear (W to E)
	EMNS.dat	Moment (N to S)
	EMEW.dat	Moment (W to E)
	EQZ.dat	Vertical
Pressure Load	PL.dat	
Hydrostatic Load	FL.dat	

Table 4-2 NASTRAN Model Data Files

	Model Data File	Note
Common	cood	Coordinate System Definition
	node_truncated.txt	Grid points (Building)
	soil_node.prn	Grid points (Soil)
	elem_truncated.txt	Shell and bar elements
	rbar_truncated.txt	Rigid bar
	pshell_truncated.txt	Properties of shell elements.
	pbar_truncated.txt	Properties of bar elements.
	mat_truncated.txt	Material properties
Soil Spring	elas_o.prn	Soil spring for vertical loads
	elas_s.prn	Soil spring for horizontal loads

Table 4-3 NASTRAN Load Data Files

Load	Load Data File	Note	Reference Table and Figure
Dead Load	DL.prn	Vertical Force at Top of Model	Table 3-1
Seismic Load	EQNS.prn	Shear Force (NS) at Top of Model	Table 3-2
	EQEW.prn	Shear Force (WE) at Top of Model	Table 3-2
	EMNS.prn	Moment (NS) Top of Model	Table 3-2
	EMEW.prn	Moment (WE) at Top of Model	Table 3-2
	EQZ.prn	Vertical Force at Top of Model	Table 3-3
Pressure Load	PL.prn	Pressure at Top of Model	Table 3-4 Figure 3-1
	pl_truncated.txt	Pressure inside RPV Pedestal	
Hydrostatic Load	FL.prn	Pressure at Top of Model	Table 3-5 Figure 3-2
	fl_truncated.txt	Pressure inside SF Pool	



**Figure 3-1 Pressure Load Applied to the RCCV Wall and the Basemat at 72 hr.
after LOCA**




Figure 3-2 Hydrostatic Load Applied to the Spent Fuel Pool Walls and the Basemat





Figure 3-3 Wall Information of Truncated Model










Figure 4-2 Modified Truncated Model

Appendix A Figures of Analysis Model




Modified Truncated Model






RPV Pedestal


View: from Inside to Outside






External Wall (RA)

View: from Outside (East) to Inside (West)



External Wall (RG)




RA RB RC RD RE RF RG

External Wall (R1)
A-6



View: from Outside (North) to Inside (South)

EL 52.05															
47001	47002	47003	47004	47005	47006	47007	47008	47009	47010	47011	47012	47013	47014	47015	47016
47017	47018	47019	47020	47021	47022	47023	47024	47025	47026	47027	47028	47029	47030	47031	47032
47033	47034	47035	47036	47037	47038	47039	47040	47041	47042	47043	47044	47045	47046	47047	47048
47049	47050	47051	47052	47053	47054	47055	47056	47057	47058	47059	47060	47061	47062	47063	47064
47065	47066	47067	47068	47069	47070	47071	47072	47073	47074	47075	47076	47077	47078	47079	47080
47081	47082	47083	47084	47085	47086	47087	47088	47089	47090	47091	47092	47093	47094	47095	47096
47097	47098	47099	47100	47101	47102	47103	47104	47105	47106	47107	47108	47109	47110	47111	47112
47113	47114	47115	47116	47117	47118	47119	47120	47121	47122	47123	47124	47125	47126	47127	47128
47129	47130	47131	47132	47133	47134	47135	47136	47137	47138	47139	47140	47141	47142	47143	47144
47145	47146	47147	47148	47149	47150	47151	47152	47153	47154	47155	47156	47157	47158	47159	47160
47161	47162	47163	47164	47165	47166	47167	47168	47169	47170	47171	47172	47173	47174	47175	47176
47177	47178	47179	47180	47181	47182	47183	47184	47185	47186	47187	47188	47189	47190	47191	47192
47193	47194	47195	47196	47197	47198	47199	47200	47201	47202	47203	47204	47205	47206	47207	47208
47209	47210	47211	47212	47213	47214	47215	47216	47217	47218	47219	47220	47221	47222	47223	47224
47225	47226	47227	47228	47229	47230	47231	47232	47233	47234	47235	47236	47237	47238	47239	47240
47241	47242	47243	47244	47245	47246	47247	47248	47249	47250	47251	47252	47253	47254	47255	47256
47257	47258	47259	47260	47261	47262	47263	47264	47265	47266	47267	47268	47269	47270	47271	47272
47273	47274	47275	47276	47277	47278	47279	47280	47281	47282	47283	47284	47285	47286	47287	47288
47289	47290	47291	47292	47293	47294	47295	47296	47297	47298	47299	47300	47301	47302	47303	47304
47305	47306	47307	47308	47309	47310	47311	47312	47313	47314	47315	47316	47317	47318	47319	47320
47321	47322	47323	47324	47325	47326	47327	47328	47329	47330	47331	47332	47333	47334	47335	47336
47337	47338	47339	47340	47341	47342	47343	47344	47345	47346	47347	47348	47349	47350	47351	47352
47353	47354	47355	47356	47357	47358	47359	47360	47361	47362	47363	47364	47365	47366	47367	47368
47369	47370	47371	47372	47373	47374	47375	47376	47377	47378	47379	47380	47381	47382	47383	47384
47385	47386	47387	47388	47389	47390	47391	47392	47393	47394	47395	47396	47397	47398	47399	47400
47401	47402	47403	47404	47405	47406	47407	47408	47409	47410	47411	47412	47413	47414	47415	47416
47417	47418	47419	47420	47421	47422	47423	47424	47425	47426	47427	47428	47429	47430	47431	47432
47433	47434	47435	47436	47437	47438	47439	47440	47441	47442	47443	47444	47445	47446	47447	47448
47449	47450	47451	47452	47453	47454	47455	47456	47457	47458	47459	47460	47461	47462	47463	47464
47465	47466	47467	47468	47469	47470	47471	47472	47473	47474	47475	47476	47477	47478	47479	47480
47481	47482	47483	47484	47485	47486	47487	47488	47489	47490	47491	47492	47493	47494	47495	47496
47497	47498	47499	47500	47501	47502	47503	47504	47505	47506	47507	47508	47509	47510	47511	47512
47513	47514	47515	47516	47517	47518	47519	47520	47521	47522	47523	47524	47525	47526	47527	47528
47529	47530	47531	47532	47533	47534	47535	47536	47537	47538	47539	47540	47541	47542	47543	47544
47545	47546	47547	47548	47549	47550	47551	47552	47553	47554	47555	47556	47557	47558	47559	47560
47561	47562	47563	47564	47565	47566	47567	47568	47569	47570	47571	47572	47573	47574	47575	47576
47577	47578	47579	47580	47581	47582	47583	47584	47585	47586	47587	47588	47589	47590	47591	47592
47593	47594	47595	47596	47597	47598	47599	47600	47601	47602	47603	47604	47605	47606	47607	47608
47609	47610	47611	47612	47613	47614	47615	47616	47617	47618	47619	47620	47621	47622	47623	47624
47625	47626	47627	47628	47629	47630	47631	47632	47633	47634	47635	47636	47637	47638	47639	47640
47641	47642	47643	47644	47645	47646	47647	47648	47649	47650	47651	47652	47653	47654	47655	47656
47657	47658	47659	47660	47661	47662	47663	47664	47665	47666	47667	47668	47669	47670	47671	47672
47673	47674	47675	47676	47677	47678	47679	47680	47681	47682	47683	47684	47685	47686	47687	47688
47689	47690	47691	47692	47693	47694	47695	47696	47697	47698	47699	47700	47701	47702	47703	47704
47705	47706	47707	47708	47709	47710	47711	47712	47713	47714	47715	47716	47717	47718	47719	47720
47721	47722	47723	47724	47725	47726	47727	47728	47729	47730	47731	47732	47733	47734	47735	47736
47737	47738	47739	47740	47741	47742	47743	47744	47745	47746	47747	47748	47749	47750	47751	47752
47753	47754	47755	47756	47757	47758	47759	47760	47761	47762	47763	47764	47765	47766	47767	47768
47769	47770	47771	47772	47773	47774	47775	47776	47777	47778	47779	47780	47781	47782	47783	47784
47785	47786	47787	47788	47789	47790	47791	47792	47793	47794	47795	47796	47797	47798	47799	47800
47801	47802	47803	47804	47805	47806	47807	47808	47809	47810	47811	47812	47813	47814	47815	47816
47817	47818	47819	47820	47821	47822	47823	47824	47825	47826	47827	47828	47829	47830	47831	47832
47833	47834	47835	47836	47837	47838	47839	47840	47841	47842	47843	47844	47845	47846	47847	47848
47849	47850	47851	47852	47853	47854	47855	47856	47857	47858	47859	47860	47861	47862	47863	47864
47865	47866	47867	47868	47869	47870	47871	47872	47873	47874	47875	47876	47877	47878	47879	47880
47881	47882	47883	47884	47885	47886	47887	47888	47889	47890	47891	47892	47893	47894	47895	47896
47897	47898	47899	47900	47901	47902	47903	47904	47905	47906	47907	47908	47909	47910	47911	47912
47913	47914	47915	47916	47917	47918	47919	47920	47921	47922	47923	47924	47925	47926	47927	47928
47929	47930	47931	47932	47933	47934	47935	47936	47937	47938	47939	47940	47941	47942	47943	47944
47945	47946	47947	47948	47949	47950	47951	47952	47953	47954	47955	47956	47957	47958	47959	47960
47961	47962	47963	47964	47965	47966	47967	47968	47969	47970	47971	47972	47973	47974	47975	47976
47977	47978	47979	47980	47981	47982	47983	47984	47985	47986	47987	47988	47989	47990	47991	47992
47993	47994	47995	47996	47997	47998	47999	47990	47991	47992	47993	47994	47995	47996	47997	47998
47999	48000	48001	48002	48003	48004	48005	48006	48007	48008	48009	48000	48001	48002	48003	48004
48001	48002	48003	48004	48005	48006	48007	48008	48009	48000	48001	48002	48003	48004	48005	48006
48007	48008	48009	48000	48001	48002	48003	48004	48005	48						




External Wall (R7)


View: from FB (South) to RB (North)



View: from Outside (South) to Inside (North)

External Wall (F3)







82351 EL -1.5

- 81351 EL -6.9



- 180351 EL -11.5





Cylindrical Inner Wall




View: from West to East




View: from West to East




Iw-R3




Inner Wall (in Reactor Building)





Iw-R4




Inner Wall (X Direction 1; in Fuel Building)




A-13




11922 EL 3.65




11322 EL -1.5



10722 EL -6.9





El -11



View: from West to East
Inner Wall (X Direction 2; in Fuel Building)

View: from West to East

A-14



Inner Wall (X Direction 3; in Fuel Building)

EL - 3.65	11941 11741 11541 11341 10841 10541 10341 10141	93472 254472 192439 62472 291472 191472 191439 191408 191382 191360 254360 254380 192360 192380 192340 192322 292304	93439 254439 192408 62408 291408 191408 191382 191360 254360 254380 192360 192380 192340 192322 292304	93408 254408 192408 62408 291408 191408 191382 191360 254360 254380 192360 192380 192340 192322 292304	93380 254380 192380 624380 291380 191380 191360 191340 254360 254380 192360 192380 192340 192322 292304	93360 254360 192360 624360 291360 191360 191340 191322 254340 254360 192340 192360 192322 192304	93322 254322 192322 624322 291322 191322 191304 191286 254304 254322 192304 192322 192304	93304 254304 192304 624304 291304 191304 191286 191277 254277 254304 192304 192322 192304	
EL - 1.5									
EL - 6.9									
EL - 11.5									

FA

FB

FC

Iw-F7


Iw-F8

Iw-F9

FE



FF


View: from North to South




9122	91107	91081	91050	10702
110924	110923	110922	110921	10502
990122	990107	990081	990059	10302
110914	110913	110912	110911	10102
990122	990107	990081	990059	10302
110904	110903	110902	110901	10102
990122	990107	990081	990059	10302


EL - 6.9**EL - 11.5**









Radial Inner Wall (No.1: 7.5°)




Radial Inner Wall (No.4: 142.5°)




Radial Inner Wall (No.2: 82.5°)




Radial Inner Wall (No.5: 180.0°)




Radial Inner Wall (No.3: 97.5°)







Radial Inner Wall (No.6: 195.0°)




Radial Inner Wall (No.9: 277.5°)




Radial Inner Wall (No.7: 217.5°)



Radial Inner Wall (No.10: 352.5°)



Radial Inner Wall (No.8: 262.5°)





EL 2.65


EL -1.5

EL -6.9

EL -10.4



RPV Pedestal Liner



Basemat Liner

Appendix B Definition of Shell Element Property in NASTRAN User Manual

PSHELL Shell Element Property

Defines the membrane, bending, transverse shear, and coupling properties of thin shell elements.

Format:

1	2	3	4	5	6	7	8	9	10
PSHELL	PID	MID1	T	MID2	$12I/T^{**3}$	MID3	TS/T	NSM	
	Z1	Z2	MID4						

Example:

PSHELL	203	204	1.90	205	1.2	206	0.8	6.32	
	+.95	-.95							

Field	Contents
PID	Property identification number. (Integer > 0)
MID1	Material identification number for the membrane. (Integer ≥ 0 or blank)
T	Default membrane thickness for Ti on the connection entry. If T is blank then the thickness must be specified for Ti on the CQUAD4, CTRIA3, CQUAD8, and CTRIA6 entries. (Real or blank)
<u>MID2</u>	<u>Material identification number for bending.</u> (Integer ≥ -1 or blank)
12I/ T^{**3}	Bending moment of inertia ratio, $12I/T^3$. Ratio of the actual bending moment inertia of the shell, I , to the bending moment of inertia of a homogeneous shell, $T^3/12$. The default value is for a homogeneous shell. (Real > 0.0 ; Default = 1.0)
<u>MID3</u>	<u>Material identification number for transverse shear.</u> (Integer > 0 or blank; unless MID2 > 0 , must be blank.)
TS/T	Transverse shear thickness ratio, T_s/T . Ratio of the shear thickness, (T_s), to the membrane thickness of the shell, T . The default value is for a homogeneous shell. (Real > 0.0 ; Default = .833333)
NSM	Nonstructural mass per unit area. (Real)

Z1, Z2	Fiber distances for stress calculations. The positive direction is determined by the right-hand rule, and the order in which the grid points are listed on the connection entry. See Remark 11. for defaults. (Real or blank)
MID4	Material identification number for membrane-bending coupling. See Remarks 6. and 13. (Integer > 0 or blank, must be blank unless MID1 > 0 and MID2 > 0, may not equal MID1 or MID2.)

Remarks:

1. All PSHELL property entries should have unique identification numbers with respect to all other property entries.
2. The structural mass is calculated from the density using the membrane thickness and membrane material properties. If MID1 is blank, then the density is obtained from the MID2 material.
3. The results of leaving an MID field blank (or MID2 = -1) are:

MID1 No membrane or coupling stiffness

MID2 No bending, coupling, or transverse shear stiffness

MID3 No transverse shear flexibility

MID4 No bending-membrane coupling unless ZOFFS is specified on the connection entry. See Remark 6.

MID2=-1 See Remark 12.

Note: MID1 and MID2 must be specified if the ZOFFS field is also specified on the connection entry.

4. The continuation entry is not required.
5. The structural damping (GE on the MATi entry) is obtained from the MID1 material. If MID1 is blank, then it is obtained from the MID2 material. If PARAM,SHLDAMP,DIFF or DIFF is any other character except SAME, then the structural damping κ^4 matrix is computed using the GE entries on the MATi entries according to rules in the following table. If a single PSHELL corresponds to row 8 of the table, then all PSHELLs in the model will follow the rule of row 8. Rows 1-7 is an attempt to maintain upward compatibility, if a user inadvertently places a SHLDAMP,DIFF in the model

Caution: Large values of damping associated with an MID4 entry, when using PARAM,SHLDAMP,DIFF, can cause structural instability in transient dynamics.

Table 8-30 SHELL Structural Damping Rules

SHELL Structural Damping Rules					
Row	MID1	MID2	MID3	MID4	K^4 based on
1*	v	v			MID1 GE value
2	v				MID1 GE value
3	v	-1			MID1 GE value
4	v	v			MID1 GE value
5		v			MID2 GE value
6		v	v		MID2 GE value
7	v1	v2	v3	v4	$n \rightarrow$ total number of non blank vi $m \rightarrow$ total number of non zero ge_i If: $n = m$ and $ge_1 = ge_2 = \dots = ge_m$ Or: $m = 1$ and $ge_1 \neq 0$ Or: $m = 0$ MID1 GE value
8	v1	v2	v3	v4	Otherwise: $ge_1 \cdot$ membrane-stiff $+ ge_2 \cdot$ bending-stiff $+ ge_3 \cdot$ transverse shear-stiff $+ ge_4 \cdot$ bending-membrane-stiff is used

* v → MIDi values the same, vi → MIDi values different or blank

$ge_i \rightarrow$ GE value from a MATj entry associated with MIDi

If for row 8, a $ge_i = 0$ it is replaced by $ge_i = 1. - 8$

- The following should be considered when using MID4.

- The MID4 field should be left blank if the material properties are symmetric with respect to the middle surface of the shell. If the element centerline is offset from the plane of the grid points but the material properties are symmetric, the preferred method for modeling the offset is by use of the ZOFFS field on the connection entry. Although the MID4 field may be used for this purpose, it may produce ill-conditioned stiffness matrices (negative terms on factor diagonal) if done incorrectly.
 - Only one of the options MID4 or ZOFFS should be used; if both methods are specified the effects are cumulative. Since this is probably not what the user intended, unexpected answers will result. Note that the mass properties are not modified to reflect the existence of the offset when the ZOFFS and MID4 methods are used. If the weight or mass properties of an offset plate are to be used in an analysis, the RBAR method must be used to represent the offset. See “[Shell Elements \(CTRIA3, CTRIA6, CTRIAR, CQUAD4, CQUAD8, CQUADR\)](#)” on page 119 of the MSC.Nastran Reference Manual.
 - The effects of MID4 are not considered in the calculation of differential stiffness. Therefore, it is recommended that MID4 be left blank in buckling analysis.
7. This entry is referenced by the CTRIA3, CTRIA6, CTRIAR, CQUAD4, CQUAD8, and CQUADR entries via PID.
 8. For structural problems, MIDi must reference a MAT1, MAT2, or MAT8 material property entry
 9. If the transverse shear material MID3 or the membrane-bending coupling term MID4 references a MAT2 entry, then G33 must be zero. If MID3 references a MAT8 entry, then G1Z and G2Z must not be zero.
 10. For heat transfer problems, MIDi must reference a MAT4 or MAT5 material property entry.
 11. The default for Z1 is $-T/2$, and for Z2 is $+T/2$. T is the local plate thickness defined either by T on this entry or by membrane thicknesses at connected grid points, if they are input on connection entries.
 12. For plane strain analysis, set MID2=-1 and set MID1 to reference a MAT1 entry. In-plane loads applied to plain strain elements are interpreted as line loads with a value equal to the load divided by the thickness. Thus, if a thickness of “1.0” is used, the value of the line-load equals the load value. Pressure can be approximated with multiple line loads where the pressure value equals the line-load divided by the length between the loads.

13. For the CQUADR and CTRIAR elements, the MID4 field should be left blank because their formulation does not include membrane-bending coupling.
14. If MID_i is greater than or equal to 10^8 , then parameter NOCOMPS is set to +1 indicating that composite stress data recovery is desired. (MID_i greater than 10^8 are generated by PCOMP entries.)
15. For a material nonlinear property, MID1 must reference a MATS1 entry and be the same as MID2, unless a plane strain (MID2 = -1) formulation is desired. Also, MID3 cannot reference a MATS1 entry.
16. If transverse shear flexibility is specified for a model with curved shells where the loading is dominated by twist, results will not converge and may be inaccurate. PARAM,SNORM should be set for this unique model condition.