

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Identified LEAKAGE not within limits for reasons other than primary to secondary LEAKAGE.	C.1 Reduce LEAKAGE to within limits.	4 hours
D. Required Action and associated Completion Time of Condition A, B, or C not met.  <u>OR</u>  Pressure boundary LEAKAGE exists.  <u>OR</u>  Primary to secondary LEAKAGE not within limit.	D.1 Be in MODE 3.  <u>AND</u>  D.2 Be in MODE 5.	6 hours    36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.13.1</p> <p>-----NOTES-----</p> <p>1. Not required to be performed until 12 hours after establishment of steady state operation.</p> <p>2. Not applicable to primary to secondary LEAKAGE.</p> <p>-----</p> <p>Verify RCS operational LEAKAGE is within limits by performance of RCS water inventory balance.</p>	72 hours