

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>b. Intermediate Power Range – Upscale Function is not bypassed when APRM Simulated Thermal Power is > Intermediate Power Range Setpoint specified in the COLR and ≤ High Power Range Setpoint specified in the COLR.</p> <p>c. High Power Range – Upscale Function is not bypassed when APRM Simulated Thermal Power > High Power Range Setpoint specified in the COLR.</p>	
<p>SR 3.3.2.1.5 Verify the RWM is not bypassed when THERMAL POWER is ≤ 10% RTP.</p> <p>SR 3.3.2.1.6 -----NOTE----- Not required to be performed until 1 hour after reactor mode switch is in the shutdown position. -----</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	<p>24 months</p> <p>24 months</p>
<p>SR 3.3.2.1.7 -----NOTE----- Neutron detectors are excluded. -----</p> <p>Perform CHANNEL CALIBRATION.</p>	<p>24 months</p>
<p>SR 3.3.2.1.8 Verify control rod sequences input to the RWM are in conformance with BPWS.</p>	<p>Prior to declaring RWM OPERABLE following loading of sequence into RWM</p>