



**Potentially relevant existing FAQ numbers:**

This guidance is specific to the characterization of Main Control Board for Bin 4 determination. The characterization and counting of electrical cabinets for Bin 15 determination is addressed by FAQ 06-0016.

**Response Section**

It is proposed that the definition of Main Control Board provided in NUREG/CR-6850, Appendix L be accepted as also being applicable for Task 6, Bin 4 counting. Any panel that is detached from the main horseshoe would generally be excluded from this definition of the main control board with few exceptions.

**Basis:**

The guidance proposed will provide more consistency when determining plant specific control room ignition frequencies while working within the bounds of the existing data provided by the NUREG. This should facilitate the review and acceptability of the results.