



TELECOPY TRANSMITTAL

DATE: 4/13/07

TO: Taye Simmons

Fax Number: 1030-55-1078

FROM: Laura Luma

RE: Control # 316081

COMMENTS:

This transmittal consists of 5 pages (including transmittal cover sheet). Please contact me if you have any questions or problems with this transmittal.

2309 Shelby Avenue
Ann Arbor, MI 48103
(734) 662-9224 Fax
(734) 662-3197

70 E. 91st Street, Suite 106
Indianapolis, IN 46240
(317) 581-1931 Fax
(317) 581-1911

1780 E. Logan Avenue
Salt Lake City, UT 84108
(801) 467-8774 Office & Fax

N7375 Crystal Ridge Drive
Beaver Dam, WI 53916
(920) 885-9872 Fax
(920) 885-9870



United States Nuclear Regulatory Commission
Region III, Office of Materials Licensing
2443 Warrenville Road, Ste 210
Lisle, IL 60532-4352

Re: Amendment NRC License No. 21-32436-01
Control # 316081, Advanced Mobile Services, LLC

ATTN: To Whom It May Concern:

Please change our mailing address from 911 E. Nine Mile Rd., Ferndale, MI. 48220 to
1220 E. 9 Mile Road, Ferndale, MI, 48220.

If you have any questions or require additional information, please contact Laura Luna
at 734-662-3197.

Sincerely,

Laura Luna, BS
Medical Physics Consultant



Medical Physics Consultants, Inc.

Close-out Survey

Date performed: February 1, 2007

Performed by: Laura M. Luna, B.S.

Comments: Sealed sources and radioactive trash were transferred to our new location prior to performing the close-out survey.

Instruments

Wipe tests analyzed with a Captus 3000 (full spectrum) Well Counter #900271.

Instrument: Well Counter

| | | | |
|-----------------|-----------------|--------------------|-----------------------|
| Radionuclide: | <u>Cs-137</u> | MDA for Co-57: | <u>143 dpm</u> |
| Date completed: | <u>04/19/06</u> | Conversion factor: | <u>2.47 cpm / dpm</u> |

Area survey performed with the following survey meter:

| | |
|-------------------------------|-------------|
| Manufacturer: | Ludlum |
| Type: | GM |
| Model Number: | Model 14C |
| Serial Number: | 223710 |
| Probe Model: | Side Window |
| Annual Calibration Due: | 01/04/07 |
| Battery check acceptable: | YES |
| Operational check acceptable: | YES |
| Current reading: | 1.0 mR/hr |

History of Radionuclides Used

Unsealed

Tc-99m

Sealed

Co-57, Ba-133, and Cs-137

Last date of byproduct radiopharmaceutical use: January 31, 2007

Medical Physics Consultants, Inc.

Close-out Survey - continued

Visual Check: The area was checked to ensure that all sealed sources and radioactive waste had been removed. No evidence of radioactive material was noted.

Sealed Source Leak Testing: No history of leaks from Sealed Sources.


Radiation Level Survey: No area within the department demonstrated radiation levels in excess of the background reading of 0.02 mR/hr.

Removable Contamination: No area within the department demonstrated removable contamination in excess of 106 dpm's. There is no history of any spills of long-lived radioisotopes.

Conclusion: No radioactive materials remain in this department. No removable contamination is present.

Medical Physics Consultants, Inc.

Advanced Mobile Services, LLC
911 E. Nine Mile Rd.
Ferndale, MI 48220



19'0"

11'0"

Medical Physics Consultants, Inc.

Sealed Source Leak Test

Licensee: Advanced Mobile Services, LLC

Date: 02/01/07

Performed by: Laura Luna

| Nuclide | Type | Calibration | Calibration | Location | M/N | S/N |
|---------|-------|-------------|-------------|----------|---------|------------|
| | | Activity | Date | | | |
| Ba-133 | Vial | 285.0 uCi | 11/01/02 | Hot Lab | MED3550 | 30468 |
| Cs-137 | Vial | 222.4 uCi | 01/01/03 | Hot Lab | MED3550 | 32117 |
| Co-57 | Flood | 10 mCi | 10/06/05 | Van | BM05-10 | BM05100400 |
| Co-57 | Flood | 10 mCi | 06/16/06 | Van | BM05-10 | BM05100506 |
| Co-57 | Flood | 10 mCi | 01/31/07 | Van | BM05-10 | BM05100611 |

Comment: The sources listed above were leak tested using a dry wipe technique and were found to have less than 0.005 uCi removable activity. The following Minimum Detectable Activities are based upon a background at the indicated value. Background was at or below these levels when the above tests were completed.

Well Counter: Captus 3000

| Nuclide | MDA | Background |
|---------|--------------------------|------------------|
| Cs-137 | 2.0×10^{-4} uCi | 145 counts/1 min |
| Ba-133 | 8.8×10^{-5} uCi | 204 counts/1 min |
| Co-57 | 1.7×10^{-5} uCi | 53 counts/1 min |

RADIATION SAFETY OFFICER: _____