

April 17, 2007

Mr. David A. Christian
Sr. Vice President and Chief Nuclear Officer
Dominion Nuclear Connecticut, Inc.
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 3 — ERRATA FOR AMENDMENT
NO. 237, DELETING REDUNDANT SURVEILLANCE REQUIREMENTS
PERTAINING TO POST MAINTENANCE/POST MODIFICATION TESTING
(TAC NO. MD0693)

Dear Mr. Christian:

On March 29, 2007, the Nuclear Regulatory Commission (NRC) issued Amendment No. 237 to Facility Operating License No. NPF-49. Subsequent to issuance of this amendment it has come to the NRC staff's attention that Technical Specification (TS) page 3/4 1-25, issued with Amendment No. 237, did not contain other changes previously approved under Amendment No. 231. Specifically, section 3.1.3.4.a listed a value of T_{avg} [average temperature] greater than or equal to 551°F [degrees Fahrenheit]. However, this value was revised to 500°F under Amendment No. 231, which was issued on August 15, 2006. In addition, a revision bar was omitted on TS page 3/4 7-20. The correct TS pages 3/4 1-25 and 3/4 7-20 for Amendment No. 237 are enclosed.

Please contact John Hughey at 301-415-3204 should you have any questions.

Sincerely,

/ra/

G. Edward Miller, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: As stated

cc w/encl: Plant Mailing List

April 17, 2007

Mr. David A. Christian
Sr. Vice President and Chief Nuclear Officer
Dominion Nuclear Connecticut, Inc.
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 3 — ERRATA FOR AMENDMENT NO. 237, DELETING REDUNDANT SURVEILLANCE REQUIREMENTS PERTAINING TO POST MAINTENANCE/POST MODIFICATION TESTING (TAC NO. MD0693)

Dear Mr. Christian:

On March 29, 2007, the Nuclear Regulatory Commission (NRC) issued Amendment No. 237 to Facility Operating License No. NPF-49. Subsequent to issuance of this amendment it has come to the NRC staff's attention that Technical Specification (TS) page 3/4 1-25, issued with Amendment No. 237, did not contain other changes previously approved under Amendment No. 231. Specifically, section 3.1.3.4.a listed a value of T_{avg} [average temperature] greater than or equal to 551°F [degrees Fahrenheit]. However, this value was revised to 500°F under Amendment No. 231, which was issued on August 15, 2006. In addition, a revision bar was omitted on TS page 3/4 7-20. The correct TS pages 3/4 1-25 and 3/4 7-20 for Amendment No. 237 are enclosed.

Please contact John Hughey at 301-415-3204 should you have any questions.

Sincerely,

/ra/

G. Edward Miller, Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: As stated

cc w/encl: Plant Mailing List

DISTRIBUTION: PUBLIC Branch Reading RidsNrrDorLpl1-2 RidsAcrsAcnwMailCenter
RidsNrrLACSola RidsNrrPMGMiller RidsOgcRp RidsRgn1MailCenter RidsNRRDorl
RidsNrrPMJHughey GHill (2)

Accession Numbers: Package-ML071080138; Errata for Amendment Letter-ML071060063; TecSpec-ML071080046

OFFICE	LPL1-2/PM	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC
NAME	JHughey	GEMiller	CSola	HChernoff
DATE	4/16/2007	4/17/2007	4/16/2007	4/17/2007

Official Record Copy

Millstone Power Station, Unit No. 3

cc:

Lillilan M. Cuoco, Esquire
Senior Counsel
Dominion Resources Services, Inc.
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385

Edward L. Wilds, Jr., Ph.D.
Director, Division of Radiation
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

First Selectmen
Town of Waterford
15 Rope Ferry Road
Waterford, CT 06385

Mr. J. W. "Bill" Sheehan
Co-Chair NEAC
19 Laurel Crest Drive
Waterford, CT 06385

Mr. Evan W. Woollacott
Co-Chair
Nuclear Energy Advisory Council
128 Terry's Plain Road
Simsbury, CT 06070

Senior Resident Inspector
Millstone Power Station
c/o U.S. Nuclear Regulatory Commission
P. O. Box 513
Niantic, CT 06357

Ms. Nancy Burton
147 Cross Highway
Redding Ridge, CT 00870

Mr. Joseph Roy,
Director of Operations
Massachusetts Municipal Wholesale
Electric Company
Moody Street
P.O. Box 426
Ludlow, MA 01056

Mr. J. Alan Price
Site Vice President
Dominion Nuclear Connecticut, Inc.
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385

Mr. Chris Funderburk
Director, Nuclear Licensing and
Operations Support
Dominion Resources Services, Inc.
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

Mr. David W. Dodson
Licensing Supervisor
Dominion Nuclear Connecticut, Inc.
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385