

April 19, 2007

Mr. Richard M. Rosenblum
Senior Vice President and Chief Nuclear Officer
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

SUBJECT: SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 -
LICENSEE RESPONSE TO GENERIC LETTER 2006-02, "GRID RELIABILITY
AND THE IMPACT ON PLANT RISK AND THE OPERABILITY OF OFFSITE
POWER" (TAC NOS MD1030 AND MD1031)

Dear Rosenblum:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued GL 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Document Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) Use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RA/RC is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities.);
- (2) Use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) Offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout"; and
- (4) Losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request for Additional Information (RAI) (ADAMS Accession No. ML063380308), regarding the resolution of GL 2006-02 to 63 of 65 holders of

operating licenses for nuclear power reactors. The RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (Reliability and Loss-of-offsite Power (LOOP) Probability; and
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letter dated April 3, 2006 (ADAMS Accession No. ML061020082), and January 31, 2007 (ADAMS Accession No. ML070370193), Southern California Edison (the licensee) responded to the information request of GL 2006-02 and the subsequent RAI for San Onofre Nuclear Generating Station, Units 2 and 3. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-1480.

Sincerely,

/RA/

N. Kalyanam, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

cc w/encl: See next page

operating licenses for nuclear power reactors. The RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (Reliability and Loss-of-offsite Power (LOOP) Probability); and
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letter dated April 3, 2006 (ADAMS Accession No. ML061020082), and January 31, 2007 (ADAMS Accession No. ML070370193), Southern California Edison (the licensee) responded to the information request of GL 2006-02 and the subsequent RAI for San Onofre Nuclear Generating Station, Units 2 and 3. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-1480.

Sincerely,
/RA/
 N. Kalyanam, Project Manager
 Plant Licensing Branch IV
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

cc w/encl: See next page

DISTRIBUTION

PUBLIC	LPLIV r/f	RidsNrrDorLpl4
RidsNrrPMNKalyanam	RidsNrrLAJBurkhardt	RidsNrrDeEeeb
RidsAcrsAcnwMailCenter	RidsOgcRp	RidsNrrDorIDpr
RidsRgn4MailCenter	JRobinson	

ADAMS Accession No: ML071070005

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/DE/EEEB	NRR/LPL4/BC
NAME	NKalyanam	JBurkhardt	GWilson	THiltz
DATE	4/18/07	4/18/07	4/18/07	4/19/07

OFFICIAL RECORD COPY

San Onofre Nuclear Generating Station
Units 2 and 3

cc:

Mr. Daniel P. Breig
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

Mr. Douglas K. Porter, Esquire
Southern California Edison Company
2244 Walnut Grove Avenue
Rosemead, CA 91770

Mr. David Spath, Chief
Division of Drinking Water and
Environmental Management
P.O. Box 942732
Sacramento, CA 94234-7320

Chairman, Board of Supervisors
County of San Diego
1600 Pacific Highway, Room 335
San Diego, CA 92101

Mark L. Parsons
Deputy City Attorney
City of Riverside
3900 Main Street
Riverside, CA 92522

Mr. Gary L. Nolff
Assistant Director - Resources
City of Riverside
3900 Main Street
Riverside, CA 92522

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Mr. Michael R. Olson
San Diego Gas & Electric Company
8315 Century Park Ct. CP21G
San Diego, CA 92123-1548

Director, Radiologic Health Branch
State Department of Health Services
P.O. Box 997414, MS 7610
Sacramento, CA 95899-7414

Resident Inspector/San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, CA 92674

Mayor
City of San Clemente
100 Avenida Presidio
San Clemente, CA 92672

Mr. James T. Reilly
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

Mr. James D. Boyd, Commissioner
California Energy Commission
1516 Ninth Street (MS 31)
Sacramento, CA 95814

Mr. Ray Waldo, Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92764-0128

Mr. Brian Katz
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92764-0128

Mr. Steve Hsu
Department of Health Services
Radiologic Health Branch
MS 7610, P.O. Box 997414
Sacramento, CA 95899

March 2006

San Onofre Nuclear Generating Station
Units 2 and 3

-2-

cc:

Mr. A. Edward Scherer
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

March 2006