

April 30, 2007

Mr. R. T. Ridenoure
Vice President - Chief Nuclear Officer
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOUN STATION, UNIT 1 - RESPONSE TO GENERIC LETTER
2006-02, "GRID RELIABILITY AND THE IMPACT ON PLANT RISK AND THE
OPERABILITY OF OFFSITE POWER" (TAC NO. MD0983)

Dear Mr. Ridenoure:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) Use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications. (The TSO, ISO, or RA/RC is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities);
- (2) Use of NPP/TSO protocols and analysis tools by the TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) Offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout"; and
- (4) Losses-of-offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a request for additional information (RAI) (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. This RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability);
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated April 3, 2006 (ADAMS Accession No. ML060930495), and January 16, 2007 (ADAMS Accession No. ML070240203), you responded to the information request of GL 2006-02 and the subsequent RAI, respectively. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training, and considers your response to GL 2006-02 complete.

If you have any questions, please contact me at 301-415-1445.

Sincerely,

/RAI

Alan Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: See next page

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability);
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated April 3, 2006 (ADAMS Accession No. ML060930495), and January 16, 2007 (ADAMS Accession No. ML070240203), you responded to the information request of GL 2006-02 and the subsequent RAI, respectively. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training, and considers your response to GL 2006-02 complete.

If you have any questions, please contact me at 301-415-1445.

Sincerely,
/RA/

Alan Wang, Project Manager
 Plant Licensing Branch IV
 Division of Operating Reactor Licensing
 Office of Nuclear Reactor Regulation

Docket Nos. 50-285

cc: See next page

DISTRIBUTION:
 PUBLIC
 LPLIV Reading
 RidsNrrDorl (CHaney/JLubinski)
 RidsNrrDorlLpl4 (THiltz)
 RidsOgcRp
 RidsNrrPMAWang
 RidsNrrLALFeizollahi
 RidsAcrsAcnwMailCenter
 RidsRegion4MailCenter
 RidsNrrDeEeeb (GWilson)

ACCESSION NO.: ML071070012

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	DE/EEEE/BC	NRR/LPL4/BC
NAME	AWang	LFeizollahi	GWilson	THiltz
DATE	4/30/07	4/26/07	4/23/07	4/30/07

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1700 K Street, N.W.
Washington, DC 20006-3817

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Hanna, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Julia Schmitt, Manager
Radiation Control Program
Nebraska Health & Human Services R & L
Public Health Assurance
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Joe L. McManis
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
Lucas State Office Building, 5th Floor
321 East 12th Street
Des Moines, IA 50319

April 2006