

April 18, 2007

Jeffery B. Archie
Vice President, Nuclear Operations
Virgil C. Summer Nuclear Station
P.O. Box 88
Jenkinsville, SC 29065

SUBJECT: SOUTH CAROLINA ELECTRIC & GAS COMPANY RESPONSE TO GENERIC LETTER 2006-02 "GRID RELIABILITY AND THE IMPACT ON PLANT RISK AND THE OPERABILITY OF OFFSITE POWER" (TAC NO. MD1037)

Dear Mr. Archie:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued GL 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Document Access and Management System (ADAMS) Accession No. ML060180352) to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) Use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RA/RC is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities);
- (2) Use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) Offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout;" and
- (4) Losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request For Additional Information (RAI)(ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees to respond to questions in the following areas:

- (1) Switchyard minimum voltage;
- (2) Loss of real-time contingency analysis (RTCA) capability;
- (3) Verification of RTCA predicted post-trip voltage;
- (4) Identification of applicable single contingencies;
- (5) Seasonal variation in grid stress (reliability and loss-of-offsite power probability);
- (6) Interface with transmission system operator during extended plant maintenance.

By letter(s) dated April 3, 2006, (ADAMS Accession No. ML060950363) and January 31, 2007 (ADAMS Accession No. ML070330134) you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 to be complete.

If you have any questions, please contact me 301-415-1493.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager
Plant Licensing Branch 2-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-395

cc: See next page

April 18, 2007

- (1) Switchyard minimum voltage;
- (2) Loss of real-time contingency analysis (RTCA) capability;
- (3) Verification of RTCA predicted post-trip voltage;
- (4) Identification of applicable single contingencies;
- (5) Seasonal variation in grid stress (reliability and loss-of-offsite power probability);
- (6) Interface with transmission system operator during extended plant maintenance.

By letter(s) dated April 3, 2006, (ADAMS Accession No. ML060950363) and January 31, 2007 (ADAMS Accession No. ML070330134) you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 to be complete.

If you have any questions, please contact me 301-415-1493.

Sincerely,

/RA/

Robert E. Martin, Senior Project Manager
 Plant Licensing Branch 2-1
 Division of Operating Licensing
 Office of Nuclear Reactor Regulation

Docket No. 50-395

cc: See next page

DISTRIBUTION:

PUBLIC	LPL2-1 R/F
RidsNrrPMRMartin (hard copy)	RidsNrrLAMCSola (hard copy)
RidsRgn2MailCenter (EGuthrie)	RidsNrrDorlLpl2-1(EMarinos)
RidsAcrcAcnwMailCenter	RidsOgcRp
GWilson, NRR	JRobinson, NRR

ADAMS Accession No. - ML071070359

OFFICE	NRR/LPL2-1/PM	NRR/LPL2-1/LA	NRR/EEEEA/BC	NRR/LPL2-1/BC
NAME	RMartin:nc	CSola	GWilson	EMarinos
DATE	04/11/07	04/19/07	04/18/07	04/18/07

OFFICIAL RECORD COPY

Virgil C. Summer Nuclear Station

cc:

Mr. Jeffrey B. Archie
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88
Jenkinsville, SC 29065

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 802
Jenkinsville, SC 29065

Resident Inspector/Summer NPS
c/o U.S. Nuclear Regulatory Commission
576 Stairway Road
Jenkinsville, SC 29065

Chairman, Fairfield County Council
Drawer 60
Winnsboro, SC 29180

Mr. Henry Porter, Assistant Director
Division of Waste Management
Bureau of Land & Waste Management
Dept. of Health & Environmental Control
2600 Bull Street
Columbia, SC 29201

Mr. Thomas D. Gatlin, General Manager
Nuclear Plant Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 300
Jenkinsville, SC 29065

Mr. Robert G. Sweet, Manager
Nuclear Licensing
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
Post Office Box 88, Mail Code 830
Jenkinsville, SC 29065

Ms. Kathryn M. Sutton
Morgan, Lewis & Bockius LLP
111 Pennsylvania Avenue, NW.
Washington, DC 20004