



April 16, 2007

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Serial No. 07-0241  
KPS/LIC/CDS: R0  
Docket No. 50-305  
License No. DPR-43

**DOMINION ENERGY KEWAUNEE, INC.**  
**KEWAUNEE POWER STATION**  
**CYCLE 27 AND 28 CORE OPERATING LIMITS REPORTS**

Pursuant to Kewaunee Power Station (KPS) Technical Specification (TS) 6.9.a.4.D, enclosed are copies of the KPS cycle 27, revision 1 and cycle 28, revision 0, Core Operating Limits Reports (COLR).

KPS TS 6.9.a.4.D states that the COLR, including any mid-cycle revisions or supplements, shall be provided upon issuance to the NRC for each reload cycle. It was recently discovered during an internal review of site reporting requirements that the attached COLR's had not been submitted upon issuance, as required. This non-conformance has been documented in the KPS corrective action program and actions have been implemented to ensure that future COLR's are submitted to NRC upon issuance, as required. We apologize for any inconvenience this may have caused.

If you have any questions or require additional information, please contact Mr. Craig Sly at (804) 273-2784.

Very truly yours,

A handwritten signature in black ink, appearing to read "Gerald T. Bischof".

Gerald T. Bischof  
Vice President - Nuclear Engineering

Commitments made by this letter: None.

References: None

Attachments:

1. TRM 2.1, Kewaunee Nuclear Power Plant Core Operating Limits Report (COLR), Cycle 27, Revision 1.
2. TRM 2.1, Kewaunee Power Station Core Operating Limits Report (COLR), Cycle 28, Revision 0.

cc: Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
2443 Warrenville Road  
Suite 210  
Lisle, IL 60532-4352

Ms. M. H. Chernoff  
U.S. Nuclear Regulatory Commission  
Mail Stop 8 G9A  
Washington, D. C. 20555

Mr. S. C. Burton  
NRC Senior Resident Inspector  
Kewaunee Power Station

**ATTACHMENT 1**

**TRM 2.1  
KEWAUNEE NUCLEAR POWER PLANT CORE OPERATING LIMITS REPORT  
(COLR), CYCLE 27, REVISION 1**

**KEWAUNEE POWER STATION**

**DOMINION ENERGY KEWAUNEE, INC.**

TRM 2.1

Kewaunee Nuclear Power Plant  
CORE OPERATING LIMITS REPORT  
(COLR)

CYCLE 27

REVISION 1

Approved

*M. J. Henry for K. Davison*  
PQRC Chairman

*Via telcom*  
7-15-05  
Date

05-103  
Mtg.#

## Table of Contents

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	CORE OPERATING LIMITS REPORT .....	1
2.0	OPERATING LIMITS .....	2
2.1	Reactor Core Safety Limits .....	2
2.2	Shutdown Margin (SDM) .....	2
2.3	Moderator Temperature Coefficient .....	2
2.4	Shutdown Bank Insertion Limit .....	2
2.5	Control Bank Insertion Limits .....	2
2.6	Nuclear Heat Flux Hot Channel Limits ( $F_Q^N(Z)$ ) .....	3
2.7	Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ ) .....	4
2.8	Axial Flux Difference (AFD) .....	4
2.9	Overtemperature $\Delta T$ Setpoint .....	5
2.10	Overpower $\Delta T$ Setpoint .....	5
2.11	RCS Pressure, Temperature, and Flow Departure From .....	6
	Nucleate Boiling (DNB) Limits	
2.12	Refueling Boron Concentration .....	6

**List of Figures**

<b>Figure</b>	<b>Title</b>	<b>Page</b>
1.	Reactor Core Safety Limits Curve (1772 MWt) .....	7
2.	Required Shutdown Reactivity vs. Boron Concentration.....	8
3.	Hot Channel Factor Normalized Operating Envelope (K(z)) .....	9
4.	Control Bank Insertion Limits .....	10
5a.	RAOC Summary of W(Z) at 150 MWD/MTU .....	11
5b.	RAOC Summary of W(Z) at 4000 MWD/MTU .....	12
5c.	RAOC Summary of W(Z) at 8000 MWD/MTU .....	13
5d.	RAOC Summary of W(Z) at 10000 MWD/MTU .....	14
5e.	RAOC Summary of W(Z) at 12000 MWD/MTU .....	15
5f.	RAOC Summary of W(Z) at 16000 MWD/MTU .....	16
6.	Penalty Factor, $F_p(\%)$ , for $F_Q^{EQ}(Z)$ .....	17
7.	Axial Flux Difference .....	18

**List of Tables**

<b><u>Table</u></b>	<b><u>Title</u></b>	<b><u>Page</u></b>
1.	NRC Approved Methodologies for COLR Parameters	19

CORE OPERATING LIMITS REPORT CYCLE 27

1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for Kewaunee Nuclear Power Plant (KNPP) has been prepared in accordance with the requirements of Technical Specification (TS) 6.9.a.4.

A cross-reference between the COLR sections and the KNPP Technical Specifications affected by this report is given below:

COLR Section	KNPP TS	Description
2.1	2.1	Reactor Core Safety Limits
2.2	3.10.a	Shutdown Margin
2.3	3.1.f.3	Moderator Temperature Coefficient
2.4	3.10.d.1	Shutdown Bank Insertion Limit
2.5	3.10.d.2	Control Bank Insertion Limits
2.6	3.10.b.1.A 3.10.b.5 3.10.b.6.C.i	Heat Flux Hot Channel Factor ( $F_Q(Z)$ )
2.7	3.10.b.1.B	Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ )
2.8	3.10.b.8	Axial Flux Difference (AFD)
2.9	2.3.a.3.A	Overtemperature $\Delta T$ Setpoint
2.10	2.3.a.3.B	Overpower $\Delta T$ Setpoint
2.11	3.10.k 3.10.l 3.10.m.1	RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
2.12	3.8.a.5	Refueling Boron Concentration
Figure 1		Reactor Core Safety Limits (1772 MWt)
Figure 2		Required Shutdown Margin
Figure 3		K(Z) Normalized Operating Envelope
Figure 4		Control Bank Insertion Limits
Figure 5a		RAOC Summary of W(Z) at 150 MWD/MTU
Figure 5b		RAOC Summary of W(Z) at 4000 MWD/MTU
Figure 5c		RAOC Summary of W(Z) at 8000 MWD/MTU
Figure 5d		RAOC Summary of W(Z) at 10000 MWD/MTU
Figure 5e		RAOC Summary of W(Z) at 12000 MWD/MTU
Figure 5f		RAOC Summary of W(Z) at 16000 MWD/MTU
Figure 6		Penalty Factor, $F_p(\%)$ , for $F_Q^{EQ}(Z)$
Figure 7		Axial Flux Difference



CORE OPERATING LIMITS REPORT CYCLE 27

---

2.0 Operating Limits

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC approved methodologies specified in Technical Specification 6.9.a.4.

2.1 Reactor Core Safety Limits

The combination of rated power level, coolant pressure, and coolant temperature shall not exceed the limits shown in COLR Figure 1 (1772 MWt). The safety limit is exceeded if the point defined by the combination of Reactor Coolant System average temperature and power level is at any time above the appropriate pressure line.

2.2 Shutdown Margin

2.2.1 When the reactor is subcritical prior to reactor startup, the SHUTDOWN margin shall be at least that shown in COLR Figure 2.

2.3 Moderator Temperature Coefficient

2.3.1 When the reactor is critical and  $\leq 60\%$  RATED POWER, the moderator temperature coefficient shall be  $\leq 5.0$  pcm/ $^{\circ}$ F, except during LOW POWER PHYSICS TESTING. When the reactor is  $> 60\%$  RATED POWER, the moderator temperature coefficient shall be zero or negative.

2.3.2 The reactor will have a moderator temperature coefficient no less negative than  $-8$  pcm/ $^{\circ}$ F for 95% of the cycle time at full power.

2.4 Shutdown Bank Insertion Limit

2.4.1 The shutdown rods shall be fully withdrawn ( $\geq 226$  steps and  $\leq 231$  steps) when the reactor is critical or approaching criticality.

2.5 Control Bank Insertion Limit

2.5.1 The control banks shall be limited in physical insertion; insertion limits are shown in COLR Figure 4.

CORE OPERATING LIMITS REPORT CYCLE 27

2.6 Nuclear Heat Flux Hot Channel Factor ( $F_Q^N(Z)$ )

2.6.1  $F_Q^N(Z)$  Limits for Fuel

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (2.35)/P \times K(Z) \text{ for } P > 0.5 \quad \text{[FRA-ANP Hvy]}$$

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (4.70) \times K(Z) \text{ for } P \leq 0.5 \quad \text{[FRA-ANP Hvy]}$$

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (2.28)/P \times K(Z) \text{ for } P > 0.5 \quad \text{[FRA-ANP Std]}$$

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (4.56) \times K(Z) \text{ for } P \leq 0.5 \quad \text{[FRA-ANP Std]}$$

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (2.50)/P \times K(Z) \text{ for } P > 0.5 \quad \text{[422 V+]}$$

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (5.00) \times K(Z) \text{ for } P \leq 0.5 \quad \text{[422 V+]}$$

where:

P is the fraction of full power at which the core is OPERATING

K(Z) is the function given in Figure 3

Z is the core height location for the  $F_Q$  of interest

2.6.2 The measured  $F_Q^{EQ}(Z)$  hot channel factors under equilibrium conditions shall satisfy the following relationship for the central axial 80% of the core for fuel:

$$F_Q^{EQ}(Z) \times 1.03 \times 1.05 \times W(Z) \times F_p \leq (2.35)/P \times K(Z) \quad \text{[FRA-ANP Hvy]}$$

$$F_Q^{EQ}(Z) \times 1.03 \times 1.05 \times W(Z) \times F_p \leq (2.28)/P \times K(Z) \quad \text{[FRA-ANP Std]}$$

$$F_Q^{EQ}(Z) \times 1.03 \times 1.05 \times W(Z) \times F_p \leq (2.5)/P \times K(Z) \quad \text{[422 V+]}$$

where:

P is the fraction of full power at which the core is OPERATING

K(Z) is the function given in Figure 3

Z is the core height location for the  $F_Q$  of interest

$F_p$  is the  $F_Q^{EQ}(Z)$  penalty factor described in 2.6.3.

W(Z) is the function given in Figure 5

$F_Q^{EQ}(Z)$  is a measured  $F_Q$  distribution obtained during the target flux determination

CORE OPERATING LIMITS REPORT CYCLE 27

---

- 2.6.3 The penalty factor of 1.0 shall be used for TS 3.10.b.6.A and TS 3.10.b.6.B.  
The penalty factor provided in Figure 6 shall be used for TS 3.10.b.6.C.i.  
The penalty factor for all burnups outside the range of Figure 6 shall be 2%.

2.7 Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ )

2.7.1  $F_{\Delta H}^N$  Limits for Fuel

$$F_{\Delta H}^N \times 1.04 \leq 1.38 [1 + 0.3(1-P)] \quad \text{[FRA-ANP Hvy]}$$

$$F_{\Delta H}^N \times 1.04 \leq 1.70 [1 + 0.3(1-P)] \quad \text{[422 V+]}$$

$$F_{\Delta H}^N \times 1.04 \leq 1.38 [1 + 0.3(1-P)] \quad \text{[FRA-ANP Std]}$$

where:

P is the fraction of full power at which the core is OPERATING

2.8 Axial Flux Difference (AFD)

- 2.8.1 The Axial Flux Difference (AFD) acceptable operation limits are provided in Figure 7.

CORE OPERATING LIMITS REPORT CYCLE 27

2.9 Overtemperature  $\Delta T$  Setpoint

Overtemperature  $\Delta T$  setpoint parameter values:

- $\Delta T_0$  = Indicated  $\Delta T$  at RATED POWER, %
- $T$  = Average temperature, °F
- $T'$   $\leq$  573.0 °F
- $P$  = Pressurizer Pressure, psig
- $P'$  = 2235 psig
- $K_1$  = 1.195
- $K_2$  = 0.015/°F
- $K_3$  = 0.00072/psig
- $\tau_1$  = 30 seconds
- $\tau_2$  = 4 seconds
- $f(\Delta I)$  = An even function of the indicated difference between top and bottom detectors of the power range nuclear ion chambers. Selected gains are based on measured instrument response during plant startup tests, where  $q_t$  and  $q_b$  are the percent power in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total core power in percent of RATED POWER, such that
  - (a) For  $q_t - q_b$  within -15, +10 %,  $f(\Delta I) = 0$
  - (b) For each percent that the magnitude of  $q_t - q_b$  exceeds +10 % the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 1.51 % of RATED POWER.
  - (c) For each percent that the magnitude of  $q_t - q_b$  exceed -15 % the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 3.78% of RATED POWER.

2.10 Overpower  $\Delta T$  Setpoint

Overpower  $\Delta T$  setpoint parameter values:

- $\Delta T_0$  = Indicated  $\Delta T$  at RATED POWER, %
- $T$  = Average temperature, °F
- $T'$   $\leq$  573.0 °F
- $K_4$   $\leq$  1.095
- $K_5$   $\geq$  0.0275/°F for increasing  $T$ ; 0 for decreasing  $T$
- $K_6$   $\geq$  0.00103/°F for  $T > T'$  ; 0 for  $T < T'$
- $\tau_3$  = 10 seconds
- $f(\Delta I)$  = 0 for all  $\Delta I$

CORE OPERATING LIMITS REPORT CYCLE 27


---

- 2.11 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
  - 2.11.1 During steady state power operation,  $T_{avg}$  shall be  $< 576.7^{\circ}\text{F}$  for control board indication or  $< 576.5^{\circ}\text{F}$  for computer indication.
  - 2.11.2 During steady state power operation, Pressurizer Pressure shall be  $> 2217$  psig for control board indication or  $> 2219$  psig for computer indication
  - 2.11.3 During steady state power operation, reactor coolant total flow rate shall be  $\geq 186,000$  gpm.
  
- 2.12 Refueling Boron Concentration
  - 2.12.1 When there is fuel in the reactor, a minimum boron concentration of 2500 ppm and a shutdown margin of  $\geq 5\% \Delta k/k$  shall be maintained in the Reactor Coolant System during reactor vessel head removal or while loading and unloading fuel from the reactor.

CORE OPERATING LIMITS REPORT CYCLE 27


Figure 1

Reactor Core Safety Limits Curve (1772 Mwt)  
(Cores Containing 422V+ fuel)



CORE OPERATING LIMITS REPORT CYCLE 27


**Figure 2**  
**Required Shutdown Reactivity vs. Boron**  
**Concentration**



CORE OPERATING LIMITS REPORT CYCLE 27

---


**Figure 3**  
**Hot Channel Factor Normalized Operating Envelope**





CORE OPERATING LIMITS REPORT CYCLE 27

**Figure 4**  
**Control Bank Insertion Limits**




Fully withdrawn shall be the condition where control rods are at a position within the interval  $\geq 226$  and  $\leq 231$  steps withdrawn.

Note: The Rod Bank Insertion Limits are based on a control bank tip-to-tip distance of 126 steps.

CORE OPERATING LIMITS REPORT CYCLE 27

Figure 5a  
RAOC Summary of W(Z) at 150 MWD/MTU




Bottom

Top

CORE OPERATING LIMITS REPORT CYCLE 27


---

Figure 5b  
RAOC Summary of W(Z) at 4000 MWD/MTU



CORE OPERATING LIMITS REPORT CYCLE 27


Figure 5c  
RAOC Summary of W(Z) at 8000 MWD/MTU



CORE OPERATING LIMITS REPORT CYCLE 27


---

**Figure 5d**  
**RAOC Summary of W(Z) at 10000 MWD/MTU**




CORE OPERATING LIMITS REPORT CYCLE 27

Figure 5e  
RAOC Summary of W(Z) at 12000 MWD/MTU



CORE OPERATING LIMITS REPORT CYCLE 27

**Figure 5f**  
**RAOC Summary of W(Z) at 16000 MWD/MTU**



CORE OPERATING LIMITS REPORT CYCLE 27

---

Figure 6  
Penalty Factor,  $F_p$  (%), for  $F_Q^{EQ}(Z)$

Cycle Burnup (MWD/MTU)	Penalty Factor $F_p$ (%)
150	2.00
19700	2.00


Note: Linear interpolation is adequate for intermediate cycle burnup.

All cycle burnups outside the range of the table shall use a penalty factor,  $F_p$ , of 2.0%.  
Refer to TS 3.10.b.6.C.



CORE OPERATING LIMITS REPORT CYCLE 27

Figure 7  
Axial Flux Difference



Note: This figure represents the Relaxed Axial Offset Control (RAOC) band used in safety analyses, it may be administratively tightened depending on in-core flux map results. Refer to Figure RD 11.4.1 of the Reactor Data Manual.

CORE OPERATING LIMITS REPORT CYCLE 27

**Table 1**

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
2.1	Reactor Core Safety Limits	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p>
2.2	Shutdown Margin	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>
2.3	Moderator Temperature Coefficient	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>
2.4	Shutdown Bank Insertion Limit	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>

CORE OPERATING LIMITS REPORT CYCLE 27

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
		Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.
2.5	Control Bank Insertion Limits	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p>
2.6	Heat Flux Hot Channel Factor	<p>WCAP-10216-P-A, Revision 1A, "Relaxation of Constant Axial Offset Control-<math>F_D</math> Surveillance Technical Specification," February 1994.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>WCAP-12945-P-A (Proprietary), "Westinghouse Code Qualification Document for Best-Estimate Loss-of-Coolant Accident Analysis," Volume I, Rev.2, and Volumes II-V, Rev.1, and WCAP-14747 (Non-Proprietary), March 1998.</p>

CORE OPERATING LIMITS REPORT CYCLE 27

Table 1 (cont)

NRC Approved Methodologies for COLR Parameters

<u>COLR Section</u>	<u>Parameter</u>	<u>NRC Approved Methodology</u>
		ANF-88-133 (P)(A) and Supplement 1, "Qualification of Advanced Nuclear Fuels' PWR Design Methodology for Rod Burnups of 62 GWd/MTU," Advanced Nuclear Fuels Corporation, dated December 1991.
	(F <sub>α</sub> (Z))	WCAP-14449-P-A, "Application Of Best Estimate Large Break LOCA Methodology To Westinghouse PWRs With Upper Plenum Injection," Revision1, and WCAP-14450-NP-A, Rev.1 (Non-Proprietary), October 1999.
		WCAP-12610-P-A, "Vantage+ Fuel Assembly Reference Core Report," April 1995.
	Model	WCAP-10054-P-A, "Westinghouse Small Break ECCS Evaluation Using the NOTRUMP Code," August 1985. Note: WCAP-10081-A as referenced in TS which is the non-prop version of WCAP-10054-P-A.
	NOTRUMP	WCAP-10054-P-A, Addendum 2, Revision 1, "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the Code: Safety Injection into the Broken Loop and COSI Condensation Model," July 1997.
2.7	Nuclear Enthalpy Rise Hot Channel Factor (F <sub>ΔH</sub> <sup>N</sup> )	WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.  Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.  Kewaunee Nuclear Power Plant-Review forKewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.

CORE OPERATING LIMITS REPORT CYCLE 27

Table 1 (cont)

NRC Approved Methodologies for COLR Parameters

<u>COLR Section</u>	<u>Parameter</u>	<u>NRC Approved Methodology</u>
		<p>XN-82-06 (P)(A) Revision 1 and Supplements 2, 4, and 5, "Qualifications of Exxon Nuclear Fuel for Extended Burnup, Exxon Nuclear Company, dated October 1986.</p> <p>ANF-88-133 (P)(A) and Supplement 1, "Qualification of Advanced Nuclear Fuels' PWR Design Methodology for Rod Burnups for 62 GWd/MTU," Advanced Nuclear Fuels Corporation, dated December 1991.</p> <p>EMF-92-116 (P)(A) Revision 0, "Generic Mechanical Design Criteria for PWR Fuel Designs," Siemens Power Corporation, dated February 1999.</p>
2.8	Axial Flux Difference	<p>WCAP-10216-P-A, Revision 1A, "Relaxation of Constant Axial Offset (AFD) Control-F<sub>0</sub> Surveillance Technical Specification," February 1994.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p>
2.9	Reactor Protection System (RPS) Instrumentation-Overtemperature $\Delta T$	<p>WCAP-8745-P-A, "Design Bases For The Thermal Overpower <math>\Delta T</math> and Thermal Overtemperature <math>\Delta T</math> Trip Functions," September 1986.</p>

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
		<p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p> <p>CENP-397-P-A, "Improved Flow Measurement Accuracy Using Cross Flow Ultrasonic Flow Measurement Technology," Rev. 1, May 2000.</p>
2.10	Reactor Protection System (RPS) Instrumentation-Overpower $\Delta T$	<p>WCAP-8745-P-A, "Design Bases For The Thermal Overpower <math>\Delta T</math> and Thermal Overtemperature <math>\Delta T</math> Trip Functions," September 1986.</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p> <p>CENP-397-P-A, "Improved Flow Measurement Accuracy Using Cross Flow Ultrasonic Flow Measurement Technology," Rev. 1, May 2000.</p>
2.11	RCS Pressure, Temperature, and Flow Departure From Nucleate (DNB) Limits	<p>WCAP-11397-P-A, "Revised Thermal Design Procedure, "April 1989, for those events analyzed using RTDP</p> <p>WCAP-15591, "Westinghouse Revised Thermal Design Procedure Instrument Uncertainty Methodology-Kewaunee Nuclear Power Plant (Power Upate to 1757 MWt-NSSS Power with Feedwater Venturis, or 1780 MWt-NSSS Power with Ultrasonic Flow Measurements, and 54F Replacement Steam Generators), Revision 1, December</p>

CORE OPERATING LIMITS REPORT CYCLE 27

---

2002, Proprietary. Safety Evaluation dated  
July 8, 2003.

Table 1 (cont)

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
2.12	Boron Concentration	<p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p> <p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985 for those events not utilizing RTDP.</p> <p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>

**ATTACHMENT 2**

**TRM 2.1  
KEWAUNEE POWER STATION CORE OPERATING LIMITS REPORT (COLR),  
CYCLE 28, REVISION 0**

**KEWAUNEE POWER STATION  
DOMINION ENERGY KEWAUNEE, INC.**



TRM 2.1

Kewaunee Power Station

CORE OPERATING LIMITS REPORT  
(COLR)

CYCLE 28

REVISION 0

Approved

Tom Webb  
PORC Chairman

8 Sept 2006  
Date

06-086  
Mtg.#

## Table of Contents

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	CORE OPERATING LIMITS REPORT .....	1
2.0	OPERATING LIMITS .....	2
2.1	Reactor Core Safety Limits .....	2
2.2	Shutdown Margin (SDM) .....	2
2.3	Moderator Temperature Coefficient .....	2
2.4	Shutdown Bank Insertion Limit .....	2
2.5	Control Bank Insertion Limits .....	2
2.6	Nuclear Heat Flux Hot Channel Limits ( $F_Q^N(Z)$ ) .....	3
2.7	Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ ) .....	4
2.8	Axial Flux Difference (AFD) .....	4
2.9	Overtemperature $\Delta T$ Setpoint .....	5
2.10	Overpower $\Delta T$ Setpoint .....	5
2.11	RCS Pressure, Temperature, and Flow Departure From .....	6
	Nucleate Boiling (DNB) Limits	
2.12	Refueling Boron Concentration .....	6

**List of Figures**

<b>Figure</b>	<b>Title</b>	<b>Page</b>
1.	Reactor Core Safety Limits Curve (1772 MWt).....	7
2.	Required Shutdown Reactivity vs. Boron Concentration.....	8
3.	Hot Channel Factor Normalized Operating Envelope (K(z)).....	9
4.	Control Bank Insertion Limits .....	10
5.	W(Z) Values (Top and Bottom 9% excluded).....	11
6.	Penalty Factor, $F_p$ (%), for $F_a^{EQ}(Z)$ .....	13
7.	Axial Flux Difference .....	14

**List of Tables**

<b><u>Table</u></b>	<b><u>Title</u></b>	<b><u>Page</u></b>
1.	NRC Approved Methodologies for COLR Parameters	15

CORE OPERATING LIMITS REPORT CYCLE 28

1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for Kewaunee Power Station (KPS) has been prepared in accordance with the requirements of Technical Specification (TS) 6.9.a.4.

A cross-reference between the COLR sections and the KPS Technical Specifications affected by this report is given below:

COLR Section	KPS TS	Description
2.1	2.1	Reactor Core Safety Limits
2.2	3.10.a	Shutdown Margin
2.3	3.1.f.3	Moderator Temperature Coefficient
2.4	3.10.d.1	Shutdown Bank Insertion Limit
2.5	3.10.d.2	Control Bank Insertion Limits
2.6	3.10.b.1.A	Heat Flux Hot Channel Factor ( $F_Q(Z)$ )
	3.10.b.5	
	3.10.b.6	
	3.10.b.6.C.i	
	3.10.b.7	
2.7	3.10.b.1.B	Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ )
2.8	3.10.b.8	Axial Flux Difference (AFD)
2.9	2.3.a.3.A	Overtemperature $\Delta T$ Setpoint
2.10	2.3.a.3.B	Overpower $\Delta T$ Setpoint
2.11	3.10.k	RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
	3.10.l	
	3.10.m.1	
2.12	3.8.a.5	Refueling Boron Concentration
Figure 1		Reactor Core Safety Limits (1772 MWt)
Figure 2		Required Shutdown Margin
Figure 3		$K(Z)$ Normalized Operating Envelope
Figure 4		Control Bank Insertion Limits
Figure 5		$W(Z)$ Values (Top and Bottom 9% excluded)
Figure 6		Penalty Factor, $F_p$ , for $F_Q^{EQ}(Z)$
Figure 7		Axial Flux Difference

CORE OPERATING LIMITS REPORT CYCLE 28

---

2.0 Operating Limits

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC approved methodologies specified in Technical Specification 6.9.a.4.

2.1 Reactor Core Safety Limits

The combination of rated power level, coolant pressure, and coolant temperature shall not exceed the limits shown in COLR Figure 1 (1772 MWt). The safety limit is exceeded if the point defined by the combination of Reactor Coolant System average temperature and power level is at any time above the appropriate pressure line.

2.2 Shutdown Margin

2.2.1 When the reactor is subcritical prior to reactor startup, the SHUTDOWN margin shall be at least that shown in COLR Figure 2.

2.3 Moderator Temperature Coefficient

2.3.1 When the reactor is critical and  $\leq 60\%$  RATED POWER, the moderator temperature coefficient shall be  $\leq 5.0$  pcm/ $^{\circ}$ F, except during LOW POWER PHYSICS TESTING. When the reactor is  $> 60\%$  RATED POWER, the moderator temperature coefficient shall be zero or negative.

2.3.2 The reactor will have a moderator temperature coefficient no less negative than  $-8$  pcm/ $^{\circ}$ F for 95% of the cycle time at full power.

2.4 Shutdown Bank Insertion Limit

2.4.1 The shutdown rods shall be fully withdrawn ( $\geq 225$  steps and  $\leq 230$  steps) when the reactor is critical or approaching criticality.

2.5 Control Bank Insertion Limits

2.5.1 The control banks shall be limited in physical insertion; insertion limits are shown in COLR Figure 4.

CORE OPERATING LIMITS REPORT CYCLE 28

---

2.6 Nuclear Heat Flux Hot Channel Factor ( $F_Q^N(Z)$ )

2.6.1  $F_Q^N(Z)$  Limits for Fuel

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (2.50)/P \times K(Z) \text{ for } P > 0.5 \quad [422 \text{ V+}]$$

$$F_Q^N(Z) \times 1.03 \times 1.05 \leq (5.00) \times K(Z) \text{ for } P \leq 0.5 \quad [422 \text{ V+}]$$

where:

P is the fraction of full power at which the core is OPERATING

K(Z) is the function given in Figure 3

Z is the core height location for the  $F_Q$  of interest

2.6.2 The measured  $F_Q^{EQ}(Z)$  hot channel factors under equilibrium conditions shall satisfy the following relationship for the central axial 80% of the core for fuel:

$$F_Q^{EQ}(Z) \times 1.03 \times 1.05 \times W(Z) \times F_p \leq (2.5)/P \times K(Z) \quad [422 \text{ V+}]$$

where:

P is the fraction of full power at which the core is OPERATING

K(Z) is the function given in Figure 3

Z is the core height location for the  $F_Q$  of interest

$F_p$  is the  $F_Q^{EQ}(Z)$  penalty factor described in 2.6.3.

W(Z) is the function given in Figure 5

$F_Q^{EQ}(Z)$  is a measured  $F_Q$  distribution obtained during the target flux determination

2.6.3 The penalty factor of 1.0 shall be used for TS 3.10.b.6.A and TS 3.10.b.6.B. The penalty factor provided in Figure 6 shall be used for TS 3.10.b.6.C.i. The penalty factor for all burnups outside the range of Figure 6 shall be 2%.

CORE OPERATING LIMITS REPORT CYCLE 28

---

2.7 Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ )

2.7.1  $F_{\Delta H}^N$  Limits for Fuel

$$F_{\Delta H}^N \times 1.04 \leq 1.70 [1 + 0.3(1-P)] \quad [422 \text{ V+}]$$

where:

P is the fraction of full power at which the core is OPERATING

2.8 Axial Flux Difference (AFD)

2.8.1 The Axial Flux Difference (AFD) acceptable operation limits are provided in Figure 7.



CORE OPERATING LIMITS REPORT CYCLE 28

---

2.9 Overtemperature  $\Delta T$  Setpoint

Overtemperature  $\Delta T$  setpoint parameter values:

- $\Delta T_0$  = Indicated  $\Delta T$  at RATED POWER, %  
T = Average temperature, °F  
T'  $\leq$  573.0 °F  
P = Pressurizer Pressure, psig  
P' = 2235 psig  
K<sub>1</sub> = 1.195  
K<sub>2</sub> = 0.015/°F  
K<sub>3</sub> = 0.00072/psig  
 $\tau_1$  = 30 seconds  
 $\tau_2$  = 4 seconds  
f( $\Delta I$ ) = An even function of the indicated difference between top and bottom detectors of the power range nuclear ion chambers. Selected gains are based on measured instrument response during plant startup tests, where  $q_t$  and  $q_b$  are the percent power in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total core power in percent of RATED POWER, such that
- (a) For  $q_t - q_b$  within -15, +10 %,  $f(\Delta I) = 0$
  - (b) For each percent that the magnitude of  $q_t - q_b$  exceeds +10 % the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 1.51 % of RATED POWER.
  - (c) For each percent that the magnitude of  $q_t - q_b$  exceed -15 % the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 3.78% of RATED POWER.

2.10 Overpower  $\Delta T$  Setpoint

Overpower  $\Delta T$  setpoint parameter values:

- $\Delta T_0$  = Indicated  $\Delta T$  at RATED POWER, %  
T = Average temperature, °F  
T'  $\leq$  573.0 °F  
K<sub>4</sub>  $\leq$  1.095  
K<sub>5</sub>  $\geq$  0.0275/°F for increasing T; 0 for decreasing T  
K<sub>6</sub>  $\geq$  0.00103/°F for T > T' ; 0 for T < T'  
 $\tau_3$  = 10 seconds  
f( $\Delta I$ ) = 0 for all  $\Delta I$


CORE OPERATING LIMITS REPORT CYCLE 28

---

- 2.11 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
  - 2.11.1 During steady state power operation,  $T_{avg}$  shall be  $< 576.7^{\circ}\text{F}$  for control board indication or  $< 576.5^{\circ}\text{F}$  for computer indication.
  - 2.11.2 During steady state power operation, Pressurizer Pressure shall be  $> 2217$  psig for control board indication or  $> 2219$  psig for computer indication
  - 2.11.3 During steady state power operation, reactor coolant total flow rate shall be  $\geq 186,000$  gpm.
- 2.12 Refueling Boron Concentration
  - 2.12.1 When there is fuel in the reactor, a minimum boron concentration of 2500 ppm and a shutdown margin of  $\geq 5\% \Delta k/k$  shall be maintained in the Reactor Coolant System during reactor vessel head removal or while loading and unloading fuel from the reactor.

CORE OPERATING LIMITS REPORT CYCLE 28


Figure 1



CORE OPERATING LIMITS REPORT CYCLE 28

---


**Figure 2**  
**Required Shutdown Reactivity vs. Boron**  
**Concentration**



CORE OPERATING LIMITS REPORT CYCLE 28


---

**Figure 3**  
**Hot Channel Factor Normalized Operating Envelope ( $K(z)$ )**



CORE OPERATING LIMITS REPORT CYCLE 28

**Figure 4**  
**Control Bank Insertion Limits**



Fully withdrawn shall be the condition where control rods are at a position between the interval  $\geq 225$  and  $\leq 230$  steps withdrawn.

Note: The Rod Bank Insertion Limits are based on a control bank tip-to-tip distance of 126 steps.

CORE OPERATING LIMITS REPORT CYCLE 28

**Figure 5 - W(Z) Values  
 (Top and Bottom 9% excluded)**

[BOTTOM] 1	Height [ft]	BU [MWd/MTU]			
		150	6000	12000	16000
		AO = 0.90	AO = -3.20	AO = -3.36	AO = -1.32
2	0.20	1.0000	1.0000	1.0000	1.0000
3	0.40	1.0000	1.0000	1.0000	1.0000
4	0.60	1.0000	1.0000	1.0000	1.0000
5	0.80	1.0000	1.0000	1.0000	1.0000
6	1.00	1.0000	1.0000	1.0000	1.0000
7	1.20	1.3228	1.2245	1.2002	1.2060
8	1.40	1.3076	1.2135	1.1899	1.1971
9	1.60	1.2899	1.2007	1.1782	1.1870
10	1.80	1.2699	1.1864	1.1652	1.1757
11	2.00	1.2507	1.1709	1.1512	1.1635
12	2.20	1.2316	1.1547	1.1367	1.1508
13	2.40	1.2116	1.1382	1.1217	1.1377
14	2.60	1.1916	1.1218	1.1071	1.1247
15	2.80	1.1724	1.1073	1.0985	1.1127
16	3.00	1.1553	1.0997	1.0953	1.1033
17	3.20	1.1434	1.0972	1.0935	1.1013
18	3.40	1.1372	1.0951	1.0912	1.1033
19	3.60	1.1341	1.0929	1.0888	1.1056
20	3.80	1.1313	1.0934	1.0858	1.1078
21	4.00	1.1281	1.0945	1.0858	1.1098
22	4.20	1.1246	1.0950	1.0891	1.1114
23	4.40	1.1207	1.0954	1.0933	1.1126
24	4.60	1.1164	1.0955	1.0970	1.1132
25	4.80	1.1115	1.0954	1.1001	1.1140
26	5.00	1.1073	1.0946	1.1029	1.1151
27	5.20	1.1034	1.0945	1.1050	1.1158
28	5.40	1.0989	1.0960	1.1066	1.1159
29	5.60	1.0940	1.0979	1.1077	1.1165
30	5.80	1.0895	1.1018	1.1084	1.1220
31	6.00	1.0899	1.1057	1.1130	1.1314
32	6.20	1.0954	1.1104	1.1198	1.1421
33	6.40	1.1021	1.1174	1.1267	1.1529
34	6.60	1.1079	1.1244	1.1376	1.1626
35	6.80	1.1127	1.1307	1.1480	1.1711
36	7.00	1.1167	1.1354	1.1571	1.1783
37	7.20	1.1197	1.1411	1.1663	1.1842
38	7.40	1.1222	1.1501	1.1753	1.1886
39	7.60	1.1246	1.1583	1.1831	1.1915
40	7.80	1.1260	1.1655	1.1896	1.1928
41	8.00	1.1264	1.1718	1.1949	1.1924
42	8.20	1.1256	1.1769	1.1988	1.1903
43	8.40	1.1238	1.1809	1.2013	1.1864
44	8.60	1.1209	1.1838	1.2023	1.1803
45	8.80	1.1180	1.1842	1.2017	1.1757
46	9.00	1.1214	1.1880	1.1993	1.1755
47	9.20	1.1366	1.1975	1.1996	1.1773
48	9.40	1.1498	1.2089	1.2069	1.1769
49	9.60	1.1624	1.2237	1.2161	1.1765
50	9.80	1.1768	1.2413	1.2232	1.1782

CORE OPERATING LIMITS REPORT CYCLE 28

**Figure 5 Cont'd**  
**(Top and Bottom 9% excluded)**

	Height [ft]	BU [MWd/MTU]			
		150 AO = 0.90	6000 AO = -3.20	12000 AO = -3.36	16000 AO = -1.32
51	10.00	1.1913	1.2555	1.2311	1.1834
52	10.20	1.2053	1.2661	1.2410	1.1893
53	10.40	1.2214	1.2764	1.2504	1.1996
54	10.60	1.2398	1.2816	1.2632	1.2128
55	10.80	1.2526	1.2878	1.2732	1.2258
56	11.00	1.0000	1.0000	1.0000	1.0000
57	11.20	1.0000	1.0000	1.0000	1.0000
58	11.40	1.0000	1.0000	1.0000	1.0000
59	11.60	1.0000	1.0000	1.0000	1.0000
60	11.80	1.0000	1.0000	1.0000	1.0000
[TOP] 61	12.00	1.0000	1.0000	1.0000	1.0000



CORE OPERATING LIMITS REPORT CYCLE 28

---

**Figure 6**

Penalty Factor,  $F_p$  (%), for  $F_Q^{EQ}(Z)$

<b>Cycle Burnup (MWD/MTU)</b>	<b>Penalty Factor <math>F_p</math> (%)</b>
150	2.00
20,743	2.00


Note: Linear interpolation is adequate for intermediate cycle burnups.

All cycle burnups outside the range of the table shall use a penalty factor,  $F_p$ , of 2.0%.

Refer to TS 3.10.b.6.C.

CORE OPERATING LIMITS REPORT CYCLE 28

Figure 7  
Axial Flux Difference



Note: This figure represents the Relaxed Axial Offset Control (RAOC) band used in safety analyses, it may be administratively tightened depending on in-core flux map results. Refer to Figure RD 11.4.1 of the Reactor Data Manual.

CORE OPERATING LIMITS REPORT CYCLE 28

---

Table 1

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
2.1	Reactor Core Safety Limits	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p>
2.2	Shutdown Margin	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>
2.3	Moderator Temperature Coefficient	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>
2.4	Shutdown Bank Insertion Limit	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>

CORE OPERATING LIMITS REPORT CYCLE 28

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
		Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.
2.5	Control Bank Insertion Limits	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p>
2.6	Heat Flux Hot Channel Factor	<p>WCAP-10216-P-A, Revision 1A, "Relaxation of Constant Axial Offset Control-F<sub>Q</sub> Surveillance Technical Specification," February 1994.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p> <p>WCAP-12945-P-A (Proprietary), "Westinghouse Code Qualification Document for Best-Estimate Loss-of-Coolant Accident Analysis," Volume I, Rev.2, and Volumes II-V, Rev.1, and WCAP-14747 (Non-Proprietary), March 1998.</p>

CORE OPERATING LIMITS REPORT CYCLE 28

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<u>COLR Section</u>	<u>Parameter</u>	<u>NRC Approved Methodology</u>
		ANF-88-133 (P)(A) and Supplement 1, "Qualification of Advanced Nuclear Fuels' PWR Design Methodology for Rod Burnups of 62 GWd/MTU," Advanced Nuclear Fuels Corporation, dated December 1991.
	(F <sub>Q</sub> (Z))	WCAP-14449-P-A, "Application Of Best Estimate Large Break LOCA Methodology To Westinghouse PWRs With Upper Plenum Injection," Revision 1, and WCAP-14450-NP-A, Rev.1 (Non-Proprietary), October 1999.
		WCAP-12610-P-A, "Vantage+ Fuel Assembly Reference Core Report," April 1995.
	Model	WCAP-10054-P-A/WCAP-10081-NP-A, "Westinghouse Small Break ECCS Evaluation Using the NOTRUMP Code," August 1985.
	NOTRUMP	WCAP-10054-P-A/WCAP-10081-NP-A, Addendum 2, Revision 1, "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the Code: Safety Injection into the Broken Loop and COSI Condensation Model," July 1997.
2.7	Nuclear Enthalpy Rise Hot Channel Factor (F <sub>N,ΔH</sub> )	WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.
		Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.
		Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP,

CORE OPERATING LIMITS REPORT CYCLE 28

Revision 3 (TAC NO MB0306) dated  
 September 10, 2001.

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<u>COLR Section</u>	<u>Parameter</u>	<u>NRC Approved Methodology</u>
		XN-82-06 (P)(A) Revision 1 and Supplements 2, 4, and 5, "Qualifications of Exxon Nuclear Fuel for Extended Burnup, Exxon Nuclear Company, dated October 1986.
		ANF-88-133 (P)(A) and Supplement 1, "Qualification of Advanced Nuclear Fuels' PWR Design Methodology for Rod Burnups for 62 GWd/MTU," Advanced Nuclear Fuels Corporation, dated December 1991.
		EMF-92-116 (P)(A) Revision 0, "Generic Mechanical Design Criteria for PWR Fuel Designs," Siemens Power Corporation, dated February 1999.
2.8	Axial Flux Difference	WCAP-10216-P-A, Revision 1A, "Relaxation of Constant Axial Offset (AFD) Control-F <sub>Q</sub> Surveillance Technical Specification," February 1994.
		Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.
		Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.
2.9	Reactor Protection System (RPS) Instrumentation-Overtemperature $\Delta T$	WCAP-8745-P-A, "Design Bases For The Thermal Overpower $\Delta T$ and Thermal Overtemperature $\Delta T$ Trip Functions," September 1986.

CORE OPERATING LIMITS REPORT CYCLE 28

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
		Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.
		CENP-397-P-A, "Improved Flow Measurement Accuracy Using Cross Flow Ultrasonic Flow Measurement Technology," Rev. 1, May 2000.
2.10	Reactor Protection System (RPS) Instrumentation-Overpower $\Delta T$	WCAP-8745-P-A, "Design Bases For The Thermal Overpower $\Delta T$ and Thermal Overtemperature $\Delta T$ Trip Functions," September 1986.
		Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.
		CENP-397-P-A, "Improved Flow Measurement Accuracy Using Cross Flow Ultrasonic Flow Measurement Technology," Rev. 1, May 2000.

CORE OPERATING LIMITS REPORT CYCLE 28

---

**Table 1 (cont)**

**NRC Approved Methodologies for COLR Parameters**

<b><u>COLR Section</u></b>	<b><u>Parameter</u></b>	<b><u>NRC Approved Methodology</u></b>
2.11	RCS Pressure, Temperature, and Flow Departure From Nucleate (DNB) Limits	<p>WCAP-11397-P-A, "Revised Thermal Design Procedure, "April 1989, for those events analyzed using RTDP</p> <p>Kewaunee Nuclear Power Plant-Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP, Revision 3 (TAC NO MB0306) dated September 10, 2001.</p> <p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985 for those events not utilizing RTDP.</p>
2.12	Boron Concentration	<p>WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.</p> <p>Safety Evaluation by the Office of Nuclear Reactor Regulation on "Qualifications of Reactor Physics Methods for Application to Kewaunee" Report, dated August 21, 1979, report date September 29, 1978.</p>