

May 3, 2007

Mr. David A. Christian  
Senior Vice President  
and Chief Nuclear Officer  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

SUBJECT: KEWAUNEE POWER STATION, MILLSTONE POWER STATION, UNIT NOS. 2 AND 3, NORTH ANNA POWER STATION, UNIT NOS. 1 AND 2, SURRY POWER STATION, UNIT NOS. 1 AND 2, RESPONSE TO GENERIC LETTER (GL) 2006-02, "GRID RELIABILITY AND THE IMPACT ON PLANT RISK AND THE OPERABILITY OF OFFSITE POWER" (TAC NOS. MD0992, MD0999, MD1000, MD1004, MD1005, MD1038 AND MD1039)

Dear Mr. Christian:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued GL 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Document Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) Use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RC/RA is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities);
- (2) Use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) Offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout;" and
- (4) Losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request For Additional Information (RAI) (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees respond to questions in the following areas:

- (1) Switchyard minimum voltage,
- (2) Loss of real-time contingency analysis (RTCA) capability,
- (3) Verification of RTCA predicted post-trip voltage,
- (4) Identification of applicable single contingencies,
- (5) Seasonal variation in grid stress (reliability and loss-of-offsite power probability),
- (6) Interface with transmission system operator during extended plant maintenance.

By letters dated April 3, 2006 (ADAMS Accession No. ML060950094) and January 30, 2007 (ADAMS Accession No. ML070310282), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me at 301-415-1564.

Sincerely,

**/RA/**

Siva P. Lingam, Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-305, 50-336, 50-423,  
50-338, 50-339, 50-280, and 50-281

cc: See next page

May 3, 2007

Subsequent to the GL, the NRC issued a Request For Additional Information (RAI) (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested licensees respond to questions in the following areas:

- (1) Switchyard minimum voltage,
- (2) Loss of real-time contingency analysis (RTCA) capability,
- (3) Verification of RTCA predicted post-trip voltage,
- (4) Identification of applicable single contingencies,
- (5) Seasonal variation in grid stress (reliability and loss-of-offsite power probability),
- (6) Interface with transmission system operator during extended plant maintenance.

By letters dated April 3, 2006 (ADAMS Accession No. ML060950094) and January 30, 2007 (ADAMS Accession No. ML070310282), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me at 301-415-1564.

Sincerely,

**/RA/**

Siva P. Lingam, Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-305, 50-336, 50-423,  
50-338, 50-339, 50-280, and 50-281

cc: See next page

DISTRIBUTION:

Public	RidsAcrsAcnwMailCenter	RidsOgcRp
LPL2-1 R/F	RidsNrrDprPgcb(CJackson)	RidsRgn2MailCenter(EGuthrie)
RidsNrrDorLpl2-1(EMarinos)	RidsNrrLAMO'Brien	RidsNrrDprPgcb(JRobinson)
RidsNrrPMSLingam	RidsNrrDeEeeb(GWilson)	RidsNrrDorLpl3-1(LRaghavan)
RidsNrrPMMChernoff	RidsNrrPMJHughey	RidsNrrDorLpl1-2(HChernoff)

ADAMS Accession No. ML071070539

OFFICE	NRR/LPL2-1/PM	NRR/LPD2-1/LA	NRR/DE/EEEE/BC	NRR/LPL2-1/BC
NAME	SLingam:nc	MO'Brien	GWilson	EMarinos
DATE	4/17/07	4/30/07	5/1/07	5/3/07

**OFFICIAL RECORD COPY**

North Anna Power Station, Units 1 & 2; Surry Power Station, Units 1 & 2; Kewaunee Power Station; and Millstone Power Station, Unit Nos. 2 and 3

cc:

Mr. C. Lee Lintecum  
County Administrator  
Louisa County  
Post Office Box 160  
Louisa, Virginia 23093

Ms. Lillian M. Cuoco, Esq.  
Senior Counsel  
Dominion Resources Services, Inc.  
Building 475, 5th floor  
Rope Ferry Road  
Waterford, Connecticut 06385

Dr. W. T. Lough  
Virginia State Corporation Commission  
Division of Energy Regulation  
Post Office Box 1197  
Richmond, Virginia 23218

Old Dominion Electric Cooperative  
4201 Dominion Blvd.  
Glen Allen, Virginia 23060

Mr. Chris L. Funderburk, Director  
Nuclear Licensing & Operations Support  
Dominion Resources Services, Inc.  
Innsbrook Technical Center  
5000 Dominion Blvd.  
Glen Allen, Virginia 23060-6711

Office of the Attorney General  
Commonwealth of Virginia  
900 East Main Street  
Richmond, Virginia 23219

Senior Resident Inspector  
North Anna Power Station  
U. S. Nuclear Regulatory Commission  
P. O. Box 490  
Mineral, Virginia 23117

Mr. Jack Davis  
Site Vice President  
North Anna Power Station  
Virginia Electric and Power Company  
Post Office Box 402  
Mineral, Virginia 23117-0402

Dr. Robert B. Stroube, MD, MPH  
State Health Commissioner  
Office of the Commissioner  
Virginia Department of Health  
Post Office Box 2448  
Richmond, Virginia 23218

Mr. Donald E. Jernigan  
Site Vice President  
Surry Power Station  
Virginia Electric and Power Company  
5570 Hog Island Road  
Surry, Virginia 23883-0315

Senior Resident Inspector  
Surry Power Station  
U. S. Nuclear Regulatory Commission  
5850 Hog Island Road  
Surry, Virginia 23883

Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

North Anna Power Station, Units 1 & 2; Surry Power Station, Units 1 & 2; Kewaunee Power Station; and Millstone Power Station, Unit Nos. 2 and 3

cc:

Resident Inspectors Office  
U.S. Nuclear Regulatory Commission  
N490 Hwy 42  
Kewaunee, WI 54216-9510

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
Suite 210  
2443 Warrenville Road  
Lisle, IL 60532-4351

David Zellner  
Chairman - Town of Carlton  
N2164 County B  
Kewaunee, WI 54216

Mr. Jeffery Kitsembel  
Electric Division  
Public Service Commission of Wisconsin  
PO Box 7854  
Madison, WI 53707-7854

Ms. Leslie N. Hartz  
Dominion Energy Kewaunee, Inc.  
Kewaunee Power Station  
N490 Highway 42  
Kewaunee, WI 54216

Mr. Thomas L. Breene  
Dominon Energy Kewaunee, Inc.  
Kewaunee Power Station  
N490 Highway 42  
Kewaunee, WI 54216

Plant Manager  
Kewaunee Power Station  
N490 Highway 42  
Kewaunee, WI 54216-9511

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental  
Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Charles Brinkman, Director  
Washington Operations Nuclear Services  
Westinghouse Electric Company  
12300 Twinbrook Pkwy, Suite 330  
Rockville, MD 20852

Senior Resident Inspector  
Millstone Power Station  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 513  
Niantic, CT 06357

Mr. J. W. "Bill" Sheehan  
Co-Chair  
Nuclear Energy Advisory Council  
19 Laurel Crest Drive  
Waterford, CT 06385

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870

North Anna Power Station, Units 1 & 2; Surry Power Station, Units 1 & 2; Kewaunee Power Station; and Millstone Power Station, Unit Nos. 2 and 3

cc:

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Mr. Joseph Roy  
Director of Operations  
Massachusetts Municipal Wholesale  
Electric Company  
P.O. Box 426  
Ludlow, MA 01056

Mr. David W. Dodson  
Licensing Supervisor  
Dominion Nuclear Connecticut, Inc.  
Building 475, 5<sup>th</sup> Floor  
Roper Ferry Road  
Waterford, CT 06385

Mr. J. Alan Price  
Site Vice President  
Dominion Nuclear Connecticut, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385