

April 19, 2007

Mr. Timothy G. Mitchell  
Vice President, Operations  
Arkansas Nuclear One  
Entergy Operations, Inc.  
1448 S. R. 333  
Russellville, AR 72802

SUBJECT: ARKANSAS NUCLEAR ONE, UNITS 1 AND 2 - RESPONSE TO GENERIC LETTER 2006-02, "GRID RELIABILITY AND THE IMPACT ON PLANT RISK AND THE OPERABILITY OF OFFSITE POWER" (TAC NOS. MD0947 AND MD0948 )

Dear Mr. Mitchell:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) Use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA), and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications. (The TSO, ISO, or RC/RA is responsible for preserving the reliability of the local transmission system. In this GL the term TSO is used to denote these entities);
- (2) Use of NPP/TSO protocols and analysis tools by the TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) Offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout"; and
- (4) Losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a request for additional information (RAI) (ADAMS Accession No. ML063380308) regarding the resolution of GL 2006-02 to 63 of 65 holders of operating licenses for nuclear power reactors. The RAI requested that the licensees respond to the questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (Reliability and Loss-of-Offsite Power Probability); AND
- (6) Interface with TSO during Extended Plant Maintenance.

By letters dated March 29, 2006 (ADAMS Accession No. ML060970321), and January 31, 2007 (ADAMS Accession No. ML070430281), you responded to the information request of GL 2006-02 and the subsequent RAI, respectively. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with the NRC regulatory requirements governing electric power sources and associated personnel training, and considers your response to GL 2006-02 complete.

If you have any questions, please contact me at 301-415-1447.

Sincerely,

*/RA/*

Farideh E. Saba, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-313  
and 50-368

cc: See next page

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (Reliability and Loss-of-Offsite Power Probability); AND
- (6) Interface with TSO during Extended Plant Maintenance.

By letters dated March 29, 2006 (ADAMS Accession No. ML060970321), and January 31, 2007 (ADAMS Accession No. ML070430281), you responded to the information request of GL 2006-02 and the subsequent RAI, respectively. Based on the information you provided, the NRC staff has concluded that compliance is being maintained with the NRC regulatory requirements governing electric power sources and associated personnel training, and considers your response to GL 2006-02 complete.

If you have any questions, please contact me at 301-415-1447.

Sincerely,

*/RA/*

Farideh E. Saba, Project Manager  
 Plant Licensing Branch IV  
 Division of Operating Reactor Licensing  
 Office of Nuclear Reactor Regulation

Docket Nos. 50-313  
 and 50-368

cc: See next page

DISTRIBUTION:

PUBLIC  
 LPLIV Reading  
 RidsAcrsAcnwMailCenter  
 RidsNrrDorlLp4

RidsOgcRp  
 RidsNrrLALFeizollahi  
 RidsNrrPMFSaba  
 RidsRgn4MailCenter  
 RidsNrrDEEeb

ADAMS Accession No.:ML071080126

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/EEEB/BC	NRR/LPL4/BC
NAME	FSaba	LFeizollahi	GWilson	THiltz
DATE	4/18/07	4/18/07	4/19/07	4/19/07

OFFICIAL RECORD COPY

Arkansas Nuclear One

cc:

Executive Vice President  
& Chief Operating Officer  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, MS 39286-1995

General Manager Plant  
Operations  
Entergy Operations, Inc.  
Arkansas Nuclear One  
1448 SR 333  
Russellville, AR 72802

Director, Nuclear Safety Assurance  
Entergy Operations, Inc.  
Arkansas Nuclear One  
1448 SR 333  
Russellville, AR 72802

Manager, Licensing  
Entergy Operations, Inc.  
Arkansas Nuclear One  
1448 SR 333  
Russellville, AR 72802

Director, Nuclear Safety & Licensing  
Entergy Operations, Inc.  
1340 Echelon Parkway  
Jackson, MS 39213-8298

Section Chief, Division of Health  
Radiation Control Section  
Arkansas Department of Health and  
Human Services  
4815 West Markham Street, Slot 30  
Little Rock, AR 72205-3867

Section Chief, Division of Health  
Emergency Management Section  
Arkansas Department of Health and  
Human Services  
4815 West Markham Street, Slot 30  
Little Rock, AR 72205-3867

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 310  
London, AR 72847

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

County Judge of Pope County  
100 W. Main Street  
Russellville, AR 72801

Vice President, Operations Support  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, MS 39286-1995