

April 30, 2007

Mr. Joseph E. Venable
Vice President of Operations
Entergy Operations, Inc.
River Bend Station
5485 US Highway 61N
St. Francisville, LA 70775

SUBJECT: RIVER BEND STATION, UNIT 1- RESPONSE TO GENERIC LETTER 2006-02,
"GRID RELIABILITY AND THE IMPACT ON PLANT RISK AND THE
OPERABILITY OF OFFSITE POWER" (TAC NO. MD1024)

Dear Mr. Venable:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RA/RC is responsible for preserving the reliability of the local transmission system. In this GL, the term TSO is used to denote these entities.);
- (2) use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout"; and
- (4) losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request for Additional Information (RAI) (ADAMS Accession No. ML063380308), regarding the resolution of GL 2006-02 to 63 of 65 holders of

operating licenses for nuclear power reactors. The RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability; and
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letter dated April 3, 2006 (ADAMS Accession No. ML061000256), as supplemented by letter dated January 31, 2007 (ADAMS Accession No. ML070370584), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-3308.

Sincerely,

/RA/

Bhalchandra Vaidya, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-458

cc: See next page

operating licenses for nuclear power reactors. The RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability; and
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letter dated April 3, 2006 (ADAMS Accession No. ML061000256), as supplemented by letter dated January 31, 2007 (ADAMS Accession No. ML070370584), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-3308.

Sincerely,

/RA

Bhalchandra Vaidya, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-458

cc: See next page

DISTRIBUTION:

PUBLIC

LPLIV r/f

RidsAcraAcnwMailCenter

RidsNrrDeEeeb (GWilson)

RidsNrrDorLpl4

RidsNrrDprPgcb (CJackson)

RidsNrrPMBVaidya

RidsNrrLAJBurkhardt

RidsOgcRp

RidsRgn4MailCenter

JRobinson, PGCB

ADAMS Accession No: ML071080162

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/EEEB/BC	NRR/PGCB/BC	NRR/LPL4/BC
NAME	BVaidya	JBurkhardt	GWilson	CJackson	THiltz
DATE	4/20/07	4/20/07	4/30/07	4/26/07	4/30/07

OFFICIAL RECORD COPY

River Bend Station

cc:

Manager, Licensing
Entergy Operations, Inc.
River Bend Station
5485 US Highway 61N
St. Francisville, LA 70775

Director, Nuclear Safety & Licensing
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213-8298

Louisiana Department of Environmental
Quality
Radiological Emergency Planning and
Response Division
P.O. Box 4312
Baton Rouge, LA 70821-4312

Louisiana Department of Environmental
Quality
Office of Environmental Compliance
P.O. Box 4312
Baton Rouge, LA 70821-4312

Senior Resident Inspector
P.O. Box 1050
St. Francisville, LA 70775

President of West Feliciana
Police Jury
P.O. Box 1921
St. Francisville, LA 70775

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Ms. H. Anne Plettinger
3456 Villa Rose Drive
Baton Rouge, LA 70806

Executive Vice President and
Chief Operating Officer
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

General Manager Plant Operations
Entergy Operations, Inc.
River Bend Station
5485 US Highway 61N
St. Francisville, LA 70775

Director, Nuclear Safety Assurance
Entergy Operations, Inc.
River Bend Station
5485 US Highway 61N
St. Francisville, LA 70775

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Mr. Jim Calloway
Public Utility
Commission of Texas
1701 N. Congress Avenue
Austin, TX 78711-3326

Attorney General
State of Louisiana
P.O. Box 94095
Baton Rouge, LA 70804-9095

Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 North Congress Avenue
Austin, Texas 78701-3326

Richard Penrod, Senior Environmental
Scientist/State Liaison Officer
Office of Environmental Services
Northwestern State University
Russell Hall, Room 201
Natchitoches, LA 71497