

April 24, 2007

Mr. Kevin T. Walsh
Vice President of Operations
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-3093

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - CLOSEOUT OF
GENERIC LETTER 2006-02, "GRID RELIABILITY AND THE IMPACT ON
PLANT RISK AND THE OPERABILITY OF OFFSITE POWER"
(TAC NO. MD1048)

Dear Mr. Walsh:

On February 1, 2006, the U.S. Nuclear Regulatory Commission (NRC) issued GL 2006-02, "Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML060180352), to all holders of operating licenses for nuclear power reactors except those who have permanently ceased operation and have certified that fuel has been removed from the reactor vessel.

GL 2006-02 notified licensees of the NRC staff's need for information in four areas as follows:

- (1) use of protocols between the nuclear power plant (NPP) and the transmission system operator (TSO), independent system operator (ISO), or reliability coordinator/authority (RC/RA) and the use of transmission load flow analysis tools (analysis tools) by TSOs to assist NPPs in monitoring grid conditions to determine the operability of offsite power systems under plant technical specifications (TSs). (The TSO, ISO, or RA/RC is responsible for preserving the reliability of the local transmission system. In this GL, the term TSO is used to denote these entities.);
- (2) use of NPP/TSO protocols and analysis tools by TSOs to assist NPPs in monitoring grid conditions for consideration in maintenance risk assessments;
- (3) offsite power restoration procedures in accordance with Section 2 of NRC Regulatory Guide (RG) 1.155, "Station Blackout"; and
- (4) losses of offsite power caused by grid failures at a frequency equal to or greater than once in 20 site-years in accordance with RG 1.155.

Subsequent to the GL, the NRC issued a Request for Additional Information (RAI) (ADAMS Accession No. ML063380308), regarding the resolution of GL 2006-02 to 63 of 65 holders of

operating licenses for nuclear power reactors. The RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability; and
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated April 3, 2006, and January 31, 2007 (ADAM Accession Nos. ML060950379 and ML070330058, respectively), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-3062.

Sincerely,

/RA/

Mel B. Fields, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

operating licenses for nuclear power reactors. The RAI requested that licensees respond to questions in the following areas:

- (1) Switchyard Minimum Voltage;
- (2) Loss of Real-Time Contingency Analysis (RTCA) Capability;
- (3) Verification of RTCA Predicted Post-Trip Voltage;
- (4) Identification of Applicable Single Contingencies;
- (5) Seasonal Variation in Grid Stress (reliability and Loss-of-offsite power (LOOP) Probability; and
- (6) Interface With Transmission System Operator During Extended Plant Maintenance.

By letters dated April 3, 2006, and January 31, 2007 (ADAM Accession Nos. ML060950379 and ML070330058, respectively), you responded to the information request of GL 2006-02 and the subsequent RAI. Based on the information you provided, the staff has concluded that compliance is being maintained with NRC regulatory requirements governing electric power sources and associated personnel training and considers your response to GL 2006-02 complete.

If you have any questions, please contact me 301-415-3062.

Sincerely,

/RA/

Mel B. Fields, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-382

cc: See next page

DISTRIBUTION

PUBLIC

LPLIV Reading

RidsAcrsAcnwMailCenter

RidsNrrDeEeeb

RidsNrrDorlLpl4

RidsNrrPMMFields

RidsNrrLAJBurkhardt

RidsOgcRp

RidsRgn4MailCenter (JClark)

JRobinson, NRR/ADRO/DPR

ADAMS Accession No. ML071080188

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/EEEE/BC	NRR/LPL4/BC
NAME	MFields	JBurkhardt	GWilson	THiltz
DATE	4/23/07	4/20/07	4/23/07	4/24/07

OFFICIAL RECORD COPY

Waterford Steam Electric Station, Unit 3

cc:

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Director, Nuclear Safety & Licensing
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213-8298

Director
Nuclear Safety Assurance
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-3093

Louisiana Department of Environmental
Quality Radiological Emergency Planning
and Response Division
P.O. Box 4312
Baton Rouge, LA 70821-4312

General Manager Plant Operations
Waterford 3 SES
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-3093

Louisiana Department of Environmental
Quality
Office of Environmental Compliance
P.O. Box 4312
Baton Rouge, LA 70821-4312

Manager, Licensing
Entergy Operations, Inc.
17265 River Road
Killona, LA 70057-3093

Chairman
Louisiana Public Services Commission
P.O. Box 91154
Baton Rouge, LA 70825-1697

Resident Inspector/Waterford NPS
P.O. Box 822
Killona, LA 70066-0751

Richard Penrod, Senior Environmental
Scientist/State Liaison Officer
Office of Environmental Services
Northwestern State University
Russell Hall, Room 201
Natchitoches, LA 71497

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Parish President Council
St. Charles Parish
P.O. Box 302
Hahnville, LA 70057

Executive Vice President &
Chief Operating Officer
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

November 2006