

DPO-2006-003: Oconee Use of Leak Before Break in ECCS

Subject: This DPO raises concerns about the installation of an ECCS LPI cross tie header at the Oconee facility. The submitter contends that the licensee should not have been allowed to use Leak Before Break technology for ECCS.

Assigned to: Jim Dyer, NRR OD
DPO Decision: 2/17/2007

DPO Follow Up Actions and Schedule

Recommendation Number/Action Item	Original Schedule	Revised Schedule*	Lead Office
1. Develop a knowledge management document describing the NRC's policy and practice on the application of LBB (NRR Yellow Ticket 020060239)	03/16/07	04/16/07 ¹	NRR

¹Division of Component Integrity needed more time to get this completed due to their work load.

B-21

NRC FORM 8C
(7-94)
NRCMD 3.57

COVER SHEET FOR CORRESPONDENCE
USE THIS COVER SHEET TO PROTECT ORIGINALS OF
MULTI-PAGE CORRESPONDENCE