

## Internal Flooding Study

The DC Cook internal flooding study was developed to meet the ASME PRA Standard. Overall it meets Category II of the Standard with a number of supporting requirements meeting Category III (e.g. IF-C6). While the internal flooding study has not gone through a formal peer review, it was developed in accordance with internal DC Cook calculation procedures, which include an independent review function.