



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

May 1, 2007

NOC-AE-07002161

File No.: G25

10 CFR 50.55a


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

South Texas Project
Unit 2
Docket No. STN 50-499
Unit 2 Weld Overlay Examination Results
(RR-ENG-2-43) (TAC Nos. MD1414-1423)

Pursuant to 10 CFR 50.55a(a)(3)(i), the STP Nuclear Operating Company (STPNOC) requested approval to use an alternative to the requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI for the structural weld overlays on the South Texas Project Unit 1 and Unit 2 pressurizer spray, relief, safety and surge nozzle safe-ends. Ultrasonic examination of the weld overlays was to be performed to support NRC approval of the STPNOC request. STPNOC completed the ultrasonic examination for the South Texas Project Unit 2 pressurizer nozzle safe-end weld overlays on April 17, 2006, during the recent Unit 2 refueling outage (2RE12). A summary of the ultrasonic examination results is attached. No repairs to the overlay material and/or base metal were required or performed.

There are no commitments in this submittal.

If there are any questions, please contact either Mr. Philip Walker at (361) 972-8392 or me at (361) 972-7431.



Brandon Jenewein
Manager,
Testing/Programs

PLW

Attachment: Summary of Ultrasonic Examination Results for 2RE12

cc:
(paper copy)

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of State Health Services
1100 West 49th Street
Austin, TX 78756-3189

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 289, Mail Code: MN116
Wadsworth, TX 77483

C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

(electronic copy)

A. H. Gutterman, Esquire
Morgan, Lewis & Bockius LLP

Mohan C. Thadani
U. S. Nuclear Regulatory Commission

Thad Hill
Christine Jacobs
Eddy Daniels
Marty Ryan
NRG South Texas LP

J. J. Nesrsta
R. K. Temple
Kevin Pollo
E. Alarcon
City Public Service

Jon C. Wood
Cox Smith Matthews

C. Kirksey
City of Austin

**South Texas Project
Unit 2
Summary of Ultrasonic Examination Results for 2RE12**

Ultrasonic Examination Procedure

Structural Integrity Associates procedure SI-UT-126, Revision 0, Procedure for the Phased Array Ultrasonic Examination of Weld Overlay Similar and Dissimilar Metal Welds, was used during the examinations. This procedure, and the examiners who applied the procedure, is qualified through the Performance Demonstrative Initiative (PDI) Program at the Electric Power Research Institute Non-Destructive Examination Center.

Examination Regions: Weld Overlay Material, Outer 25% Dissimilar Metal Weld and Adjacent Base Material, and Outer 25% Safe End-to-Pipe Weld and Adjacent Base Material.

Complete Code Required Coverage was achieved on the Weld Overlay and Outer 25% of the original welds and adjacent base material.

Axial Examination Angles: 0° through 83°

Circumferential Examination Angles: 0° through 63° (0° through 70° for the Surge Nozzle)

The examination gain was adjusted to maintain the procedure-specified baseline noise level from 5% to 20% of full screen height. The lower range of examination angles detected responses from the inside surface of the component which are useful for monitoring search unit contact / coupling effectiveness during the examination.

Surge Nozzle N1 Weld Overlay Examination

Component Identification: PZR-2-N1-SE-WOL

Examination Summary: The examination of the required volumes in the weld overlay and underlying upper 25% of base material found one indication within the weld overlay volume. This finding is a spot indication with no discernable length or width. The indication was determined to be within the WOL weld material. The indication was characterized in accordance with IWA-3300 of Section XI as a subsurface spot planar indication. The indication was then evaluated in accordance with IWB-3514, Code Case N-504-2, and Appendix Q, and was determined to be acceptable.

Spray Nozzle N2 Weld Overlay Examination

Component Identification: PZR-2-N2-SE-WOL

Examination Summary: The examination of the required volumes in the weld overlay and underlying upper 25% of base material found no suspected flaw indication. A small indication was recorded outside the examination volume in the underlying dissimilar metal weld. The indication is not crack-like and appears to be fabrication-related and not service-induced. The indication was conservatively evaluated to ASME Section XI standards (IWB-3500) and was determined to be acceptable.

Safety Nozzle N3 Weld Overlay Examination

Component Identification: PZR-2-N3-SE-WOL

Examination Summary: The examination of the required volumes in the weld overlay found no suspected flaw indication. The examination of the underlying 25% of the dissimilar metal weld and base material found no suspected flaw indications. The examination of the underlying 25% of the elbow to safe-end weld identified numerous fabrication indications. Porosity was identified in this area on the construction radiograph and during the PT examinations prior to overlay. In addition, the original preservice UT examination identified fabrication indications in this weld. The indications appear to be primarily indicative of porosity within the weld and can be seen originating from multiple locations within the stainless steel elbow to safe-end weld. The design of the weld overlay was conservatively evaluated and was determined to be adequate.

Relief Nozzle N4A Weld Overlay Examination

Component Identification: PZR-2-N4A-SE-WOL

Examination Summary: The examination of the required volumes in the weld overlay and underlying upper 25% of base material found no suspected flaw indication. A small spot indication was recorded outside the examination volume in the underlying dissimilar metal weld. This indication is a spot indication with no discernable length or width. The indication appears to be fabrication-related and not service-induced. This indication was conservatively evaluated to ASME Section XI standards (IWB-3500) and was determined to be acceptable.

Safety Nozzle N4B Weld Overlay Examination

Component Identification: PZR-2-N4B-SE-WOL

Examination Summary: The examination of the required volumes in the weld overlay and underlying upper 25% of base material found no suspected flaw indication.

Safety Nozzle N4C Weld Overlay Examination

Component Identification: PZR-2-N4C-SE-WOL

Examination Summary: The examination of the required volumes in the weld overlay and underlying upper 25% of base material found no suspected flaw indication. Two small indications were recorded outside the examination volume in the underlying adjacent base metal. The indications have no measurable through-wall dimension and are not crack-like. They appear to be fabrication-related and not service-induced. The indications were conservatively evaluated to ASME Section XI standards (IWB-3500) and were determined to be acceptable.