

P.O. Box 63 Lycoming, NY 13093

May 1, 2007

U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

ATTENTION: Document Control Desk

SUBJECT:Nine Mile Point Nuclear Station
Unit No. 1; Docket No. 50-220
Core Operating Limits Report, COLR1-18 Revision 0

Attached is a copy of the Core Operating Limits Report, COLR1-18 Revision 0, for Nine Mile Point Unit 1 (NMP1). This report is being submitted pursuant to NMP1 Technical Specification 6.6.5.d.

Should you have any questions regarding the information in this submittal, please contact M. H. Miller, Director Licensing, at (315) 349-5219.

Very truly yours

Mark A. Schimmel Plant General Manager

MAS/MHS/

Attachment: (1) Core Operating Limits Report, COLR1-18 Revision 0

cc: S. J. Collins, NRC Regional Administrator, Region I L. M. Cline, NRC Senior Resident Inspector M. J. David, NRR Project Manager

ATTACHMENT (1)

)

NINE MILE POINT UNIT 1

CORE OPERATING LIMITS REPORT

COLR1-18

REVISION 0

Nine Mile Point Nuclear Station, LLC May 1, 2007

CORE OPERATING LIMITS REPORT

Document No.:	COLR1-18				
Revision 0	Controlled Document Copy For Latest Information Check CDS				
. ·	Name	Title	Date		
Prepared by:	<u>C. W. Lepine</u>	Fuel Engineer	3-28-07		
Reviewed by:	J. L. Winklebleck	Fuel Engineer	3-29-07		
Independently Reviewed by:	Wil Carter	J35 107 Fuel Engineer	3/29/07		
Approved by:	M. A. Armenta	Engineering Supervisor, Nuclear Fuels Services	3/30/07		
Approved by:	J. D. Darweesh	Supervisor, Reactor Engineering	3/30/07		
Approved by:	166-A. Philangboki P. I. Wengloski P& Telewa	General Supervisor, Nuclear Fuels Services	3/32/0		

This Controlled Document provides cycle specific core operating limits for use in conjunction with the Nine Mile Point Unit 1 Technical Specifications. Document pages may only be changed through a reissue of the entire document.

TERMS AND DEFINITIONS

Average Planar Linear Heat Generation Rate (APLHGR)

The Average Planar Linear Heat Generation Rate (APLHGR) shall be applicable to a specific planar height and is equal to the sum of the heat generation rate per unit length of fuel rod for all fuel rods in the specified bundle at the specified height, divided by the number of fuel rods in the fuel bundle at that height.

BOC

Beginning of Cycle

Core Maximum Fraction of Limiting Power Density (CMFLPD)

The highest value of the fraction of limiting power density which exists in the core.

Critical Power Ratio (CPR)

The ratio of critical power to the bundle power at the reactor condition of interest.

EOC

End of Cycle

EOR

End of Rated Conditions (i.e. cycle exposure at 100% power, 100% flow, all rods-out, all feedwater heaters in service and equilibrium xenon)

Fraction of Limiting Power Density (FLPD)

The linear heat generation rate (LHGR) existing at a given location divided by the specified LHGR limit for that bundle type.

FRTP

Fraction of Rated Thermal Power where Rated Thermal Power equals 1850 MW

K(f)

MCPR flow dependent multiplier

Linear Heat Generation Rate (LHGR)

The heat generation per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the fuel length.

<u>MAPLHGR</u>

Maximum Average Planar Linear Heat Generation Rate

Minimum Critical Power Ratio (MCPR)

The minimum in-core critical power ratio.

<u>RSLD</u>

Reload Specific Lattice Data Document

CORE OPERATING LIMITS REPORT

1.0 <u>AVERAGE PLANAR LINEAR HEAT GENERATION RATE</u> (APLHGR)

1.1 Limits for Technical Specification 3.1.7.a

During power operation, the APLHGR for each type of fuel as function of axial location and average planar exposure shall not exceed the limiting values shown in Table 1a, 1b, 1c, and 1d.

1.2 Limits for Technical Specification 3.1.7.e

During partial loop operation with four recirculation loops in operation, the APLHGR as a function of axial location and average planar exposure shall not exceed 98 percent of the limiting values shown in Table 1a, 1b, 1c, and 1d.

During partial loop operation with three recirculation loops in operation, the APLHGR as a function of axial location and average planar exposure shall not exceed 98 percent of the limiting values shown in Table 1a, 1b, 1c, and 1d.

2.0 MINIMUM CRITICAL POWER RATIO (MCPR)

2.1 Limits for Technical Specification 3.1.7.c

During power operation, the operating MCPR shall be greater than or equal to the Operating Limit MCPR⁽¹⁾ from the appropriate⁽²⁾ Figure (2a thru 2d) with tau (or " τ ") defined as follows:

 $\tau = (\tau_{ave} - \tau_B) / (\tau_A - \tau_B)$ where:

 $\tau_{A} = 0.868$ seconds, control rod average scram insertion time limit to notch 39

$$\tau_{\rm B} = .672 + 1.65 * \left[N_1 / \sum_{i=1}^{n} N_i \right]^{1/2} * .016$$

 $\tau_{ave} = \sum_{i=1}^{n} N_{i} \tau_{i}) / (\sum_{i=1}^{n} N_{i})$

n = number of surveillance tests performed in cycle

 N_i = number of active control rods measured in the ith surveillance test

 τ_i = average scram time to notch 39 of all rods measured in the ith surveillance test N₁ = total number of active rods measured in the first test at BOC

For core flows other than rated the MCPR limit shall be the Operating Limit MCPR identified above times K(f) where K(f) is as shown in Figure 2e.

Additional limits for operation between 45% and 90% $RTP^{(3)}$ are required for operations without a backup pressure regulator. These limits are shown in Figure 2f.

2.2 Limits for Technical Specification 3.1.7.e

During 3 loop operation, the Operating Limit MCPR shall be increased by 0.02. No adjustment is needed during 4 loop operation.

NOTES:

1. Based on a 1.07 MCPR Safety Limit (SLCPR).

- 2. If the feedwater pump configuration, as defined by Nuclear Engineering Report No. NER-1M-022, is such that a feedwater controller failure could result in maximum feedwater flow greater than that for two feedwater pumps (i.e., the shaft-driven pump plus one motor-driven pump), then the Operating Limit MCPR shall be as shown in Figures 2c or 2d, depending on exposure.
- 3. Below 45% and above 90% RTP no additional limits are required for operation without a backup pressure regulator.
- 4. These limits are valid for 3, 4, and 5 loop operation. (Note that for the MCPR Limit for 70% ≤ P< 90%, i.e. MCPR Limit = (Rated OLMCPR) / FRTP, the Rated OLMCPR is as determined by 2.1 and 2.2 above.)

5. EOR on Figures 2a through 2d is the end of rated exposure as defined in the Cycle Management report.

3.0 LINEAR HEAT GENERATION RATE (LHGR)

3.1 Limits for Technical Specification 3.1.7.b

During power operation, the Linear Heat Generation Rate (LHGR) of any rod in any fuel assembly at any axial location shall not exceed the limiting values shown in RSLD-19, Revision 0, "Nine Mile Point Unit 1 Reload 19, Reload Specific Lattice Data". This document contains the LHGR limits for both UO2 rods (which contain no gadolinium) and the most limiting gadolinium-bearing rods. Other gadolinium-bearing rods have LHGR limits which lie between these two curves. Compliance with these limits will be monitored by the plant's 3D-Monicore computer.

Additional limits for operation between 45% and 90% RTP⁽¹⁾ are required for operations without a backup pressure regulator. These limits are shown in Figure 3.

NOTE:

(1)

Below 45% and above 90% RTP no additional limits are required for operation without a backup pressure regulator.

4.0 POWER/FLOW RELATIONSHIP DURING OPERATION

4.1 Limits for Technical Specification 3.1.7.d and e

The power/flow relationship shall not exceed the limiting values shown in Figure 4.

6.0 SOURCE DOCUMENTS

The Core Operating Limits contained in this report were obtained from the following documents:

CORE OPERATING LIMITS

APLHGR Limits (Section 1.0) Table 1 and corresponding three and four loop multipliers

Lattice Descriptions

MCPR Limits (Section 2)

Pressure Regulator Out-of-Service Restriction

EOR Definition

LHGR Limits (Section 3)

Pressure Regulator Out-of-Service Restriction

Power/Flow Relationship (Section 4)

REFERENCE

0000-0053-5239-SRLR, Revision 1, March 2007, Supplemental Reload Licensing Report for Nine Mile Point Nuclear Station Unit 1, Reload 19 Cycle 18

RSLD-19 Nine Mile Point Unit 1 Reload 19 Specific Lattice Data

0000-0053-5239-SRLR, Revision 1, March 2007, Supplemental Reload Licensing Report for Nine Mile Point Nuclear Station Unit 1, Reload 19 Cycle 18

0000-0053-5247-ER, Revision 1, March 2007, Engineering Report for Nine Mile Point Nuclear Station Unit 1, Reload 19

GE-NE-J11-03433-16-01-R1, "Pressure Regulator Out of Service Calculations for Nine Mile Point Unit 1", January 2005

NMP1CMR Nine Mile Point Unit 1 Cycle 18 Cycle Management Report

0000–0053–5247–ER, Revision 1, March 2007, Engineering Report for Nine Mile Point Nuclear Station Unit 1,Reload 19

GE-NE-J11-03433-16-01-R1, "Pressure Regulator Out of Service Calculations for Nine Mile Point Unit 1", January 2005

NMP1 Technical Specification Amendment 92, Figure 3.1.7.aa

Table 1a

Average Planar Exposure	MAPLHGR Limits (kw/ft)					
GWd/ST	Bundle GE11-C15	Bundle GE11-C16A	Bundle GE11-C16B	Bundle GE11-C17		
0.00	8.82	9.93	9.93	9.81		
0.20	8.82	9.93	9.93	9.81		
1.00	8.89	9.89	9.90	9.78		
5.00	9.22	9.78	9.70	9.64		
10.00	9.56	9.61	9.67	9.49		
15.00	9.50	9.53	9.53	9.36		
17.50	9.49	9.53	9.53			
20.00	9.44	9.08	9.08	8.87		
25.00	8.76	8.83	8.83	8.55		
30.00	8.32	8.63	8.63	·,		
35.00	8.43	8.60	8.60	8.47		
45.00	8.51	8.62	8.62	8.48		
50.00		8.65	8.65			
55.00	8.58	8.66	8.66	8.54		
65.00	8.65	6.38	6.38	8.63		

MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE^{(1) (2)}

NOTE:

(1) A "--" indicates that there is no entry for this box and the limit can be determined by linearly interpolating between the previous and next point in each column.
MAPLHGRs are interpolated between exposure points for which explicit values are given.
(2) These MAPLHGR are not lattice dependent, therefore the values shown also correspond to the

limiting value for the most limiting lattice for use when hand calculations are required.

Fuel Type	
GE11-P9DUB362-13GZ-100T-145-T6-3899	
GE11-P9DUB376-12GZ-100T-145-T6-2585	•
GE11-P9DUB376-12GZ-100T-145-T6-2586	
GE11-P9DUB382-13GZ-100T-145-T6-2831	

Page 7 of 18

<u>ID</u> GE11-C15 GE11-C16A GE11-C16B GE11-C17

Table 1b

MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE Bundle Type: GE11-P9DUB381-13GZ-100T-145-T6-2945 (GE11)

Average Planar	MAPLHGR Limits ⁽¹⁾ (kw/ft)						
Exposure GWd/ST	Lattice 7433	Lattice 7434	Lattice 7435	Lattice 7436	Lattice 7437	Lattice 7438	Most Limiting
0.00	9.91	9.91	9.87	9.87	9.87	9.87	9.87
0.20	9.91	9.91	9.87	9.87	9.87	9.87	9.87
1.00	9.87	9.87	9.86	9.86	9.86	9.86	9.86
5.00	9.72	9.72	9.76	9.76	9.76	9.76	9.72
10.00	9.67	9.67	9.63	9.63	9.63	9.63	9.63
15.00	9.51	9.51 ·	9.52	9.52	9.52	9.52	9.51
20.00	9.47	9.47	9.48	9.48	9.48	9.48	9.47
25.00	8.77	8.77	8.74	8.74	8.74	8.74	8.74
35.00	8.45	8.45	8.54	8.54	8.54	8.54	8.45
45.00	8.53	8.53	8.53	8.53	8.53	8.53	8.53
55.00	8.57	8.57	8.57	8.57	8.57	8.57	8.57
65.00	8.64	8.64	8.64	8.64	8.64	8.64	8.64

(1) These MAPLHGR are lattice dependent. The values shown in the Most Limiting Column correspond to the limiting value for the most limiting lattice for use when hand calculations are required. Lattice desciptions are contained in the RSLD.

Table 1c

MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE Bundle Type: GE11-P9DUB381-14GZ-100T-145-T6-2946 (GE11)

Average Planar	MAPLHGR Limits ⁽¹⁾ (kw/ft)						
Exposure GWd/ST	Lattice 7433	Lattice 7439	Lattice 7440	Lattice 7441	Lattice 7442	Lattice 7443	Most Limiting
0.00	10.56	10.56	10.51	10.51	10.51	10.51	10.51
0.20	10.56	10.56	10.51	10.51	10.51	10.51	10.51
1.00	10.52	10.52	10.51	10.51	10.51	10.51	10.51
5.00	10.22	10.22	10.16	10.16	10.16	10.16	10.16
10.00	9.72	9.72	9.63	9.63	9.63	9.63	9.63
15.00	9.51	9.51	9.48	9.48	9.48	9.48	9.48
20.00	9.48	9.48	9.49	9.49	9.49	9.49	9.48
25.00	9.00	9.00	8.97	8.97	8.97	8.97	8.97
35.00	8.50	8.50	8.48	8.48	8.48	8.48	8.48
45.00	8.56	8.56	8.54	8.54	8.54	8.54	8.54
55.00	8.62	8.62	8.60	8.60	8.60	8.60	8.60
65.00	8.70	8.70	8.69	8.69	8.69	8.69	8.69

(1) These MAPLHGR are lattice dependent. The values shown in the Most Limiting Column correspond to the limiting value for the most limiting lattice for use when hand calculations are required. Lattice desciptions are contained in the RSLD.

Page 9 of 18

Table 1d

MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE Bundle Type: GE11-P9DUB380-13GZ-100T-145-T6-2948 (GE11)

Average Planar	MAPLHGR Limits ⁽¹⁾ (kw/ft)						
Exposure GWd/ST	Lattice 7433	Lattice 7449	Lattice 7450	Lattice 7451	Lattice 7447	Lattice 7448	Most Limiting
0.00	10.02	10.02	10.00	10.00	10.00	10.00	10.00
0.20	10.02	10.02	10.00	10.00	10.00	10.00	10.00
1.00	9.99	9.99	9.97	9.97	9.97	9.97	9.97
5.00	9.86	9.86	9.80	9.80	9.80	9.80	9.80
10.00	9.68	9.68	9.61	9.61	9.61	9.61	9.61
15.00	9.52	9.52	9.53	9.53	9.53	9.53	9.52
20.00	9.67	9.67	9.70	9.70	9.70	9.70	9.67
25.00	8.85	8.85	8.84	8.84	8.84	8.84	8.84
35.00	8.51	8.51	8.51	8.51	8.51	8.51	8.51
45.00	8.53	8.53	8.55	8.55	8.55	8.55	8.53
55.00	8.57	8.57	8.59	8.59	8.59	8.59	8.57
65.00	8.66	8.66	8.65	8.65	8.65	8.65	8.65

(1) These MAPLHGR are lattice dependent. The values shown in the Most Limiting Column correspond to the limiting value for the most limiting lattice for use when hand calculations are required. Lattice desciptions are contained in the RSLD.

Page 10 of 18



(1) as defined by Nuclear Engineering Report No. NER-1M-022

Page 11 of 18

COLR1-18 Rev. 0





Page 12 of 18





Page 13 of 18



(1) as defined by Nuclear Engineering Report No. NER-1M-022

Page 14 of 18

COLR1-18, Revision 0

Figure 2e NMP-1 K(f) Curve for MCPR



Page 15 of 18





1

Page 16 of 18



Figure 3: LHGR Limits for Operation Between 45% and 90% RTP Without a Backup Pressure Regulator

Core Thermal Power (P) in units of % Rated Thermal Power (%RTP)

Page 17 of 18





Page 18 of 18