

Exelon Generation Company, LLC
Quad Cities Nuclear Power Station
22710 206th Avenue North
Coitdova, IL 61242-9740

www.exeloncorp.com

10CFR50.55a

SVP-07-027

May 5, 2007

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Quad Cities Nuclear Power Station Unit 2
Renewed Facility Operating License No. DPR-30
NRC Docket No. 50-265

Subject: 90-Day Post Outage ISI Letter

Reference: Quad Cities 90-Day Post Outage ISI Letter dated July 14, 2006 (SVP-07-057)

Enclosed is a revision to the Quad Cities Nuclear Power Station Unit 2 Post-Outage (90 day) Summary Report for Inservice Inspection examinations and Repair/Replacement activities conducted from the end of the March 2004 refueling outage through the April 2006 refueling outage. This report was originally issued on July 14, 2006. The report is being reissued due to a pagination error (i.e., an incomplete sentence at the top of page 8).

This report is submitted in accordance with the requirements of ASME Section XI, Article IWA-6200, "Requirements."

If there are any questions or comments concerning this letter, please refer them to Mr. Wally Beck, Regulatory Assurance Manager, at (309) 227-2800.

Sincerely,



Timothy J. Tulon
Site Vice President
Quad Cities Nuclear Power Station

Attachment: Quad Cities Nuclear Power Station - Unit 2
Post Outage (90 day) Summary Report

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Quad Cities Nuclear Power Station

A047

ATTACHMENT

**Quad Cities Nuclear Power Station-Unit 2
Post Outage (90 day) Summary Report
June 22, 2006**

Quad Cities Nuclear Power Station - Unit 2
Post Outage (90 Day) Summary Report
June 22, 2006

Refueling Outage Q2R18
Outage Start Date: March 24, 2006
Outage End Date: April 18, 2006

Commercial Service Date: March 10, 1973
22710 206th Avenue North,
Cordova, IL 61242

Exelon Generation Company, L.L.C.
300 Exelon Way
Kennett Square, PA 19348

Prepared by: Mathew Rice/Virgil Goetz

Reviewed by: David Kunzmann

Reviewed by: David Peters

Reviewed by: Gary Knapp

Approved by: Tom Wojcik

Table of Contents

1.0	INTRODUCTION	3
1.1.	OUTAGE, PERIOD AND INTERVAL START AND END DATES	3
1.2.	EXAMINATION PROGRAM REQUIREMENTS	3
2.0	NIS-1 FORM.....	4
3.0	ABSTRACT OF EXAMINATIONS, CONDITIONS NOTED AND CORRECTIVE MEASURES.....	6
3.1.	SECTION XI EXAMINATIONS SUMMARY	6
3.2.	BWRVIP-75/GENERIC LETTER 88-01	7
3.3.	INVESSEL INSPECTIONS (IVI).....	7
	<i>Table 3.1-1 Quad Cities Unit 2 ASME Section XI Outage Scope</i>	<i>9</i>
	<i>Table 3.1-1A Quad Cities Unit 2 ASME Section XI Limited Coverage Scope</i>	<i>11</i>
	<i>Table 3.1-2 Quad Cities Unit 2 Pressure Testing Summary</i>	<i>12</i>
	<i>Table 3.1-3 Quad Cities Unit 2 Snubber Functional Tests</i>	<i>13</i>
	<i>Table 3.1-4 Quad Cities Unit 2 Conditions Noted and Corrective Actions</i>	<i>14</i>
	<i>Table 3.3 Number and Percentage of Examinations Completed.....</i>	<i>15</i>
4.0	REPAIR / REPLACEMENT SUMMARY	16
4.1.	NIS-2 INDEX	16
	Table 4.1-1	16
4.2.	NIS-2 FORMS	19

1.0 Introduction

1.1. Outage, Period and Interval Start and End Dates

This Inservice Inspection Summary Report addresses examinations performed between the end of the previous refueling outage March 28, 2004 through the end of the most recent refueling outage. This most recent refueling outage was the 18th refueling outage for Quad Cities Nuclear Power Station Unit Two. The outage started March 24, 2006 and was completed April 18, 2006 when the unit returned to service.

This refueling outage was the second outage during the first inspection period of the fourth inspection interval, which began on March 10, 2003. The first inspection period of the fourth inspection interval ends with this refueling outage on April 18, 2006. This report covers examinations performed to the first period, fourth interval requirements.

Tests, examinations, repairs and/or replacements associated with American Society of Mechanical Engineers (ASME) Code, Section XI were witnessed or otherwise verified by the Authorized Nuclear Inservice Inspectors. Non-ASME Section XI or augmented examinations were not witnessed or otherwise verified by the Authorized Nuclear Inservice Inspectors and are marked "Not Required" or "N/A" on the applicable examination reports. The Authorized Nuclear Inservice Inspectors are inspectors of the Hartford Steam Boiler Inspection & Insurance Company of Connecticut (HSB-CT). The HSB-CT Regional Office is located at 2443 Warrenville Road Suite 500, Lisle, Illinois, 60532-9871.

1.2. Examination Program Requirements

The examination requirements of ASME Boiler and Pressure Vessel Code, Section XI, Division 1, "Rules for Inservice Inspection of Nuclear Power Plant Components", 1995 Edition through 1996 Addenda were implemented for Class 1, 2 and 3 components except where written relief has been granted by the NRC. Written relief, in the form of Relief Request I4R-02 approving Risk Informed Inservice Inspection (RI-ISI) as an inspection program alternative for Code Categories B-F, B-J, C-F-1 and C-F-2, was utilized during Q2R18. The ultrasonic examination volumes for RI-ISI components were increased, from the Section XI requirements, to meet the RI-ISI Program.

The ultrasonic examination requirements of ASME Boiler and Pressure Vessel Code, Section XI, Appendix VIII, 1995 Edition with Addenda through 1996, as required by 10 CFR 50.55a, "Codes and Standards", and amended by the Federal Register Notice 64 FR 51370 dated September 22, 1999 is executed through the Performance Demonstration Initiative (PDI) Program according to the schedule defined in 10 CFR 50.55a(g)(6)(ii)(C), for wrought austenitic piping welds, ferritic piping welds, bolts/studs, reactor vessel welds, nozzle to vessel welds, nozzle inside radius sections and full structural overlaid wrought austenitic piping welds.

FORM NIS-1 (Back)

8. Examination Dates: 3/28/04 to 4/18/06

9. Inspection Period
Identification: 1st Period – From 3/10/03 to 4/18/06 for the 4th Interval

10. Inspection Interval Identification: 4th Interval – From 3/10/03 to 3/9/13

11. Applicable Edition of Section XI 1995 Addenda 1996

12. Date/Revision of Inspection Plan: 11/29/05 Revision 2 (4th Interval)

13. Abstract of Examination and Tests. Include a list of examinations and tests and a statement concerning status of work required for the Inspection Plan. See Section 3.0 and Tables 3.1-1, 3.1-1A, 3.1-2, 3.1-3, 3.1-4, and 3.3.

14. Abstract of Results of Examinations and Tests. See Section 3.0 and Tables 3.1-1 3.1-1A, 3.1-2, 3.1-3, 3.1-4, and 3.3

15. Abstract of Corrective Measures. See Section 3.0 and Table 3.1-4.

We certify that a) the statement made in this report are correct, b) the examinations and tests meet the Inspection Plan as required by the ASME Code, Section XI, and c) corrective measures taken conform to the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A
Date 20 Signed Exelon Corporation By Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the under signed, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by Hartford Steam Boiler of Connecticut of Connecticut have inspected the components described in the Owner's Report during the period 3/28/04 To 4/18/06, and state that to the best of my knowledge and belief, the

Owner has performed examinations and tests and taken corrective measures described in this Owner's Report in accordance with the Inspection Plan and as required by the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature _____ Commissions IL 1005
National Board, State, Province, and Endorsements

Date _____ 20 _____

3.0 Abstract of Examinations, Conditions Noted and Corrective Measures

3.1. Section XI Examinations Summary

A combination of ultrasonic (UT), liquid penetrant (PT), magnetic particle (MT) and visual (VT) testing were performed prior to and during the 18th refueling outage on ISI Program components. Examinations were performed by General Electric (GE), IHI Southwest Technologies (ISwT), and Exelon Nuclear personnel. Volumetric and surface examinations were compared with the recorded results of previous examinations for applicable Class 1, 2 and RI-ISI components. ISI inspections comprised of 33 volumetric (16 were RI-ISI, Category R-A welds), 4 surface examinations and 24 visual examinations were performed on Class 1, 2 and RI-ISI components. Thirteen of the visual exams were subsequent exams due to IWF-2200(b) for corrective action from Q2R17. Code cases used for ISI or Repair/Replacement activities are listed in the ISI Program Plan.

The 13 subsequent exams as required by IWF-2200(b) were a result of the "As-Found" cold settings being out of tolerance for both Constant Spring Can Component Supports and Flued Head Anchors that did not meet acceptance criteria during Q2R17. The subsequent examinations found no additional relevant conditions.

Table 3.1-1A, "Quad Cities Unit 2 ASME Section XI Limited Coverage Summary" contains the volumetric examinations that did not meet coverage requirements of ASME Section XI Code (i.e. greater than 90 percent of the specified examination volume). These exams were limited by design specific geometry. Accessibility could not be improved. Four of the exams were on nozzle welds that have received relief for exam limitations in the past. The four nozzle welds coverage increased over the previous interval exams. The last limited exam was for exam category R-A where previous single sided access coverage had achieved 100% when including only ¼" of base metal. Risk informed inspection requirements increased base metal to ½" causing this single sided exam coverage to decrease in total examinable volume. Relief requests as required by 10 CFR 50.55a(g)5(iii) and 50.55a(g)5(iv) will be generated and submitted within twelve (12) months following the end of the inspection interval.

A portion of the reactor vessel vertical welds were examined during Q2R17 in accordance with the requirements of 10CFR50.55a "Codes and Standards" regarding the section entitled "Augmented Examination of Reactor Vessel". The remaining reactor vessel vertical welds were examined during Q2R18.

Pressure testing VT-2 examinations not related to repair/replacement activities are documented in Table 3.1-2, "Quad Cities Unit 2 Pressure Testing Summary". The Class 1 Vessel Leakage Test and the Reactor Vessel Head Flange Seal Leak Detection System Test were performed in accordance with the 1995 Edition 1996 Addenda of the ASME Code for the first period of the fourth Interval.

Exelon personnel performed functional tests on a total of fifteen (15) snubbers for operability per the Service Life Monitoring/Failure Trending Sample and ASME OM Code

Subsection ISTD. Nine (9) of the fifteen (15) snubbers were ASME Section XI Code designated. Of the fifteen (15) snubbers tested, one was found unacceptable for continued operation (IR# 471469). An additional nine (9) snubbers were tested for expanded sampling due to snubber failure. Eight (8) of the nine (9) expanded sample snubbers were ASME Section XI Code designated. Of the additional nine (9) snubbers tested, two (2) snubbers were found unacceptable for continued operation (IR# 472956 and 472989). The three (3) unacceptable snubbers were replaced with like-for-like units. Snubber testing activities are summarized in Table 3.1-3, "Quad Cities Unit 2 Snubber Functional Tests".

Table 3.1-4 "Quad Cities Unit 2 Conditions Noted and Corrective Actions" summarizes the conditions noted during the examinations and corrective measures taken prior to returning the unit to service.

Table 3.3 identifies number and percentage of examinations completed in the fourth interval.

NRC performed an audit of the Inservice Inspection (ISI) Program during Q2R18 (IR 05000254(265)/2006004). No findings were noted.

3.2. BWRVIP-75/Generic Letter 88-01

Augmented examinations required by Generic Letter 88-01, "NRC Position on Intergranular Stress Corrosion Cracking (IGSCC) in BWR Austenitic Stainless Steel Piping" and BWRVIP-75, "BWR Vessel and Internals Project Technical Bases for Revisions to Generic Letter 88-01 Inspection Schedules", were implemented in the previous outage Q2R17. No exams were performed this outage.

3.3. In-vessel Inspections (IVI)

To implement the requirements of the Boiling Water Reactor Vessel Internals Program, (BWRVIP), GE was contracted to perform the In-Vessel Visual Inspections (IVVI). The following components and assemblies were examined: Jet Pump Assemblies in accordance with the BWR Jet Pump Assembly Inspection and Flaw Evaluations Guidelines (BWRVIP-41-A), Core Spray Internal Piping in accordance with the BWR Core Spray Internals Inspection and Flaw Evaluation Guidelines (BWRVIP-18-A), Core Shroud Ring Segment Vertical Welds in accordance with the BWR Core Shroud Inspection and Flaw Inspection Guideline (BWRVIP-76), Reactor Pressure Vessel attachments associated with the Feedwater Spargers and steam dryer wall support lugs in accordance with the BWR Vessel ID Weld Inspection and Flaw Evaluation Guidelines (BWRVIP-48-A), and Control Rod Guide Tubes in accordance with BWR Vessel and Internals Project Boiling Water Reactor Lower Plenum Inspection and Flaw Evaluation Guidelines (BWRVIP-47-A).

A 10-year re-inspection of the core shroud repair hardware (tie rods) was performed during Q2R18. Additional detailed inspections were performed in accordance with GE and BWRVIP recommendations in response to recent findings at Plant Hatch. No recordable indications were identified.

Indications were observed on two of the core shroud rings during Q2R18. At the Core Support Flange Ring, multiple crack-like indications were observed at the heat affected zone of circumferential weld H-5 (IR 475862). These indications do not pose a challenge to the structural integrity of the core support ring since the shroud stabilizers (tie rods) structurally reinforce welds H1 through H7. Another indication was found on the top surface of the Shroud Head Flange ring (IR 475332). The indication appeared to be a scratch or small gouge. It did not line up with any probable heat affected zone and did not have any depth when viewed from the vertical surface.

During the IVVI examinations four (4) jet pumps were identified with evidence of main wedge (WD-1) movement. GE Indication Notification Reports (INRs) and Exelon Issue Reports (IRs) were generated to document these conditions (IR 474814, IR 475009, IR 474491 and IR 474070). Additional inspections were performed as required by BWRVIP-41-A including supplemental visual inspections of the affected jet pumps to confirm overall pump integrity. The most severe wedge movement (on Jet Pump #07) was corrected via a planned restrainer bracket replacement under WO 823272-01. Quad Cities shall continue to monitor the condition of jet pump wedges during future IVVI visual inspections.

Seven of eight Feedwater Sparger End Bracket pins were welded into place during Q2R18. This was a planned activity in response to a missing nut on a Feedwater Sparger End Bracket pin identified during Q2R17, which was welded into place during Q2R17. In addition, two of the pinheads were observed to be wearing into the bracket hardware during Q2R18 due to flow-induced vibration (IR 474497). This is not a concern for the immediate future. The worst worn bracket still has greater than 90% of its original thickness remaining. Quad Cities will continue to monitor this condition. In the meantime, long-term repair options are being evaluated.

Table 3.1-1
Quad Cities Unit 2
ASME Section XI Outage Scope (4th Interval)

Drawing	Component	Class	Category	Item	Inspection	Date	Results
M-3121 SHT. 2	RPV-VSC1-317	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC1-197	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC1-261	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC1-77	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-MRA-011	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC2-141	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC2-22	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC3-197	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC3-317	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-VSC3-77	1	B-A	B1.12	UT	4/02/06	NRI
M-3121 SHT. 2	RPV-CW-C4FLG	1	B-A	B1.30	UT	4/02/06	NRI
M-3121 SHT. 2	N1A NOZ	1	B-D	B3.90	UT	4/01/06	NRI
M-3121 SHT. 2	N2B NOZ	1	B-D	B3.90	UT	4/01/06	NRI
M-3121 SHT. 2	N2D NOZ	1	B-D	B3.90	UT	4/02/06	NRI
M-3121 SHT. 2	N2E NOZ	1	B-D	B3.90	UT	4/04/06	NRI
M-3121 SHT. 2	N1A IRS	1	B-D	B3.100	UT	4/01/06	NRI
M-3121 SHT. 2	N2B IRS	1	B-D	B3.100	UT	4/01/06	NRI
M-3121 SHT. 2	N2D IRS	1	B-D	B3.100	UT	4/02/06	NRI
M-3121 SHT. 2	N2E IRS	1	B-D	B3.100	UT	4/04/06	NRI
M3115 SHT. 1	REACTOR HEAD N6A FLANGE	1	B-G-2	B7.50	VT-1	3/31/06	NRI
M3115 SHT. 1	REACTOR HEAD N6B FLANGE	1	B-G-2	B7.50	VT-1	3/31/06	NRI
M3115 SHT. 1	REACTOR HEAD N7 FLANGE	1	B-G-2	B7.50	VT-1	3/31/06	NRI
M3113 SHT. 3	DECON FLANGE 3"(A)	1	B-G-2	B7.50	VT-1	3/30/06	NRI
M3113 SHT. 3	DECON FLANGE 3"(B)	1	B-G-2	B7.50	VT-1	3/30/06	NRI
M-3111 SHT. 1	3001B-W-102A	1	B-K	B10.20	MT	3/31/06	NRI
M-3113 SHT. 2	0200-W-133A	1	B-K	B10.40	PT	4/03/06	NRI
N/A	RPV INTERIOR	1	B-N-1	B13.10	VT-3	4/14/06	ACCEPTABLE
N/A	RPV INTERNALS	1	B-N-2	B13.20	VT-1	4/14/06	ACCEPTABLE
M-3136 SHT. 7	1008A-W-203A	2	C-C	C3.20	MT	3/21/06	NRI
M-3136 SHT. 9	1024A-W-201A	2	C-C	C3.20	PT	3/21/06	NRI
M-3114 SHT. 1	1403-M-104	1	F-A	F1.10	VT-3	4/01/06	NRI
M-3111 SHT. 1	3204C-W-101A&B	1	F-A	F1.10	VT-3	4/01/06	NRI
M-3111 SHT. 1	3001B-W-102A&B	1	F-A	F1.10	VT-3	3/29/06	NRI
M-3136 SHT. 8	1013A-W-201	2	F-A	F1.20	VT-3	3/16/06	NRI
M-3137 SHT. 4	2304-M-209	2	F-A	F1.20	VT-3	3/28/06	NRI
M-3135 SHT. 4	1403-M-203	2	F-A	F1.20	VT-3	3/24/06	NRI
M-3136 SHT. 6	1006A-W-201	2	F-A	F1.20	VT-3	3/21/06	ACCEPTABLE
M-3137 SHT. 4	2304-G-205	2	F-A	F1.20	VT-3	3/17/06	NRI
M-3113 SHT. 3	0200-W-127A&B	2	F-A	F1.40	VT-3	4/02/06	NRI

Table 3.1-1

Quad Cities Unit 2 ASME Section XI Outage Scope (4 th Interval)							
Drawing	Component	Class	Category	Item	Inspection	Date	Results
M-3113 SHT. 3	0200-W-128A&B	2	F-A	F1.40	VT-3	4/02/06	NRI
M-3113 SHT. 3	0200-W-129A&B	2	F-A	F1.40	VT-3	4/02/06	NRI
M-3136 SHT. 6	1008A-3	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/22/06	NRI
M-3136 SHT. 7	1010-6	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/23/06	NRI
M-3112 SHT. 2	32C-S2	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/30/06	NRI
M-3136 SHT. 6	1008A-17	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/22/06	NRI
M-3136 SHT. 4	1006C-3	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/21/06	NRI
M-3136 SHT. 4	1008B-1	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/21/06	NRI
M-3136 SHT. 4	1006C-4	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/21/06	NRI
M-3136 SHT. 6	1008A-16	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/22/06	NRI
M-3111 SHT. 2	32A-F11	1	R-A	R1.11	UT-E (RISI EXPANDED)	3/29/06	NRI
M-3111 SHT. 1	30A-S10	1	R-A	R1.20	UT-E (RISI EXPANDED)	3/29/06	NRI
M-3111 SHT. 1	30B-S0	1	R-A	R1.20	UT-E (RISI EXPANDED)	3/30/06	NRI
M-3111 SHT. 1	30A-S9	1	R-A	R1.20	UT-E (RISI EXPANDED)	3/29/06	NRI
M-3111 SHT. 2	30C-S18	1	R-A	R1.20	UT-E (RISI EXPANDED)	3/31/06	NRI
M-3111 SHT. 1	30A-S11	1	R-A	R1.20	UT-E (RISI EXPANDED)	4/05/06	NRI
M-3111 SHT. 2	30C-S19	1	R-A	R1.20	UT-E (RISI EXPANDED)	3/29/06	NRI
M-3111 SHT. 1	30A-F1	1	R-A	R1.20	UT-E (RISI EXPANDED)	3/30/06	NRI
Subsequent Exams Due to IWF-2200(b)							
M-3112 SHT. 1	3204B-W-101	1	F-A	F1.10	VT-3	3/31/06	NRI
M-3112 SHT. 2	3204A-W-102	1	F-A	F1.10	VT-3	3/31/06	NRI
M-3112 SHT. 2	3204A-M-101	1	F-A	F1.10	VT-3	3/31/06	NRI
M-3111 SHT. 1	3001B-W-103	1	F-A	F1.10	VT-3	3/29/06	NRI
M-3111 SHT. 1	3001B-M-106	1	F-A	F1.10	VT-3	3/30/06	NRI
M-3118 SHT. 1	2305-M-104	1	F-A	F1.10	VT-3	3/28/06	ACCEPTABLE
M-3112 SHT. 2	3204A-M-104	1	F-A	F1.10	VT-3	3/30/06	ACCEPTABLE
M-3111 SHT. 2	3001C-M-106	1	F-A	F1.10	VT-3	3/30/06	NRI
M-3111 SHT. 2	3001D-M-105	1	F-A	F1.10	VT-3	3/30/06	NRI
M-3111 SHT. 1	3001A-M-105	1	F-A	F1.10	VT-3	3/30/06	NRI
M-3112 SHT. 1	3204B-M-103	1	F-A	F1.10	VT-3	3/30/06	ACCEPTABLE
M-3111 SHT. 2	3001C-W-102A&B	1	F-A	F1.10	VT-3	3/29/06	NRI
M-3111 SHT. 1	3001B-W-104A&B	1	F-A	F1.10	VT-3	3/28/06	NRI

Table 3.1-1A

Quad Cities Unit 2
 ASME Section XI Limited Coverage Summary (4th Interval)

Drawing	Component	Class	Category	Item	Inspection	ASME % Coverage
M-3111 SHT. 2	30C-S18 ¹	1	R-A	R1.20	UT	71
M-3121 SHT. 2	RPV-VSC1-197 ²	1	B-A	B1.12	UT	38
M-3121 SHT. 2	RPV-VSC2-22 ²	1	B-A	B1.12	UT	66
M-3121 SHT. 2	RPV-VSC3-77 ²	1	B-A	B1.12	UT	82
M-3121 SHT. 2	RPV-VSC3-197 ²	1	B-A	B1.12	UT	75
M-3121 SHT. 2	RPV-VSC3-317 ²	1	B-A	B1.12	UT	79
M-3121 SHT. 2	N1A NOZ ²	1	B-D	B3.90	UT	21
M-3121 SHT. 2	N2B NOZ ²	1	B-D	B3.90	UT	37
M-3121 SHT. 2	N2D NOZ ²	1	B-D	B3.90	UT	37
M-3121 SHT. 2	N2E NOZ ²	1	B-D	B3.90	UT	37

¹NOTE: Previous coverage on this weld using ¼" of base metal was considered to be essentially 100%. Risk informed inspection increased base metal to ½" causing this single sided access exam to decrease in the total examinable volume. 30C-S18 has been removed and replaced with 30C-S18R with new pre-service inspections under the Acoustic Side Branch Modification.

²NOTE: These welds were limited during the 3rd interval and were granted relief under Exelon Relief Request CR-20 and CR-32. Coverage was equal or greater under new examination.

Table 3.1-2
Quad Cities Unit 2
Pressure Testing Summary (4th Interval)

Component	Inspection	Category	Item Number	Procedure/ Report	Completion Date	Relief Request	Remarks
RX, Class 1 and Class 2	Visual, VT-2	B-P	B15.10, 15.50, 15.60, 15.70	QCOS 0201-08 VT Report VT2-047	04/13/06	I4R-07	Class 1 & 2 System leakage Test
N10 IRS	Visual, VT-2	B-D	B3.100	QCOS 0201-08 VT Report VT2-047	04/13/06	I4R-01	Class 1 System leakage Test
Core Spray Class 1	Visual, VT-2	B-P	B15.50, 15.70	QCOS 0201-08 VT Report VT2-047	04/13/06	I4R-07	Class 1 System leakage Test
RHR Class 1	Visual, VT-2	B-P	B15.50, 15.70	QCOS 0201-08 VT Report VT2-047	04/13/06	I4R-07	Class 1 System leakage Test
Line 2-0236-1" and 2-0234-1"	Visual, VT-2	C-H	C7.30, C7.70	VT Report Q2R18-BOP-099	03/30/06	I4R-05	Reactor Vessel Head Flange Seal Leak Detection System
Core Spray	Visual, VT-2	C-H	C7.30, C7.50, C7.70	VT2-277 VT2-266	10/18/05 09/08/05	I4R-07	Class 2 System Leakage Test
CRD	Visual, VT-2	C-H	C7.10, C7.30, C7.70	VT2-040 VT2-018	02/09/06 01/10/06	I4R-06, I4R-07	Class 2 System Leakage Test
ECCS Torus Suction	Visual, VT-2	C-H	C7.30, C7.70	VT2-035 VT2-281	01/20/06 10/21/05	I4R-07	Class 2 System Leakage Test
ECCS Fill	Visual, VT-2	C-H	C7.30, C7.50, C7.70	VT2-279	10/21/05	I4R-07	Class 2 System Leakage Test
HPCI	Visual, VT-2	C-H	C7.30, C7.50, C7.70	VT2-287 VT2-281 VT2-237* *QCTS 0762-02	11/16/05 10/21/05 05/12/05	I4R-07	Class 2 System Leakage Test
RHR	Visual, VT-2	C-H	C7.30, C7.50, C7.70	VT2-042* VT2-016 VT2-002* VT2-271 VT2-239 *QCTS 762-07 TIC 1358	02/13/06 01/06/06 01/05/06 09/23/05 05/12/05	I4R-07	Class 2 System Leakage Test
SBLC	Visual, VT-2	C-H	C7.30, C7.50, C7.70	VT2-043 VT2-014 VT2-013 VT2-233* VT2-257 *QCTS 0762-08	2/24/06 01/06/06 01/06/06 05/11/05 12/10/04	I4R-07	Class 2 System Leakage Test
Scram Discharge Volume	Visual, VT-2	C-H	C7.10, C7.30, C7.70	QCOS 0201-08 VT Report VT2-225	03/26/04	I4R-07	Class 2 System Leakage Test

Table 3.1-3

Quad Cities Unit 2
 Snubber Functional Tests (4th Interval)

Drawing	Component	T/S Number	Class	Category	Item	Inspection	Date Tested	Results
M-1026D-311	1012A-W-102 ¹	2-006	1	F-A	F1.40	FT	04-Apr-06	PASS
M-1026D-319	1012B-W-101	2-008	1	F-A	F1.40	FT	28-Mar-06	PASS
M-1022D-270	0200-W-109 A&B	2-013	1	F-A	F1.40	FT	31-Mar-06	PASS
M-1022D-271	0200-W-128 A&B	2-014	1	F-A	F1.40	FT	29-Mar-06	PASS
M-1024D-7	1307-M-106 ¹	2-042	1	F-A	F1.40	FT	30-Mar-06	FAIL
M-328E Sht. 2	3001A-M-101.2	2-055	1	F-A	F1.40	FT	28-Mar-06	PASS
M-328G Sht. 8	2305-M-101.2 ¹	2-076	1	F-A	F1.40	FT	29-Mar-06	PASS
M-328G Sht. 9	2305-M-101.1	2-077	1	F-A	F1.40	FT	28-Mar-06	FAIL
M-328G Sht. 22	2305-M-102.1 ¹	2-078	1	F-A	F1.40	FT	30-Mar-06	FAIL
M-1802-04 Sht. 1, 2	1025-M-219	2-097	2	F-A	F1.20	FT	22-Mar-06	PASS
M-1802-26 Sht. 1, 2	1025-M-201	2-102	2	F-A	F1.20	FT	23-Mar-06	PASS
M-1813-03	2306-M-206.1	2-114	2	F-A	F1.20	FT	20-Mar-06	PASS
M-1017D-59	2305-M-207 ¹	2-120	2	F-A	F1.20	FT	30-Mar-06	PASS
M-1806-04	1015B-M-203 A&B ¹	2-126	2	F-A	F1.20	FT	04-Apr-06	PASS
M-1806-04	1015B-M-203 A&B ¹	2-127	2	F-A	F1.20	FT	04-Apr-06	PASS
M-1806-07	1015B-M-201.1	2-128	2	F-A	F1.20	FT	21-Mar-06	PASS
M-1813-06	2306-M-201 ¹	2-143	2	F-A	F1.20	FT	02-Apr-06	PASS
M-329B Sht. 6	N/A	2-026	NA	NA	NA	FT	28-Mar-06	PASS
M-1026D-93	N/A	2-036	NA	NA	NA	FT	20-Mar-06	PASS
M-1023D-57	N/A	2-038	NA	NA	NA	FT	28-Mar-06	PASS
M-1020D-502 Sht.	N/A ¹	2-040	NA	NA	NA	FT	03-Apr-06	PASS
M-328F Sht. 15	N/A	2-065	NA	NA	NA	FT	28-Mar-06	PASS
M-1814-04	N/A	2-116	NA	NA	NA	FT	21-Mar-06	PASS
M-1815-02 Sht. 1, 2	N/A	2-119	NA	NA	NA	FT	23-Mar-06	PASS

¹ NOTE: These snubbers were tested as part of the expanded sample testing as a result of functional test failures (IRs 00471469, 00472956, and 00472989).

Table 3.1-4

**Quad Cities Unit 2
 Conditions Noted and Corrective Actions (4th Interval)**

Component ID	Description / Resolution
Pressure Test	
	During the Unit 2 Class 1 Leakage Test the listed components were identified to be leaking. Corrective actions were taken as follows:
"B" Recirculation Pump Flange.	Corrective actions completed <ul style="list-style-type: none"> • Engineering evaluation (EC # 0000335753) was performed (as permitted by Relief Request I4R-07) on the 2B Recirculation Pump and determined the leakage to be acceptable.
2-3299-129 Flange leak 2-0220-44 Flange leak	Reference VT report # VT2-047 dated 04/13/06 Issue Report 478659 Tightened Flange Issue Report 478644 Repaired Valve
HCU Vlv Flange leaks	Reference EC 359753 evaluating Leakage Observed Report VT2-018
Visual Inspections	
Containment Penetrations X1 and X2 Moisture Barriers	As a result of inspections in accordance with ASME Section XI IWE 1992 Edition, 1992 Addenda degraded moisture barriers on penetrations X1 and X2 were identified. X1 and X2 were repaired under Work Order # 907825.
In Vessel Inspections	
Core Shroud Ring Segments	Indications were observed on two of the core shroud rings during Q2R18. At the Core Support Flange Ring, multiple crack-like indications were observed at the heat affected zone of circumferential weld H-5 (IR 475862). These indications do not pose a challenge to the structural integrity of the core support ring since the shroud stabilizers (tie rods) structurally reinforce welds H1 through H7. Another indication was found on the top surface of the Shroud Head Flange ring (IR 475332). The indication appeared to be a scratch or small gouge. It did not line up with any probable heat affected zone and did not have any depth when viewed from the vertical surface.
Jet Pump WD-1 Wedge Wear	During the IVVI visual examinations four (4) jet pumps were identified with evidence of main wedge (WD-1) movement. GE Indication Notification Reports (INRs) and Exelon Issue Reports (IRs) were generated to document these conditions (IR 474814, IR 475009, IR 474491 and IR 474070). Additional inspections were performed as required by BWRVIP-41a including supplemental visual inspections of the affected jet pumps to confirm overall pump integrity. The most severe wedge movement (on Jet Pump #07) was corrected via a planned restrainer bracket replacement under WO 823272-01. Quad Cities shall continue to monitor the condition of jet pump wedges during future IVVI visual inspections.
Feedwater Sparger End Brackets	Seven of eight Feedwater Sparger End Bracket pins were welded into place during Q2R18. This was a planned activity in response to a missing nut on a Feedwater Sparger End Bracket pin identified during Q2R17. In addition, two of the pinheads were observed to be wearing into the bracket hardware during Q2R18 due to flow-induced vibration (IR 474497). This is not a concern for the immediate future. The worst worn bracket still has greater than 90% of its original thickness remaining. Quad Cities will continue to monitor this condition. In the meantime, a long-term repair options are being evaluated. Engineering Evaluation EC 360359 determined that all of the indications are acceptable for at least one cycle of continued operation.

Table 3.3

Quad Cities Unit 2 Number and Percentage of Examinations Completed (4th Interval)				
Category	Exams Completed in Q2R18	Exams Completed to Date	Total Exams in the Interval	Percentage Complete for Interval
B-A ⁴	11	15	25	60
B-D	8	20	58	34
B-G-1 ¹	0	5	6	83
B-G-2	5	7	19	37
B-K	2	4	9	44
B-L-2 ⁵	Not Applicable	Not Applicable	Not Applicable	Not Applicable
B-M-2 ⁵	1	1	1	100
B-N-1 ²	1	1	1	100
B-N-2 ²	1	1	1	100
B-O ⁴	0	0	2	0
B-P ³	1	1	1	100
C-A	0	1	4	25
C-B ⁶	6	8	14	57
C-C	2	3	10	30
C-H ³	1	1	1	100
F-A	11	34	91	37
R-A	17	35	98	36

¹Note: Category B-G-1 is for reactor vessel studs and nuts. Items in this category are repeated each period and may result in greater than the limiting percentage of exams.

²Note: Category B-N-1 and B-N-2 are inspected each period.

³Note: Category B-P and C-H exams are tracked under Table 3.1-2.

⁴Note: Exam Category B-A and B-O are scheduled to coincide with previous interval to maintain ten year interval between exams and are performed in accordance with 10CFR50.55a. Period completion percentage does not apply.

⁵Note: Categories B-L-2, and B-M-2 are inspected and credited under the Repair/Replacement Program only when the component is disassembled.

⁶Note: Categories C-B components are examined during the performance of the system pressure test each inspection period and can result in greater than the limiting percentage of exams. Some of VT-2 for item number C2.33 were completed during 10/24/05 maintenance outage.

4.0 Repair / Replacement Summary

4.1 NIS-2 Index

Table 4.1-1
Quad Cities Unit 2
NIS-2 List

Program Number	Component EPN	Work Request Number or Purchase Order	ASME XI Class
01-056	0-Spare-V26	99225877-02	1
02-149	0-Spare-V25	00410536-01	1
03-056 & 061	2-0203-2A	99149021-01,11	1
03-084	2-0203-2D	00905448-01	1
04-092	0-Spare-V-26	00638775-03	1
04-093	0-Spare -V26	00638775-04	1
05-019	2-0203-3A	00741114-01	1
05-057	0-Spare-V25	00749529-02	1&2
05-059	2-0203-3A	00741114-09	1
05-061	2-0201-N6A	00732708-18	1
05-063	2-3001-A56	00810572-01	1
05-064	2-0300-34-55	00809436-01	1
05-065	2-0201-1	00687492-02	1
05-070	0-Spare-V25	00749530-02	1&2
05-073	2-1001-67C	00634293-01	2
05-076	2-1001-67B	00634292-01	2
05-083	2-0300-26-23	00678367-01	1
05-084	2-0300-10-31	00678367-02	1
05-090	0-Spare-V25	00797734-02	1&2
05-094	2-0300-38-11	00678367-03	1
05-095	2-0300-30-07	00678367-04	1
05-096	2-0300-38-03	00678367-05	1
05-097	2-0300-38-07	00678367-06	1
05-098	2-0300-38-15	00678367-07	1
05-099	2-0300-18-27	00678367-08	1
05-100	2-0300-22-39	00678367-09	1
05-101	2-0300-22-31	00678367-10	1
05-102	2-0300-26-07	00678367-11	1
05-103	2-0300-30-39	00678367-12	1
05-104	2-0300-42-07	00678367-13	1
05-105	2-0300-46-11	00678367-14	1
05-106	2-0300-46-23	00678367-15	1
05-107	2-0300-58-27	00678367-16	1
05-108	2-0300-10-27	00678367-17	1
05-109	2-0300-18-39	00678367-18	1
05-110	2-0300-14-39	00678367-19	1
05-111	2-0300-30-35	00678367-20	1
05-112	2-1402-28B	00711451-02	2
05-113	2-2301-23	00790545-02	2
05-114	2-1001-36B	00683075-01	2

Table 4.1-1
Quad Cities Unit 2
NIS-2 List

Program Number	Component EPN	Work Request Number or Purchase Order	ASME XI Class
05-115	2-1699-9	00765109-02	2
05-117	2-3007C-1.5"	00701257-01	1
05-118	2-3007D-1.5"	00701258-01	1
05-119	2-2330-1.5"	00701259-01	1
05-120	2-3007B-1.5"	00701256-01	1
05-121, 06-077	2-1001-125C	00732429-03,01	2
05-127 & 128	2-1106A	00738096-03,01	2
05-134, 06-083, 06-085	2-2301-74.	00774917-01	2
05-139	2-1001-34B	00454494-01	2
06-003	2-0203-4B	00812173-01	1
06-004	2-0203-4A	00812172-01	1
06-005	2-0203-4F	00729408-01	1
06-006	2-0203-4E	00729090-01	1
06-007	2-0203-3B	00789813-01	1
06-013	2-0203-3D	00883853-01	1
06-021	TS-2-28	00886262-01	1
06-022	2-3001-A55	00656068-01	1
06-025	2-0203-4C	00885318-01	1
06-026	2-0203-4D	00885319-01	1
06-027	2-0203-4G	00885320-01	1
06-028	2-0203-4H	00885321-01	1
06-034	2-0203-3E	00789812-01	1
06-039	0-Spare-V26	00902278-01	1
06-040	0-Spare-V26	00902278-02	1
06-041	0-Spare-V26	00902278-03	1
06-043	2-0203-4A thru H 2-0203-3B thru E	00885018-13	1
06-044	2-0203-3C/D 2-0203-4C/D/G/H	885018-04	1
06-045	2-0203-3B/E 2-0203-4A/B/E/F	885018-01	1
06-049	0-Spare-D15	PO# 707 Rel. 151547	1
06-050	0-Spare-D15	PO# 707 Rel. 151547	1
06-051	0-Spare-D15	PO# 707 Rel. 151547	1
06-052	0-Spare-D15	PO# 707 Rel. 151547	1
06-053	0-Spare-D15	PO# 707 Rel. 151547	1
06-054	0-Spare-D15	PO# 707 Rel. 151547	1
06-055	0-Spare-D15	PO# 707 Rel. 151547	1
06-056	0-Spare-D15	PO# 707 Rel. 151547	1
06-057	0-Spare-D15	PO# 707 Rel. 151547	1
06-058	0-Spare-D15	PO# 707 Rel. 151547	1
06-059	0-Spare-D15	PO# 707 Rel. 151547	1
06-060	0-Spare-D15	PO# 707 Rel. 151547	1
06-061	0-Spare-D15	PO# 707 Rel. 151547	1
06-062	0-Spare-D15	PO# 707 Rel. 151547	1

Exelon Generation Company, L.L.C.
 300 Exelon Way
 Kennett Square, PA 19348
 Commercial Service Date March 10, 1973

Quad Cities Nuclear Power Station
 Unit 2
 22710 206th Avenue North,
 Cordova, IL 61242

Table 4.1-1
Quad Cities Unit 2
NIS-2 List

Program Number	Component EPN	Work Request Number or Purchase Order	ASME XI Class
06-063	0-Spare-D15	PO# 707 Rel. 151547	1
06-064	0-Spare-D15	PO# 707 Rel. 151547	1
06-065	0-Spare-D15	PO# 707 Rel. 151547	1
06-066	0-Spare-D15	PO# 707 Rel. 151547	1
06-067	0-Spare-D15	PO# 707 Rel. 151547	1
06-068	0-Spare-D15	PO# 707 Rel. 151547	1
06-070	2-2305-77	00656074-01	1
06-071	2-0220-2	00905901-01	2
06-075	2-1001-125A	00832684-01	2
06-076	2-1001-125B	00776113-01	2
06-078	2-2305-78	00906180-01	1
06-079	TS-2-042	00906183-01	1
06-082	TS-2-127	00907358-01	2
06-086	2-0203-3A	00818566-07	1
06-125	2-1810-35	99242367-02	2

Exelon Generation Company, L.L.C.
300 Exelon Way
Kennett Square, PA 19348
Commercial Service Date March 10, 1973

Quad Cities Nuclear Power Station
Unit 2
22710 206th Avenue North,
Cordova, IL 61242

4.2 NIS-2 Forms (Attached)

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 02/19/03
Sheet: 1 of 1
Unit: 0

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program Number 01-056 WO# 99225877-02
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam: Class 1 (spare)

5. (a) Applicable Construction Code: USAS B31.1 1965 Edition, None Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1989 Edition, N/A Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Electromatic Relief Valve	Dresser	BK 7069	N/A	0-Spare-V26	N/A	Replacement	No

7. Description of Work: Replaced the seal weld as required by the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure ___ psi Test Temp. ___ °F

9. Remarks: No pressure testing required.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ASI COORDINATOR Date FEBRUARY 19 20 03
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 16/25/01 to 02/19/03, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspectors Signature [Signature] Commissions IL 1580
National Board, State, Province, and Endorsements

Date FEB 19 20 03

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL. 60555

Date: 3/3/2006
 Sheet: 1 of 1
 Unit: 0

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL. 61242

Program No. 02-149 WO 00410536-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL. 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Feedwater, Class 1 (Spare)

- i. (a) Applicable Construction Code: USAS B31.1 1967 Edition, None Addenda, N/A Code Case
- (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1989 Edition, None Addenda, N-496-1 Code Case

ii. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Check Valve	Crane	N/A	N/A	0-spare-V25	N/A	Repaired	No

Description of Work: Repaired valve bonnet by installing helicoil in accordance with the WO.

Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

Remarks: None.

CERTIFICATE OF COMPLIANCE

I hereby certify that the statements made in this report are correct and this repair conforms to the rules of ASME Code, Section XI

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date March 3 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors in the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during period 12/14/05 to 4/2/06, and state that to the best of my knowledge and belief, the owner has performed examinations and corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Signed [Signature] Commissions IL 1005
Inspectors Signature National Board, State, Province, and Endorsements

4/2/06 20 _____

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555
Date: 05/25/2006
Sheet: 1 of 1
Unit: 2
2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242
Program No. 03-056, 03-061 WO 99149021-01, -11
Repair Organization P.O. No., Job No., etc.
3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242
Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A
4. Identification of System: Main Steam, Class I
5. (a) Applicable Construction Code: ASA B31.1 1955 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case
6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Exelon	N/A	N/A	2-0203-2A	N/A	Repaired	No

7. Description of Work: Overhauled valve in accordance with the WO.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F
9. Remarks: Appendix J testing.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed J. M. H. Engng. Prog. Supervisor Date May 25 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors in the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during a period 12/14/05 to 6/14/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature J. C. Ouyang Commissions IL 1005
National Board, State, Province, and Endorsements

ite 6/14 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/18/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 03-084 WO 905448-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASA B31.1 1955 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

5. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Exelon	N/A	N/A	2-0203-2D	N/A	Repaired	No

6. Description of Work: Overhauled valve and replaced bonnet bolting in accordance with the WO.

7. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

8. Remarks: Appendix J testing.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engrs Prog Supvr Date May 19 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors in the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 06/15/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements
Date June 15 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 04/6/2006
Sheet: 1 of 1
Unit: 0

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 04-092 WO 00638775
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System Spare Electromatic Relief Valve. Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Dresser IND.	BX-00293	N/A	0-Spare-V26	N/A	Replacement	No

7. Description of Work: Seal weld the insert ring disc retainer plate to the valve cage in accordance with W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date April 12 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/2005 to 4/18/2006, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements
Date 4/18 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 04/6/2006
 Sheet: 1 of 1
 Unit: 0

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 04-093 WO 00638775-04
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System Spare Electromatic Relief Valve, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Section III 1980, 1995 Edition, 1980, 1996 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Dresser IND.	BX-00293	N/A	0-Spare-V26	N/A	Replacement	No

7. Description of Work: Performed EPRI 2 to 1 weld on body to pipe weld in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supervisor Date April 21 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors of the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during a period 12/14/2005 to 4/21/06, and state that to the best of my knowledge and belief, the owner has performed examinations and corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Signed [Signature] Commissions 12/10/05
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/21 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 02/20/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, Il. 60555 Unit: 2

2. Plant: Quad Cities Generating Station Program No. 05-019 WO 741114-01
22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASME Sect. III 1968 Edition, Winter 1968 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Exelon	N/A	N/A	2-0203-3A	N/A	Replacement	No

7. Description of Work: Replaced valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B: QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date February 20 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 2/23/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. In signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 161005
National Board, State, Province, and Endorsements

Date 2/23 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 03/20/2006
Sheet: 1 of 1
Unit: 0

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-057 WO 00749529-02
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Reactor Feedwater, Class 1 or 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Exelon	N/A	N/A	0-SPARE-V25	N/A	Replacement	No

7. Description of Work: Replaced valve disc hard-facing by machining and welding in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Supvr Date March 24 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 3/27/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 14 1005
National Board, State, Province, and Endorsements
Date 3/27 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 02/20/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-059 WO 741114-09
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASME Sect. III 1968 Edition, Winter 1968 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Exelon	N/A	N/A	2-0203-3A	N/A	Replacement	No

7. Description of Work: Installed hydranuts on Target Rock relief valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Supvr Date February 20 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 2/23/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements
Date 2/23/ 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 03/20/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-061 WO 00732708-18
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Reactor Vessel, Class 1

5. (a) Applicable Construction Code: ASME Section III 1965 Edition, Summer 1965 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Flange assembly	Exelon	N/A	N/A	2-0201-N6A	N/A	Replacement	No

7. Description of Work: Installed flange and special fasteners for dryer monitoring instrumentation in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Supvr Date March 24 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 3/24/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 12 1005
National Board, State, Provice, and Endorsements
3/24 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/23/2005
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-063 WO 00810572-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber Clamp	Exelon	N/A	N/A	2-3001-A56	N/A	Replacement	No

7. Description of Work: Replaced missing snubber clamp nut in accordance with the Work Order.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement.

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date May 24 2006
Owner or Owner's Designate, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 06/21/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspectors Signature National Board, State, Province, and Endorsements

Date June 21 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 02/21/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-064 WO 809436-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Control Rod Drive, Class 1

5. (a) Applicable Construction Code: ASME Sect. III 1974 Edition, Winter 1975 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Control Rod Drive	Exelon	N/A	N/A	2-0300-34-55	N/A	Replacement	No

7. Description of Work: Replaced CRD flange bolting in accordance with the WO.

3. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

8. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date February 21 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 02/23/06, and state that to the best of my knowledge and belief, the owner has performed examinations and any corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

In signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Signed [Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/23 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 3/2/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-065 WO 00687492-02
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Reactor Vessel, Class I

5. (a) Applicable Construction Code: ASME Sect. III Class A 1965 Edition, Summer 1965 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Reactor Vessel	Chicago Bridge & Iron	T22	N/A	2-0201-1	1970	Replacement	Yes

7. Description of Work: Replaced reactor vessel flange bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date March 3 20 06
Owner of Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 3/9/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Jurisdictions
Date 3/9 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 04/6/2006
Sheet: 1 of 1
Unit: 0

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-070 WO 00749530
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System Spare Feed Water Check Valve, Class 1 or 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve Disc	Crane Nuclear	N/A	N/A	0-Spare-V25	N/A	Replacement	No

7. Description of Work: Replaced the hard facing on the disc in accordance with W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Emerg Prog Supvr Date April 12 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 4/15/06 and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 14 1005
National Board, State, Province, and Endorsements

Date 4/18 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL. 60555

Date: 7/22/2005
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 05-073 WO 00634293
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Check Valve	CS Valve CO.	N/A	N/A	2-1001-67C	N/A	Replacement	No

7. Description of Work: Replaced the valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date July 22 2002
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 06/06/05 to 07/25/05, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL1580
Inspector's Signature National Board, State, Province, and Endorsements

Date July 25 20 05

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 7/22/2005
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-076 WO 00634292
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Check Valve	CS Valve CO.	N/A	N/A	2-1001-67B	N/A	Replacement	No

7. Description of Work: Replaced the check valve in accordance with the WO.

Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: IR 355917

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date July 22 20 02
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 05/10/05 to 07/25/05, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL1580
Inspectors Signature National Board, State, Province, and Endorsements

Date July 25 20 05

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 5/4/2006
Sheet: 1 of 3
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. Various, WO 00678367
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Control Rod Drive, Class 1

5. (a) Applicable Construction Code: Component: ASME Section III 1965 Edition, W-1965 Addenda: N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
See Att. A							

7. Description of Work: Replaced Control Rod Drives and bolting in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Supvr Date May 6 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/8/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements
Date May 8 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT (Supplement)

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 5/4/2006
Sheet: 2 of 3
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. Various, WO 00678367
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Control Rod Drive, Class 1

5. (a) Applicable Construction Code: Component: ASME Section III 1965 Edition, W-1965 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

Attachment A

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)	Program No.
Control Rod Drive	GE Nuclear Energy	S/N: 1203	N/A	2-0300-26-23	N/A	Replacement	Yes	05-083
Control Rod Drive	GE Nuclear Energy	S/N: 1824	N/A	2-0300-10-31	N/A	Replacement	Yes	05-084
Control Rod Drive	GE Nuclear Energy	S/N: 565	N/A	2-0300-38-11	N/A	Replacement	Yes	05-094
Control Rod Drive	GE Nuclear Energy	S/N: 6184	N/A	2-0300-30-07	N/A	Replacement	Yes	05-095
Control Rod Drive	GE Nuclear Energy	S/N: 1940	N/A	2-0300-38-03	N/A	Replacement	Yes	05-096
Control Rod Drive	GE Nuclear Energy	S/N: 676	N/A	2-0300-38-07	N/A	Replacement	Yes	05-097
Control Rod Drive	GE Nuclear Energy	S/N: 331	N/A	2-0300-38-15	N/A	Replacement	Yes	05-098
Control Rod Drive	GE Nuclear Energy	S/N: 163	N/A	2-0300-18-27	N/A	Replacement	Yes	05-099
Control Rod Drive	GE Nuclear Energy	S/N: 558	N/A	2-0300-22-39	N/A	Replacement	Yes	05-100
Control Rod Drive	GE Nuclear Energy	S/N: 484	N/A	2-0300-22-31	N/A	Replacement	Yes	05-101
Control Rod Drive	GE Nuclear Energy	S/N: 370	N/A	2-0300-26-07	N/A	Replacement	Yes	05-102
Control Rod Drive	GE Nuclear Energy	S/N: 9350	N/A	2-0300-30-39	N/A	Replacement	Yes	05-103
Control Rod Drive	GE Nuclear Energy	S/N: 6473	N/A	2-0300-42-07	N/A	Replacement	Yes	05-104
Control Rod Drive	GE Nuclear Energy	S/N: 637	N/A	2-0300-46-11	N/A	Replacement	Yes	05-105
Control Rod Drive	GE Nuclear Energy	S/N: 1451	N/A	2-0300-46-23	N/A	Replacement	Yes	05-106

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT (Supplement)

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 5/4/2006
 Sheet: 3 of 3
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. Various, WO 00678367
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Control Rod Drive , Class I

5. (a) Applicable Construction Code: Component: ASME Section III 1965 Edition, W-1965 Addenda. N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda. N/A Code Case

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)	Program No.
Control Rod Drive	GE Nuclear Energy	S/N: 7069	N/A	2-0300-58-27	N/A	Replacement	Yes	05-107
Control Rod Drive	GE Nuclear Energy	S/N: 571A	N/A	2-0300-10-27	N/A	Replacement	Yes	05-108
Control Rod Drive	GE Nuclear Energy	S/N: 156	N/A	2-0300-18-39	N/A	Replacement	Yes	05-109
Control Rod Drive	GE Nuclear Energy	S/N: A4564	N/A	2-0300-14-39	N/A	Replacement	Yes	05-110
Control Rod Drive	GE Nuclear Energy	S/N: 1924	N/A	2-0300-30-35	N/A	Replacement	Yes	05-111

FORM NS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 03/20/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 0

2. Plant: Quad Cities Generating Station Program No. 05-090 WO 00797734-02
 22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
 22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Reactor Feedwater, Class 1 or 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Exelon	N/A	N/A	0-SPARE-V25	N/A	Replacement	No

7. Description of Work: Replaced valve disc hard-facing by machining and welding in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Suprscr Date March 23 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 3/24/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 12/005
National Board, State, Province, and Endorsements

Date 3/24 20 06

FORM 115-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 06/09/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station Program No. 05-112 WO 00711451-02
 22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
 22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: High Pressure Coolant Injection, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Dresser	TL 99325	N/A	2-1402-28B	N/A	Replacement	Yes

7. Description of Work: Replaced the relief valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure ___ psi Test Temp. ___ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supervisor Date June 9 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 06/14/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspected by [Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date 6/14/06 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 4-20-2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-113 WO 00790545-02
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: High Pressure Coolant Injection, Class 2

5. (a) Applicable Construction Code: Section VIII Div. 1 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Dresser	TP21765	N/A	2-2301-23	N/A	Replacement	Yes

7. Description of Work: Replaced the relief valve in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date April 24 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 04/25/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 14 1005
Inspector's Signature National Board, State, Province, and Endorsements
Date 4/25 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 06/20/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-114 WO 00683075-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Globe Valve	Crane	N/A	N/A	2-1001-36B	N/A	Replacement	NO

7. Description of Work: Replaced plug assembly in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure Test Temp. °F

9. Remarks: Performed Appendix J Testing.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engn Prog Supvr Date June 21 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT, of Connecticut, have inspected the components described in this Owner's Report during the period 12/14/05 to 6/22/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspectors Signature National Board, State, Province, and Endorsements

Date 6/22 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 4-11-2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-115 WO 00765109
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: High Pressure Coolant Injection, Class 2

5. (a) Applicable Construction Code: Section VIII 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Consolidated/Dresser	IL91267	N/A	2-1699-9	N/A	Replacement	Yes

7. Description of Work: Replaced the relief valve in accordance with the W.O.

3. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure 44.4 psi Test Temp. Ambiant °F

8. Remarks: Performed Appendix J Testing.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Super Date April 16 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 4/17/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 121005
National Board, State, Province, and Endorsement
Date APRIL 17 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/10/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-117 WO 00701257-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-2 Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Piping	Exelon	N/A	N/A	2-3007C-1.5"	N/A	Replacement	No

7. Description of Work: Replaced piping with chrome-moly piping in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Energy Prog. Supervisor Date May 10 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/4/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 14 1005
Inspectors Signature National Board, State, Province, and Endorsements
Date 5/10 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL. 60555

Date: 05/10/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-118 WO 00701258-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-2 Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Piping	Exelon	N/A	N/A	2-3007D-1.5"	N/A	Replacement	No

7. Description of Work: Replaced piping with chrome-moly piping in accordance with the WO.

3. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

8. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Emergency Prep Supervisor Date May 10 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/19/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements

Date 5/10/06 20 _____

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/6/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-119 WO 00701259-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System High Pressure Coolant Injection, Class I

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-2 Code Case

5. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Piping	Exelon	N/A	N/A	2-2330-1.5"	N/A	Replacement	No

7. Description of Work: Replaced piping with chrome-moly piping in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Energy Prod. Supervisor Date May 9 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 06/22/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements
Date 6/22 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/10/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-120 WO 00701256-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-2 Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Piping	Exelon	N/A	N/A	2-3007B-1.5"	N/A	Replacement	No

7. Description of Work: Replaced piping with chrome-moly piping in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date May 10 20 06
Owner of Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements

Date 5/10 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: **Exelon Generation Company, LLC**
 4300 Winfield Road
 Warrenville, IL 60555

Date: 4/15/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: **Quad Cities Generating Station**
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-077 & 05-121 W000732429
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: **Quad Cities Generating Station**
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: **Residual Heat Removal, Class 2**

5. (a) Applicable Construction Code: USAS B31.1 1967 Editions, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-3 Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Dresser	TP 30710	N/A	2-1001-125C	N/A	Replacement	Yes

7. Description of Work: Replaced the flange bolting, pipe, and flange in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng. Prog. Supvr Date April 20 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors of the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during a period 12/14/05 to 4/27/06, and state that to the best of my knowledge and belief, the owner has performed examinations and any corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Jurisdictions

Issued APRIL 27 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 4/2/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 05-127 & 05-128 WO 00738096
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Standby Liquid Control, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Trigger Assembly	Contax Buffalo Corp.	132	N/A	2-1106A	UNK.	Replacement	No
Inlet Plug	Contax Buffalo Corp.	N/A	N/A	2-1106A	UNK.	Replacement	No

7. Description of Work: Replaced the trigger assembly and inlet plug in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog. Supervisor Date April 2 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 4/13/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/13 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 4/15/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station Program No. 06-083 06-085 & 05-134 WO 00774917
 22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
 22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: High Pressure Coolant Injection, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Editions, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Check Valve	Exelon	N/A	N/A	2-2301-74	N/A	Replacement	No

7. Description of Work: Replaced the flange bolting, plug, and tack welded the nut to disc in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: It is not considered a Category A valve and is not leakage tested since the steam exhaust line terminates below the minimum water level in the suppression pool, providing a qualified water seal per Appendix J.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date April 16 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 4/21/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 12 1005
National Board, State, Province, and Endorsements

Date APR 21 2006

700 4/21/06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/09/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 05-139 WO-454494-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda: N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Crane Valve Co.	N/A	N/A	2-1001-34B	N/A	Repaired	No

7. Description of Work: Replaced wedge in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date May 16 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector Signature: [Signature] Commissions 12/05
National Board, State, Province, and Endorsements
Date May 10 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 06/06/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-003 WO 00812173-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: ASME Section III 1965, 1968 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BL 1132	N/A	2-0203-4B	N/A	Replacement	Yes

7. Description of Work: Replaced Safety Valve in accordance with the WO.

3. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

8. Remarks: IR# 00497311

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Energy Prog. Supv Date June 9 2006
Owner of Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 3/29/06 to 6/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 1L1005
Inspectors Signature National Board, State, Province, and Endorsements

Date 6/12 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 04/28/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station Program No. 06-004 WO 00812172-01
 22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
 22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Sect. III 1965, 1968 Edition: N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 7164	N/A	2-0203-4A	N/A	Replacement	Yes

7. Description of Work: Replaced Safety Valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, QA Program

Certificate of Authorization No. N/A Expiration Date N/A

signed [Signature] Date May 01 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/1/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions: IL 1005
Inspectors Signature National Board, State, Province, and Endorsements
 Date 5/1 2006

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 06/06/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-005 WO 00729408-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASME Section III 1965, 1968 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 6251	N/A	2-0203-4F	N/A	Replacement	Yes

7. Description of Work: Replaced Safety Valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: IR# 00497311

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date June 9 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 1/12/06 to 6/12/06 and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 14 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date 6/12 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 04/24/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station Program No. 06-006 WO 00729090-01
22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Sect. III 1965, 1968 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BL 1120	N/A	2-0203-4E	N/A	Replacement	Yes

7. Description of Work: Replaced Safety Valve in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Supvr Date May 01 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/2005 to 05/11/2006, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 14 1005
Inspectors Signature National Board, State, Province, and Endorsements
Date May 1 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 03-06-2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-013 WO 00883853-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASME Section III 1980, 1995 Edition, 1980, 1996 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Electromatic Relief Valve	Dresser Industries	BY-94632	N/A	2-0203-3D	UNK.	Replacement	No

7. Description of Work: Replaced the ERV and bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog. Supvr Date March 7 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 3/7/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.
By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 16 1005
National Board, State, Province, and Endorsements
Date 3/7 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 05/6/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-021 WO 00886262-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: USAS B31.1 1967/Section I 1965 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber	Lisega Hydraulic	61310/36	N/A	TS-2-28	N/A	Replacement	No

7. Description of Work: Replaced load pin in accordance with the WO.

3. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure ___ psi Test Temp. ___ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date May 9 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 12/10/05
National Board, State, Province, and Endorsements
Date May 10 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 06/19/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-022 WO 00656068-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967/Section I 1965 Edition, N/A Addenda: N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber	Lisega Hydraulic	61300/62	N/A	2-3001-A55	N/A	Replacement	No

7. Description of Work: Replaced load pins in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date June 20 2006
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 2/6/06 to 6/21/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

Issued 6/21 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 5/10/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-025 WO 00885318-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Sect. III 1965, 1968 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 7163	N/A	2-0203-4C	N/A	Replacement	Yes

7. Description of Work: Replaced the inlet bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date May 11 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 05/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature: [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements

Date 5/12 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 5/10/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-026 WO 00885319-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Sect. III 1965, 1968 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 6266	N/A	2-0203-4D	N/A	Replacement	Yes

7. Description of Work: Replaced the inlet bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date May 11 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 12 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date 5/12 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 5/10/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-027 WO 00885320-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Sect. III 1965, 1968 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 6529	N/A	2-0203-4G	N/A	Replacement	Yes

7. Description of Work: Replaced the inlet bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Emerg Prog Supvr Date May 11 20 06
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Employer Licenses

Date May 12 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 5/10/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-028 WO 00885321-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967/ASME Sect. III 1965, 1968 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 6278	N/A	2-0203-4H	N/A	Replacement	Yes

7. Description of Work: Replaced the inlet bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date May 11 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 05/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date May 12 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 06/06/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-034 WO 00789812-*cl*
Repair Organization P.O. No., Job No., etc. *all filled*

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: ASME Section III 1980, 1995 Edition, 1980, 1996 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Electromatic Relief Valve	Dresser Industries	BK-7062	N/A	2-0203-3E	UNK.	Replacement	No

7. Description of Work: Replaced the ERV in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: IR# 00497311

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q.A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Super Date June 9 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 6/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 16 1005
National Board, State, Province, and Endorsements

Date 6/12 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 05/24/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-039 WO 00902278-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: ASME Section III 1980, 1995 Edition, 1980, 1996 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 7062	N/A	0-Spare V-26	N/A	Replacement	Yes

7. Description of Work: Replaced drain line weld at the main valve flange in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date May 24 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/25/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Jurisdictions
Date May 25 2006

FORM INS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 05/24/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-040 WO 00902278-02
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: ASME Section III 1980, 1995 Edition, 1980, 1996 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BX 00290	N/A	0-Spare V-26	N/A	Replacement	Yes

7. Description of Work: Replaced drain line weld at the main valve flange in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date May 24 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/25/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements
 Date 5/25 2006

1. Owner: Exelon Generation Company, LLC Date: 05/24/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-041 WO 00902278-03
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASME Section III 1980, 1995 Edition, 1980, 1996 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve	Consolidated Valve	BK 7072	N/A	0-Spare V-26	N/A	Replacement	Yes

7. Description of Work: Replaced drain line weld at the main valve flange in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure ___ psi Test Temp. ___ °F

9. Remarks: N/A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Engng Prog Supv Date May 24 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during a period 12/14/05 to 5/25/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, District, and Exemptions

Date 5/25 2006

FORM 115-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 06/02/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-044 WO 885018-04
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Main Steam, Class 1

5. (a) Applicable Construction Code: ASME Section I 1965 Edition, Summer 1966 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-3 Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Safety Valve Standpipes	Exelon	N/A	N/A	2-0203-3C/D 2-0203-4C/D/G/H	N/A	Replaced	No

7. Description of Work: Installed acoustic side branch assemblies on south ERV and SRV standpipes in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: System leakage test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supervisor Date June 02 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT, of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 6/9/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Embroiderments
 Date June 9 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 04/5/2006
Sheet: 1 of 3
Unit: 0

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

PO# 707 REL. 1297REC. 151547

Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Spare Control Rod Drive , Class I

5. (a) Applicable Construction Code: Component: ASME Section III 1965 Edition, W-1965 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
See Att. A							

7. Description of Work: Refurbished the Control Rod Drive as required by the PO

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code , Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], Energy Prog Supervisor Date April 12 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors in the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 4/18/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 12 1005
National Board, State, Province, and Endorsements

Date 4/18 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT (Supplement)

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 04/5/2006
Sheet: 2 of 3
Unit: 0

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

PO# 707 REL. 12947/REC 151547
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Spare Control Rod Drive, Class I

5. (a) Applicable Construction Code: Component: ASME Section III 1965 Edition, W-1965 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

Attachment A

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)	Program No.
Control Rod Drive	GE Nuclear Energy	S/N: 156	N/A	0- Spare-D15	N/A	Replacement	Yes	06-049
Control Rod Drive	GE Nuclear Energy	S/N: 163	N/A	0- Spare-D15	N/A	Replacement	Yes	06-050
Control Rod Drive	GE Nuclear Energy	S/N: 331	N/A	0- Spare-D15	N/A	Replacement	Yes	06-051
Control Rod Drive	GE Nuclear Energy	S/N:370	N/A	0- Spare-D15	N/A	Replacement	Yes	06-052
Control Rod Drive	GE Nuclear Energy	S/N:484	N/A	0- Spare-D15	N/A	Replacement	Yes	06-053
Control Rod Drive	GE Nuclear Energy	S/N: 558	N/A	0- Spare-D15	N/A	Replacement	Yes	06-054
Control Rod Drive	GE Nuclear Energy	S/N: 565	N/A	0- Spare-D15	N/A	Replacement	Yes	06-055
Control Rod Drive	GE Nuclear Energy	S/N: 571A	N/A	0- Spare-D15	N/A	Replacement	Yes	06-056
Control Rod Drive	GE Nuclear Energy	S/N: 637	N/A	0- Spare-D15	N/A	Replacement	Yes	06-057
Control Rod Drive	GE Nuclear Energy	S/N: 676	N/A	0- Spare-D15	N/A	Replacement	Yes	06-058
Control Rod Drive	GE Nuclear Energy	S/N: 1203	N/A	0- Spare-D15	N/A	Replacement	Yes	06-059
Control Rod Drive	GE Nuclear Energy	S/N: 1451	N/A	0- Spare-D15	N/A	Replacement	Yes	06-060
Control Rod Drive	GE Nuclear Energy	S/N: 1824	N/A	0- Spare-D15	N/A	Replacement	Yes	06-061
Control Rod Drive	GE Nuclear Energy	S/N: 1924	N/A	0- Spare-D15	N/A	Replacement	Yes	06-062
Control Rod Drive	GE Nuclear Energy	S/N: 1940	N/A	0- Spare-D15	N/A	Replacement	Yes	06-063

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT (Supplement)

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 04/5/2006
 Sheet: 3 of 3
 Unit: 0

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

PO# 707 REL.12947/REC 151547
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Spare Control Rod Drive , Class 1

5. (a) Applicable Construction Code: Component: ASME Section III 1965 Edition, W-1965 Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)	Program No.
Control Rod Drive	GE Nuclear Energy	S/N: 6184	N/A	0- Spare-D15	N/A	Replacement	Yes	06-064
Control Rod Drive	GE Nuclear Energy	S/N:6473	N/A	0- Spare-D15	N/A	Replacement	Yes	06-065
Control Rod Drive	GE Nuclear Energy	S/N: 7069	N/A	0- Spare-D15	N/A	Replacement	Yes	06-066
Control Rod Drive	GE Nuclear Energy	S/N: 9350	N/A	0- Spare-D15	N/A	Replacement	Yes	06-067
Control Rod Drive	GE Nuclear Energy	S/N: A4564	N/A	0- Spare-D15	N/A	Replacement	Yes	06-068

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 05/09/2006
Sheet: 1 of 1
Unit: 1

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-071 WO 905901-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve	Anchor Darling	N/A	N/A	2-0220-2	N/A	Repaired	No

7. Description of Work: Overhauled valve in accordance with the WO.

3. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

8. Remarks: Appendix J test.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B. QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date May 9 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 12 1005
Inspectors Signature National Board, State, Province, and Endorsements
ite 5/10 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 6/28/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-075 WO 00832684-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Editions, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-3 Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	CONSOLIDATED VALVE CORP	TP-34857	N/A	2-1001-125A	N/A	Replacement	Yes

7. Description of Work: Replaced valve, flange, and bolting in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI, repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B: O A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supervisor Date July 3 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

The undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Ix, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period _____ to _____, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions 12543, A, NT
Inspector's Signature National Board, State, Province, and Endorsements

Date 7/5/06 20 _____

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 6/08/2006
 4300 Winfield Road Sheet: 1 of 1
 Warrenville, IL 60555 Unit: 2

2. Plant: Quad Cities Generating Station Program No. 06-076 WO 00776113-01
 22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
 22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Editions, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N-416-3 Code Case

5. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Dresser	TP 32874	N/A	2-1001-125B	N/A	Replacement	Yes

7. Description of Work: Replaced the flange bolting, pipe, and flange in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
 repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supervisor Date June 9 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 6/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

atc 6/12 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 06/19/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-078 WO 00906180-01
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: High Pressure Coolant Injection, Class 1

5. (a) Applicable Construction Code: USAS B31.1 1967 Editions, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber	Basic-PSA INC.	40258	N/A	2/2305-78	N/A	Replacement	No

7. Description of Work: Replaced snubber in accordance with the W.O.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date June 20 2006
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 6/21/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements

Date 6/21 2006

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 05/6/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-079 WO 00906183-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Reactor Core Isolation Cooling, Class I

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber	PSA	30696	N/A	TS-2-042	N/A	Replacement	No

7. Description of Work: Replaced snubber in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F

9. Remarks: N/A

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Date May 11 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 05/12/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Enforcement

Date 5/12/06 20

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT

As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
 4300 Winfield Road
 Warrenville, IL 60555

Date: 05/6/2006
 Sheet: 1 of 1
 Unit: 2

2. Plant: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Program No. 06-082 WO 00907358-01
 Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
 22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
 Authorization No.: None
 Expiration Date: N/A

4. Identification of System: Residual Heat Removal, Class 2

5. (a) Applicable Construction Code: USAS B31.1 1967 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber	PSA	14007	N/A	TS-2-127	N/A	Replacement	No

7. Description of Work: Replaced load pin in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: N/A.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B: Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date May 9 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 5/10/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions IL 1005
National Board, State, Province, and Endorsements

Effective Date 5/10 20 06

FORM NIS-2 OWNERS REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Date: 4/15/2006
Sheet: 1 of 1
Unit: 2

2. Plant: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Program No. 06-086 WO00818566
Repair Organization P.O. No., Job No., etc.

3. Work Performed by: Quad Cities Generating Station
22710 206th Ave. North, Cordova, IL 61242

Type Code Symbol Stamp: None
Authorization No.: None
Expiration Date: N/A

4. Identification of System: Main Steam, Class I

5. (a) Applicable Construction Code: ASME Sect. III 1968 Editions, Winter 1968 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case

6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Relief Valve	Target Rock	N/A	N/A	2-0203-3A	N/A	Replacement	No

7. Description of Work: Replaced the bolting in accordance with the WO.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

9. Remarks: None.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this replacement conforms to the rules of ASME Code, Section XI repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, QA Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Engng Prog Supvr Date April 16 20 06
Owner or Owner's Designated Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/2005 to 4/17/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions IL 1005
Inspector's Signature National Board, State, Province, and Endorsements

Date 4/17 20 06

OWNER'S REPORT OF REPAIR OR REPLACEMENT
As Required by the Provisions of ASME Code Section XI

1. Owner: Exelon Generation Company, LLC Date: 06/16/2006
4300 Winfield Road Sheet: 1 of 1
Warrenville, IL 60555 Unit: 2
2. Plant: Quad Cities Generating Station Program No. 06-125 WO 99242367-02
22710 206th Ave. North, Cordova, IL 61242 Repair Organization P.O. No., Job No., etc.
3. Work Performed by: Quad Cities Generating Station Type Code Symbol Stamp: None
22710 206th Ave. North, Cordova, IL 61242 Authorization No.: None
Expiration Date: N/A
4. Identification of System: Core Spray, Class 2
5. (a) Applicable Construction Code: USAS B31.1 1967 Editions, N/A Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements: 1995 Edition, 1996 Addenda, N/A Code Case
6. Identification of Components Repaired or Replaced, and Replacement Components:

Name of Component	Name of Mfr.	Mfrs. Ser. No.	Nat'l Bd. No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pipe Support	Exelon	N/A	N/A	2-1810-35	N/A	Repair	No

7. Description of Work: Welded stiffening plate to pipe support.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F
9. Remarks: IR# 501724

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this repair conforms to the rules of ASME Code, Section XI
repair or replacement

Type of Code Symbol Stamp N/A - Exelon Nuclear 10CFR50 App B, Q A Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] Energy Prog. Supvr Date June 20 2006
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Illinois, and employed by HSB CT. of Connecticut have inspected the components described in this Owner's Report during the period 12/14/05 to 06/21/06, and state that to the best of my knowledge and belief, the owner has performed examinations and taken corrective measures described in this Owner's Report in accordance the requirements of the ASME Code, Section XI. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Inspector's Signature [Signature] Commissions 1C 1005
National Board, State, Province, and Endorsements
Date 6/21 2006