From: Ilka Berrios
To: Kathy K. (GE Infra Energy) Sedney
Date: 05/15/2007 6:52:05 AM
Subject: RAI 17.4-15 S02

Kathy,

See attached request for supplemental information needed to resolve Chapter 17.4 RAI 17.4-15 S02.

Please contact me with a schedule for your response to this item. If you have any questions regarding this request or would like to schedule a telecon do not hesitate to contact me.

Thanks,

Ilka

Ilka Tamara Berrios
US Nuclear Regulatory Commission
Project Manager
NRO/DNRL/NGE1
301-415-3179
NSPDP '08

CC: Amy Cubbage

Mail Envelope Properties (464990D5.F3B : 14 : 11964)

Subject: RAI 17.4-15 S02
Creation Date 05/15/2007 6:52:05 AM
From: Ilka Berrios

Created By: IXB3@nrc.gov

Recipients
ge.com
kathy.sedney (Kathy K. (GE Infra Energy) Sedney)

nrc.gov
OWGWPO03.HQGWDO01
AEC CC (Amy Cubbage)

Post Office	**Route**
	ge.com
OWGWPO03.HQGWDO01	nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	1126	05/15/2007 6:52:05 AM
Sup02RAIsCh17.doc	20480	05/15/2007 6:47:34 AM

Options
Expiration Date: None
Priority: Standard
ReplyRequested: No

Return Notification:
Send Notification when Opened

Concealed Subject: No
Security: Standard

GE ESBWR
Supplemental RAI
Chapter 17 Quality Assurance

RAI 17.4-15, Supplement 02:

Comments on GE's response supplemental response to 17.4-15 (MFN-06-486 Supp. 1 dated May 11, 2007).

1. List the February 22, 2000, revision to Section 11 of NUMARC 93-01 as a separate document in the list of Maintenance Rule reference documents in Subsection 17.4.9.

2. Remove the word "including" in the 17.4.9 reference list because the version of 93-01 (rev 2) currently endorsed by RG 1.160 (rev.2) does not include the revised Section 11 (separately endorsed by RG 1.182).

3. List the February 22, 2000, revision to Section 11 of NUMARC 93-01 as a separate document in the list of references Subsection 17.4.14.